



water & sanitation

Department:
Water and Sanitation
REPUBLIC OF SOUTH AFRICA

SUPPLY AND DELIVERY OF READY MIX CONCRETE FOR THE CONSTRUCTION OF VLAKFONTEIN CANAL NEAR STANDERTON IN THE MPUMALANGA PROVINCE FOR A PERIOD OF 24 MONTHS. BID NO: DWS02-0720 WTE

NOTICE TO TENDERERS – ADDENDUM No 1

17 August 2020

Herewith please find Addendum No 1, which forms an integral part of the above mentioned Tender:

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM AS FOLLOWS:

1. Complete and sign each page of this Addendum and submit the original completed form with the bid document.

Failure to acknowledge receipt could prejudice your tender.

Mr. Shai Mohale
For DWS Supply Chain Management

We herewith acknowledge receipt of **ADDENDUM No 1 for DWS02-0720 WTE**

SIGNATURE OF AUTHORISED PERSON:

DATE:

ON BEHALF OF BIDDER:

Issued by:

Department of Water and Sanitation
Private Bag X313
PRETORIA
0001
Tel: +27 (0)12 336 7413
Attention: Mr. Mohale Shai



ADDENDUM No 1

PROCEDURE FOR ADDENDA

This Addendum forms an integral part of the Tender Document and the subsequent Contract with the successful Tenderer. The variations and amendments to the Tender Document as described hereafter, shall take precedence. Notwithstanding anything said during the Tender Period or Site Inspection, only the additional information or variations and amendments contained in this Addendum, and subsequent Addenda, if any, will be legally binding.

Bidders are required to make any correction or amendment instructed in Addenda by deleting and or adding such text in the Tender Document and to sign next to such amendment in black ink before making copies for submission of the Bid.

TABLE OF CONTENTS

1. AMMENDMENTS REQUIRED TO TENDER DOCUMENT

ATTACHMENTS

ATTACHMENT A: MINUTES OF COMPULSORY BREIFING SESSION

1. AMMENDMENTS REQUIRED TO TENDER DOCUMENTS

Amendment No 1 – Tax Clearance Certificate

Potential suppliers/ bidders were requested to attach a copy of Tax Clearance Certificate and PIN issued (Tax Compliance Status document) under Phase 2 “Administrative Compliance”.

The department will consider the Tax Compliance Status (TCS) PIN to verify potential suppliers/ bidder’s compliance status online via SARS eFiling and Central Supplier Database (CSD) system.

Amendment No 2 – CERTIFIED UIF CERTIFICATE

Potential suppliers/ bidders were requested to attach a valid certified copy of UIF certificate of compliance issued by “Department of Labour”.

The department will consider valid copy of UIF certificate of compliance issued by “Department of Labour”.



Contractor



Witness 1



Witness 2



Employer



Witness 1



Witness 2



Amendment No 3 – BRIEFING SESSION CERTIFICATE OF ATTENDANCE







Potential suppliers/ bidders were requested to return their bid response with the original attendance certificate which is signed by both parties.

No original attendance certificate was issued to potential suppliers/ bidders at the compulsory briefing session. Confirmation of attendance will be based on the signed attendance register.

Amendment No 4 – TENDER DATA

Under the "Special notice" it is stated that concrete will be tested for the following strength dates, 7 days (min +10Mpa) and 28 days (25Mpa).

The correct strength dates is, 7 days (min +10Mpa) and 28 days (30Mpa).

					
Contractor	Witness 1	Witness 2	Employer	Witness 1	Witness 2