

THE COPYRIGHT IN THIS DRAWING, INCLUDING THE
DESIGN AND DETAILS SHOWN HEREON, IS RESERVED
BY THE ENGINEERS.

TES:

TOLERANCES SHALL BE DEGREE OF ACCURACY II
 UNLESS OTHERWISE SPECIFIED

CONCRETE

EXPOSED CORNERS SHALL BE CHAMFERED 25mm x mm.

ENDING SHALL BE OF CLASS 15/19 mm

SS CONCRETE SHALL BE OF CLASS 15/19 mm

STRUCTURAL CONCRETE SHALL BE OF CLASS 35/19 mm

EXPOSED FORMED CONCRETE SURFACES SHALL BE
SMOOTH OFF SHUTTER FINISH

SURFACES EXPOSED TO WATER SHALL BE STEEL
POWELED FINISHED. WALKWAY AND TOP OF WALLS
ALL BE WOOD FLOAT FINISH.

ENFORCEMENT

CONCRETE COVER TO REINFORCEMENT TO BE MINIMUM
mm. COVER TO REINFORCEMENT WHERE CONCRETE
CAST AGAINST SOIL SHALL BE AT LEAST 75mm.

LOADING, HEATING TREATMENT AND GAS CUTTING OF
REINFORCEMENT SHALL NOT BE PERMITTED



REF. TO STRUCTURAL DWG. NO.
34905-STR-300, 301 & 352

PROJECT TITLE

NOMLACU WTW
UPGRADES & EXTENSIONS

DRAWING TITLE	
PULSATOR GENERAL LAYOUT & SECTION	
SCALE: AS SHOWN	
DRAWING NO. 34905-CIV-2-2	REV. 0