



water & sanitation

Department:
Water and Sanitation
REPUBLIC OF SOUTH AFRICA

Enquiries: L Tloubatla
Telephone: 015 290 1228
Reference: 6/2/2/6

MINISTER OF WATER AND SANITATION

NATIONAL ASSEMBLY: QUESTION ★334 FOR ORAL REPLY

A draft reply to the above mentioned question asked by Ms M S Khawula (EFF) is attached for your consideration.

ACTING DIRECTOR-GENERAL

DATE: 20/11/2018

~~DRAFT REPLY APPROVED/AMENDED~~

**NKWINTI GE, MP
MINISTER OF WATER AND SANITATION**

DATE: 03/12/2018

FOR ORAL REPLY

QUESTION NO ★334

DATE OF PUBLICATION IN INTERNAL QUESTION PAPER: 12 NOVEMBER 2018
(INTERNAL QUESTION PAPER NO. 40)

★334. Ms M S Khawula (EFF) to ask the Minister of Water and Sanitation:

- (a) By what date will all the residents of Dzanani in Limpopo have access to running water and (b) what has been the reason for a lack of access to running water? NO4003E

---0000---

THE MINISTER OF WATER AND SANITATION

- (a) The district drilled a borehole at TshituniTsaGavhe, which is located at approximately 3 km away. Currently, the constructed borehole is operational and the residents of Dzanani (Biaba) township have access to running water.
- (b) The major reason for lack of access to running water for Dzanani (Biaba) township was mainly due to illegal connections on the pumping main, which supplies water from MutshedziTreatment Plant to the township.

---0000---