



water & sanitation

Department:
Water and Sanitation
REPUBLIC OF SOUTH AFRICA

Enquiries: N Ntli
Telephone: 082 803 3204
Reference: 6/2/2/6

NATIONAL COUNCIL OF PROVINCES

FOR WRITTEN REPLY

QUESTION NO 105

DATE OF PUBLICATION IN INTERNAL QUESTION PAPER: 4 MARCH 2022
(INTERNAL QUESTION PAPER NO. 5)

105. Mr M S Moletsane (Free State: EFF) to ask the Minister of Water and Sanitation.
(Interdepartmental transfer – 22/04)

When will pit toilets be completely eradicated in the Free State as they still exist in areas like Botshabelo?

CW107E

---0000---

MINISTER OF WATER AND SANITATION

The Department does not fund Metropolitan Municipalities for water and sanitation programmes since such municipalities receive the Urban Settlement Development Grant (USDG) from the Department of Human Settlements (DHS). The USDG is intended to fund programmes related to the Built Environment for the provision of basic municipal services, including water and sanitation infrastructure.

The Department of Water and Sanitation engaged with Mangaung Metropolitan Municipality (MMM) about short-medium term plans towards the eradication of pit toilets in Botshabelo and obtained the following report:

- Botshabelo is affected by bulk sanitation constraints. The main outfall sewer needs an upgrade at an estimated cost of R60 million. Additionally, the wastewater treatment works

needs to be upgraded from its current capacity of 20MI/d to 40MI/d at an estimated cost of R380 million.


- The current hydraulic load at the WWTW is 18ML/d, which means that there is a spare capacity of 2ML/d. The upgrade of the main outfall sewer is expected to be completed by December 2023. The project to eradicate pit toilets in Botshabelo is planned for the 2022/23 financial year. The current bulk sanitation spare capacity is adequate to accommodate the additional imposed demand caused by the planned upgrade.
- MMM plans to install an upgradable alternative sanitation solution as a short-term measure to overcome bulk challenges. A budget of R94.5 million has been appropriated for the programme under USDG over the Medium-Term Expenditure Framework period. A total of 5 300 units will be constructed and later converted to a full waterborne system after installation of the bulk infrastructure. The project is at the procurement stage and awaiting the National Treasury directive on procurement matters due to the constitutional court finding on the PPPFA.

---0000---

DRAFT REPLY: RECOMMENDED/ ~~NOT RECOMMENDED~~/ AMENDED


DR SEAN PHILLIPS
DIRECTOR-GENERAL
DATE: 28/04/22


DRAFT REPLY: APPROVED/ NOT APPROVED/ AMENDED


MR SENZO MCHUNU, MP
MINISTER OF WATER AND SANITATION
DATE: 05/05/22