



Headline Statistics

WCWSS DAM STORAGE
(%)

90.5

WEEKLY DAM LEVEL CHANGE
(%)

1.20

AVERAGE TOTAL
DAILY WATER USE
(MLD)

843

Water Resource Status

WATER RESOURCE STATUS	MEANING OF CURRENT STATUS
Wise Water Use	Although the water resource status is "wise water use", it is important to continue using water wisely. Note: The Water Resource status is updated every three (3) months. It will next be updated in August.

Water Production from Different Sources

MAJOR DAMS
(MLD)

816


MINOR DAMS
(MLD)

19

GROUND WATER
AND SPRINGS
(MLD)

8

Overall Water Usage Trend (2010 - Present)



WCWSS means Western Cape Water Supply System

MLD means million litres per day

More information on Water Saving and Restrictions is available on the City of Cape Town's 'ThinkWater' website


Water Stored in Major Dams (WCWSS)

Overall Percentage Full 90.5%


Weekly Change 1.2%

MAJOR DAMS (WCWSS)	STORAGE						
	CAPACITY	%	%	%	%	%	%
	MI	18 August 2025	Previous week	2024	2023	2022	2021
BERG RIVER	130 010	100.0	101.5	100.8	100.4	95.1	100.3
STEENBRAS LOWER	33 517	96.0	93.9	102.9	99.6	83.1	90.5
STEENBRAS UPPER	31 767	101.0	100.8	103.8	98.2	82.9	85.1
THEEWATERSKLOOF	480 188	85.6	84.5	104.3	101.1	77.9	101.7
VOËLVLEI	164 095	93.9	89.9	104.3	94.8	64.0	90.0
WEMMERSHOEK	58 644	91.7	91.0	100.0	99.9	71.3	97.6
TOTAL STORED	898 221	813 285	801 934	929 116	894 564	698 667	881 048
% STORAGE		90.5%	89.3%	103.4%	99.6%	77.8%	98.1%




WCWSS Storage Record (2008 - Present)



WCWSS Comparative Storage Graph



Projected WCWSS Dam Storage Levels



Water Stored in Minor Dams

Overall Percentage Full	86.3	Weekly Change	-1.07
-------------------------	------	---------------	-------

MINOR DAMS	STORAGE						
	CAPACITY	%	%	%	%	%	%
	MI	18 August 2025	Previous week	2024	2023	2022	2021
ALEXANDRA (Table Mountain)	126	83.5	86.9	ND	90.6	100.0	42.4
DE VILLIERS (Table Mountain)	243	100.7	100.3	ND	100.7	94.6	91.2
HELY-HUTCHINSON (Table Mount)	925	100.2	101.5	ND	100.5	99.7	99.5
KLEINPLAATS (Simon's Town)	1 368	68.5	66.5	91.5	97.5	64.0	100.0
LAND-EN-ZEEZICHT (Helderberg)	451	99.7	96.4	100.0	99.4	79.8	100.0
LEWIS GAY (Simon's Town)	182	100.9	100.9	100.9	99.0	35.5	100.9
VICTORIA (Table Mountain)	128	57.8	55.4	ND	100.8	101.2	97.0
WOODHEAD (Table Mountain)	954	93.3	101.2	ND	84.5	89.6	88.2
Total Stored	4 377	3779.2	3826.0	ND	4137.0	3540.5	4108.1
Percentages stored		86.3	87.4	ND	94.5	80.9	93.9


Rainfall Recorded

RAINFALL (mm)	11-Aug	12-Aug	13-Aug	14-Aug	15-Aug	16-Aug	17-Aug	Aug	
								Total*	LT Average
Blackheath Upper	0.0	0.0	0.0	0.0	0.0	4.0	0.0	35.2	77.7
Brooklands	0.0	0.0	0.0	0.0	0.0	0.0	0.0	70.0	135.1
Newlands	0.0	0.0	0.0	0.0	0.0	9.0	0.0	151.7	237.0
Steenbras	0.0	0.0	0.0	0.0	0.0	0.5	0.0	72.7	127.1
Table Mountain (Woodhead)	0.0	0.0	0.0	0.0	0.0	5.0	0.0	78.6	215.8
Theewaterskloof	0.0	0.0	0.0	0.0	0.0	0.0	0.0	28.2	76.0
Tygerberg	0.0	0.0	0.0	0.0	0.0	2.8	0.0	57.7	86.5
Voëlville	0.0	0.0	0.0	0.0	0.0	0.6	0.0	34.9	90.2
Wemmershoek	0.0	0.0	0.0	0.0	0.0	1.5	0.0	93.2	146.0
Wynberg	0.0	0.0	0.0	0.0	0.4	5.4	0.0	144.6	191.1

Notes: *Total/cummulative rainfall for month indicated above
LT: Long Term

Accumulated Monthly Rainfall at Wemmershoek

Note: Wemmershoek station used due to long record and mountainous location



Drinking Water Quality

SAMPLE PASS RATE		
Month	Water Quality Compliance (%)	Target (%)
Nov-21	99.11	98
Dec-21	99.09	98
Jan-22	99.04	98
Feb-22	99.04	98
Mar-22	98.99	98
Apr-22	98.96	98
May-22	98.90	98
Jun-22	98.96	98
Jul-22	99.46	99
Aug-22	99.47	99
Sept-22	99.46	99.00
Oct-22	99.47	99.00
Nov-22	99.45	99.00
Dec-22	99.36	99.00
Jan-23	99.36	99.00
Feb-23	99.35	99.00
Mar-23	99.29	99.00
Apr-23	99.24	99.00
May-23	99.24	99.00
Jun-23	99.18	99.00
Jul-23	99.19	99.00
Aug-23	99.14	99.00
Sept-23	99.10	99.00
Oct-23	99.10	99.00
Nov-23	99.04	99.00
Dec-23	99.15	99.00
Jan-24	99.16	99.00
Feb-24	99.12	99.00
Mar-24	99.16	99.00
Apr-24	99.20	99.00
May-24	99.21	99.00
Jun-24	99.26	99.00
Jul-24	99.27	99.00
Aug-24	99.31	99.00
Sept-24	99.33	99.00
Oct-24	99.37	99.00
Nov-24	99.42	99.00
Dec-24	99.42	99.00
Jan-25	99.48	99.00
Feb-25	99.57	99.00
Mar-25	99.61	99.00
Apr-25	99.65	99.00
May-25	99.66	99.00
Jun-25	99.62	99.00

This table shows CCT drinking water quality compliance according to the South African National Standard 241:2015. Compliance, measured against all prescribed chemical and microbiological components, consistently exceeds the very high CCT target of 99%. (Overall compliance percentages of continuous sampling and analysis are released on a monthly basis.