

**REPUBLIC OF TRANSKEI**

**DEPARTMENT OF WORKS AND ENERGY**

**UMZIMVUBU BASIN DEVELOPMENT**

**OVERALL FEASIBILITY REPORT**

**EXECUTIVE SUMMARY**

**March 1987**

**H. Olivier and Associates  
Binnie and Partners  
Kennedy and Donkin  
IN ASSOCIATION WITH  
M.J. Mountain and Associates  
KDM**

# UMZIMVUBU BASIN DEVELOPMENT

## EXECUTIVE SUMMARY OF OVERALL FEASIBILITY REPORT

### CONTENTS

	Page
INTRODUCTION	1
CONCLUSIONS	4
DESCRIPTION OF PROJECT AREA	6
WATER UTILISATION WITHIN SOUTHERN AFRICA	10
DAMS AND HYDROELECTRIC PROJECTS	14
ROLE OF POWER STATIONS	17
CAPITAL COSTS OF DAMS AND POWER DEVELOPMENT	19
ECONOMIC EVALUATION OF POWER BENEFITS	20
PROGRAMME FOR DEVELOPMENT	23
TWO YEAR STUDY WITH EMPHASIS ON WATER USES	25
TABLES	
Table 1 - Summary of conduit features	26
Table 2 - Summary of water transfer costs	26
Table 3 - Summary of key technical data of dams and hydroelectric projects	27/28
Table 4 - Load forecast for ESCOM	29
Table 5 - Load forecast for TESCO	30
Table 6 - Total capital costs for alternative Mbokazi schemes	31
Table 7 - Total capital costs for alternative Nkwadini schemes	31
Table 8 - Mbokazi - Comparative simulation costs	32
Table 9 - Nkwadini - Comparative simulation costs	33
Table 10 - Nkwadini - comparative simulation costs	33

# UMZIMVUBU BASIN DEVELOPMENT

## EXECUTIVE SUMMARY OF OVERALL FEASIBILITY REPORT

### CONTENTS

#### FIGURES

- Figure 1 - Transkei Orientation Map
- Figure 2 - Mbokazi Location and Catchment
- Figure 3 - Overview of Scheme
- Figure 4 - Possible Institutional Arrangement for an Umzimvubu Basin Development Authority (UBDA)
- Figure 5 - Water Transfer Scheme - General Outline
- Figure 6 - Water Transfer - Route A
- Figure 7 - Water Transfer - Route N
- Figure 8 - Mbokazi Dam - General Layout
- Figure 9 - Mbokazi Dam - Typical Cross Section
- Figure 10 - Mbokazi Spillway
- Figure 11 - Mbokazi Power Tunnels - Typical Sections
- Figure 12 - Mbokazi Power Station - General Layout
- Figure 13 - Mbokazi Power Station - Cross Section
- Figure 14 - Nkwalini Dam - General Layout
- Figure 15 - ESCOM LDC 1997
- Figure 16 - Possible Winter Load Curves for ESCOM in 2000
- Figure 17 - Mbokazi Hydroelectric Project - Development Programme
- Figure 18 - Mbokazi Hydroelectric Project - Construction Programme
- Figure 19 - Water Transfer Construction Programme - West Route.

# UMZIMVUBU BASIN DEVELOPMENT

## EXECUTIVE SUMMARY OF OVERALL FEASIBILITY REPORT

### INTRODUCTION

The Umzimvubu river is one of the largest in Southern Africa, with a mean annual runoff (MAR) of about  $3\ 000 \times 10^6 \text{ m}^3$  (i.e. an average rate of flows of  $95 \text{ m}^3/\text{s}$ ). So far this natural resource has not been developed and substantial water and hydroelectric potential, from which the Transkei and Southern Africa as a whole could benefit has not been realised. The location of Transkei relative to Southern Africa is shown in Figure 1.

In December 1985 the Olivier Consortium was appointed by the Government of the Transkei to carry out a feasibility study of the development of the Umzimvubu river by a large dam at Mbokazi and a smaller reregulation dam downstream (see Figure 2). Conceptual planning of the hydroelectric development in the Umzimvubu Basin was reported on by Henry Olivier and Associates in November 1979 following four years of study. The location of the Mbokazi dam site was identified in their report and it is this site which has now been studied in more detail. The development uses renewable resources to provide hydroelectricity for Transkei through the system operated by TESCOR and also generates a large amount of peak power for export to RSA by feeding into the ESCOM system in which most generation is by large coal-fired thermal stations which do not operate so efficiently over short periods. There is, in addition potential for interbasin transfer of water to the irrigable land on the plateaux in the Transkei and to RSA and supply for domestic and industrial use. In suitable areas such a project could transform present day subsistence farms into highly productive areas of efficient land use with potential for sale of cash crops to RSA and further afield.

The implementation of such large projects requires substantial funds, bold decisions and the determination to see the project through. Schemes take many years to progress from conception to realisation and, even following a tight programme, completion would not be before 1997. The population and the demand for food and electricity will have almost doubled by then.

The consortium comprised:

**Henry Olivier & Associates** (Leader)  
**Binnie & Partners** (Direction, planning, coordination, civil engineering)  
**Kennedy & Donkin** (Mechanical and electrical engineering, economics)

in association with

**M J Mountain & Associates** (Geology and supervision of site investigation)  
**Knight, Dames & Moore** (Seismicity)

The study team received cooperation and constructive help from TESCORA and ESCOM for the electricity studies and on water aspects from the Department of Agriculture and Forestry and TRACOR in Transkei and the Department of Water Affairs, RSA.

Southern Africa is a diverse region consisting of many states with a range of systems of government. The well being of all states is closely linked through such factors as shared river basins, utilisation of resources (including labour) and economies of scale. The project appraisal, at this stage, has therefore been made on a regional basis by considering the alternative means of satisfying the demand for electricity in the region (i.e. the systems run by TESCORA and ESCOM) and identifying the potential uses for water both in Transkei and RSA and also for export. Very long term power forecasts and generation development plans are uncertain, but it is possible to make a reasonable assessment of electricity benefits in relation to reasonable predictions and alternative resources. Medium term water management options are outlined in a report being prepared by the Department of Water Affairs RSA (DWA). The water transfer proposals in this study are more extensive and perhaps longer term than discussed by DWA. Obviously with a multi purpose scheme such as the Umzimvubu development; all uses and benefits should be considered together in relation to the total costs.

The meteorology and topography of Southern Africa is variable ranging from desert to sub-tropical conditions and coastal regions to high altitude plateaux. The Umzimvubu basin and Mbokazi dam site have certain characteristics which favour their development over many other existing or potential sites. The basin as a whole has a long reliable summer rain season with low evaporation and is drained by four major rivers which meet just upstream of Mbokazi dam site which, therefore, gives maximum control of the water resource. Part of the upper catchment is in RSA.

### **Projects**

Various types and sizes of projects were conceived, drawn up and costed and their benefits assessed. On the basis of information available, analyses and judgement, the following project elements are proposed (Figure 3):

- (1) Mbokazi dam (210 m high with full supply level of 250 masl) with a total storage of  $5\,950 \times 10^6 \text{ m}^3$  and live storage of  $4\,300 \times 10^6 \text{ m}^3$  to provide over year storage and a high reliable yield;
- (2) Mbokazi power station (1 600 MW) to be connected to and integrated into the ESCOM electricity grid and to be operated by ESCOM. The hydro power station will have peaking and reserve roles with firm annual peaking energy of 1 080 GWh;
- (3) Nkwalini dam (43 m high) 17 km downstream of Mbokazi to even out the irregular discharges from Mbokazi power station so that a reasonable flow is always discharged down the river;
- (4) Nkwalini power station (50 MW) fed from Nkwalini dam and connected to the TESCORA electricity grid and operated by TESCORA to meet base and peaking requirements, with average annual energy of 192 GWh;



- (5) Water conduits for interbasin transfer consisting of river offtakes, pipes, tunnels, canals and pumping stations. The main route would be to the west, serving the plateau within Transkei and feeding into either or both the Orange and Fish rivers in RSA and could be constructed in two or three stages of 20 m<sup>3</sup>/s. A separate smaller conduit (10 m<sup>3</sup>/s) would feed to the north east within Transkei;
- (6) Water conduits for export of water consisting of river offtake, water treatment works, pipelines, balancing reservoir, pumping stations and a single buoy mooring (SBM) offshore from which water would be loaded onto tankers at an average rate of about 3 m<sup>3</sup>/s over a year.

Maximum benefits would be realised if all developments proceeded together, however, financial and other constraints may preclude this but some elements are interdependent, eg. power stations are associated with their dams. Also major water transfer schemes require the regulated water flow from Mbokazi reservoir. Operation of the scheme would consider all requirements but flexibility over a few days is provided by the balancing storage at Nkwalini. Water could be exported at a rate of 3 m<sup>3</sup>/s without Mbokazi reservoir and being only 3% of the MAR, implementation would have no effect on other uses.

#### **Umzimvubu Basin Development Authority**

We propose the setting up of an Umzimvubu Development Board backed by an Authority who would be responsible for steering the project through the next stages of design and construction while at the same time establishing agreements for financing construction and running costs as well as arrangements for receiving income from the benefits. The Authority would work with other bodies dealing with water and electricity in Transkei and RSA. The completed scheme would be operated by the Authority. The proposed organisation is shown in Figure 4.

#### **Executive summary**

This report summarises the work undertaken in the overall feasibility study. The 6 volumes of the draft feasibility report submitted in December 1986, one year after the start of this study, give more details on the information collected, analyses, engineering designs, assessment of benefits and economic analyses. Particularly critical aspects were identified by sensitivity studies and received most attention. However, proposals should be treated in the context of the first detailed feasibility study of the site with wide ranging long term benefits so that optimisation and refinement must follow.

## CONCLUSIONS

The report covers the desk study and field work carried out to investigate the technical feasibility and economic viability of utilising the resources of the Umzimvubu river by constructing a large multi-purpose dam at Mbokazi. The project was generally treated as a scheme for Southern Africa as a whole because benefits could accrue for Transkei and RSA directly and to neighbouring states indirectly because of interlinked power systems and shared trade.

The main conclusions that can be drawn from the present knowledge and analyses are that:

1. The five major tributaries in the Umzimvubu basin meet a few km upstream of the Mbokazi dam site creating a large river with a mean annual runoff of  $3\ 000 \times 10^6 \text{ m}^3/\text{a}$ . The reservoir is located in a narrow valley in a zone of low evaporation losses.
2. The valley at Mbokazi is topographically suitable for a dam with a full supply level up to 290 masl, i.e. about 250 m high. A sharp bend in the river creates a suitable site for a rockfill embankment dam and ancillary structures.
3. The geological investigation has shown that: a pronounced lineation along which the river tends to flow is an intruded shear zone which shows no sign of recent movement; material in a large land slide on the right bank can be used within the shoulders of an embankment dam; and generally the bedrock has low permeability except for one 15 m thick horizon in baked shale that can be grouted and drained. On the basis of the investigation so far it would be prudent to limit the full supply level of a reservoir to about 250 masl. The reservoir would be water tight. Construction materials can be obtained locally for an embankment dam or concrete dam.
4. Engineering studies show that a scheme with full supply level (FSL) of 250 masl and reservoir capacity of  $6\ 000 \times 10^6 \text{ m}^3$  can generate firm energy of 1080 GWh with 98% assurance and average energy of 1190 GWh/a. Downstream water releases would vary from an average rate of 68 to 102  $\text{m}^3/\text{s}$  which is a large regulated flow in the Southern African context.
5. Near the end of the century the ESCOM system can absorb hydroelectric power designed to operate at a low load factor. Preliminary analyses indicate that, for a reservoir with FSL of 250 masl, a power station of 1600 to 2000 MW would be appropriate depending on the rate of increase in the demand and on the effect of demand side management.
6. At about the same time the TESCO system could absorb a moderately sized power station utilising the discharge from Mbokazi power station.
7. Current development plans for the Umzimvubu basin and adjacent valleys do not envisage any major increase in water use locally. However, Transkei has substantial areas on the plateaux where the soil, slopes and climate are suitable for large scale agricultural development. To

the north in the coastal region about 45 000 ha would benefit from winter irrigation whilst to the west about 115 000 ha could be developed mainly for summer crops. These areas can be served by large water conduits which would also supply water for domestic and industrial use and small scale agriculture for local consumption. The western conduit could be extended to RSA to enable water to be transferred to the Orange river (including the Hendrik Verwoerd dam) and to the Fish river.

8. Some water could also be shipped overseas from Transkei without significantly reducing the availability for Southern Africa. Such a scheme is unlikely to consume more than a few cubic metres per second and would be possible even without Mbokazi dam.
9. The total cost of the hydroelectric project with reservoir FSL of 250 masl and 1600 MW power station at Mbokazi plus the Nkwalini scheme is estimated to be about R1 850 x 10<sup>6</sup> at September 1986 prices excluding interest during construction and price contingencies (escalation) but including engineering and administration costs.
10. Preliminary economic analyses shows that an ESCOM development programme including this project would be more economic than one based on coal-fired thermal stations. The equalising discount rate is over 12 percent.
11. Nkwalini power station would also be economic compared with purchasing from ESCOM. The power station should have a capacity in the range of 40 to 50 MW.
12. The estimated cost of a 20 m<sup>3</sup>/s conduit reaching as far as the Orange and Fish rivers would be about R2 000 x 10<sup>6</sup> at September 1986 prices. Running costs would be about R180 x 10<sup>6</sup>/a. The northern route carrying 10 m<sup>3</sup>/s is estimated to cost R350 x 10<sup>6</sup> to build and R30 x 10<sup>6</sup>/annum to run.
13. The social and political benefits of a reliable large water supply to areas that are at present deficient are likely to be very significant but are difficult to quantify at this stage. Further socio-economic analyses are required in order to demonstrate the true value to the whole region.
14. Apart from the main benefits of providing water and electricity the scheme would also give:
  - (a) recreational opportunities and tourism;
  - (b) improved infrastructure in the area;
  - (c) high voltage transmission lines across Transkei that would reinforce power supply in the East London and Port Elizabeth sectors of the ESCOM network;
  - (d) some reduction in flooding downstream of Nkwalini dam.
15. The next stages of the project development and appraisal should proceed smoothly and without delay if the project is to meet the needs near the end of this century.



## DESCRIPTION OF PROJECT AREA

### Hydrology

The Umzimvubu river basin drains an area of 20 000 km<sup>2</sup>. The catchment as a whole is mountainous, and the main river valleys are deeply incised. The Umzimvubu itself and its principal tributaries rise along the Drakensberg escarpment at elevations between 2 400 and 2 900 metres.

Within the whole basin, only the valleys of the Kinira catchment north-west of Matatiele, and of the upper Umzimvubu north of Cedarville are reasonably flat.

Outside the basin along the coast to the north the land is relatively flat forming a plateau at about 350 to 500 masl which drains towards the coast. To the west the main plateau between Umtata and Queenstown is at about 1 000 masl and is bordered to the north by the extension of the Drakensberg escarpment.

Geologically, sedimentary rocks predominate (sandstones, siltstones and mudstones) and the stratification is close to horizontal. The landforms are essentially erosional, which accounts for the general absence of flat land in the basin. The soils, which are generally thin, and the vegetation, which is mainly grassveld of various kinds, combine to give a high runoff potential.

The climate of Transkei and the Umzimvubu basin is subjected to the influences of the Indian Ocean and of the three escarpments or plateau ridges which divide Transkei into three major terraces. Of the escarpments, that of the Drakensberg is both the most conspicuous and the most significant in its effect on precipitation.

The area can be divided into two regions: the southeastern coastal region and the Drakensberg region with the boundary in the vicinity of a line through Umtata and Kokstad. Both the regions experience summer rainfall with the maximum in March in the coastal region and in January in the Drakensberg region. June and July are the months of minimum rainfall.

In the coastal region, the area of maximum rainfall lies close to the coast, where the average annual fall reaches around 1 400 mm. Rainfall decreases inland, and reaches a minimum towards the boundary with the Drakensberg region (the transition zone). The average annual rainfall in this zone is 600 to 700 mm.

In the inland, or Drakensberg region, the maximum rainfall occurs just to the east of the main escarpment, where the average annual rainfall again reaches 1 200 to 1 400 mm. Due to the effects of elevation and relief, other local maxima also occur, but reach only around 1 000 mm. The minimum rainfall in the Drakensberg region occurs in the flatter and wider areas giving average annual rainfall of about 700 mm.

Measured annual evaporation from a free water surface is over 1 000 mm for the region being higher in the summer than winter.

The rainfall and evaporation rates affect the river flow within the Umzimvubu catchment and also the natural availability of moisture for agriculture. Generally the western plateau of Transkei experiences variable low rainfalls which, coupled with evaporation rates, is inadequate for more than hazardous subsistence farming. To the north rainfall, on the coast, is variable but adequate for summer crops in most years.

The reservoir at Mbokazi is large relative to annual runoff so critical droughts have a duration of a few years. Operation studies were based on a 64 year sequence of historic monthly flows from Oct 1921 consisting partly of flows measured within the catchment (but not at Mbokazi) since the 50's and 60's and partly of synthesised runoff calculated using longer rainfall records and selected catchment characteristics. We have recommended that recent gauging records should be processed to improve the historic sequence.

Average flows in  $10^6 \text{ m}^3$  are

Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Annual
133	248	336	432	548	565	255	113	74	77	64	84	2929

Major droughts occurred in the early 50's, 70's and 80's.

For the present study we have used the basic methodology for design flood estimation and sizing spillways which is described in the 1972 report of the Hydrological Research Unit (HRU) of the University of the Witwatersrand consisting of:

- (a) estimation of the probable maximum precipitation over the basin for a range of durations;
- (b) estimation of losses and hence of net or effective precipitation for a range of durations;
- (c) estimation of the catchment response to effective precipitation, using unit hydrographs;
- (d) combination (convolution) of the effective precipitation estimated with the unit hydrograph(s) to estimate the corresponding flood hydrographs at the dam site;
- (e) routing of the flood hydrographs through the proposed reservoir and spillway arrangements.

This gave a probable maximum flood for Mbokazi with a peak flow of  $33\ 000 \text{ m}^3/\text{s}$  and volume of  $5\ 570 \times 10^6 \text{ m}^3$  over one week.

The average unit rate of sediment discharge for the catchment is  $500 \text{ t}/\text{km}^2/\text{a}$  i.e. sediment inflow of  $10 \times 10^6 \text{ t}/\text{a}$  to the reservoir. In 50 years the loss of volume of the reservoir would be  $370 \times 10^6 \text{ m}^3$  which is not significant compared with the live storage of  $4\ 350 \times 10^6 \text{ m}^3$ .

## Geology

The geology of the bedrock and superficial deposits at Mbokazi and Nkwalini was established by field mapping, desk study of aerial photographs, drillholes, test pits and seismic surveys. In total 15 holes were drilled up to 120 m deep, 72 pits were dug and 9 seismic surveys were made. The investigation established subsurface conditions which affected the design and location of the dam and appurtenant structures and which had a significant effect on the accuracy to which the overall costs could be established.

The area around the Mbokazi dam is underlain by near horizontally bedded sedimentary strata of the Dwyka and Ecca formations, Karoo Supergroup. The strata were intruded by dolerite dykes and sills during igneous activity, also of Karoo age. The sedimentary strata dip at about  $10^{\circ}$  to the northwest except near dolerite intrusions.

These formations have been used successfully for construction purposes elsewhere in Southern Africa. The Dwyka formation tillite is of glacial origin and, when fresh, is a greenish-blue hard rock with a dense clay-sized matrix containing coarse, often angular rock fragments. Weathered tillite is a yellowish-brown clayey sand. The tillite grades upwards into the overlying Ecca Formation which consists of a uniform sequence of bluish-grey (when fresh) shales. The shales weather on exposure to an angular gravel-sand and, when completely weathered, form a yellowish-brown silty clay.

Dolerite occurs mainly in a massive continuous sill up to 200 metres thick which intrudes the Ecca Formation about 100 m above the tillite/shale contact. The intruded dolerite sill has baked and hardened the Ecca shales and in a 15 m thick zone on the right abutment has caused some fracturing. When fresh, the dolerite is a dark coloured, fine to medium grained and very hard rock. Decomposed dolerite consists of a red and yellow coloured sandy clayey soil, containing boulders of partly weathered rock.

The proposed Mbokazi dam will be situated with its base and lower flanks in Dwyka formation tillite (60-80m thickness), the middle flanks in Ecca formation shales (50-100m thickness) and the upper flanks in dolerite (60-110m thickness).

An intruded shear zone forms a prominent lineation passing through a neck in the right abutment and is weathered deeper than adjacent undisturbed rock. The shear zone will not affect the stability of the proposed dam or the reservoir.

Most soils in the area are transported, shallow and derived from the underlying rock types. Deeper alluvial soils occur in and near the river channel but rock is exposed in the river bed at the dam site. Areas of instability often occur at contacts between dolerite sills and underlying softer, less pervious, argillaceous rocks, especially where the contact dips towards the ground slope. A large landslide on the right abutment was found to be over 60 m deep and to contain  $7 \times 10^6 \text{ m}^3$  of broken rock which could be used in the dam.

Because of the high topography surrounding the dam basin, the impervious nature of the rocks and the near horizontal bedding, leakage from the basin will be negligible and the reservoir rim is safe. The area is one of low to moderate seismic activity.

Adequate borrow areas of fine grained material suitable for an impermeable core were proved on the left bank and rockfill can be obtained from large landslides, necessary excavation and rock quarries. Dolerite is considered the most suitable rock for concrete aggregate and drainage material and is readily available locally.

## WATER UTILISATION WITHIN SOUTHERN AFRICA

The proposals put forward in this section are medium and long term planning options for large water transfer conduits. Staged development could meet requirements well into the next century.

### Demand

At present no significant use is being made of the natural, but variable, flow of the Umzimvubu river in its lower reaches. Once the Mbokazi reservoir has been formed, a well regulated discharge would be available downstream of the dam. The potential for local agricultural development would be greatly enhanced and major transfers to adjacent valleys or plateaux in Transkei would be technically straightforward. With an assured supply and therefore negligible risk of crop failure it is worthwhile to set up an efficient agricultural development including spending more on high quality seeds with good fertilisers to increase yields of cash crops. Crops could be selected for the local Transkei market and for sale to RSA and overseas as raw, processed, frozen or tinned products.

An agricultural/social strategy that would be feasible because of large water transfer is:

- (a) domestic supplies to villages/towns for drinking, household use and subsistence gardening. This is of enormous social importance and might affect perhaps 1 000 000 rural people;
- (b) small scale irrigation schemes at village level;
- (c) new medium and large scale commercial irrigation ventures which will require the modification of existing land tenure arrangements in specific high potential areas;
- (d) agriculture related industries.

A number of potential water transfer routes appear to be technically feasible and of potential value. As an illustration of one option a reconnaissance level study was made of routing the water westwards towards a zone of low and unreliable rainfall, traversing western Transkei. Depending on the final routing, the water may be spilled into a tributary of the Orange river or into a tributary of the Great Fish river or both. Spillage into the Orange would be above the Hendrik Verwoerd dam and the upper end of the Orange-Fish tunnel and water leaving Transkei would be available to supply the bulk of the Orange basin and the entire Fish basin. Suitable large areas exist at the following places in western Transkei along a possible pipeline route:

- (a) 15 000 ha west and north of Lady Frere;
- (b) 60 000 ha at Ncora and in a large block of land well to the east of Ncora, east of the Tsomo river and west of the Qumanco river;
- (c) 40 000 ha east of Engcobo in the catchments of the Xuka and Mbashe rivers.



These areas are deficient in summer rainfall.

An additional option is the possibility of routing some of the water in a north-north-easterly direction to command an area of Pondoland below the 500 m contour (frost and hail free) or below the 800 m contour (predominantly frost free) and possibly even to spill surplus water into Natal. This is an area that has generally high summer rainfall but new and existing agriculture on 45 000 ha would benefit from irrigation during the winter.

South Africa is a dry country poorly endowed with natural resources in relation to its population projections. Drought is an ever present constraint on agriculture. The past decade has been particularly bad. Existing irrigation schemes in the Eastern Cape Province and on the Orange river and Vaal rivers have suffered from severe water restrictions.

Damage has come from:

- the need to restrict areas of annual crops;
- crop reductions or failures with perennial crops;
- high levels of salinity in irrigation water caused by low flow.

The reliability of flow in South African rivers which would result from the Mbokazi project proposals would have a very significant value.

Usage might comprise:

State/Province	Use to which water put	Water requirement total (x10 <sup>6</sup> m <sup>3</sup> /a)
1. Transkei	Domestic rural and small-scale irrigation	300
2. Transkei	Medium and large scale irrigation projects - west	800
3. Transkei	Medium and large scale irrigation projects- Pondoland	150
4. RSA	Irrigation schemes in Fish River Catchment and Karoo via Wapadsberg Tunnel, Coonap, Bushmans	1 000
5. RSA	Orange River adjacent to river	1 500
6. RSA	Namaqualand	*
7. Natal/Kwazulu	Medium scale supplementary	150
8. Kwazulu	Domestic and small scale irrigation	100*
		<u>3 900+</u>

\* possible use

Clearly there is no difficulty in finding suitable land on which to use the proposed supply.

Under present circumstances the following crops suggest themselves as the best candidates for development on the very large scale projects needed to utilise the water from the Mbokazi scheme.

- (a) Pastures for intensive sheep production (all areas).
- (b) Wheat (all areas).
- (c) Citrus (frost free Eastern Cape).
- (d) Other fruits, both sub-tropical and deciduous - pawpaws, mangoes, figs, litchis, dates, sultanas, table grapes (various parts of the Orange river valley).
- (e) Vegetables (all areas).
- (f) Sugar cane - Pondoland, Transkei and Natal/Kwazulu.
- (g) Tea - Pondoland, Transkei and Natal/Kwazulu.

### **Transfer conduit systems**

The major proposed transfer scheme is to the west via Umtata to RSA and serving the north-western agricultural area in Transkei and urban areas including Umtata. It could have a capacity eventually of over 50 m<sup>3</sup>/s supplied by more than one route. The system to the northeast would be based on the same principles and criteria but is unlikely to carry more than 10 m<sup>3</sup>/s, mainly in the winter (see Figure 5).

Each route might be developed with different combinations of water conduits of tunnels, sealed pipes and penstocks with gravity canals. Pumping could be by a few high lift pumping stations or by more stations with lower lifts. At this stage no attempt has been made to prepare an "optimum scheme" because the location and size of demand has not been established. On the other hand some idea is required of the order of cost of transferring water so that a judgement can be made on whether such a scheme could be worthwhile and include it into the long term overall planning of the distribution of the scarce water resources of Southern Africa.

Water would be abstracted from the Umzimvubu river downstream of Mbokazi dam so that the generation of peaking hydroelectricity in the basin would not be adversely affected by the transfer of water. Electricity for pumping could be obtained from ESCOM in the same way as any other large consumer thereby taking advantage of cheap base load electricity from efficient large coal-fired thermal power stations.

A selection of possible alternative routes of water conduits to the west are shown in plan on Figure 5. The engineering works required for all options are similar and are of the same order of cost (see Tables 1 and 2). Feeding to the Orange will be more costly but has the advantage that the transferred water would flow into the Hendrik Verwoerd reservoir which could be used to even out fluctuations in demand while maintaining a steady rate of pumping. The most northerly route (labelled B) climbs up to the escarpment just north of Umtata and then is relatively flat to Dordrecht and on to Molteno. The conduit could discharge into the Orange catchment at Dordrecht or could be taken to Molteno and Tarkastad if both catchments and the western edge of Transkei are to be fed. This route does not pass through the better areas for irrigation in Transkei but water could be released into the southward draining natural water courses from whence it could be abstracted for local use. Alternatively conduits could be laid down to the irrigation areas to minimise losses but at greater expense. At

this stage no attempt has been made to collect any flows from intermediate catchments.

All other routes run to the south of Umtata and branch into various options to the west of Engcobo. Route E discharges directly into the Fish only or can be lengthened as in Route A to feed both the Fish and Orange. Route D climbs up the escarpment but the rest traverses the irrigable areas in the Kei catchment. Sections along route A and N are given in Figures 6 and 7.

### **Export of Water from Southern Africa**

Certain countries in the Middle East are significantly short of water and have expressed an interest in importing water by tanker. So far no satisfactory system has been devised whereby a tanker can take oil in one direction and return with fresh potable water utilising the same storage compartments. The studies of offshore markets, demand rates, organisational aspects and alternative sources were carried out by other, separate organisations based in Britain and Japan and reports were submitted regularly to this consortium. Economic viability for a tanker shuttle service has not yet been established.

Within this study the technical feasibility of exporting water was established and outline engineering schemes and costs were prepared. A single buoy mooring (SBM) would be constructed about 4 km offshore of Port St Johns. Raw water would be abstracted from the Umzimvubu downstream from Nkwalini, treated in a works on the left bank, the potable water would be pumped to a balancing reservoir near the coast in a 1,7 m diameter pipe and thence fed by gravity through twin 1,25 m diameter pipes to the SBM. A small harbour would be constructed to shelter service craft.

A system to export  $90 \times 10^6 \text{ m}^3/\text{a}$  (i.e. 300 tankers per year of capacity 300 000 tons) would cost  $R270 \times 10^6$  to build and  $R14 \times 10^6/\text{a}$  to operate and maintain.

## DAMS AND HYDROELECTRIC PROJECTS

Key technical data on the dams and hydroelectric projects are given in Table 3.

### Mbokazi Dam

In its lower reaches, the Umzimvubu river has cut down through the general plateau of Transkei producing a deep valley flowing along incised meanders with banks formed mainly within the in situ bedrock. Habitations are concentrated traditionally on the higher ground away from the river so only about 20 small settlements would be affected by the reservoir.

The dam site has been selected because of many advantageous natural features including control of as much as possible of the catchment where the valley is narrow so that the volume of the dam structure is not excessive. Immediately downstream of the dam site the river bends sharply to the right through more than a right angle and the short path through the spur can be utilised for locating ancillary structures such as the spillway, power system and diversion conduits.

The size of the proposed dam (200 m high) and reservoir ( $6\ 000 \times 10^6\ m^3$  total volume) was based on consideration of the topography, geology, hydrology, dam costs and benefits.

The dam alignment was selected after studying 5 options for embankment dams and 2 for concrete dams. A rockfill dam was chosen because one could be constructed safely from locally available material more economically than a concrete dam.

The rockfill dam layout is shown in Figure 8. The diversion tunnels spillway and power systems are all on the right bank with intake structures upstream of the right abutment of the dam. Most of the upstream cofferdam is incorporated in the upstream shoulder of the main embankment.

The dam has three major zones (see Figure 9). The core, which forms the water barrier, is placed centrally with a slight inclination. The core is supported upstream and downstream by rockfill shoulders with a riprap protecting layer on the upstream face in the normal reservoir operating range. A chimney filter and drain system on the downstream side of the core collect and discharge seepage into the blanket drain placed on the foundation beneath the downstream shoulder. Borrow areas for all construction materials have been identified within reasonable haul distances.

Mbokazi dam falls into the very large category of dams by world standards and the highest degree of safety is required to avoid failure and the risk of a catastrophic uncontrolled release of water. The spillway design flood has been selected to be equal to the probable maximum flood (PMF). Not only is the incoming flood very large but the head difference between reservoir level and tail water is also high at over 200 m.

The reinforced concrete spillway consists of three parts: the gated overflow headworks; the chute; and the flip bucket for energy dissipation (Figure 10). The principle of a spillway controlled by gates was accepted



because Mbokazi includes a large power station which will require skilled professional staff full time who will be on hand to maintain and operate spillway gates. A concrete lined chute carries the discharge to a flip bucket set on the right bank of the river about 60 m above river level. The chute is split into three channels. Modest floods would be discharged through one channel only so that the unit discharge is high enough to flip properly at the bucket and to be thrown clear of the structure.

The diversion system passes the 1 in 100 year flood through two ungated 12 m diameter concrete lined tunnels on the right bank. One tunnel is converted to a permanent low level outlet and the other will be plugged.

The power system is located on the right bank (Figure 11). The tunnels pass through the spur forming the river meander with the power station well downstream of the dam. The power intakes would be located immediately upstream of the dam on the right bank and set about 20 m below minimum operating level. From the power intakes, concrete lined tunnels about 650 m long lead to vertical shafts extending upwards as surge shafts which, to satisfy hydraulic transient conditions and to minimise the length of costly steel tunnel linings, are located as close as possible to the power station having regard to the topography. The switchyard would be located on the left side of the river.

The power intakes would be of the upstream sloping gate type avoiding the need for a separate vertical gate shaft and allowing the whole length of the tunnels up to the intake to be dewatered for inspection. The power tunnels and shafts would be concrete lined except at the downstream ends where rock cover is less than about half of the static head and steel liners would have to be used.

The Mbokazi surface power station for a six unit 1 600 MW installation is shown on Figures 12 and 13. The layout is conventional and provides for the control room, offices and workshop to be housed in a two-storey building as an annex to the loading bay. The floor levels of the loading bay and downstream deck provide a margin above the estimated maximum flood level.

The switchyard configuration will be a standard double busbar arrangement which is consistent with the ESCOM 400 kV philosophy with gas insulated switchgear. Two overhead line entries will be required at each end of the substation.

Integration of the project into the ESCOM transmission system is proposed at two locations, namely Mersey (near Pietermaritzburg) and Neptune (near East London). Four transmission lines of 275 km are required, and this configuration will be sufficient for a station output between 1 200 and 2 000 MW. Because of the levels of power transfer involved and the relatively long route lengths, Quad Zebra configuration has been chosen.

For the six unit 1 600 MW scheme the generators and transformers would be rated at 2 000 MW and generation at this output would be possible at reservoir levels above 210 m. 1 600 MW will be generated at the minimum reservoir operating level of 180 m.



The turbines will be vertical shaft Francis turbines with butterfly inlet valves. The runners will be approximately 5 m in diameter.

The turbines will be directly coupled to conventional air cooled umbrella type generators with static excitation and a thrust bearing mounted below the rotor. The generators will be rated 390 MVA at 0,85 power factor.

#### **Nkwalini Dam**

A reregulation dam is proposed downstream of Mbokazi to even out the fluctuating discharges from the power station. The size of the reregulation reservoir is sufficient to store the weekday releases from Mbokazi over 5 week days and to generate over seven days. The full supply level (FSL) is at the normal operating tailwater level (TWL) for Mbokazi dam, i.e. 43 masl and minimum drawdown would be 37 masl.

The dam structure is a conventional overflow concrete gravity dam incorporating a 16 000 m<sup>3</sup>/s spillway to handle the discharge from Mbokazi plus a 3 unit 50 MW power station on the right bank to generate electricity for the TESCOR system (see Figure 14).

The turbines would be vertical shaft Kaplan type operating at a rated speed of 200 rpm with concrete spiral casings. The runner will be approximately 3,3 m in diameter.

The turbines will be directly coupled to conventional air cooled umbrella type generators with static excitation and thrust bearing mounted below the rotor. The generators will be rated 20,6 MVA at 0,85 power factor with a rated voltage of 11 kV. The transformers would be three phase units rated at 20 MVA, 11/132 kV. The 132 kV switchyard located on the right bank adjacent to the power station will be of the conventional outdoor type in single busbar formation. Three 132 kV outgoing feeders are foreseen comprising a double circuit line to Zimbane and a single circuit line to Magwa.

## ROLE OF POWER STATIONS

### Mbokazi

The current (mid 1986) ESCOM forecast is for 5% p.a. increase in maximum demand and 5,5% p.a. increase in energy demand over the period to 1996. The difference between these two rates represents the effect of demand side management (DSM) i.e. tariffs to discourage use of peak electricity.

After 1996 there is no formal ESCOM forecast, but others expect growth in both maximum demand and energy demand of 4,55% p.a. (Table 4).

The approximate shape of the annual load duration curve (LDC) in 1985 was estimated from hourly system demand data in each calendar month. This estimated LDC is shown in Figure 15. It can be seen that generating plants supplying the top 10% of the demand would have an average plant factor of less than 5% and a maximum plant factor of 10%. On this basis, therefore, there would appear to be a role for at least 1 800 MW of low plant factor peaking plant in 1985. This compares with an actual capacity of 882 MW of hydroelectric and gas turbine units. The above simplified assessment underestimates the potential for peaking capacity (operating at plant factors of less than 10%) due to the substantial reserve capacity requirements and the total amount of such plant might be expected to be in the order of 10% of the total capacity (i.e. 2 500 MW in 1985) rather than 10% of the maximum demand.

ESCOM expect that, due to the implementation of demand side management, the annual system load factor will increase to 79,5% by 1997 with consequent changes to the peak load region of the LDC. A preliminary estimate of the shape of the 1997 annual LDC is also shown in Figure 15. This indicates a potential for peaking plant up to 10% plant factor of over 3 000 MW in that year. With respect to the need for additional peaking capacity, it may be noted that the existing ESCOM hydro stations (540 MW) are not actually very low plant factor schemes since they have an average plant factor of approximately 20%. Also the existing gas turbine units (342 MW) will be reaching the end of their useful lives by that time. On the other hand, the pumped storage plant (1 400 MW) could change to lower plant factor operation as the proportion of high efficiency plant increases.

ESCOM have a generation development programme which they estimate will meet demand increases up to the year 1997, provided that the maximum demand increase rate is 5% per year. In 1997, with the present development plan almost entirely consisting of coal fired thermal stations, there should be a total installed net capacity on the integrated ESCOM system of 42 321 MW to meet a forecast demand of 32 474 MW, i.e. a reserve margin of 30,3%. This capacity will comprise 28 000 MW of large coal-fired units (600/660 MW units size), about 10 000 MW of other coal-fired plant, one 1 840 MW nuclear station and peaking capacity comprising gas turbines (342 MW) hydro (540 MW) and pumped storage (1 400 MW). Thus, in 1997 the gas turbine and hydroelectric units will represent 2,7% of the demand and the pumped storage plant 4,3%.

By the year 2000 there will be a requirement for a total of some 48 250 MW of capacity on the ESCOM system. Figure 16 shows typical and peak winter weekday load curves for the ESCOM system in 2000. These were constructed

based on similar curves for 1985. The possible operating role of a 2 000 MW peaking hydro station occupying the top of the peak is also shown. This could represent Mbokazi with an installed capacity of 1 600 MW, since this is capable of 2 000 MW much of the time. For both the peak day and the typical day the station would operate twice a day, but the energy generated during the evening peak is much less than that generated during the morning. The approximate energy required is 7,4 GWh for the peak day, and 5,3 GWh during the average winter weekday.

The average energy output of Mbokazi for the 290 m, 250 m and 230 m FSL are 1 579 GWh, 1 192 GWh and 985 GWh per annum, i.e. 4,6 GWh for every weekday on average for 250 m FSL. If the output for Mbokazi is 1 600 MW the approximate energy that could be generated subject to the constraints of the load curve falls to 5,4 GWh for the peak winter day and 2,6 GWh for the typical winter weekday. All three alternative dam heights would provide sufficient energy for the typical weekday, and the 290 m option would provide more energy than is necessary for the peak day. A scheme based on 1 600 MW installed capacity would therefore operate in a marginally less peaking role in order to fully utilise all available energy.

The role of Mbokazi power station is expected to change with time as the demand increases and also to differ between winter and summer.

### **Nkwalini**

Since the formation of TESCO in August 1979 the maximum demand on its interconnected system has increased steadily, the 1985 level being approximately 41,3 MW. The average rate of increase in demand has been 10% per year over this period. The energy demand (generation plus purchase) has increased from 122,1 GWh in 1981 to 198,4 GWh in 1985, an increase rate of 13% per year. The annual system load factor has varied between 51,6% and 54,8% over the latter period on a calendar year basis. Load forecasts have been prepared by various advisers to TESCO and we have adopted a maximum demand increase at 8,5% per year up to 1993/94, with increases thereafter constant at 8,0% per year. The load forecast is shown in Table 5.

Over the period to 1995, TESCO plan to commission a fourth 14 MW unit at Collywobbles and to build a 60 MW power station at Qalweni or equivalent alternatives.

It can be demonstrated that the Nkwalini power station can make a useful contribution to the TESCO system but the exact role will depend on the other stations completed before Nkwalini, the pattern of water releases required downstream of Nkwalini and the amount of storage available in the small reservoirs serving other power stations.

## CAPITAL COSTS OF DAMS AND POWER DEVELOPMENT

Capital cost estimates were prepared for nine alternative Mbokazi options embracing the range of dam heights from 290 m to 230 m FSL and a range of installed capacities between 1 000 and 2 000 MW, together with three options for Nkwalini of 40, 50 and 60 MW installed capacity. All costs are based on September 1986 price levels. Where appropriate foreign exchange rates have been assumed of 3,2 Rand equals 1 Pound Sterling and 2,2 Rand equals US\$ 1. Physical contingencies and engineering have been included in the costs.

The costs of the civil works are based on the outline designs. Quantities have been estimated for the main construction activities such as excavation, embankment fill, tunnel construction, adits with grout and drainage curtains, and concrete in the spillway and power station. Unit rates for construction were derived. The major cost item is Mbokazi dam structure at 40% of the total. Unmeasured items and physical contingencies have been taken as 15% at this stage. In addition engineering and administration charges have been added at 8% of the total construction costs.

The basis for the cost estimates for electrical and mechanical plant was a combination of actual contract costs for similar plant under international competitive tendering and manufacturers' budgetary estimates. These costs include generators, turbines, valves, electrical and mechanical auxiliaries and powerhouse cranes. Physical contingencies and engineering are included at a combined rate of 20%.

Switchyard costs include a 400 kV switchyard and generator transformers on the basis of a GIS installation. Physical contingencies and engineering are included at a combined rate of 15%.

Costs have been added for four 275 km long 400 kV Quad Zebra overhead lines to interconnect Mbokazi into the ESCOM system including compensation and integration costs to the ESCOM substations. Physical contingencies and engineering are included at a combined rate of 15%.

Since the role of Nkwalini is to reregulate the flow of water down the Umzimvubu river to an acceptable regime, a portion of the civil costs of Nkwalini dam and spillway should be included in the costs of Mbokazi. This portion has been taken to be 80% for the purposes of this study, i.e. a cost of R70,33 million. Physical contingencies and engineering have been included for at rates of 20% and 8% respectively because of greater uncertainties in foundation conditions.

The total cost assumptions for all options are summarised in Table 6. The range of specific capital costs for these options varies between Rand 1 125 per kilowatt for the 250 m 2 000 MW option to Rand 1 794 per kilowatt for the 290 m 1 200 MW option.

Cost estimates for the power development at Nkwalini have been prepared using the same general approach as for Mbokazi (Table 7).

## ECONOMIC EVALUATION OF POWER BENEFITS

The Mbokazi and Nkwalini schemes have been separately considered within the context of the ESCOM and TESCOR systems respectively, and the integration of the schemes into the power systems has been examined over a 10 year period.

All costs of the dams, power stations and transmission lines have been included although if the water transfer scheme proceeds some of these features assist both projects and costs should be shared. Any sharing will improve the economics of the hydroelectric project.

The evaluation of the Mbokazi scheme has been carried out in quasi-economic terms as a project serving Southern Africa. Local market prices have been used for coal, for example, which do not necessarily correspond to economic prices. SACU rebates on the capital costs have also been excluded. No shadow prices have been applied to any of the capital cost elements. The rationale for this approach is that at this stage a comparison has to be made between a number of competing schemes, both within and outside RSA.

Only base-load coal-fired steam stations are being considered for installation on the ESCOM system up to the late 1990's. The main economic comparisons have been made on the assumption that the Mbokazi scheme would replace or delay the construction of further plant of the same type after the presently scheduled power stations have been completed. Alternative generation planting programmes were drawn up, each of which met the ESCOM security criterion. The programmes cover a ten year period, starting in 1997 (the first year in which it was assumed the Mbokazi plant could be commissioned).

The nine programmes were based on the alternative options for Mbokazi covering 290 m to 230 m dam heights, with variation in installed capacity. In addition to these programmes an all-thermal programme was developed as a datum against which to measure the Mbokazi based programmes.

The estimated cost of the coal-fired power station assumed in the evaluation is R1 200/kW at September 1986 price levels. This represents the cost of the power station, plus the switchyard and necessary transmission to interconnect it to the main ESCOM system. This cost excludes GST.

The capital and operating costs of each programme were determined on an annual basis over the ten year period using a probabilistic type computer program. This simulates system operation subject to the constraints of the load duration curve, plant availabilities, merit order, etc. The costs in the final year of simulation were run out over the life of the hydro scheme, thereby avoiding any calculation of significant residual values. The capital costs of any thermal plants commissioned during the simulation period were reintroduced into the cost stream as appropriate at the end of their economic lives.

Throughout the analysis costs common to all alternative generation planting programmes have been ignored. No retirements of existing generating plant have been made.



The evaluation of Nkwalini is essentially similar to that for Mbokazi, with a calculation of total system costs. Alternative generation planting programmes were derived based upon the 40, 50 and 60 MW alternatives for Nkwalini, with a fourth case based on no Nkwalini development. It was assumed that growth in electricity demand would be met by either:

- (a) input from ESCOM, based on the costs of large coal-fired generating plant, or
- (b) import from ESCOM, costed on the basis of the ESCOM tariff, before and after allowance for SACU rebate.

These alternatives represent consideration of the Nkwalini scheme in a Southern African and Transkei context respectively.

Due to the very marked seasonality in the outputs and operating regime of the hydro plants in Transkei, all modelling has been done on a seasonal basis with different load duration curves for the summer and winter seasons.

In the context of methodology adopted for this study it was decided to adopt a test discount rate of 6% p.a. This rate corresponds closely to the rate used by ESCOM of 5,5% p.a. It is understood that DBSA use a lower rate of 3% in the analysis of projects in the agricultural sector. However, it was decided to use a range of discount rates from 3% to 12%.

Table 8 shows the comparative benefits for the nine alternative Mbokazi options considered at the test discount rate of 6%. The least cost development is seen to be that based on a 2 000 MW scheme with a 250 m FSL. Also given is the Equalising Discount Rate (EDR) i.e. the rate at which hydro and thermal options are equally economic. If the test discount rate is less than the EDR, Mbokazi is favoured. The results indicate increasing economic viability for Mbokazi with increasing installed capacity for each dam height. Increasing the size of Mbokazi power station, however, decreases its load factor since at any dam height the energy output is virtually fixed.

The economic analysis carried out shows that on the assumptions made, a development of 2 000 MW output with a FSL of 250 m represents the most attractive alternative when compared with the developments based on coal fired thermal power stations. This conclusion was found to be the most robust when subject to changes in basic assumptions including capital costs of Mbokazi and the coal fired thermal alternative, fuel prices and the shape of the load duration curve (see Table 8 for effects on the 1 600 MW, 250 masl scheme).

In practice a development with a 1 600 MW installed capacity has a potential output 2 000 MW for reservoir levels higher than 210 masl. The value of this additional power output has not been quantified in the analysis but it would be available for 90% of the time. It will increase the flexibility of operation of Mbokazi both in terms of peaking and for system reserve. This additional benefit should be examined in a detailed economic appraisal.

The most attractive development at Nkwalini was shown to be that based on

schemes between 40 and 50 MW (Table 9). These offered a lower cost than importation from ESCOM if imports are based on the ESCOM tariff, either with or without the SACU rebate. If viewed from a Southern African context the total costs of development assuming imports are costed at direct ESCOM costs of are lower than the equivalent costs with Nkwadini. This result, however, is very sensitive to the assumptions made regarding the cost allocation of Nkwadini dam civil works between Mbokazi and Nkwadini (Table 10).

## PROGRAMME FOR DEVELOPMENT

### Study and design

Multipurpose development of the Umzimvubu basin is recommended with the main elements being the hydroelectric scheme at Mbokazi and the water utilisation schemes within Transkei and RSA. The most beneficial use of the river would include both aspects which are interdependent in that both require the dam at Mbokazi. However, separate development programmes are presented to show clearly the steps required for realisation of each element and the time that they will take. It is emphasised that such large projects take many years to come to fruition and that the next stages in this process should follow directly on from this report if the schemes are to be ready when required near the end of this century.

#### (a) Hydroelectric project

The rate of increase in electrical demand and development plans of both ESCOM and TESCOR point to commissioning the first units in early 1998. This fits well with award of the main civil contract for the Mbokazi project dams and power stations, etc at the end of 1990 with a seven year construction programme. A programme of activities for the dam and hydro power development between now and start of construction is set out in Figure 17. This programme is based on the assumption that the civil works construction would be carried out by a large consortium of national and international companies who have constructed similar schemes already.

Apart from negotiations on interstate agreements further economic and financial studies, detailed site investigation, testing, hydraulic modelling and preparation of contract designs must be completed before tendering or negotiation of contracts. Award of the main civil contract would be at the end of 1990.

#### (b) Water transfer projects

The more detailed study of the agricultural potential and benefits that would accrue from large scale development within Transkei and RSA is a top priority. The benefits should be assessed in socio-economic terms to show the advantages of the project to the whole region. Taking into account the different organisations that would have an input to such a study, a period of two years should be allowed for comprehensive soil surveys, selecting suitable crops, market surveys and predictions, planning large farm developments and assessing demand for water on a seasonal basis region by region. The water requirements for rural, urban and industrial use should be derived from long term plans for Transkei. Socio-economic and financial analyses would demonstrate the viability of development and indicate the scope of the first stage.

Preparation of tender documents for such a long conduit through Transkei to RSA could take up to four years depending on the number of contracts and the extent of secondary and smaller offtake conduits included.

Award of the first contract for large water transfer conduit through Transkei could be in 1993.

## Construction

### (a) Mbokazi and Nkwalini dams

The programmes for construction of Mbokazi dam and Nkwalini dam are given in Figure 18. The first unit is commissioned after 7 years and the last in the ninth year. The civil works should be let as one contract because of the interaction between project features in the compact site. In particular economic earth moving will require careful programming of construction sequences. The mechanical and electrical equipment would be supplied under separate contracts. The critical path is through the construction of the diversion tunnels, the embankment and impounding to a high enough level to test and commission the first two units in January of year 8. Construction of the civil works for the power system and erection of the generating plant and transmission lines are not on the critical path for commissioning the project.

### (b) Water transfer conduits

The construction programme for the water conduit system would depend mainly on the supply of pipes. It would be preferable if these were manufactured in a special factory established locally for this purpose. Construction of the conduit would probably be let in a number of contracts of the size that can be handled by contractors in Southern Africa but could possibly be arranged with one large contractor or consortium either acting as main contractor or as contract manager controlling sub-contracts.

A simplified construction programme for the western route is set out in Figure 19.

## TWO YEAR STUDY WITH EMPHASIS ON WATER USES

### Activities

#### 1. Management and engineering, including

- direction and coordination of study
- liaison with coordinating committee
- liaison with government departments in Transkei and RSA
- liaison with the Development Bank of Southern Africa
- preparation and circulation of regular progress reports on all aspects
- estimating growth of domestic and industrial water requirements in study area
- overall planning
- engineering of water transfer, routes, systems, sizes, pumping rates, optimisation, access routes
- selection of pumps, transmission lines
- costing
- meteorology, hydrology
- detailed reservoir operation studies
- review of land tenure aspects, shared water basin, shared benefits
- implementation and construction programme including staged development
- coordination and preparation of final report

#### 2. Geology

- mapping of routes for pipes, canals, tunnels with some seismic surveys
- mapping of pumping station sites including drilling if necessary
- identification of borrow areas

#### 3. Agriculture

- review reconnaissance study
- identify areas suitable for irrigation (soils, slopes, settlements, present usage)
- carry out detailed soil mapping including testing
- identify possible crops (winter, summer and perennial)
- establish marketability in Transkei, RSA and export as raw and processed products
- prepare outline schemes for large scale commercial agriculture and local irrigation
- assess overall economic (including social) benefits

#### 4. Electrical benefits

- review with ESCOM, role and integration of Mbokazi in their system
- review with TESCOR, role and integration of Nkwadini with other alternatives in their system
- optimisation of operations of both power stations and water transfer schemes



**TABLE 1**  
**SUMMARY OF CONDUIT FEATURES**

Route	Pipeline and siphons km	Canals km	Total km	Pumping station no.	Total Static lift m	End point(s)
Western						
A	351	115	466	11	1750	Molteno Tarkastad
B	346	76	422	10	1750	Molteno Tarkastad
B1	282	0	282	9	1650	Dordrecht
E	377	0	377	9	1350	Tarkastad
Northern						
N	94	-	94	3	600	Umtamvuna

**TABLE 2**  
**SUMMARY OF WATER TRANSFER COSTS**

Route	Capital cost R x 10 <sup>6</sup>	Running Costs Rx10 <sup>6</sup> p.a.			
		Pumping	Maintenance	Operation	Total
Western (20 m <sup>3</sup> /s)					
A	2090	170	12,0	1,3	183
B	2000	168	11,4	1,2	181
B1	1540	158	9,0	0,9	168
E	2045	130	11,4	1,1	143
Northern (10 m <sup>3</sup> /s)					
N	353	28	2,2	0,3	31

**Notes :** A - via Queenstown.  
: B - via Dordrecht.  
:B1- discharge to Orange but reach Fish through Orange/Fish tunnel.  
: E - not to Orange.

TABLE 3

SUMMARY OF KEY TECHNICAL DATA OF DAMS AND HYDROELECTRIC PROJECTS

1. **Mbokazi**

**Reservoir**

Catchment area	20 000 km <sup>2</sup>
Mean annual runoff (MAR)	3 000 x 10 <sup>6</sup> m <sup>3</sup>
Full supply level (FSL)	250 masl
Reservoir area at FSL	85 km <sup>2</sup>
Minimum operating level	180 masl
Total storage volume	5 950 x 10 <sup>6</sup> m <sup>3</sup>
Live storage volume	4 350 x 10 <sup>6</sup> m <sup>3</sup>

**Dam Type**

Rockfill with central earth core

Crest elevation	260 masl
Crest length	850 m
Maximum height above foundations	210 m
Volume of dam	47 x 10 <sup>6</sup> m <sup>3</sup>

**Spillway Type**

Gated crest overflow with flip bucket

Sill level	237 masl
Maximum discharge in PMF	27 400 m <sup>3</sup> /s
Number and size of radial gates	9 - 15,56 m W, 14 m H

**Diversion Conduits**

Number and diameter	2 - 12 m
Average length	1 675 m
Lining	Concrete

**Power System**

Number of gates	4
Penstocks - number and diameter	2 - 11 m
- lining	Concrete
trifurcating to:	
- number and diameter	6 - 6,5 m
- lining	Concrete with steel encasement
Surge tanks - number and diameter	2 - 11 m
	(27 m above 270 masl)
Power station type	Surface, indoor
Installed capacity	1 600 MW
Number of units	6
Turbine type	Francis
Rated speed	136 rpm
Generator rating	390 MVA

2. **Nkwalini**

**Reservoir**

Full supply level (FSL)	43 masl
Reservoir area at FSL	3,25 km <sup>2</sup>
Minimum operating level	37 masl
Total storage volume	59 x 10 <sup>6</sup> m <sup>3</sup>
Live storage volume	19 x 10 <sup>6</sup> m <sup>3</sup>

<b>Dam Type</b>	Concrete, gravity
Crest elevation	53 masl
Crest length	375 m
<b>Spillway Type</b>	Gated overflow, roller bucket
Sill level	31 masl
Hydraulic design capacity	16 000 m <sup>3</sup> /s
Number and size of radial gates	9 - 14,3 m W, 20 m H
<b>Power Station Type</b>	Integral, indoor
Installed capacity	50 MW
Number of units	3
Turbine type	Kaplan
Rated speed	200 rpm
Generator rating	20,6 MVA

**TABLE 4**  
**LOAD FORECAST FOR ESCOM**

Year	Maximum Demand (MW)	Energy sent out (GWh)
1990	23 178	157 047
1995	29 582	205 254
1996	31 061	216 554
1997	32 474	226 397
1998	33 952	236 698
1999	35 496	247 468
2000	37 111	258 728
2001	38 800	270 500
2002	40 565	282 807
2003	42 411	295 675
2004	44 341	309 128
2005	46 358	323 194
2006	48 468	337 899
2007	50 673	353 273
2008	52 979	369 347
2009	55 389	386 153
2010	57 909	403 723
2011	60 544	422 092
2012	63 299	441 297
2013	66 179	461 376
2014	69 190	482 369
2015	72 338	504 317
2016	75 630	527 263

- Notes :**
1. Maximum demand forecast based on 5% pa increase to 1996 and 4,55% thereafter.
  2. Energy forecast based on 5,5% pa increase to 1996 and 4,55% thereafter.

**TABLE 5**  
**LOAD FORECAST FOR TESCOR**

Year	Maximum Demand (MW)	Energy sent out (GWh)
1985	42,7(1)	209,5(2)
1986	46,3	227,1
1987	50,2	246,3
1988	54,5	267,4
1989	59,1	289,9
1990	64,2	314,4
1991	69,6	341,4
1992	75,4	369,9
1993	81,8	401,3
1994	88,3	433,2
1995	95,4	468,0
1996	103,0	505,3
1997	111,3	546,0
1998	120,1	589,2
1999	129,8	636,7
2000	140,2	687,8

- Notes :**
1. Financial year, i.e. 1985 is year ending 31 March 1986.
  2. Actual figures for 1985/1986 were 41,7 MW and 207,8 GWh (system load factor 56,9%).
  3. Maximum demands and energy demands after 2 000 assumed to increase at annual rate of 8%.



**TABLE 6**  
**TOTAL CAPITAL COSTS FOR ALTERNATIVE MBOKAZI SCHEMES**

Rands x 10<sup>6</sup>

FSL	Installed Capacity (m)	Civil Works (1) (MW)	Generation Plant (2)	Transmission	Total	Rand/kW
290	2000	1666	492	330	2488	1244
	1600	1617	422	296	2335	1459
	1200	1570	313	268	2151	1792
250	2000	1395	524	330	2249	1125
	1600	1334	441	296	2071	1294
	1200	1284	335	268	1887	1572
230	1600	1235	443	296	1974	1234
	1200	1168	335	268	1771	1476
	1000	1145	293	230	1668	1668

Notes: 1. Including R70.33 x 10<sup>6</sup> for attributable cost for Nkwalini  
2. Including substation costs

**TABLE 7**  
**TOTAL CAPITAL COSTS FOR ALTERNATIVE NKWALINI SCHEMES**

Rands x 10<sup>6</sup>

Installed Capacity MW	Civil Works	Generating Plant	Transmission	Total	Rand/kW
40	41	34	7	82	2 055
50	42	42	7	91	1 820
60	43	51	7	101	1 680

Notes: 1. Excluding R70,33 x 10<sup>6</sup> attributable to Mbokazi.  
2. Including Nkwalini sub-station costs.

TABLE 8

MBOKAZI - COMPARATIVE SIMULATION COSTS

Base case

Dam FSL	Mbokazi installed capacity			
	1 000 MW	1 200 MW	1 600 MW	2 000 MW
(a) Savings in costs (R x 10 <sup>6</sup> ) discounted to 1986 at 6% discount rate				
290 m		-38	161	507
250 m		42	290	610
230 m	141	84	321	
(b) Equalising Discount Rate (EDR)				
290 m		5,7%	8,8%	* 12%
250 m		7,1%	* 12%	* 12%
230 m	9,3%	8,2%	* 12%	

Note : \* is greater than.

Sensitivity Checks

Present value of cost savings at 6% discount rate for 250 m 1 600 MW scheme with the following changes:

		Rand x 10 <sup>6</sup>
Coal-fired thermal costs	+ 20%	585
	- 20%	- 4
Mbokazi costs	+ 20%	37
	- 20%	543
Fuel costs	+ 20%	284
LDC shape as 1985		368

TABLE 9

NKWALINI - COMPARATIVE SIMULATION COSTS

Costs in Rands x 10<sup>6</sup> discounted to 1986 at 6% discount rate

Costing basis	60 MW	50 MW	40 MW
Tariff before SACU rebate	25	31	31
Tariff after SACU rebate	12	18	19
ESCOM costs	-11	- 5	- 4



TABLE 10

NKWALINI - COMPARATIVE SIMULATION COSTS

20% change to Nkwadini capital costs


Costs in Rands x 10<sup>6</sup> discounted to 1986 at 6% discount rate

Costing basis	60 MW		50 MW		40 MW	
	+20%	-20%	+20%	-20%	+20%	-20%
Tariff before SACU rebate	13	37	19	43	21	41
Tariff after SACU rebate	0	24	7	29	9	29
ESCOM costs	-24	1	-16	6	-14	6



- LEGEND**
- MAIN ROADS
  - - - NEW ACCESS ROADS
  - - - EXISTING SECONDARY ROADS
  - ⊙ PUMPING STATION


<b>REPUBLIC OF TRANSKEI</b> H. Olivier and Associates Binnie and Partners Kennedy and Donkin <small>IN ASSOCIATION WITH</small> M.J. Mountain and Associates KDM		<b>DEPARTMENT OF WORKS AND ENERGY</b> <b>UMZIMVUBU BASIN DEVELOPMENT</b> <b>MBOKAZI POWER AND WATER PROJECT</b>  OVERVIEW OF SCHEME  FIG. 3	
--	--	---	--



**LEGEND**

--- INTERNATIONAL BOUNDARIES  
(1:500 000 MAPPING 1983 EDITION)



--- CATCHMENT BOUNDARY



<b>REPUBLIC OF TRANSKEI</b> H. Olivier and Associates Binnie and Partners Kennedy and Donkin <small>IN ASSOCIATION WITH</small> M.J. Mountain and Associates K.Q.M.	<b>DEPARTMENT OF WORKS AND ENERGY</b> <b>UMZIMVUBU BASIN DEVELOPMENT</b> <b>MBOKAZI POWER AND WATER PROJECT</b>  MBOKAZI LOCATION AND CATCHMENT
---	--

FIG. 2






REPUBLIC OF TRANSKEI	DEPARTMENT OF WORKS AND ENERGY
H. Olivier and Associates Binnie and Partners Kennedy and Donkin IN ASSOCIATION WITH M.J. Mountain and Associates KDM	UMZIMVUBU BASIN DEVELOPMENT MBOKAZI POWER AND WATER PROJECT
TRANSKEI ORIENTATION MAP	
FIG. 1	

YEAR NUMBER		1	2	3	4	5	6	7
DATE		93	94	95	96	97	98	99
1	ESTABLISHMENT	—————						
2	PIPELINE: MANUFACTURE	—————						
	EXCAVATION		—————					
	LAYING		—————					
3	CANAL: EARTHWORKS					—————		
	LINING					—————		
4	TUNNELS		—————					
5	CROSSINGS / STRUCTURES		- - - - -			—————		
6	PUMP STATIONS		—————					
7	COMMISSIONING							———

NB. PROGRAMME FOR ROUTE TO WESTERN TRANSKEI AND RSA .


REPUBLIC OF TRANSKEI	DEPARTMENT OF WORKS AND ENERGY
H. Olivier and Associates Binnie and Partners Kennedy and Donkin IN ASSOCIATION WITH M.J. Mountain and Associates KDM	UMZIMVUBU BASIN DEVELOPMENT MBOKAZI POWER AND WATER PROJECT  WATER TRANSFER CONSTRUCTION PROGRAMME WEST ROUTE
	FIG. 19



YEAR NUMBER		1	2	3	4	5	6	7
DATE		85	86	87	88	89	90	91
1	OVERALL FEASIBILITY		—					
2	REVIEW / DISCUSSION			—				
3	DECISION TO PROCEED			X				
4	DETAILED ECONOMIC/FINANCIAL STUDY(HYDRO-POWER)			—	—			
5	DRAFTING/NEGOTIATING INTERSTATE AGREEMENTS				—	—		
6	ARRANGE FINANCE				—	—		
7	DETAILED PLANNING			—	—			
8	SI AND LAB TESTING			—	—	—		
9	HYDRAULIC MODEL TESTS			—	—	—		
10	CONTRACT DESIGN				—	—		
11	CONTRACT DOCUMENTS					—		
12	REVIEW					—		
13	DECISION TO CONSTRUCT						X	
14	PREQUALIFY CONTRACTORS					—		
15	TENDER PERIOD						—	
16	TENDER APPRAISAL / NEGOTIATIONS						—	
17	CONTRACT AWARD							X
18	CONSTRUCTION DRAWINGS						—	—

CIVIL WORKS

<b>REPUBLIC OF TRANSKEI</b> <b>H. Olivier and Associates</b> <b>Binnie and Partners</b> <b>Kennedy and Donkin</b> <small>IN ASSOCIATION WITH</small> <b>M.J. Mountain and Associates</b> <b>KDM</b>	<b>DEPARTMENT OF WORKS AND ENERGY</b> <b>UMZIMVUBU BASIN DEVELOPMENT</b> <b>MBOKAZI POWER AND WATER PROJECT</b>  <b>MBOKAZI HYDROELECTRIC PROJECT</b> <b>DEVELOPMENT PROGRAMME</b>  <b>FIG. 17</b>
---	---



/// ENERGY GENERATED BY  
2000 MW HYDRO PLANT  
DURING PEAK DAY


/// ENERGY GENERATED BY  
2000 MW HYDRO PLANT  
DURING AVERAGE DAY

REPUBLIC OF TRANSKEI	DEPARTMENT OF WORKS AND ENERGY
H. Olivier and Associates Binnie and Partners Kennedy and Donkin IN ASSOCIATION WITH M.J. Mountain and Associates KDM	UMZIMVUBU BASIN DEVELOPMENT MBOKAZI POWER AND WATER PROJECT
	POSSIBLE WINTER LOAD CURVES FOR ESCOM IN 2000
	FIG. 16




# LOAD DURATION CURVE — ESCOM

1985



# LOAD DURATION CURVE — ESCOM

1997



REPUBLIC OF TRANSKEI

H. Olivier and Associates

Binnie and Partners

Kennedy and Donkin

IN ASSOCIATION WITH

M.J. Mountain and Associates






KDM

DEPARTMENT OF WORKS AND ENERGY

UMZIMVUBU BASIN DEVELOPMENT  
MBOKAZI POWER AND WATER PROJECT

ESCOM LDC 1997


FIG.15



NOTES  
 1 ALL DIMENSIONS ARE IN METRES  
 2 ALL ELEVATIONS ARE IN METRES ABOVE MEAN SEA LEVEL


REPUBLIC OF TRANSKEI <b>H. Olivier and Associates</b> Binnie and Partners Kennedy and Donkin IN ASSOCIATION WITH M.J. Mountain and Associates KDM	DEPARTMENT OF WORKS AND ENERGY <b>UMZIMVUBU BASIN DEVELOPMENT</b> <b>MBOKAZI POWER AND WATER PROJECT</b>  <b>NKWALINI DAM</b> <b>GENERAL LAYOUT</b>
---	--

FIG. 14




**NOTES :**

1. REFER TO FIG.9.1 FOR GENERAL LAYOUT OF POWER STATION
2. ALL DIMENSIONS ARE IN METRES
3. ALL ELEVATIONS ARE IN METRES ABOVE MEAN SEA LEVEL
4. CAPACITY OF POWER STATION 1600 MW
5. SECOND STAGE CONCRETE




REPUBLIC OF TRANSKEI	DEPARTMENT OF WORKS AND ENERGY
14 Olivier and Associates Binnie and Partners Kennedy and Donkin IN ASSOCIATION WITH M.J. Mountain and Associates KDM	UMZIMVUBU BASIN DEVELOPMENT MBOKAZI POWER AND WATER PROJECT
	MBOKAZI POWER STATION CROSS SECTION
	FIG. 13



FLOOR PLAN




NOTES

1. ARRANGEMENT SHOWN FOR CAPACITY OF 1600 MW
2. FOR POSITIONING OF STATION REF. FIG. 7.1
3. FOR SECTION THROUGH POWER STATION REF. FIG. 9.2
4. ALL DIMENSIONS IN METRES
5. ALL ELEVATIONS ARE IN METRES ABOVE MEAN SEA LEVEL




REPUBLIC OF TRANSKEI	DEPARTMENT OF WORKS AND ENERGY
H. Olivier and Associates Binnie and Partners Kennedy and Donkin IN ASSOCIATION WITH M.J. Mountain and Associates KDM	UMZIMVUBU BASIN DEVELOPMENT MBOKAZI POWER AND WATER PROJECT
	MBOKAZI POWER STATION GENERAL LAYOUT


FIG. 12



SECTION A-A




SECTION B-B



SECTION C-C





NOTES:

1. ALL DIMENSIONS ARE IN METRES.
2. ALL ELEVATIONS ARE IN METRES ABOVE MEAN SEA LEVEL.



REPUBLIC OF TRANSKEI	DEPARTMENT OF WORKS AND ENERGY
H. Olivier and Associates Binnie and Partners Kennedy and Donkin IN ASSOCIATION WITH M.J. Mountain and Associates KDM	UMZIMVUBU BASIN DEVELOPMENT MBOKAZI POWER AND WATER PROJECT  MBOKAZI POWER TUNNELS TYPICAL SECTIONS
	FIG.11





NOTES:  
 1. ALL DIMENSIONS ARE IN METRES  
 2. ALL ELEVATIONS ARE IN METRES ABOVE MEAN SEA LEVEL

REPUBLIC OF TRANSKEI H. Olivier and Associates Binnie and Partners Kennedy and Donkin IN ASSOCIATION WITH M.J. Mountain and Associates KDM	DEPARTMENT OF WORKS AND ENERGY UMZIMVUBU BASIN DEVELOPMENT MBOKAZI POWER AND WATER PROJECT MBOKAZI SPILLWAY
--	--


FIG. 10

EMBANKMENT ZONES

- ① EARTH CORE
- ② ROCKFILL
- ③ FILTERS
- ④ TRANSITION ZONE
- ⑤ RIP-RAP



MATERIAL

- COMPACTED CLAY
- COMPACTED DOLORITE, TILLITE AND SHALE
- PROCESSED CRUSHED ROCK TO SPECIFIED GRADING
- SELECTED WELL GRADED MATERIAL
- SELECTED LARGE ROCKFILL AS SLOPE PROJECTION



REPUBLIC OF TRANSKEI	DEPARTMENT OF WORKS AND ENERGY
H. Olivier and Associates Binnie and Partners Kennedy and Donkin IN ASSOCIATION WITH M.J. Mountain and Associates KDM	UMZIMVUBU BASIN DEVELOPMENT MBOKAZI POWER AND WATER PROJECT MBOKAZI DAM TYPICAL CROSS SECTION

FIG. 9




SCALE

**NOTES :**


1. MINOR PERMANENT ACCESS ROADS OMITTED FOR CLARITY
2. SELECTED EXCAVATION SLOPES SHOWN
3. ALL DIMENSIONS ARE IN METRES
4. ALL ELEVATIONS ARE IN METRES ABOVE MEAN SEA LEVEL


REPUBLIC OF TRANSKEI H. Olivier and Associates Binnie and Partners Kennedy and Donkin IN ASSOCIATION WITH M.J. Mountain and Associates KDM	DEPARTMENT OF WORKS AND ENERGY UMZIMVUBU BASIN DEVELOPMENT MBOKAZI POWER AND WATER PROJECT MBOKAZI DAM GENERAL LAYOUT FIG. 8
--	---



REPUBLIC OF TRANSKEI	DEPARTMENT OF WORKS AND ENERGY
H. Olivier and Associates Binnie and Partners Kennedy and Donkin IN ASSOCIATION WITH M.J. Mountain and Associates KDM	UMZIMVUBU BASIN DEVELOPMENT MBOKAZI POWER AND WATER PROJECT WATER TRANSFER ROUTE N
	FIG.7









**PROPOSED ROUTES**

- A
- B
- C
- - - - D
- x-x-x-x E
- △-△-△ N
- INTERNATIONAL BORDERS
- ⊙ TAKE OFF POINT

REPUBLIC OF TRANSKEI H. Olivier and Associates Binnie and Partners Kennedy and Donkin IN ASSOCIATION WITH M.J. Mountain and Associates KDM	DEPARTMENT OF WORKS AND ENERGY <b>UMZIMVUBU BASIN DEVELOPMENT</b> <b>MBOKAZI POWER AND WATER PROJECT</b>  WATER TRANSFER SCHEME GENERAL OUTLINE  FIG. 5
--	--







POSSIBLE INSTITUTIONAL ARRANGEMENT FOR AN  
 UMZIMVUBU BASIN DEVELOPMENT AUTHORITY (UBDA)

REPUBLIC OF TRANSKEI	DEPARTMENT OF WORKS AND ENERGY
H. Olivier and Associates Binnie and Partners Kennedy and Donkin IN ASSOCIATION WITH M.J. Mountain and Associates KOM	UMZIMVUBU BASIN DEVELOPMENT MBOKAZI POWER AND WATER PROJECT
	POSSIBLE INSTITUTIONAL ARRANGEMENT FOR UBDA