

**Client : Mosomo Consulting Engineers (Pty) Ltd**

2.2(4466)

**GROUNDWATER DEVELOPMENT AT  
NTWANE/ELANDSDOORN/MALAENENG VILLAGE:  
GREATER SEKHUKHUNE DISTRICT MUNICIPALITY,  
LIMPOPO PROVINCE**



M



# LESHIKA

CONSULTING  
(Pty) Ltd

**Engineers, Geohydrologists, ISD Practitioners & Project Managers**

---

**OFFICES**

- POLOKWANE:** Suite No. 7, Albatross Centre, 19 Market Street, P.O. Box 3316, Polokwane, 0700, Tel: 015 291-5191, Fax 015 291-5268, E-Mail: polokwane@wsmlshika.co.za
  - MOKOPANE:** 1st Floor, Medical Centre, 40 Van Riebeeck Street, P.O. Box 638, Mokopane, 0600, Tel: 015 491-4756, Fax 015 491-2086, E-Mail: mokopane@wsmlshika.co.za
  - TSHWANE:** 11 Argentum Building, 66 Glenwood Street, Lynnwood Glen, P.O. Box 33276, Glenstantia 0010, Tel: 012 348-8595, Fax 012 348-8598, E-Mail: tshwane@wsmlshika.co.za
  - NDLAMBE:** Suite 13 & 14, Port Francis House, 33 van der Riet Street, P.O. Box 2752, Port Alfred, 6170, Tel: 046 624-1400, Fax 046 624-1400, E-Mail: ndlambe@wsmlshika.co.za
  - AMATHOLE:** 4 Stanton Road, Vincent East London, 5241, Tel: 043 726-2194, Fax: 086 618-2615, E-Mail: Jamie@mycontact.co.za
- 

**GROUNDWATER DEVELOPMENT AT  
NTWANE/ELANDSDOORN/MALAENENG VILLAGE:  
GREATER SEKHUKHUNE DISTRICT MUNICIPALITY,  
LIMPOPO PROVINCE**

W6105/reports

JUNE 2006

---

**COMPILED BY**  
WSM Leshika (Pty) Ltd  
Suite No 7, Albatross Centre  
19 Market Street  
POLOKWANE  
0699

P O Box 3316  
POLOKWANE  
0700  
Tel no : (015) 291-5191  
Fax no : (015) 291-5268

**CONTACT PERSON :** DUNCAN FUNZANI MUNYAI

111 12/02/07



# LESHIKA

CONSULTING  
(Pty) Ltd

**Engineers, Geohydrologists, ISD Practitioners & Project Managers**

---

## Memo

To : Mosomo Consulting Engineers (Pty) Ltd  
Attention : Abrie Cilliers  
From : Funzani Duncan Munyai  
Date : 21 June 2006  
Subject : Ground Water Development ~ Elandsdoorn  
Our Ref : Elandsdoorn Village Borehole Testing (WH 06105)


---

### 1. BACKGROUND

WSM Leshika Consulting (Pty) Ltd was appointed by Mosomo Consulting Engineers of Tzaneen to pump test the existing boreholes at Elandsdoorn village (Figure 1). Elandsdoorn community is located approximately 30 Km south west of Groblersdal, Greater Sekhukhune Municipal Area, Limpopo Province.

Hydrocensus was conducted and five boreholes were selected for pump testing (see attachment)

This memorandum summarizes the test pumping, water chemistry results and gives equipping recommendations for the boreholes developed under this investigation.



**LESHIKA (Pty) Ltd** **ELANDSDOORN/NTWANE BOREHOLE LOCALITY MAP** **FIGURE 1**

## 2. TEST PUMPING RESULTS

Summarized in Table 1 are results pertaining to the testing of the 4 boreholes (H36-0030, H36-0031, H36-0032 and H36-0033). One borehole H36-0036 could not be tested as it had collapsed. Attached are the plotted data (log – normal) for reference. A description of the test data is as follows:

### H36-0030 ✓

A four by 60-minute step test was carried out at 0.5 l/sec, 1.08 l/sec, 2.77 l/sec and finally at 5 l/sec, reaching the drawdown of 13.40 m. The 24-hour constant rate test was conducted at 3.57 l/sec reaching a final drawdown of 10.75 m on completion of the test. Recovery is moderate at 97 % after the pumping period ( $T/T' = 2.00$  or 24 hours). Specific capacity is calculated at 0.4 l/sec/m drawdown and transmissivity at 28.23 m<sup>2</sup>/day.

The recommended pumping rate is 1.06 l/sec for 20 hours/day ~ 76 Kl/day. The pump inlet is to be set at 25 mbgl and the dynamic head calculated at 14 m @ 1.06 l/sec.

### H36-0031 ✓

A two by 60-minute step test was conducted at 0.7 l/sec, 1.6 l/sec, and finally, reaching pump suction within 8 minutes of the 3<sup>rd</sup> and final step at a drawdown of 33.18 m. The 24-hour constant rate test was conducted at 1.33 l/sec reaching a final drawdown of 14.90 m on completion of the test. Recovery is good at 99 % after the pumping period ( $T/T' = 2.00$  or 24 hours). Specific capacity is calculated at 0.29 l/sec/m drawdown and transmissivity at 9.14 m<sup>2</sup>/day.

The recommended pumping rate is 0.46 l/sec for 20 hours per day ~ 33 Kl/day. The pump is to be set at 40 m below ground level and the dynamic head is calculated at 25 mbgl.

### H36-0032 ✓

Four complete (60 minutes each) steps were done at 0.90 l/sec, 2.40 l/sec, 4.00 l/sec, 8.60 l/sec and finally at 12.00 l/sec, reaching pump suction within 6 minutes of the fifth and incomplete test. The final drawdown was measured at 11.99 m. The 24-hour

TABLE 1 : TEST PUMPING DETAILS

B32H ✓  
2529 AC

ARM or VILLAGE NAME	BOREHOLE No	CO ORDINATES		DATE TESTED	WATER LEVEL (mbgl)	WATER STRIKE (mbgl)	DEPTH (m)	STEP TEST		CONSTANT DISCHARGE TEST				RECOMMENDATIONS				WATER QUALITY CLASS
		South	East					Time (mins)	% Recy	Duration (mins)	Rate (l/sec)	T (m <sup>3</sup> /d/m)	% Rec	Rate (l/sec)	Dirty cycle (hrs/day)	Supply (Kl/day)	Pump set (mbgl)	
Elandsdoorn	H36-0030 ✓	-25.29840	29.22960	25/05/2005	12.47	Unknown	37.87	240	97	1440	3.57	28.23	97	1.06	20	76	25	CLASS II
Elandsdoorn	H36-0031 ✓	-25.29228	29.22941	25/05/2006	20.85	Unknown	34.65	128	100	1440	1.33	9.14	99	0.46	20	33	40	CLASS II
Elandsdoorn	H36-0032 ✓	-25.29171	29.22833	27/05/2006	19.35	Unknown	35.9	248	99	1440	6.66	87.77	95	3	20	216	25	CLASS II
Elandsdoorn	H36-0033 ✓	-25.29192	29.22757	27/05/2006	18.47	Unknown	39.54	240	100	1440	5	16.81	100	1.5	20	108	50	CLASS II

constant rate test was done at 6.66 l/sec and reached the drawdown of 5.51 m on completion of the test. Recovery is moderate at 95 % ( $T/T' = 2.00$  or 24 hours).

The recommended pumping rate is 3 l/sec for 20 hours per day ~ 216 Kl/day. The pump is to be set at 25 m below ground level and the dynamic head is calculated at 21 mbgl.

### H36-0033 ✓

Four complete (60 minutes each) steps were done at 0.62 l/sec, 1.71 l/sec, 3.52 l/sec, and finally at 5.45 l/sec, reaching the drawdown of 12.41 m. The 24-hour constant rate test was conducted at 5.00 l/sec and reached 52.65 m on completion of the test. Recovery is good at 100 % ( $T/T' = 2.00$  or 24 hours).

The recommended pumping rate is 1.5 l/sec for 20 hours per day ~ 108 Kl/day. The pump is to be set at 50 m below ground level and the dynamic head is calculated at 24 mbgl.

## 3. WATER CHEMISTRY RESULTS

Analyses of the samples taken from the four tested boreholes are listed in Table 2. Both boreholes (H36-0030, H36-0031, H36-0032 and H36-0033) have elevated hardness levels 397.1, 385.6, 384 and 366 as CaCO<sub>3</sub> (Class II), respectively. A "brak" taste will be noticed with respect to first time users. Scale is also expected to develop on heating elements and metal fittings. The remaining constituents all fall within Class 0 – Class I category for domestic consumption. The analyses show that both samples from these boreholes are portable and can be consumed with insignificant health risk.

## 4. PUMP INSTALLATION DETAILS

Based on the test results, the following equipping details are recommended at the new boreholes. Specific details are:

### H36-0030 ✓

Pumping Rate	1.06 l/sec @ 20 hrs/day OR 2.65 l/sec @ 8 hrs/day
Borehole Depth	37.67 m
Installation Depth	25 mbgl

**TABLE 2 : WATER CHEMISTRY**

ANALYSES	UNIT	H36-0030	H36-0031	H36-0032	H36-0033	CLASSIFICATION				
						Class 0	Class I	Class II	Class III	Class IV
pH		6.91	6.97	6.9	7.01	5.5 - 9.5	4.5 - 10	4 - 10.5	3 - 11	< 3 or > 11
Conductivity	mS/m	53.4	53.7	55.8	53.8	< 70	70 - 150	150 - 370	370 - 520	> 520
TDS	mg/l	359	363	375	369	< 450	450 - 1000	1000 - 2400	2400 - 3400	> 3400
Nitrate (N)	mg/l	7.73	8.02	6.94	8.73	< 6	6 - 10	10 - 20	20 - 40	> 40
Fluoride	mg/l	0.07	0.04	0.24	0.12	< 0.7	0.7 - 1	1 - 1.5	1.5 - 3.5	> 3.5
Sulphate	mg/l	72.6	37	5.3	22.3	< 200	200 - 400	400 - 600	600 - 1000	> 1000
Chloride	mg/l	23.3	20	23.3	18.3	< 100	100 - 200	200 - 600	600 - 1200	> 1200
P - Alkalinity		0	0	0	0					
M - Alkalinity		162.8	178.4	190.2	171.8					
Carbonate		0	0	0	0					
Bicarbonate		198.4	217.5	231.9	209.4					
Total Hardness	CaCo3	397.1	385.6	384	366	< 200	200 - 300	300 - 600	> 600	
Ca - Hardness		164.7	170.6	181.4	167.6					
Mg - Hardness		232.4	215	202.6	198.4					
Calcium	mg/l	66	68.3	72.6	67.1	< 80	80 - 150	150 - 300	> 300	
Magnesium	mg/l	56.4	52.2	49.2	48.2	< 70	70 - 100	100 - 200	200 - 400	> 400
Sodium	mg/l	9.5	8.2	5.4	5.5	< 100	100 - 200	200 - 400	400 - 1000	> 1000
Potassium	mg/l	1.19	0.45	0.6	0.51	< 25	25 - 50	50 - 100	100 - 500	> 500
Iron	mg/l	0	0	0	0	< .5	.5 - 1	1 - 5	5 - 10	> 10
Manganese	mg/l	0	0	0	0	< .1	.1 - .4	.4 - 4	4 - 10	> 10
<b>WATER CLASS</b>		<b>CLASS II</b>	<b>CLASS II</b>	<b>CLASS II</b>	<b>CLASS II</b>					
Sum Cations		8.38	8.07	7.92	7.57					
Sum Anions		8.44	8.15	7.94	7.61					



S W L 12.47 m  
Dynamic Head 14 m at 1.06 l/sec  
Supply per day 76 Kl/day  
WATER CLASS **CLASS II**

**H36-0031** ✓

Pumping Rate 0.46 l/sec @ 20 hrs/day OR 1.15 l/sec @ 8 hrs/day  
Borehole Depth 58.8 m  
Installation Depth 40 mbgl  
S W L 20.85 m  
Dynamic Head 25 m at 0.46 l/sec  
Supply per day 33 Kl/day  
WATER CLASS **CLASS II**

**H36-0032** ✓

Pumping Rate 3 l/sec @ 20 hrs/day OR 7.5 l/sec @ 8 hrs/day  
Borehole Depth 35.6 m  
Installation Depth 25 mbgl  
S W L 19.35 m  
Dynamic Head 21 m at 1.72 l/sec  
Supply per day 216 Kl/day  
WATER CLASS **CLASS II**

**H36-0033** ✓

Pumping Rate 1.5 l/sec @ 20 hrs/day OR 3.75 l/sec @ 8 hrs/day  
Borehole Depth 99.54 m  
Installation Depth 50 mbgl  
S W L 18.47 m  
Dynamic Head 24 m at 2.45 l/sec  
Supply per day 108 Kl/day  
WATER CLASS **CLASS II**

## 5. SUMMARY & RECOMMENDATIONS

A summary of the results pertaining to the water supply to Elandsdoorn Village is as follows:

- i. Borehole H36-0030 has a tested supply of 76 Kl/day. The borehole may be equipped to pump at a rate of 1.06 l/sec for 20 hours per day.
- ii. Borehole H36-0031 has a tested supply of 33 Kl/day. The borehole may be equipped to pump at a rate of 0.46 l/sec for 20 hours per day.
- iii. Borehole H36-0032 has a tested supply of 216 Kl/day. The borehole may be equipped to pump at a rate of 3 l/sec for 20 hours per day.
- iv. Borehole H36-0033 has a tested supply of 108 Kl/day. The borehole may be equipped to pump at a rate of 1.5 l/sec for 20 hours per day.
- v. Both boreholes (H36-0030, H36-0031, H36-0032 and H36-0033) have elevated hardness levels 397.1, 385.6, 384 and 366 as CaCO<sub>3</sub> (Class II), respectively.
- vi. The analyses show that both samples from these boreholes are potable and can be consumed with insignificant health risk.

We recommend H36-0030 and H36-0032 as production boreholes. H36-0033 must be used as a back up to H36-0032; they should not be pumped simultaneously. These boreholes are very close to each other (see Figure 1).

If additional water is required for the community, H36-0036 can be rehabilitated and developed to serve the needs of the community.

**Duncan F Munyai (Hydrogeologist)**



***ATTACHMENTS***

***ATTACHMENT 1***

***HYDROCENSUS***



H36-0030



H36-0031



H36-0032



H36-0033



H36-0034



H36-0035



H36-0036

*Hydrocensus at Ntwane/ Elandsdoorn*

BH_N	Village	Latitude	Longitude	Old_Number	New_Number	Blow_Yield	Depth	Status
BH_1	Elandsdoom	-25.29840	29.22960		H36-0030 ✓			Casing only newly drilled BH
BH_2	Elandsdoom	-25.29228	29.22941	M01-0076	H36-0031 ✓	0.3 l/s	60 m	Casing in good condition
BH_3	Elandsdoom	-25.29171	29.22833	T419216	H36-0032 ✓			Only pumphead and no Engine
BH_4	Elandsdoom	-25.29192	29.22757	M01-0077	H36-0033 ✓	0.6 l/s	100 m	Casing only
BH_5	Elandsdoom	-25.29225	29.22829	T419215 ✗	H36-0034 ✓			Vandalised = open BH filled with materials
BH_6	Elandsdoom	-25.30032	29.23162		H36-0035 ✓			Vandalised = open BH filled with materials
BH_7	Elandsdoom	-25.30072	29.23186		H36-0036 ✓			Casing inside the cement cage = check photo

→A

2529AC

B32H

***ATTACHEMENT 2***  
***TEST PUMPING RESULTS***

B33H  
2529AC

PROJECT		ELANDSDOORN ✓				DATE		25/05/2006		TIME STARTED		00h00	
BOREHOLE No		H36-0030				AVAIL. DRAWDOWN		22.03 m		JOB NO		WH06105	
BOREHOLE DEPTH		37.67 m				PUMP DEPTH		34.5 m		LAT		-25.2984	
STATIC WATER LEVEL		12.47 m				PUMP TYPE		1302		LONG		29.2296	
		STEP 1	STEP 2	STEP 3	STEP 4	STEP 5	STEP 6	T/T	RECOVERY	CD	T/T	RECOVERY	
AVERAGE YIELD (l/s)		0.50	1.08	2.77	6.00				2.31	3.57		3.57	
TIME(hrs)	TIME(min)									380			
-1	0.50	-0.22	-0.88	-1.85	-5.72			481.00	-8.49	-3.10	2881.00	-7.27	
	1.00	-0.24	-0.93	-2.41	-6.55			241.00	-5.27	-3.98	1441.00	-5.21	
	1.50	-0.26	-0.96	-2.62	-7.29			161.00	-3.64	-4.65	961.00	-4.09	
	2.00	-0.27	-0.99	-2.75	-7.76			121.00	-2.75	-5.16	721.00	-3.51	
	2.50	-0.28	-1.01	-2.86	-8.20			97.00	-2.21	-5.44	577.00	-3.17	
	3.00	-0.29	-1.04	-2.94	-8.57			81.00	-1.94	-5.74	481.00	-3.01	
	4.00	-0.32	-1.10	-3.07	-9.02			81.00	-1.78	-6.24	361.00	-2.86	
	5.00	-0.33	-1.12	-3.38	-9.33			49.00	-1.65	-6.55	289.00	-2.79	
	6.00	-0.34	-1.12	-3.66	-9.47			41.00	-1.58	-6.76	241.00	-2.74	
	7.00	-0.35	-1.12	-3.87	-9.63			35.29	-1.52	-6.90	206.71	-2.74	
	8.00	-0.36	-1.13	-3.99	-9.76			31.00	-1.48	-7.02	181.00	-2.70	
	9.00	-0.37	-1.13	-4.08	-9.92			27.67	-1.43	-7.12	161.00	-2.66	
	10.00	-0.38	-1.13	-4.13	-10.07			25.00	-1.41	-7.20	145.00	-2.63	
	12.00	-0.39	-1.13	-4.23	-10.34			21.00	-1.33	-7.36	121.00	-2.60	
	15.00	-0.40	-1.15	-4.34	-10.59			17.00	-1.23	-7.50	97.00	-2.56	
	20.00	-0.43	-1.17	-4.47	-10.85			13.00	-1.11	-7.69	73.00	-2.50	
	25.00	-0.45	-1.19	-4.55	-11.10			10.60	-1.05	-7.80	58.60	-2.40	
0.5	30.00	-0.45	-1.21	-4.65	-11.38			9.00	-0.97	-7.95	49.00	-2.33	
	35.00	-0.46	-1.22	-4.66	-11.90			7.86	-0.88	-8.06	42.14	-2.26	
	40.00	-0.48	-1.23	-4.73	-12.37			7.00	-0.86	-8.10	37.00	-2.22	
	50.00	-0.49	-1.27	-4.82	-12.97			5.80	-0.78	-8.22	29.80	-2.12	
1	60.00	-0.50	-1.28	-4.89	-13.40			5.00	-0.71	-8.38	25.00	-2.05	
	70.00							4.43	-0.67	-8.52	21.57	-1.99	
	80.00							4.00	-0.60	-8.57	19.00	-1.94	
1.5	90.00							3.67	-0.57	-8.70	17.00	-1.84	
	100.00							3.40	-0.54	-8.80	15.40	-1.81	
2	120.00							3.00	-0.50	-8.94	13.00	-1.75	
	140.00							2.71	-0.47	-9.12	11.29	-1.72	
	160.00							2.50	-0.45	-9.20	10.00	-1.66	
3	180.00							2.33	-0.41	-9.28	9.00	-1.55	
	210.00							2.14	-0.38	-9.38	7.86	-1.43	
4	240.00							2.00	-0.35	-9.49	7.00	-1.34	
	270.00									-9.59	6.33	-1.32	
5	300.00									-9.68	5.80	-1.20	
	330.00									-9.75	5.36	-1.22	
6	360.00									-9.80	5.00	-1.15	
7	420.00									-9.90	4.43	-1.03	
8	480.00									-10.00	4.00	-0.96	
9	540.00									-10.07	3.67	-0.90	
10	600.00									-10.13	3.40	-0.84	
11	660.00									-10.16	3.18	-0.78	
12	720.00									-10.23	3.00	-0.72	
13	780.00									-10.35	2.85	-0.69	
14	840.00									-10.47	2.71	-0.65	
15	900.00									-10.88	2.60	-0.61	
16	960.00									-10.79	2.50	-0.54	
18	1080.00									-10.87	2.33	-0.50	
20	1200.00									-10.50	2.20	-0.46	
22	1320.00									-10.68	2.09	-0.41	
24	1440.00									-10.75	2.00	-0.35	


EXISTING EQUIPMENT

MOTOR :  
PUMP :  
CONDITION :


COLUMN SIZE :  
No OF COLUMNS :

BORIHOLE NO : H36-0030


**CONSTANT DISCHARGE TEST**




**STEP TEST**



**RECOVERY CONSTANT DISCHARGE TEST**



**RECOVERY STEP TEST**



ELANDSDOORN

BORIHOLE DATA		RECOMMENDATIONS		INTERPRETATION		EXISTING PUMPING EQUIPMENT	
DEPTH :	31.67 m	PUMPING RATE	60m <sup>3</sup> /hr	NEO GRANITE	39.63 m <sup>3</sup> /day	MOTOR :	
S.W.L :	12.47 m	ALLOWED	2101.32	PROCESSED	39.61 m <sup>3</sup> /day	POWER	
STRIDE :	1502 m	RECOMMENDED :	640.53	UNDESIRABLE	29.23 m <sup>3</sup> /day	PHASE	
TEST PUMP TYPE :	1502	ABSTRACTION PER DAY :	3.82	CLASS II	N/A	MAX. CAPACITY :	
PUMP DEPTH :	34.5 m	PERMISSIBLE DROUGHT PER DAY :	74	STORAGE CAPACITY :	0.40	CURRENT SIZE :	
DATE TESTED :	26/02/2008	PERMISSIBLE DROUGHT (m) :	22	SPECIFIC CAPACITY (after 2 hrs pumping) :		CONNECTION :	
				TOTAL HARDNESS			
				GEOLOGY :			
				ROCK TYPE :			
				RECOVERY :			
				WATER QUALITY :			
				PROBLEM SPECIES :			
				GENERAL COMMENTS :			
				HYDRAULIC PARAMETERS			

**WSM LESHKA**

332H  
2529AC

PROJECT	ELANDSDOORN ✓	DATE	25/05/2006	TIME STARTED	00h00
BOREHOLE No	H36-0031	AVAIL. DRAWDOWN	34.65 m	JOB NO	WH06105
BOREHOLE DEPTH	58.8 m	PUMP DEPTH	55.5 m	LAT	-25.29228
STATIC WATER LEVEL	20.85 m	PUMP TYPE		LONG	29.22941

		STEP 1	STEP 2	STEP 3	STEP 4	STEP 5	STEP 6	T/T	RECOVERY	CD	T/T	RECOVERY
AVERAGE YIELD (l/s)		0.70	1.60	2.07					1.08	1.33		1.33
TIME(hrs)	TIME(min)									2131		
-1	0.50	-0.92	-2.62	-19.59				257.00	-28.46	-2.07	2881.00	-11.20
	1.00	-1.20	-3.27	-21.46				129.00	-25.39	-2.88	1441.00	-7.23
	1.50	-1.35	-3.64	-23.00				86.33	-21.42	-3.34	961.00	-5.05
	2.00	-1.43	-3.91	-24.55				65.00	-18.75	-3.45	721.00	-3.12
	2.50	-1.54	-4.10	-26.29				52.20	-15.68	-3.81	577.00	-1.85
	3.00	-1.57	-4.28	-27.17				43.67	-12.77	-3.94	481.00	-1.15
	4.00	-1.61	-4.54	-28.41				33.00	-7.67	-4.15	361.00	-0.45
	5.00	-1.63	-4.65	-29.64				26.60	-3.91	-4.33	289.00	-0.32
	6.00	-1.64	-4.96	-30.82				22.33	-1.90	-4.42	241.00	-0.32
	7.00	-1.66	-5.38	-31.77				19.29	-1.07	-4.48	206.71	-0.32
	8.00	-1.69	-5.67	-33.18				17.00	-0.62	-4.50	181.00	-0.32
	9.00	-1.73	-5.83					15.22	-0.40	-4.52	161.00	-0.45
	10.00	-1.75	-5.94					13.80	-0.32	-4.53	145.00	-0.45
	12.00	-1.75	-7.19					11.67	-0.26	-4.55	121.00	-0.58
	15.00	-1.75	-8.10					9.53	-0.22	-4.25	97.00	-0.59
	20.00	-1.77	-9.98					7.40	-0.20	-4.25	73.00	-0.58
	25.00	-1.77	-11.64					6.12	-0.19	-4.27	58.60	-0.57
0.5	30.00	-1.79	-13.59					5.27	-0.17	-4.27	49.00	-0.55
	35.00	-1.82	-14.87					4.66	-0.16	-4.35	42.14	-0.55
	40.00	-1.82	-15.26					4.20	-0.16	-4.41	37.00	-0.53
	50.00	-1.84	-15.57					3.56	-0.15	-4.49	29.80	-0.52
1	60.00	-1.84	-16.66					3.13	-0.14	-4.53	25.00	-0.50
	70.00							2.83	-0.13	-4.56	21.57	-0.48
	80.00							2.60	-0.12	-4.59	19.00	-0.47
1.5	90.00							2.42	-0.11	-4.59	17.00	-0.46
	100.00							2.28	-0.09	-4.62	15.40	-0.46
2	120.00							2.07	-0.07	-4.66	13.00	-0.45
	140.00							1.91	-0.05	-4.71	11.29	-0.43
	160.00							1.80	-0.04	-4.76	10.00	-0.40
3	180.00							1.71	-0.03	-4.86	9.00	-0.40
	210.00							1.61	-0.03	-4.86	7.86	-0.39
4	240.00							1.53	-0.02	-4.87	7.00	-0.38
	270.00							1.47	-0.02	-4.88	6.33	-0.36
5	300.00									-4.91	5.80	-0.36
	330.00									-4.98	5.36	-0.34
6	360.00									-5.07	5.00	-0.33
7	420.00									-5.07	4.43	-0.32
8	480.00									-5.10	4.00	-0.32
9	540.00									-5.13	3.67	-0.31
10	600.00									-5.31	3.40	-0.30
11	660.00									-5.84	3.18	-0.29
12	720.00									-6.17	3.00	-0.28
13	780.00									-6.58	2.85	-0.27
14	840.00									-6.91	2.71	-0.26
15	900.00									-7.34	2.60	-0.26
16	960.00									-8.80	2.50	-0.25
18	1080.00									-10.07	2.33	-0.25
20	1200.00									-12.77	2.20	-0.24
22	1320.00									-13.86	2.09	-0.24
24	1440.00									-14.90	2.00	-0.22

EXISTING EQUIPMENT

MOTOR :  
PUMP :  
CONDITION :

COLUMN SIZE :  
No OF COLUMNS :



B32H 2529 AC

PROJECT		ELANDSDOORN ✓				DATE		27/05/2006		TIME STARTED		00h00	
BOREHOLE No		H36-0032				AVAIL. DRAWDOWN		12.15 m		JOB NO		WH06105	
BOREHOLE DEPTH		35.9 m				PUMP DEPTH		31.5 m		LAT		-25.29171	
STATIC WATER LEVEL		19.35 m				PUMP TYPE				LONG		29.22833	
		STEP 1	STEP 2	STEP 3	STEP 4	STEP 5	STEP 6	T/T'	RECOVERY	CD	T/T'	RECOVERY	
AVERAGE YIELD (l/s)		0.90	2.40	4.00	8.60	12.00			7.04	6.66		6.66	
TIME(hrs)	TIME(min)									0.931			
-1	0.50	-0.25	-0.87	-2.11	-3.52	-8.21		493.00	-2.64	-1.27	2881.00	-3.08	
	1.00	-0.25	-0.95	-2.24	-3.52	-8.99		247.00	-1.83	-1.40	1441.00	-2.40	
	1.50	-0.25	-0.97	-2.32	-3.61	-9.61		165.00	-1.66	-1.48	961.00	-2.16	
	2.00	-0.31	-0.99	-2.38	-3.65	-10.06		124.00	-1.51	-1.57	721.00	-2.05	
	2.50	-0.35	-1.01	-2.42	-3.69	-10.35		99.40	-1.41	-1.60	577.00	-1.99	
	3.00	-0.36	-1.04	-2.43	-3.73	-10.63		83.00	-1.32	-1.74	481.00	-1.94	
	4.00	-0.38	-1.09	-2.47	-3.79	-10.94		62.50	-1.20	-1.94	361.00	-1.90	
	5.00	-0.40	-1.16	-2.50	-4.18	-11.68		50.20	-1.11	-2.20	289.00	-1.88	
	6.00	-0.41	-1.27	-2.52	-4.60	-11.99		42.00	-1.03	-2.81	241.00	-1.87	
	7.00	-0.42	-1.30	-2.54	-4.60			36.14	-0.97	-3.22	206.71	-1.86	
	8.00	-0.43	-1.31	-2.56	-5.11			31.75	-0.93	-3.40	181.00	-1.84	
	9.00	-0.44	-1.31	-2.60	-5.45			28.33	-0.88	-3.47	161.00	-1.82	
	10.00	-0.45	-1.32	-2.60	-5.57			25.60	-0.83	-3.53	145.00	-1.8	
	12.00	-0.49	-1.34	-2.63	-5.72			21.50	-0.78	-3.60	121.00	-1.77	
	15.00	-0.50	-1.36	-2.65	-5.73			17.40	-0.70	-3.76	97.00	-1.71	
	20.00	-0.52	-1.37	-2.66	-5.92			13.30	-0.64	-3.89	73.00	-1.67	
	25.00	-0.53	-1.38	-2.69	-6.10			10.84	-0.56	-3.92	58.60	-1.57	
0.5	30.00	-0.54	-1.55	-2.72	-6.20			9.20	-0.54	-3.95	49.00	-1.48	
	35.00	-0.54	-1.57	-2.75	-6.28			8.03	-0.53	-3.99	42.14	-1.45	
	40.00	-0.54	-1.59	-2.77	-6.42			7.15	-0.50	-4.04	37.00	-1.42	
	50.00	-0.55	-1.64	-2.81	-6.49			5.92	-0.48	-4.09	29.80	-1.34	
1	60.00	-0.56	-1.68	-2.85	-6.55			5.10	-0.42	-4.14	25.00	-1.27	
	70.00							4.51	-0.39	-4.18	21.57	-1.24	
	80.00							4.08	-0.37	-4.20	19.00	-1.21	
1.5	90.00							3.73	-0.35	-4.25	17.00	-1.15	
	100.00							3.46	-0.33	-4.27	15.40	-1.12	
2	120.00							3.05	-0.30	-4.33	13.00	-1.05	
	140.00							2.76	-0.27	-4.40	11.29	-1.01	
	160.00							2.54	-0.22	-4.45	10.00	-0.97	
3	180.00							2.37	-0.19	-4.48	9.00	-0.94	
	210.00							2.17	-0.17	-4.55	7.86	-0.91	
4	240.00							2.03	-0.15	-4.60	7.00	-0.83	
	270.00							1.91	-0.13	-4.67	6.33	-0.79	
5	300.00									-4.73	5.80	-0.75	
	330.00									-4.78	5.36	-0.73	
6	360.00									-4.78	5.00	-0.70	
7	420.00									-4.87	4.43	-0.67	
8	480.00									-4.98	4.00	-0.62	
9	540.00									-5.01	3.67	-0.57	
10	600.00									-5.05	3.40	-0.53	
11	660.00									-5.10	3.18	-0.48	
12	720.00									-5.17	3.00	-0.43	
13	780.00									-5.21	2.85	-0.41	
14	840.00									-5.26	2.71	-0.39	
15	900.00									-5.30	2.60	-0.37	
16	960.00									-5.36	2.50	-0.35	
18	1080.00									-5.47	2.33	-0.33	
20	1200.00									-5.47	2.20	-0.31	
22	1320.00									-5.51	2.09	-0.29	
24	1440.00									-5.51	2.00	-0.27	

EXISTING EQUIPMENT





MOTOR :  
PUMP :  
CONDITION :

COLUMN SIZE :  
NO OF COLUMNS :

**WSM LESHKA** CONSULTING (Pty) Ltd

BOREHOLE NO : H30-0032

ELANDSDOORN



BOREHOLE DATA		RECOMMENDATIONS		INTERPRETATION		HYDRAULIC PARAMETERS		ELECTRIC PUMPING EQUIPMENT	
DEPTH :	33.9 m	PUMPING RATE	l/h	71.15	MOTOR :	139.10	139.10	139.10	139.10
9 W/L :	19.30 m	MAXIMUM	l/h	87.77	PUMP :	105.32	105.32	105.32	105.32
STRIDE :	0	RECOMMENDED :	l/h	98 %	T (RECOVERY STEP) :	1.54	1.54	1.54	1.54
PUMP TYPE :	0	MAX ABSTRACTION PER DAY :	l/h	CLASS :	T (CONSTANT DISCHARGE) :				
PUMP DEPTH :	31.5 m	PUMP SETTING (m) :	26	PROBLEM SPECIES :	T (RECOVERY CONSTANT DISCHARGE) :				
DATE TESTED :	27/02/2008	PRESSURABLE DRAWDOWN (m) :	12	TOTAL HARDNESS	STORAGE COEFFICIENT :				
					SPECIFIC CAPACITY (after 2 hrs pumping) :				
				GEOLOGY :		NEO GRANITE			
				GEOLOGY TYPE :		FRACTURED			
				DRILL TARGET :		UNKNOWN			
				RECOVERY :		98 %			
				WATER QUALITY :		CLASS			
				TOTAL HARDNESS					
				GENERAL COMMENTS					

WSM LESHKA

B32H 2529AC

PROJECT		ELANDSDOORN				DATE		27/05/2006		TIME STARTED		00h00	
BOREHOLE No		H36-0033				AVAIL. DRAWDOWN		55.03 m		JOB NO		WH06105	
BOREHOLE DEPTH		99.54 m				PUMP DEPTH		73.5 m		LAT		-25.29192	
STATIC WATER LEVEL		18.47 m				PUMP TYPE		11.05		LONG		29.22757	
		STEP 1	STEP 2	STEP 3	STEP 4	STEP 5	STEP 6	T/T	RECOVERY	CD	T/T	RECOVERY	
AVERAGE YIELD (l/s)		0.62	1.71	3.52	5.45				2.79	5.00		5.00	
TIME(hrs)	TIME(min)									0801			
-1	0.50	-0.29	-1.09	-1.96	-5.46			481.00	-7.53	-2.84	2881.00	-3.53	
	1.00	-0.39	-1.30	-2.47	-6.04			241.00	-4.49	-4.10	1441.00	-3.52	
	1.50	-0.43	-1.45	-3.07	-6.72			161.00	-2.23	-5.11	961.00	-1.25	
	2.00	-0.45	-1.51	-3.55	-7.27			121.00	-1.88	-5.62	721.00	-1.29	
	2.50	-0.46	-1.54	-3.83	-7.53			97.00	-1.05	-6.00	577.00	-0.89	
	3.00	-0.47	-1.57	-4.04	-7.88			81.00	-0.84	-6.45	481.00	-0.57	
	4.00	-0.54	-1.60	-4.24	-8.28			61.00	-0.66	-6.72	361.00	-0.40	
	5.00	-0.56	-1.57	-4.35	-8.31			49.00	-0.58	-7.10	289.00	-0.62	
	6.00	-0.56	-1.64	-4.45	-9.15			41.00	-0.53	-7.40	241.00	-0.30	
	7.00	-0.57	-1.65	-4.50	-9.47			35.29	-0.51	-7.50	206.71	-0.89	
	8.00	-0.57	-1.66	-4.45	-9.69			31.00	-0.48	-7.63	181.00	-0.86	
	9.00	-0.58	-1.67	-4.50	-9.90			27.67	-0.46	-7.80	161.00	-0.33	
	10.00	-0.59	-1.67	-4.61	-10.07			25.00	-0.45	-7.90	145.00	-0.31	
	12.00	-0.60	-1.70	-4.68	-10.30			21.00	-0.43	-7.99	121.00	-0.28	
	15.00	-0.60	-1.72	-4.82	-10.55			17.00	-0.43	-8.12	97.00	-0.96	
	20.00	-0.61	-1.75	-5.02	-10.77			13.00	-0.40	-8.38	73.00	-0.92	
	25.00	-0.62	-1.76	-5.08	-10.95			10.60	-0.38	-8.46	58.60	-0.90	
0.5	30.00	-0.63	-1.77	-5.11	-11.07			9.00	-0.35	-8.56	49.00	-0.88	
	35.00	-0.63	-1.78	-5.14	-11.46			7.86	-0.35	-8.65	42.14	-0.85	
	40.00	-0.64	-1.79	-5.16	-11.64			7.00	-0.32	-8.76	37.00	-0.83	
	50.00	-0.64	-1.81	-5.22	-12.29			5.80	-0.30	-8.89	29.80	-0.80	
1	60.00	-0.65	-1.82	-5.26	-12.41			5.00	-0.28	-8.97	25.00	-0.77	
	70.00							4.43	-0.27	-9.13	21.57	-0.74	
	80.00							4.00	-0.25	-9.89	19.00	-0.72	
1.5	90.00							3.67	-0.24	-10.46	17.00	-0.70	
	100.00							3.40	-0.23	-10.64	15.40	-0.67	
2	120.00							3.00	-0.22	-10.64	13.00	-0.65	
	140.00							2.71	-0.20	-10.78	11.29	-0.62	
	160.00							2.50	-0.18	-11.16	10.00	-0.60	
3	180.00							2.33	-0.18	-11.50	9.00	-0.58	
	210.00							2.14	-0.17	-12.04	7.86	-0.55	
4	240.00							2.00	-0.16	-12.82	7.00	-0.53	
	270.00									-13.60	6.33	-0.48	
5	300.00									-14.89	5.80	-0.40	
	330.00									-16.10	5.36	-0.44	
6	360.00									-17.19	5.00	-0.42	
7	420.00									-20.94	4.43	-0.37	
8	480.00									-23.96	4.00	-0.36	
9	540.00									-25.60	3.67	-0.34	
10	600.00									-27.50	3.40	-0.31	
11	660.00									-30.72	3.18	-0.29	
12	720.00									-33.41	3.00	-0.27	
13	780.00									-35.98	2.85	-0.25	
14	840.00									-38.15	2.71	-0.22	
15	900.00									-41.36	2.60	-0.20	
16	960.00									-44.41	2.50	-0.18	
18	1080.00									-46.68	2.33	-0.16	
20	1200.00									-48.77	2.20	-0.14	
22	1320.00									-50.57	2.09	-0.12	
24	1440.00									-52.65	2.00	-0.09	





EXISTING EQUIPMENT

MOTOR :  
PUMP :  
CONDITION :

COLUMN SIZE :  
NO OF COLUMNS :

ELANGSOORN

BOREHOLE NO : H08-0033



BOREHOLE DATA		RECOMMENDATIONS		INTERPRETATION		EXISTING PUMPING EQUIPMENT	
DEPTH :	93.54 m	PUMPING RATE	6 m³/h	NEO GRANITE	T (STEP 1) :	19.51 m³/day/m	MOTOR :
S.W.L. :	19.47 m	MAXIMUM :	2873.87 m³/h	FRACURED	T (RECOVERY STEP1) :	49.02 m³/day/m	PUMP :
STRIKE :	11.05 m	RECOMMENDED :	1189.43 m³/h	UNKNOWN	T (CONSTANT DISCHARGE) :	15.81 m³/day/m	COLUMN SIZE :
TEST PUMP TYPE :	73.5 m	MAX ABSTRACTION PER DAY :	6.40 m³/day	100 %	T (RECOVERY CONSTANT DISCHARGE) :	188.14 m³/day/m	No of COLUMNS :
PUMP DEPTH :	73.5 m	PUMP SETTING (m) :	188 m	CLASS II	STORAGE CAPACITY :	NA	OUTLET SIZE :
DATE TESTED :	27/02/2006	PERMISSIBLE DRAWDOWN (m) :	55 m	TOTAL HARDNESS	SPECIFIC CAPACITY (after 2 hrs pumping) :	0.47 l/s per m	CONDITION :

WSM LESHKA

