



Attention: Mr. Tony Kriel  
Port Ferry 71 (PTY) LTD  
Author: A.J. van Rooyen  
Date: 31 July 2003  
Technical Report No: AD/012/03  
Project No: AD/006/03

**KHAMANGA BAY RESIDENTIAL DEVELOPMENT  
BULK WATER SUPPLY STUDY  
REPORT FOR THE PROPOSAL CALL  
FOR THE FEASIBILITY STUDY AND PILOT PROJECT  
ON THE GROUNDWATER POTENTIAL  
AMATOLE DISTRICT MUNICIPALITY (DC13)  
GREAT KEI LOCAL MUNICIPALITY  
EAST LONDON MAGISTERIAL DISTRICT**



**KHAMANGA BAY RESIDENTIAL DEVELOPMENT  
BULK WATER SUPPLY STUDY  
REPORT FOR THE PROPOSAL CALL  
FOR THE FEASIBILITY STUDY AND PILOT PROJECT  
ON  
THE GROUNDWATER POTENTIAL**

**CONTENTS**

1		ABBREVIATIONS	
2		GLOSSARY	
3		EXECUTIVE SUMMARY	
6		1. INTRODUCTION	
6		1.1 TERMS OF REFERENCE	
6		1.2 SCOPE OF THE INVESTIGATION	
6		1.3 LOCATION OF THE STUDY AREA	
7		2.0 DESK STUDY	
7		2.1 INFORMATION SOURCES	
7		2.2 DESK STUDY RESULTS	
8		3. EXISTING INFORMATION	
8		3.1 SURFACE WATER SOURCES	
8		3.2 GROUNDWATER SOURCES	
5		4. GENERAL GEOLOGY AND GEOHYDROLOGY	
5		4.1 REGIONAL GEOLOGICAL SETTING	
5		4.1.1 Structure of the area	
7		5. BOREHOLE SITING	
7		5.1 METHODOLOGY	
7		5.1.1 Magnetic method	
7		5.1.2 Frequency domain electro-magnetic method	
7		5.2 EFFICACY OF SITING WORK	
8		5.3 SCOPE OF SITING WORK	
9		6.0 RESULTS	
9		6.1 NEWLY DRILLED BOREHOLES	
9		6.1.1 Borehole KHAM 1 (Target Area 1)	
9		6.1.2 Borehole Kham 2 (Target Area 1)	
10		6.1.3 Borehole KHAM 3 (Target Area 1)	
10		6.1.4 Borehole KHAM 4 (Target Area 2)	
11		6.1.5 Borehole KHAM 5 (Target Area 2)	
12		6.1.6 Borehole KHAM 6 (Target Area 2)	
13		6.1.7 Borehole KHAM 7 (Target Area 2)	
14		7. CONCLUSIONS AND RECOMMENDATIONS	
15		8. BIBLIOGRAPHY	

**LIST OF FIGURES**

- FIGURE 1 Locality map
- FIGURE 2 Project map

**LIST OF APPENDICES**

- APPENDIX A Detailed hydrocensus results
- APPENDIX B Detailed pump test results
- APPENDIX C Detailed chemical test results

° C	Degrees Celsius
CMAS	Catchment Management Agencies
DECAS	Department of Environmental and Cultural Affairs and Sport
DEM	Digital Elevation Model
DWAF	Department of Water Affairs and Forestry
EC	Electrical conductivity
EIA	Environmental Impact Assessment
ESE	East south-east
EVT	Evapotranspiration
GIS	Geographic Information System
IGS	Institute for Groundwater Studies
k	permeability
km	kilometer
m	metre
m <sup>2</sup>	square meter
MAI	Mean Annual Infiltration
MAP	Mean Annual Precipitation
MAR	Mean Annual Run-off
mg/l	milligram per litre
Mm <sup>3</sup>	Million cubic metres
mS/m	millisiemens per metre
n	porosity
NW	North West
NWA	National Water Act
S	storativity
SE	South East
S <sub>s</sub>	specific storage
WNW	West north-west
WRC	Water Research Commission
WRYM	Water Resources Yield Model
WSDP	Water Services Development Plan
WUA	Water User Associations

**ABBREVIATIONS**

**Unconfined aquifer** : An aquifer in which the water table (i.e. the top of the saturated zone at which pore water pressure is at atmospheric pressure) is free to fluctuate.

**Confined aquifer** : An aquifer which is overlain by a confining layer of significantly lower permeability which restricts vertical movement of water and contains the groundwater under pressure greater than atmospheric pressure. If the aquifer is penetrated, the water level may rise above the top of the aquifer, and even above the ground surface, to reach its potentiometric level on an imaginary surface representing pressure or hydraulic head in the artesian aquifer, analogous to the water table of an unconfined aquifer.

**Aquifer** : A consolidated or unconsolidated geologic unit (material, stratum, or formation) or set of connected units that yield a significant quantity of water of suitable quality to wells or springs in economically usable amounts.

**Aquifard** : a geologic material, stratum, or formation of low permeability (a confining unit) that transmits significant amounts of water on a regional scale or over geologic time.

**Aquiclude** : a geologic material, stratum, or formation that contains water (i.e. has porosity) but does not transmit it (i.e. has zero or negligible permeability).

**Specific storage** : The volume of water that a unit volume releases from or takes into storage when the pressure head in the unit volume changes a unit amount.

**Storativity** : The volume of water an aquifer releases from or takes into storage per unit surface area of aquifer per unit change in the component of pressure head normal to that surface.

## GLOSSARY

**REPORT TITLE: The Potential for Exploiting Groundwater**

**KHAMANGA BAY RESIDENTIAL DEVELOPMENT**

**WATER SUPPLY STUDY**

**REPORT FOR THE PROPOSAL CALL**

**FOR THE FEASIBILITY STUDY AND PILOT PROJECT**

**ON**

**THE POTENTIAL FOR EXPLOITING GROUND WATER**

**EXECUTIVE SUMMARY**

The Amatole District Municipality is responsible for water demand management in the Amatole District of the Eastern Cape.

Khamanga Bay is a private residential country estate being developed at Moonshine Bay near Cintsa West. One of the keystones to the development is a sustainable water supply of good quality. A total of 241 plots are to be developed with an estimate water need of 1200 l/d per plot (289 m<sup>3</sup>/day or 3.35 l/s on a 24 hour pump cycle).

The undesirable levels of water supply risk in terms of quantity and especially quality at all the existing developments, in this region, along the coast are a critical restraint that threatens the viability of the development. The development agency thus initiated this study to investigate the following options to ensure an adequate supply of water:

- Ground water (borehole) development
- Bulk water supply from Amatole District Municipality
- Desalination

The purpose of this study was to investigate the above three options at a pre-feasibility level as a first phase, and to ensure that all major issues relating to them are identified, so that they may be addressed in a subsequent phase. The results from this study should enable recommendations to be made on the phasing of the development of future raw water supply sources.

The important aspects concerning the groundwater (borehole) option, and contained in this report, are summarized below:

- To produce water from a large subterranean reservoir (aquifer);
- To obtain fundamental information about hydrogeological properties and parameters in the aquifer, and its interaction with related systems, in preparation for possible future expansion;
- To set up a coordinated management and monitoring system to address the medium- to long-term uncertainties about sustainability, impact on the environment and existing usage, either surface or groundwater;

**Hydrogeology of the investigated area**

- The area designated for further groundwater-directed investigation forms part of the R30B quaternary sub-catchment.
- The project area is located in hilly terrain along the coast, where mean annual precipitation (MAP) was calculated to be ~900 mm/a.
- The Beaufort Group is the geologically dominant unit in the catchment, and is divided into two subgroups, namely,

○ Tarkastad Subgroup

o Adelaide Subgroup

Sand, dune sand and dune rock borders the sea.

- Two areas of existing abstraction with acceptable water qualities were identified. The first area (Existing 1) is located directly east of the development and supplies the existing three houses on the development. The second area (Existing 2) is located in the Inkwenkwezi Game Reserve.
- Two target areas were identified for exploration. Target area 1 is located south of the development in a ravine and has a southeast-northwest orientation. Target area 2 is an elongated area just inland from the coastal dunes to the north of the development (See the project map).

Critical Data

- Several methods from the Recharge Program written by the IGS were used to estimate the recharge in the area. An infiltration proportion of 4.3% of MAP was derived.
- There is one existing borehole of good quality in Existing Area 1. The recommended abstraction for this borehole is 17.28 m<sup>3</sup>/d. The recharge area was calculated to be ~ 0.2982 km<sup>2</sup> resulting in potential annual recharge of 0.0115 Mm<sup>3</sup>/a or 31.6 m<sup>3</sup>/d.
- Two boreholes of good water quality are available in Existing Area 2. The recommended abstraction from these boreholes BH9 and BH11 are 25.92 and 30.24 m<sup>3</sup>/d respectively. Borehole BH9 is currently in use by the reservation at a rate of 10.8 m<sup>3</sup>/d. There is thus spare capacity and further exploration is possible in this area. This area is however far from the proposed development.
- The water quality of the boreholes drilled in Target Area 1 proved to be unsuitable for human consumption over an extended period. Treatment of this water is an option. The equipment of borehole Khm2 is however recommended. This water can be utilized in the construction of the roads, houses etc. This would help to alleviate stress on the fresh water source in Target Area 2.
- The water quality in Target Area 2 is acceptable and a single borehole (Kham 6) is available for abstraction. The recommended abstraction rate for this borehole is 64.8 m<sup>3</sup>/d.
- The catchment for Target Area 2 was calculated to be ~1.916 km<sup>2</sup> resulting in potential annual recharge of 0.074 Mm<sup>3</sup>/a or 203.26 m<sup>3</sup>/d.
- Local confined aquifer drawdowns much larger than 10 m are possible at well sites, without impacting in any way on the aquifer's saturated thickness. However to protect the freshwater aquifer and to ensure that the surrounding cone of depression do not adversely affect base flow we restricted the recommended abstraction rate to ensure a maximum drawdown of less than 10 m. Subsequently only borehole Kham 6 is recommended for abstraction at a rate of 0.75 l/s for a 24 hour pumping period. This ensures an adequate supply for 54 plots.
- This leaves a shortage for the development as a whole but provides enough water for the initial development. See the table below for an example of the typical developmental pace (water need) for this kind of development.

Table 1: Expected developmental progress

Period:	No. of registered plots for the period	No of houses built for the period	Total no of houses built up to end of the period	Estimated water need (m <sup>3</sup> /d)*
01/12/2003 to	90 Plots	5 Houses	5 Houses	6.0
01/12/2004	120 Plots	7 Houses	12 Houses	14.4
01/12/2005	150 Plots	11 Houses	23 Houses	27.6
01/12/2006	180 Plots	13 Houses	36 Houses	43.2
01/12/2007	210 Plots	14 Houses	50 Houses	60
01/12/2008	240 Plots	15 Houses	65 Houses	78

\* This estimation do not take into account the water needed for the building of the houses, roads etc.

The Water Services Development Plan (WSDP) of Amatole District Municipality plan to provide bulk water to Cintsa West by the year 2007.

The National Water Act (No. 36 of 1998) and the Water Services Act (No. 108 of 1997) now govern the use of water. The latter imposes certain responsibilities upon (new) local authorities for the town of Cintsa-West. Enquiries should be made about the current status of their planning and how these might be impacted upon by the proposed development.

An Environmental Impact Assessment (EIA) would be required in order to inform the authorities as to the likely environmental implications of the proposed development. Involvement of interested and affected parties is integral to the EIA process. The competent authority would be the provincial Department of Environmental and Cultural Affairs and Sport, if the applicant were a private company or local authority, and the national Department of Environmental Affairs and Tourism, should the applicant be a provincial or national government department.

**Legal and Social Aspects**

- Efforts and resources should be spent on a monitoring programme. Monitoring boreholes were drilled in Target Area 1 and 2 for this purpose.
- The impact on the environment is likely to be as much a function of appropriate management as of the numerous relevant variables other than the actual groundwater abstraction. A little-discussed risk is the decision-making process and the ecosystem knowledge base required to switch pumps off timeously, if the impact resulting from groundwater abstraction is considered unacceptable.
- Possible water-quality considerations could include: Impacts on the freshwater ecosystem waters related to either abnormally-high or abnormally-low concentrations of key constituents.
- Disruption to the nutrient contribution to the ocean via the aquifer (unlikely).

**Environmental Constraints**

- There are no drilling or pumping technology limitations to the exploration
- Borehole design considerations dictate that the boreholes be effectively and permanently cased, to the depth of solid rock. PVC casing and screens was installed in the production boreholes.
- The potential for easy and relatively inexpensive connections to existing water-supply infrastructure was an important consideration in the selection of the most appropriate sites.

**Technical Constraints**

- Introducing a water treatment plant. A more than adequate supply of water is available from Target Area 1 for this purpose or,
- Exploration in Existing Area 2 and the laying of a pipeline to the development.
- Increased abstraction from Existing Area 1 is not recommended since the recharge to the aquifer system is limited.
- Increased abstraction from Target Area 2 might be feasible at this stage if the rainfall, abstraction and water level monitoring data indicate potential to do so.

Failure to supply bulk water by this date will mean that the supply from Target Area 2 will have to be augmented by:

**1. INTRODUCTION**

**1.1 TERMS OF REFERENCE**

AD Geo Consultants was appointed to investigate the supply of water to the Khamanga Bay development from groundwater sources. The aims of the study were as follows:

- To document all relevant geohydrological data
- To evaluate and comment on the current groundwater sources
- To evaluate and recommend alternative groundwater supply sources

**1.2 SCOPE OF THE INVESTIGATION**

The following actions were undertaken in order to reach these aims:

- A hydro census in and around the Khamanga Bay development.
- Data collection, and the evaluation of historical data
- Evaluation of structural geology
- The evaluation of the results of yield tests conducted at existing boreholes located in the vicinity of the development
- The identification and evaluation of areas exhibiting groundwater potential
- The drilling of exploration boreholes in these areas for the supply of groundwater to the development
- To evaluate the yield characteristics of the highest yielding exploration borehole(s)
- To evaluate the groundwater quality at the highest yielding borehole(s) with regards to drinking water
- Supervision with regards to the development of new groundwater sources
- To compile a comprehensive geohydrological report that details all methodology, results and utilisation recommendations

**1.3 LOCATION OF THE STUDY AREA**

The development of Khamanga Bay is located at Moonshine Bay near Cintisá-West in the Great Kei Local Municipality of the Amatole District Municipality. The natural vegetation cover in and around the development has generally been removed. The study area is indicated by the locality map.

## 2.0 DESK STUDY

### 2.1 INFORMATION SOURCES

The following sources of information were referenced:

<u>Geology map</u>	
-	Geological map of the Republic of South Africa and the Kingdoms of Lesotho and Swaziland, 1997; scale 1 : 1 000 000.
-	3228 KEI MOUTH, 1979; scale 1 : 250 000.
<u>Topographical map</u>	
-	2328 CC GONUBIE, Fifth Edition, 1996; scale 1 : 50 000.

### 2.2 DESK STUDY RESULTS

A generalized impression of the geological setting of the study area was obtained from the available geological maps, with more detailed information obtained from topographical maps and regional mapping during a site visit.

A localised hydrocensus revealed the presence of twenty existing boreholes in the immediate vicinity of the study area (Figure 2). Of these thirteen boreholes is motorised (5 with Mono pumps and 8 with submersibles), Four are unequipped and three are deemed destroyed/dry. See Appendix A.

Two target areas were identified in the study area. One is located to the north of the development and one to the west of the development. These target areas were further investigated by means of geophysical surveys.




FIGURE 1: KHAMANGA BAY DEVELOPMENT - LOCATION MAP

### 3. EXISTING INFORMATION

#### 3.1 SURFACE WATER SOURCES

The development is ~2 km south of the Cintis River. There are no perennial streams or other significant surface water sources in the vicinity of the development. Several small west-east trending non-perennial streams sustained by small earth dams divide the investigated area.

Surface water is therefore not deemed to be freely available for domestic or industrial use.

#### 3.2 GROUNDWATER SOURCES

A detailed borehole survey was undertaken in the area as indicated by Figure 2.

Details regarding the results of the hydro census are given in Appendix A, while the detailed results of pump- and chemical tests are given by Appendices B and C respectively.

Two areas of existing abstraction with acceptable water qualities were identified. The first area (Existing 1) is located directly east of the development and supplies the existing three houses on the development. The second area (Existing 2) is located in the Inkwenkwezi Game Reserve.

The following existing production boreholes were identified within these areas:

##### Borehole Bh7 (Existing Area 1)

##### Yield characteristics

The yield characteristics of this borehole were tested by means of a stepped discharge- and recovery test conducted in the period between June, 25 and 26, 2003.

The static groundwater level was located at a depth of 7.08 m below the datum level<sup>1</sup> at the time of testing. The test pump was placed at a depth of 67.0 m below the datum level, with a total borehole depth of 104.0 m being recorded.

##### Stepped discharge test

This test comprised two 60-minute steps conducted at yields of 0.25 and 0.5 L/s respectively. A maximum drawdown of 59.92 m was achieved during the test.

##### Recovery test

The groundwater level recovered to 93.12% of its original level after a period of 2 hours (120 minutes).

##### Groundwater quality

A groundwater sample was taken and submitted to Messrs. Pollution Control Technologies for the determination of the macro-chemical composition of the water for domestic purposes.

The groundwater classifies as:

- Domestic use: Class 2  
Water of marginal quality

<sup>1</sup> Taken as a distance of 0.37 m above the ground surface.

The borehole is currently in use and equipped with a submersible pump.

**Borehole Bh9 (Existing Area 2)**

**Yield characteristics**

The yield characteristics of this borehole were tested by means of a stepped discharge- and recovery test conducted in the period between June, 30 and July, 5 2003.

The static groundwater level was located at a depth of 32.49 m below the datum level<sup>2</sup> at the time of testing. The test pump was placed at a depth of 89.8 m below the datum level, with a total borehole depth of 115.0 m being recorded.

**Stepped discharge test**

This test comprised of three 60-minute steps conducted at yields of 0.39, 0.54 and 1.02 L/s respectively. A maximum drawdown of 57.31 m was achieved during the test.

**Constant discharge test**

This test was conducted at an average yield of 0.5 L/s for a period of 72 hours (4320 minutes). A maximum drawdown of 23.25 m was achieved during the test, which translates to approximately 41 percent of the available drawdown.

**Recovery test**

The groundwater level recovered to 94.19% of its original level after a period of 35 hours (2100 minutes).

**Groundwater quality**

A groundwater sample was taken and was submitted to Pollution Control Technologies for the determination of the macro-chemical composition of the water for domestic purposes.

The groundwater classifies as:

- Domestic use: Class 2  
Water of marginal quality

The borehole is currently in use and equipped with a submersible pump.

**Borehole Bh11 (Existing Area 2)**

**Yield characteristics**

The yield characteristics of this borehole were tested by means of a stepped discharge- and recovery test conducted in the period between July, 14 and 19, 2003.

The static groundwater level was located at a depth of 13.14 m below the datum level<sup>2</sup> at the time of testing. The test pump was placed at a depth of 53.0 m below the datum level, with a total borehole depth of 64.9 m being recorded.

2

Taken as a distance of 0.61 m above the ground surface.

3

Taken as a distance of 0.28 m above the ground surface.

Stepped discharge test  
This test comprised two 120-minute steps conducted at yields of 0.52 and 1.83 L/s respectively. A maximum drawdown of 39.86 m was achieved during the test.

Constant discharge test  
This test was conducted at an average yield of 0.58 L/s for a period of 72 hours (4320 minutes). A maximum drawdown of 23.15 m was achieved during the test, which translates to approximately 58 percent of the available drawdown.

Recovery test  
The groundwater level recovered to 99.8% of its original level after a period of 36 hours (2160 minutes).

### Groundwater quality

A groundwater sample was taken and was submitted to Messrs. Pollution Control Technologies for the determination of the macro-chemical composition of the water for domestic purposes.

The groundwater classifies as:

Domestic use: Class 2

Water of marginal quality

The borehole is currently unused and equipped with an old mono pump. It used to supply water to a tomato packaging plant.

## 4. GENERAL GEOLOGY AND GEOHYDROLOGY

### 4.1 REGIONAL GEOLOGICAL SETTING

The Beaufort Group is the geologically dominant unit in the catchment, and is divided into two subgroups, namely,

- Tarkastad Subgroup
- Adelaide Subgroup

Sand, dune sand and dune rock borders the sea.

The Tarkastad Subgroup consists of the Burgersdorp and Katberg Formations. The Burgersdorp Formation consists mainly (70-80%) of brownish-red and grey mudstone. Sandstone layers are typically 2 to 3 m thick. The Katberg Formation consists of mainly (~90%) sandstone. The sandstone is fine-grained to medium-grained, horizontally laminated, cross-bedded or massive.

The Adelaide Subgroup consists of grayish-green and brownish-red mudstone interspersed with multi-layered river channel stones. The sandstone to mudstone ratio is of the order of 1:2.

Dolerite sheets occurring in the area are superficial and related to dyke intrusions.

#### 4.1.1 Structure of the area

**Faulting:** Two major east-west striking hinge faults occur to the north of the development. Their downthrows are the south along the coast but diminishes inland and dies out within 20 km.

**Folding:** Variations in dip steepness and direction occur locally next to some intrusions. Dips increase in the faulted areas at the coast and are mainly eastward.

**Fracturing:** Localized fracturing associated with dolerite intrusions occur within the dolerite and the host rock. Fractures also form as a result of weathering, tectonic forces and stress release on unloading by denudation. Lithological boundaries often represent opportunity when there is local flexure and rock competence contrasts.

**Weathering:** Climate conditions and rock type influence the intensity and mode of weathering. Decomposition due to chemical weathering prevails in the area. The weathered zone is not expected to exceed 30 m in depth.

**Stress regime:** The maximum horizontal compression is NW-SE trending in the area – Andreoli *et al*(1996). NW-SE trending structures are thus likely to be in tension (open) and those at right angles to this in compression (closed)

Gay (1975) concluded that horizontal stresses tend to be larger than vertical stress at shallow depths. At greater depths the vertical stress is nearly twice those acting horizontally. This implies that horizontal fractures are more likely to be open at shallow depths but closed deeper down due to increasing load pressure.

Given the NW-SE maximum horizontal stress The NW-SE trending (vertical) fractures are most likely to be open at depth.

#### 4.2 HYDROGEOLOGY

Groundwater occurs mainly in the rock matrix. Principal Transmissivity is derived from large but infrequent fractures. These fractures have a relatively low storage capacity. Secondary Transmissivity occur by numerous micro fissures with higher Storativity but lower Transmissivity; hence the name "Dual Porosity Aquifers". Deeper fractures often have a higher Transmissivity but lower Storativity

than shallow fractures. Groundwater abstracted from deeper fractures via boreholes, or other means, is replenished by downward leakage.

Yields of up to 2.00 l/s are obtainable but can be as high as 12.00 l/s in exceptional cases in fractured sedimentary rock. The norm would however be in the order of 1.50 l/s. The influence of dolerite intrusions raises the average yields in fractured sedimentary rock and approximately 20% of the boreholes targeting dolerites yield more than 5.0 l/s.

Several methods from the Recharge Program written by the IGS were used to estimate the recharge in the area. An infiltration proportion of 4.3% of MAP was derived.

## 5. BOREHOLE SITING

### 5.1 METHODOLOGY

The initial procedure comprises a desk study, which incorporates a detailed ortho-photograph interpretation and the collation of existing data. This is followed by regional geological mapping during a walk-over site inspection, and ground magnetic- and electro-magnetic surveys to identify and locate the most suitable drilling targets. The geophysical traverses are conducted at right angles to structures targeted for exploration where possible.

#### 5.1.1

##### Magnetic method

The different magnetic susceptibilities of the different rock types result in contrasting magnetic signatures. Thus, magnetic anomalies identified during the surveys can be interpreted to represent intrusive structures (such as dykes), geological contacts and faults which may have a bearing on the occurrence, storage and movement of ground water. These geological structures are deemed to be primary targets in the selection of drilling sites for ground water exploration.

A Geotron model G4 Proton-precession magnetometer, which measures the strength of the total magnetic field at a given locality directly, was utilized during the study. A station interval of five m was used on the traverses.

#### 5.1.2

##### Frequency domain electro-magnetic method

The Fdem EM system can be used for the rapid and simple measurement of site conductivities, which facilitates the detection of steeply dipping conductive targets (for example: dykes, fracture zones and faults) by means of electro-magnetic coupling.

The Fdem is a moving-source, moving-receiver system which measures the ratio of both the vertical and horizontal in- and out-phases components of a secondary magnetic field to the free space primary magnetic field. The transmitter and receiver units are connected by a light-weight 2-conductor Teflon cable which acts as a reference to the primary magnetic field.

Different types of magnetic anomalies, often having the same order of magnitude, can be distinguished by correlating electromagnetic data with magnetic data. The electromagnetic signature of a geological contact or fault can be distinguished by a step in the magnetic background response where typical dyke-like anomalies are absent, while intrusive dykes possess distinct magnetic signatures. The presence of remnant magnetism and the lack of background definition may however, hamper the interpretation of dip direction from magnetic data. The centre of an electromagnetic anomaly may coincide with the centre or edge of the dyke, depending on the width of the dyke and the degree of weathering.

The dip direction can often be interpreted from the geometry of the electromagnetic anomaly, while the width and position of dyke contacts can be identified from negative electromagnetic anomalies.

### 5.2 EFFICACY OF SITING WORK

Major geological structures could readily be identified from the results of the geophysical surveys, that together with the available geological, topographical and drainage data were sufficient to identify possible drilling sites.

The siting methods utilized during this study are thus deemed to be efficacious.

Magnetic and electro-magnetic surveys were conducted in two target areas identified for exploration. Target area 1 is located south of the development in a ravine and has a southeast-northwest orientation. Target area 2 is an elongated area just inland from the coastal dunes to the north of the development (See the project map).

**5.3 SCOPE OF SITING WORK**

**NOTE:** It must be kept in mind that although structures with a relatively higher groundwater potential can readily be identified by means of the above-mentioned methods, no known technique can measure the water bearing qualities of such structures.

6.0 RESULTS

Detailed geological- and geohydrological logs are included as Appendix D, with borehole positions indicated by the project map.

6.1 NEWLY DRILLED BOREHOLES

6.1.1 Borehole KHAM 1 (Target Area 1)

Drilling results

The borehole was drilled to a depth of 78 m by Messrs. Drilling Africa Trust on 3/4 May 2003.

The borehole was drilled to a diameter of 205 mm to a depth of 14 m, after which the borehole was drilled to a diameter of 165 mm. Solid steel casing, with an outside diameter of 178 mm and a sidewall thickness of 4 mm, was installed from the surface to a depth of 14 m. Perforated steel casing, with a diameter of 165 mm and a sidewall thickness of 4 mm, was installed from a 22 m up to a depth of 43 m.

Groundwater seepage occurred at a depth of 52 m. A total estimated blow yield of 1.4 L/s was reported. A sanitary seal with a concrete collar was installed and the borehole capped with a steel lid.

Yield characteristics

The yield characteristics of this borehole were not tested. The static groundwater level was located at a depth of 22.31 m below the top of the casing.

Groundwater quality

A groundwater sample was taken and submitted to Messrs. Pollution Control Technologies for the determination of the macro-chemical composition of the water for domestic purposes.

The groundwater classifies as:

- Domestic use: Class 4  
Dangerous water quality

6.1.2 Borehole Kham 2 (Target Area 1)

Drilling results

The borehole was drilled to a depth of 78 m by Messrs. Drilling Africa Trust on 6/7 May 2003.

The borehole was drilled to a diameter of 205 mm to a depth of 15 m, after which the borehole was drilled to a diameter of 165 mm. Solid steel casing, with an outside diameter of 178 mm and a sidewall thickness of 4 mm, was installed from the surface to a depth of 15 m. The borehole was not developed (cased) as a production borehole due to the chemical quality of the water.

Groundwater seepage occurred at a depth of 41 m and 68 m. A total estimated blow yield of 5.0 L/s was reported.

A sanitary seal with a concrete collar was installed, and the borehole capped with a steel lid.

**Yield characteristics**  
The yield characteristics of this borehole were not tested due to the chemical quality of the water. The static groundwater level was located at a depth of 9.38 m below the top of the casing.

**Groundwater quality**

A groundwater sample was taken and submitted to Messrs. Pollution Control Technologies for the determination of the macro-chemical composition of the water for domestic purposes.

The groundwater classifies as:

- Domestic use: Class 3 Poor water quality – unsuitable for use without treatment

**6.1.3 Borehole KHAM 3 (Target Area 1)**

**Drilling results**

The borehole was drilled to a depth of 86 m by Messrs. Drilling Africa Trust on 8/9 May 2003.

The borehole was drilled to a diameter of 205 mm to a depth of 11 m, after which the borehole was drilled to a diameter of 165 mm. Solid steel casing, with an outside diameter of 178 mm and a sidewall thickness of 4 mm, was installed from the surface to a depth of 11 m.  
Groundwater seepage occurred at a depth of 68 m. A total estimated blow yield of 1.67 l/s was reported.

A sanitary seal with a concrete collar was installed, and the borehole capped with a steel lid.

**Yield characteristics**

The yield characteristics of this borehole were not tested. The static groundwater level was located at a depth of 8.07 m below the top of the casing.

**Groundwater quality**

A groundwater sample was taken and submitted to Messrs. Pollution Control Technologies for the determination of the macro-chemical composition of the water for domestic purposes.

The groundwater classifies as:

- Domestic use: Class 3 Poor water quality – unsuitable for use without treatment

**6.1.4 Borehole KHAM 4 (Target Area 2)**

**Drilling results**

The borehole was drilled to a depth of 101 m by Messrs. Drilling Africa Trust on 22/23 May 2003.

The borehole was drilled to a diameter of 205 mm to a depth of 24 m, after which the borehole was drilled to a diameter of 165 mm. Solid steel casing, with an outside diameter of 178 mm and a sidewall thickness of 4 mm, was installed from the surface to a depth of 24 m.

Groundwater seepage occurred at a depth of 28 m. A total estimated blow yield of 1.4 L/s was reported. A sanitary seal with a concrete collar was installed, and the borehole capped with a steel lid.

#### Yield characteristics

The yield characteristics of this borehole were not tested. The static groundwater level was located at a depth of 8.39 m below the casing.

#### Groundwater quality

A groundwater sample was taken and was submitted to Messrs. Pollution Control Technologies for the determination of the macro-chemical composition of the water for domestic purposes.

The groundwater classifies as:

- Domestic use: Class 3 Poor water quality – unsuitable for use without treatment

### 6.1.5 Borehole KHAM 5 (Target Area 2)

#### Drilling results

The borehole was drilled to a depth of 78 m by Messrs. Drilling Africa Trust on 23/24 May 2003.

The borehole was drilled to a diameter of 256 mm to a depth of 6 m, 205 mm to a depth of 18 m after which the borehole was drilled to a diameter of 165 mm. Solid steel casing, with an outside diameter of 178 mm and a sidewall thickness of 4 mm, was installed from the surface to a depth of 18 m.

Groundwater seepage occurred at a depth of 58 m. A total estimated blow yield of 0.28 L/s was reported.

A sanitary seal with a concrete collar was installed, and the borehole capped with a steel lid.

#### Yield characteristics

The yield characteristics of this borehole were not tested. The static groundwater level was located at a depth of 4.57 m below the casing.

#### Groundwater quality

A groundwater sample was taken and was submitted to Messrs. Pollution Control Technologies for the determination of the macro-chemical composition of the water for domestic purposes.

The groundwater classifies as:

- Domestic use: Class 4 Dangerous water quality

6.1.6 Borehole KHAM 6 (Target Area 2)

**Drilling results**

The borehole was completed to a depth of 58 m by Messrs. Drilling Africa Trust on 7/8 July 2003.

The borehole was drilled to a diameter of 256 mm to a depth of 6 m, after which the borehole was drilled to a diameter of 205 mm and a sidewall thickness of 6 mm, was installed from the surface to a depth of 6 m. Solid U-pvc casing, with an inner diameter of 144 mm and a sidewall thickness of 8 mm, was installed from the surface to a depth of 43 m. Perforated U-pvc casing, with an inner diameter of 144 mm and a sidewall thickness of 8 mm, was installed from a 43 m up to a depth of 58 m.

Groundwater seepage occurred at a depth of 48 m. A total estimated blow yield of 3.3 L/s was reported. A sanitary seal with a concrete collar, as well as a gravel pack, was installed, and the borehole capped with a steel lid.

**Yield characteristics**

The yield characteristics of this borehole were tested by means of a stepped discharge-, constant discharge- and recovery test conducted in the period between 21 and 26 July 2003.

The static groundwater level was located at a depth of 5.48 m below the datum level<sup>4</sup> at the time of testing. The test pump was placed at a depth of 52.5 m below the datum level, with a total borehole depth of 60.0 m being recorded.

- **Stepped discharge test**

This test comprised two 60-minute steps conducted at yields of 1.03 and 1.83 L/s respectively. A maximum drawdown of 27.4 m was achieved during the test.

- **Constant discharge test**

This test was conducted at an average yield of 1.4 L/s for a period of 72 hours (4320 minutes). A maximum drawdown of 25.22 m was achieved during the test, which translates to approximately 55.6 percent of the available drawdown.

- **Recovery test**

The groundwater level recovered to 99.6 % of its original level after a period of 30 hours (1 800 minutes).

**Groundwater quality**

A groundwater sample was taken and was submitted to Messrs. Pollution Control Technologies for the determination of the macro-chemical composition of the water for domestic purposes.

The groundwater classifies as:

- Domestic use: Class 2
- Water of marginal quality

<sup>4</sup> Taken as a distance of 0.40 m above the ground surface.

## 6.1.7 Borehole KHAM 7 (Target Area 2)

### Drilling results

The borehole was drilled to a depth of 78 m by Messrs. Drilling Africa Trust on 9/10 July 2003.

The borehole was drilled to a diameter of 205 mm to a depth of 6 m, after which the borehole was drilled to a diameter of 165 mm. Solid steel casing, with an inside diameter of 205 mm and a sidewall thickness of 6 mm, was installed from the surface to a depth of 6 m. Solid U-pvc casing, with an inside diameter of 144 mm and a sidewall thickness of 2 mm, was installed from the surface to a depth of 50 m. Perforated U-pvc casing, with a diameter of 144 mm and a sidewall thickness of 3 mm, was installed from a 50 m up to a depth of 62 m

Groundwater seepage occurred at a depth of 58 m. A total estimated blow yield of 3.3 L/s was reported. A sanitary seal with a concrete collar, as well as a gravel pack, was installed, and the borehole capped with a steel lid.

### Yield characteristics

The yield characteristics of this borehole were not tested. The static groundwater level was located at a depth of 8.47 m.

### Groundwater quality

No groundwater sample was taken.

## 7. CONCLUSIONS AND RECOMMENDATIONS

In the light of the results of the hydrogeological study that was conducted in the vicinity of the development, the following recommendations can be made:

The recharge in the area is estimated to be 4.3% of MAP.

Existing boreholes Bh7, Bh9 and Bh11 have good quality water (Class 2). The recommended abstraction for these boreholes is 17.28, 25.92 and 30.24 m<sup>3</sup>/d respectively. Borehole Bh7 supplies the three existing houses on the development. There is no scope for additional abstraction in the area surrounding this borehole. Borehole Bh9 is currently in use by the reservation at a rate of 10.8 m<sup>3</sup>/d. There is thus spare capacity and further exploration is possible in the general area of boreholes Bh9 and Bh11. This area is however far from the proposed development.

The study has shown that approximately 64.8 m<sup>3</sup>/d of groundwater can be safely abstracted from the newly drilled borehole (Kham 6) in Target Area 2 which is deemed to be adequate to supply in the initial needs of the development. The catchment for Target Area 2 was calculated to be ~1.916 km<sup>2</sup> resulting in potential annual recharge of 0.074 Mm<sup>3</sup>/a or 203.26 m<sup>3</sup>/d. Kham 6 is recommended for abstraction at a rate of 0.75 l/s for a 24 hour pumping period. This ensures an adequate supply for 54 plots.

The water quality of the boreholes drilled in Target Area 1 proved to be unsuitable for human consumption over an extended period. Treatment of this water is an option. The equipment of borehole Kham2 is however recommended. This water can be utilized in the construction of the roads, houses etc. This would help to alleviate stress on the fresh water source in Target Area 2.

Sodium and chloride ions dominate the composition of the waters with other ions generally at low to very low concentrations.

The pH is usually in the neutral range (6.7 – 8.0).

The water is characterized by a median electrical conductivity in the 390 – 420 mS/m range. The conductivity for the recommended boreholes lie within the maximum acceptable limit for town supply (300 mS/m).

Either of the following two options is recommended for implementation during the establishment of a monitoring programme to evaluate groundwater levels and abstraction rates at borehole Kham 6:

Option A: Installation of an automatic (permanent) water level recorder, with data being collected on a six monthly basis by Ad Geo Consultants

Option B: Manual measurement of the groundwater levels to be conducted on a weekly basis

## 8. BIBLIOGRAPHY

- BELL, P. and WRIGHT, D., 1985. Rock and minerals. *Hamlyn Practical Guide*, Hamlyn Publishing, England.
- MIDDLEY, D C, PITMAN, W V and MIDDLETON, B J, 1994. *Surface water resources of South Africa 1990, Book of Maps*. Water Research Commission report number 298/1.2/94.
- SOUTH AFRICAN COMMITTEE FOR STRATIGRAPHY (SACS), 1980. Stratigraphy of South Africa. Part 1 (Comp. L E Kent). Lithostratigraphy of the Republic of South Africa, South West Africa/Namibia, and the Republics of Bophuthatswana, Transkei and Venda. *Handbook of the Geological Survey of South Africa*, No. 8, Government Printer, Pretoria.
- THE DEPARTMENT OF WATER AFFAIRS AND FORESTRY, 1997. *Minimum standards and guidelines for groundwater resource development for the Community Water*.
- THE DEPARTMENT OF WATER AFFAIRS AND FORESTRY, THE DEPARTMENT OF HEALTH, and THE WATER RESEARCH COMMISSION, 1998. *Quality of domestic water supplies Volume 1: Assessment Guide*. Second Edition.
- VISSER, D J L, 1989. *Toelgting tot die 1:1000000 Geologiese Kaart - vierde uitgawe, 1984: Die geologie van die Republieke van Suid-Afrika, Transkei en Bophuthatswana, Venda en Ciskei, en die Koninkryke van Lesotho en Swaziland*. The Government Printer, Pretoria.
- XU, Y and BRAUNE, E, 1995. *A guideline for groundwater protection for the Community Water Supply and Sanitation Programme*. The Department of Water Affairs and Forestry, Pretoria.

Detailed hydrocensus results

APPENDIX A

HYDRO CENSUS RESULTS

Installation no	Comment	Photo no	Latitude			Longitude			Elevation	Equipment	Yield	Quality Class	EC	Ph	Temp	Bh depth	Comment
			Dec	Min	Sec	Dec	Min	Sec									
Bh1	Existing Bh	355	32	49	52.74	28	6	26.82	17	Submersible pump						Pump located in small room behind house. Supply water to holiday resort.	
Bh2	Existing Bh	356	32	50	38.94	28	6	54.54	36	Mono pump						Borehole located in open area. Supply water to holiday resort.	
Bh3	Existing Bh	357	32	50	43.32	28	6	56.64	47	Submersible pump						Pump located next to house (drain cover over). Supply water to holiday resort.	
Bh4 (2)	Existing Bh	358	32	50	33.66	28	6	57.12	47	Submersible pump	2	84	8.84			40 George's Property	
Bh5	Existing Bh	359	32	50	49.38	28	6	43.5	47	Open	0.42	165	8.25			40 Kent's place - Caravan park	
Bh6	Existing Bh	360	32	50	51.72	28	6	55.56	36	Borehole collapsed	0.22					110 Kent place - Caravan park	
Bh7 (2)	Existing Bh	361	32	51	1.5	28	6	59.1	33	Submersible pump	0.19	2	122	8.24		100 Allan Mosh	
Bh8	Existing Bh		32	50	48.86	28	6	18.14	99	Dry bh	0.00					110 Allan Mosh	
Bh9 (2)	Existing Bh		32	50	12.08	28	4	34.44	98	Submersible pump		2	133	8.21		110 Game reserve	
Bh10	Existing Bh		32	50	13.74	28	4	34.74	93	Borehole blocked with stones						Game reserve	
Bh11	Existing Bh	363	32	50	13.74	28	4	34.74	89	Old mono pump						Game reserve - Borehole not in use	
Bh12	Existing Bh	364	32	50	13.74	28	4	34.56	88	Open borehole - old pumphouse						Game reserve - Borehole not in use	
Bh13	Existing Bh	365	32	50	20.94	28	5	22.26	86	Submersible pump						Game reserve - Borehole not in use	
Bh14	Existing Bh	366	32	50	20.58	28	5	18.24	86	Open borehole						V/d Bank	
Bh15	Existing Bh	367	32	50	29.82	28	5	23.04	95	Mono pump 3 pipe						100 V/d Bank	
Bh16	Existing Bh	368	32	51	33.18	28	5	13.8	95	Submersible pump		161	8.19			Next to soil dam	
Bh17	Existing Bh	369	32	51	46.38	28	5	17.46	100	Mono pump						Graham	
Bh18	Existing Bh	370	32	52	24.84	28	2	35.7	118	Submersible pump	4.44	558	8.31			New borehole (water strike at 50, 65 and 85-118 90m)	
Bh19	Existing Bh	371	32	53	2.22	28	3	31.8	87	Mono		453	7.99			120 Strong borehole	
Bh20	Existing Bh	372	32	51	16.38	28	6	5.64	37	Open borehole						80	
Bh21	Existing Bh		32	50	40.6	28	6	41.3		Submersible pump	0.25	510	6.9			100 Old windmill north of Trevors place	
Bh22	Existing Bh		32	50	43.1	28	6	47.5		Submersible pump	0.13	142	7.37			80 Near Trevor's house. Just above dam	
Weir	Stream abstraction		32	50	8.2	28	6	46.3		Weir abstraction point		160	7.9			Backpacker camp water source	
KHAM1	New Bh	395	32	51	21.3	28	6	13.6		Open	1.39	4	423	7.29		78	
KHAM2	New Bh	394	32	51	11.1	28	6	0.9		Open	5.00	3	435	7.05		78	
KHAM3	New Bh	393	32	51	8	28	5	59.6		Open	1.67	3	392	6.93		86	
KHAM4	New Bh	396	32	50	21.1	28	6	49.2		Open	1.39	2	120	7.95		101	
KHAM5	New Bh	397	32	50	16.1	28	6	48.4		Open	0.28	3	247	7.89		78	
KHAM6	New Bh	398	32	50	1.19	28	6	50.4		Open	3.33	1	96	7.75		60 Production borehole	
KHAM7	New Bh		32	50	29.8	28	6	54.1		Open	3.33	108	7.85			62 Monitoring borehole	


RH = 7




BH9




BH7



BH6




BH5




BH4




BH3




BH2




BH1




Bh18




Bh17




Bh16




Bh15




Bh14




Bh13




Bh12




Bh11




Kham6



Kham5




Kham4



Kham3




Kham2




Kham1



Bh20



Bh19




Dunes



Fractures in dune rock



Fractures in dune rock



Kham7



Weir

Pump test results

APPENDIX B



AD Geo Consultants cc

### BOREHOLE TEST RECORD

CONSULTANT: AD GEO CONSULTANTS CC  
 DISTRICT: AMATOLA  
 PROVINCE: EASTERN CAPE  
 SITE NAME: KHAMANGA BAY DEVELOPMENT - ALLAN MOSS  
 PROJECT NO. KHAMANGA BAY  
 DATE TESTED: 25/6/2003

MAP REFERENCE: 3228CC

CO-ORDINATES:

LATITUDE: 32 51' 01.5"  
 LONGITUDE: 28 06' 59.1"

BOREHOLE NO.:

Bh 7  
 Monitor 1:  
 Monitor 2:

TRANSMISSIVITY VALUE:

EXIST B/H

BOREHOLE DEPTH: (mbgl)

104.00

BOREHOLE DEPTH: 104.00  
 WATER LEVEL (mbgl): 7.08  
 CASING HEIGHT (magl): 0  
 DATUM LEVEL ABOVE CASING (m): 0.37  
 DEPTH OF PUMP(m): 67  
 Diam pump inlet (mm): 132  
 EXISTING PUMPTYPE: Submersible Pump  
 CONTRACTORS: KHAMANGA  
 TEST PUMP TYPE: BP77H

COMMENTS:

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

DESCRIPTION:	UNIT	QTY	UNIT	QTY
STRAIGHTNESS TEST:	NO	0	NO	0
VERTICALLY TEST:	NO	0	M	0
CASING DETECTION:	NO	0	YES/NO	0
STEEL BOREHOLE COVER:	NO	0	NO	0
BOREHOLE MARKING	NO	0	NO	0
SITE CLEANING & FINISHING	NO	0	M	0

**FORM 5 E  
STEP DISCHARGE TEST & RECOVERY**

**BOREHOLE TEST RECORD SHEET**

PROJ NO: KHAMANGA BAY	MAP REFERENCE: 3228CC	PROVINCE: EASTERN CAPE
BOREHOLE NO: Bh 7	CO-ORDINATES: LATITUDE: 32 54' 01.5" LONGITUDE: 28 06' 59.1"	DISTRICT: AMATOLA
ALTBH NO: 0	SITE NAME: KHAMANGA BAY DEVELOPMENT - ALLAN MOSS	EXISTING PUMP: Submersible Pump
WATER LEVEL (mbgl): 7.08	CASING HEIGHT (magl): 0	CONTRACTOR: KHAMANGA
BOREHOLE DEPTH (m): 104.00	DATUM LEVEL ABOVE CASING (m): 0.37	TEST PUMP TYPE: BPT7H

DISCHARGE RATE 1	DISCHARGE RATE 2	DISCHARGE RATE 3
RPM	RPM	RPM

DATE:	TIME:	TIME:	DATE:	TIME:	DATE:	TIME:
25/6/2003	10:30	-	-	-	-	-
TIME	YIELD	DOWN (M)	TIME	YIELD	DOWN (M)	TIME
RECOVERY	(M)	(MIN)	RECOVERY	(M)	(MIN)	RECOVERY
1	1.28	1	1	25.60	1	1
2	3.44	2	2	29.84	2	2
3	5.84	3	3	32.80	3	3
5	7.20	5	5	36.64	5	5
7	7.76	7	7	39.36	7	7
10	8.24	10	10	42.08	10	10
15	8.88	15	15	44.80	15	15
20	10.16	20	20	46.32	20	20
30	13.28	30	30	48.72	30	30
40	16.64	40	40	51.28	40	40
50	17.84	50	50	54.00	50	50
60	18.56	60	60	56.88	60	60
70		70	70	59.92	70	70
80		80	80	59.92	80	80
90		90	90	59.92	90	90
100		100	100	0.31	100	100
110		110	110		110	110
AVERAGE YIELD	0.25	AVERAGE YIELD	0.49			
PH	-	PH	-			
TEMP (c)	-	TEMP (c)	-			
EC (ms/cm)	-	EC (ms/cm)	-			
DISCHARGE RATE 4	DISCHARGE RATE 5	DISCHARGE RATE 6				
RPM	RPM	RPM				
DATE:	DATE:	DATE:				
TIME:	TIME:	TIME:				
RECOVERY	RECOVERY	RECOVERY				
(M)	(M)	(M)				
DOWN (M)	DOWN (M)	DOWN (M)				
(US)	(US)	(US)				
YIELD	YIELD	YIELD				
DRAW	DRAW	DRAW				
TIME	TIME	TIME				
(MIN)	(MIN)	(MIN)				


DATE:	TIME:	DATE:	TIME:	DATE:	TIME:
25/6/2003	10:30	25/6/2003	10:30	25/6/2003	10:30
TIME	YIELD	TIME	YIELD	TIME	YIELD
RECOVERY	(M)	RECOVERY	(M)	RECOVERY	(M)
1	1.28	1	25.60	1	1
2	3.44	2	29.84	2	2
3	5.84	3	32.80	3	3
5	7.20	5	36.64	5	5
7	7.76	7	39.36	7	7
10	8.24	10	42.08	10	10
15	8.88	15	44.80	15	15
20	10.16	20	46.32	20	20
30	13.28	30	48.72	30	30
40	16.64	40	51.28	40	40
50	17.84	50	54.00	50	50
60	18.56	60	56.88	60	60
70		70	59.92	70	70
80		80	59.92	80	80
90		90	59.92	90	90
100		100	0.31	100	100
110		110		110	110
AVERAGE YIELD	0.25	AVERAGE YIELD	0.49		
PH	-	PH	-		
TEMP (c)	-	TEMP (c)	-		
EC (ms/cm)	-	EC (ms/cm)	-		
DISCHARGE RATE 4	DISCHARGE RATE 5	DISCHARGE RATE 6			
RPM	RPM	RPM			
DATE:	DATE:	DATE:			
TIME:	TIME:	TIME:			
RECOVERY	RECOVERY	RECOVERY			
(M)	(M)	(M)			
DOWN (M)	DOWN (M)	DOWN (M)			
(US)	(US)	(US)			
YIELD	YIELD	YIELD			
DRAW	DRAW	DRAW			
TIME	TIME	TIME			
(MIN)	(MIN)	(MIN)			

Comments: During the recovery test two water strikes was identified 1) 25.88m and 2) 47.14 m


**STEP & CONSTANT DISCHARGE TEST GRAPHICS**

PROJ NO : KHAMANGA BAY	MAP REFERENCE: 3228CC	PROVINCE: EASTERN CAPE
BORHOLE NO: B4 7	CO-ORDINATES: LATITUDE 32 51' 01.5" LONGITUDE 28 06' 59.1"	DISTRICT: AMATOLA
ALT BH NO: 0		SITE NAME: KHAMANGA BAY
ALT BH NO: 0		EXIST BH
BORHOLE DEPTH (m): 104.00	DATUM LEVEL ABOVE CASING (m): 0.37	EXISTING PUMP: CONTRACTOR: BP77H
WATER LEVEL (mbgl): 7.08	CASING HEIGHT (mm): 67.00	PUMP TYPE:
DEPTH OF PUMP (m):		

**STEPPED DISCHARGE TEST & RECOVERY**



**CONSTANT DISCHARGE TEST & RECOVERY**



**COMMENTS**

Tel: (043) 748 2723; Fax: (043) 748 2723  
 5 High Field road, Beacon Bay, 5205  
 E-mail: adgeoconsul@telkomsa.



AD Geo Consultants cc

## BOREHOLE TEST RECORD

CONSULTANT: AD GEO CONSULTANTS CC  
 DISTRICT: AMATOLA  
 PROVINCE: EASTERN CAPE  
 SITE NAME: KHAMANGA BAY DEVELOPMENT - GAME PARK  
 PROJECT NO: KHAMANGA BAY  
 DATE TESTED: \_\_\_\_\_  
 MAP REFERENCE: 3228CC  
 CO-ORDINATES:  
 LATITUDE: 32 50' 12.06"  
 LONGITUDE: 28 04' 33.12"  
 BOREHOLE NO: Bh 9  
 TRANSMISSIVITY VALUE: \_\_\_\_\_  
 TYPE INSTALLATION: EXIST B/H  
 BOREHOLE DEPTH: (m) 105 m

BOREHOLE DEPTH: 115  
 WATER LEVEL (m): 32.49  
 CASING HEIGHT (m): 0.2  
 DATUM LEVEL ABOVE CASING (m): 0.41  
 DEPTH OF PUMP (m): 89.8  
 Diam pump inlet (mm): 132  
 EXISTING PUMPTYPE: Submersible Pump  
 CONTRACTORS: KHAMANGA  
 TEST PUMP TYPE: BP16H

COMMENTS:  
 4 Boreholes drilled with in a area of 400 m.  
 Bh 9 - Equipped with submersible pump (supply water to reception / restaurant building)  
 Bh 10 - Newly drilled borehole (never been equipped - filled with rocks)  
 Bh 11 - Old borehole equipped with an old mono pump (borehole was used for tomato package plant - not in use)  
 Bh 12 - Old borehole - filled with rocks and old pipes

DESCRIPTION:	UNIT	QTY	UNIT	QTY
STRAIGHTNESS TEST:	NO	0	NO	0
VERTICALLY TEST:	NO	0	NO	0
CASING DETECTION:	NO	0	NO	0
STEEL BOREHOLE COVER:	NO	0	NO	0
BOREHOLE MARKING	NO	0	NO	0
SITE CLEANING & FINISHING	NO	0	NO	0
	UNIT	QTY	UNIT	QTY
	M	0	M	0
BOREHOLE DEPTH AFTER TEST:				
BOREHOLE WATER LEVEL AFTER TEST:	M	0	M	0
SAND/GRAVEL/SILT PUMPED?	YES/NO	0	YES/NO	0
DATA REPORTING AND RECORDING	NO	0	NO	0
SLUG TEST:	NO	0	NO	0
LAYFLAT (M):	M	0	M	0




**CONSTANT DISCHARGE TEST & RECOVERY**

CONSTANT DISCHARGE TEST & RECOVERY											
PROJ NO:	KHAMANGA BAY		MAP REFERENCE:	3228CC		PROVINCE:	EASTERN CAPE		DISTRICT:	AMATOLA	
MONITOR BH NO:	Bh 11		LATITUDE:	32 50' 12.06"		LONGITUDE:	28 04' 33.12"		SITE NAME:	KHAMANGA BAY DEVELOPMENT - GAME PARK	
BOREHOLE NO:	Bh 9		CO-ORDINATES:			EXISTING PUMP:	Submersible Pump		CONTRACTOR:	KHAMANGA	
BOREHOLE DEPTH:	115.00		DATUM LEVEL ABOVE CASING (m):	0.41		PUMP TYPE:	BP16H		DEPTH OF PUMP (m):	89.80	
WATER LEVEL (mbgl):	32.49		CASING HEIGHT (magl):	0.20		DIA M PUMP INLET (mm):	132.00		TEST STARTED	DATE:	
DATE:			TEST COMPLETED	DURATION:		DATE:			TEST STARTED	DATE:	
AND OBSERVATION HOLES IN M:	OBSERVATION HOLE 1		NR:	Bh 11		NR:	Bh 10		NR:	Bh 12	
DISTANCE BETWEEN DISCHARGE:	OBSERVATION HOLE 2		NR:	Bh 11		NR:	Bh 10		NR:	Bh 12	
DISTANCE:	-		DISTANCE:	38.55		DISTANCE:	-		DISTANCE:	-	
TIME (MIN)	DOWN (M)	DRAW (M)	YIELD (L/S)	TIME	RECOVERY	TIME (MIN)	DOWN (M)	DRAW (M)	RECOVERY	TIME (MIN)	DRAW (M)
1	2.21	19.8	1	0	19.8	1	0	1	0	1	0
2	3.66	18	2	0	18	2	0	2	0	2	0
3	4.56	16.1	3	0	16.1	3	0	3	0	3	0
5	5.94	13.6	5	0	13.6	5	0	5	0	5	0
7	6.93	12.6	7	0	12.6	7	0	7	0	7	0
10	7.85	11.2	10	0	11.2	10	0	10	0	10	0
15	9.54	9.9	15	0	9.9	15	0	15	0	15	0
20	10.46	9.1	20	0.50	9.1	20	0	20	0.50	20	0
30	12.49	8.35	30		8.35	30	0	30		30	0
40	13.29	8.05	40		8.05	40	0.021	40		40	0.021
50	13.63	7.7	50		7.7	50	0.021	50		50	0.021
60	14.00	7.45	60		7.45	60	0.021	60		60	0.021
70	14.55	7.22	70		7.22	70	0.021	70		70	0.021
80	15.67	7.1	80		7.1	80	0.028	80		80	0.028
90	16.78	6.82	90		6.82	90	0.032	90		90	0.032
100	17.31	6.63	100		6.63	100	0.033	100		100	0.033
110	17.85	6.44	110		6.44	110	0.039	110		110	0.039
120	18.46	6.23	120		6.23	120	0.04	120		120	0.04
150	19.00	5.77	150		5.77	150	0.041	150		150	0.041
180	19.74	5.4	180		5.4	180	0.043	180		180	0.043
210	20.12	5.4	210		5.4	210	0.049	210		210	0.049
240	20.22	4.93	240		4.93	240	0.05	240		240	0.05
300	20.53	4.59	300		4.59	300	0.058	300		300	0.058
360	20.63	4.23	360		4.23	360	0.059	360		360	0.059
420	20.71	4.06	420		4.06	420	0.061	420		420	0.061
480	20.81	3.83	480		3.83	480	0.072	480		480	0.072
540	20.91	2.96	540	0.50	2.96	540	0.079	540	0.50	540	0.079
600	21.00	2.19	600		2.19	600	0.089	600		600	0.089
720	21.15	1.35	720		1.35	720	0.085	720		720	0.085
840	21.33	0.85	840		0.85	840	0.09	840		840	0.09
960	21.45	0.95	960		0.95	960	0.095	960		960	0.095
1080	21.65	0.1	1080		0.1	1080	0.1	1080		1080	0.1
1200	21.70	0.105	1200		0.105	1200	0.105	1200		1200	0.105
1320	22.00	0.11	1320		0.11	1320	0.11	1320		1320	0.11
1440	22.15	0.12	1440		0.12	1440	0.12	1440		1440	0.12
2880	22.53	0.125	2880		0.125	2880	0.125	2880		2880	0.125
3360	22.63	0.13	3360		0.13	3360	0.13	3360		3360	0.13
3600	22.70	0.135	3600		0.135	3600	0.135	3600		3600	0.135
3840	22.75	0.14	3840		0.14	3840	0.14	3840		3840	0.14
4080	22.80	0.14	4080		0.14	4080	0.14	4080		4080	0.14
4320	23.15	0.14	4320		0.14	4320	0.14	4320		4320	0.14
4320	23.25	0.15	4320		0.15	4320	0.15	4320		4320	0.15
4200		0.15	4200		0.15	4200	0.15	4200		4200	0.15
4320			4320			4320		4320		4320	
Total time pumped (min):			4320	W/L			12.69	W/L			4320
Average yield (l/s):			0.51	W/L				W/L			

STEP & CONSTANT DISCHARGE TEST GRAPHICS

PROJ NO: KHAMANGA BAY	MAP REFERENCE: 3228CC	PROVINCE: EASTERN CAPE
BOREHOLE NO: B49	CO-ORDINATES: 32 50' 12.05"	DISTRICT: AMATOLA
MONITOR BH NO: B411	LATITUDE: 28 04' 33.12"	SITE NAME: KHAMANGA BAY
MONITOR BH NO: B412	LONGITUDE: 32 50' 12.05"	EXISTING PUMP: EXIST BH
BOREHOLE DEPTH (m): 105 m	DATUM LEVEL ABOVE CASING (m): 0.20	CONTRACTOR: KHAMANGA
WATER LEVEL (m): 8.85	CASING HEIGHT (m): 180.00	PUMP TYPE: BP16H
DEPTH OF PUMP (m): 38.16	DIAM PUMP INLET (mm):	

STEPPED DISCHARGE TEST & RECOVERY




DISCHARGE RATES (Q)

Q1 = 0.39 l/s  
 Q2 = 0.54 l/s  
 Q3 = - l/s  
 Q4 = - l/s  
 Q5 = - l/s

SWL = 8.85 m.b.g.l.

■ = Drawdown data  
 ○ = Recovery data

CONSTANT DISCHARGE TEST & RECOVERY



Abstraction

Q = 0.5 l/s  
 T = 0.48 m<sup>2</sup>/day  
 SWL = 8.85 m.b.g.l.

Class 2 water

778 m<sup>3</sup>/month  
 26 m<sup>3</sup>/day

■ = Drawdown data  
 - = Recovery data  
 = Monitor bore data

COMMENTS



### BOREHOLE TEST RECORD

CONSULTANT: AD GEO CONSULTANTS CC  
 DISTRICT: AMATOLA  
 PROVINCE: EASTERN CAPE  
 SITE NAME: KHAMANGA BAY DEVELOPMENT - GAME PARK  
 PROJECT NO: KHAMANGA BAY  
 DATE TESTED: 8/6/2003

MAP REFERENCE: 3228CC  
 CO-ORDINATES:

LATITUDE: 32 50' 13.7"  
 LONGITUDE: 28 04' 34.7"  
 BOREHOLE NO: Bh 11  
 TRANSMISSIVITY VALUE: Monitor 1: Bh 9  
 TYPE INSTALLATION: Monitor 2: Bh 10 / 12

EXIST B/H: \_\_\_\_\_  
 BOREHOLE DEPTH: (mbgl) 64.9 m

BOREHOLE DEPTH: 64.9  
 WATER LEVEL (mbgl): 13.14  
 CASING HEIGHT (magl): 0  
 DATUM LEVEL ABOVE CASING (m): 0.28  
 DEPTH OF PUMP(m): 53  
 Diam pump inlet (mm): 132  
 EXISTING PUMPTYPE: OPEN  
 CONTRACTORS: KHAMANGA  
 TEST PUMP TYPE: BP16H

COMMENTS:  
 4 Boreholes drilled with in an area of 400 m.  
 Bh 9 - Equipped with a submersible pump (supply water to reception / restaurant building)  
 Bh 10 - Newly drilled borehole (never been equipped - filled with rocks)  
 Bh 11 - Old borehole equipped with old mono pump (borehole was used for tomato package plant - not in use)  
 Bh 12 - Old borehole - filled with rocks and old pipes

DESCRIPTION:	UNIT	QTY	UNIT
STRAIGHTNESS TEST:	NO	0	M
VERTICALLY TEST:	NO	0	M
CASING DETECTION:	NO	0	YES/NO
STEEL BOREHOLE COVER:	NO	0	NO
BOREHOLE MARKING	NO	0	NO
SITE CLEANING & FINISHING	NO	0	M

**FORM 5 E  
STEP DISCHARGE TEST & RECOVERY  
BOREHOLE TEST RECORD SHEET**

PROJ NO :	KHAMANGA BAY	MAP REFERENCE:	3228CC	PROVINCE:	EASTERN CAPE
BOREHOLE NO:	Bh 11	CO-ORDINATES:	32 50' 13.7"	DISTRICT:	AMATOLA
MONITOR HOLE:	Bh 9	LATITUDE	28 04' 34.7"	SITE NAME:	KHAMANGA BAY DEVELOPMENT - GAME PARK
MONITOR HOLE:	Bh 10 / 12	LONGITUDE:		EXISTING PUMP:	OPEN
BOREHOLE DEPTH (m)	64.90	DATUM LEVEL ABOVE CASING (m):	0.28	CONTRACTOR:	KHAMANGA
WATER LEVEL (m):	13.14	CASING HEIGHT (m):	0	TEST PUMP TYPE:	BP16H
DEPTH OF PUMP (m):	63.00	DIAM PUMP INLET (mm):	132		

**STEPPED DISCHARGE TEST & RECOVERY**

DISCHARGE RATE 1		DISCHARGE RATE 2		DISCHARGE RATE 3	
TIME	YIELD	TIME	YIELD	TIME	YIELD
1	1.06	1	9.95	1	37.24
2	1.93	2	10.55	2	34.13
3	2.47	3	10.90	3	31.09
5	3.25	5	11.20	5	24.51
7	3.87	7	11.43	7	19.30
10	4.60	10	11.75	10	11.67
15	5.49	15	12.10	15	9.00
20	6.13	20	12.55	20	7.89
30	6.85	30	16.13	30	6.37
40	7.20	40	21.20	40	5.00
50	7.37	50	26.30	50	3.80
60	7.70	60	31.25	60	2.96
70	8.25	70	35.55	70	2.45
80	8.50	80	39.86	80	2.10
90	8.70	90	39.86	90	1.81
100	8.80	100	39.86	100	0.65
120	9.00	120	39.86	120	0.00
AVERAGE YIELD	0.52	AVERAGE YIELD	1.83	AVERAGE YIELD	#DIV/0!
pH	-	pH	-	pH	150
TEMP (c)	-	TEMP (c)	-	TEMP (c)	180
EC (ms/cm)	-	EC (ms/cm)	-	EC (ms/cm)	210
DISCHARGE RATE 4		DISCHARGE RATE 5		DISCHARGE RATE 6	
TIME	YIELD	TIME	YIELD	TIME	YIELD
1	1.06	1	9.95	1	37.24
2	1.93	2	10.55	2	34.13
3	2.47	3	10.90	3	31.09
5	3.25	5	11.20	5	24.51
7	3.87	7	11.43	7	19.30
10	4.60	10	11.75	10	11.67
15	5.49	15	12.10	15	9.00
20	6.13	20	12.55	20	7.89
30	6.85	30	16.13	30	6.37
40	7.20	40	21.20	40	5.00
50	7.37	50	26.30	50	3.80
60	7.70	60	31.25	60	2.96
70	8.25	70	35.55	70	2.45
80	8.50	80	39.86	80	2.10
90	8.70	90	39.86	90	1.81
100	8.80	100	39.86	100	0.65
120	9.00	120	39.86	120	0.00
AVERAGE YIELD	0.52	AVERAGE YIELD	1.83	AVERAGE YIELD	#DIV/0!
pH	-	pH	-	pH	150
TEMP (c)	-	TEMP (c)	-	TEMP (c)	180
EC (ms/cm)	-	EC (ms/cm)	-	EC (ms/cm)	210

DISCHARGE RATE 1		DISCHARGE RATE 2		DISCHARGE RATE 3	
TIME	YIELD	TIME	YIELD	TIME	YIELD
1	1.06	1	9.95	1	37.24
2	1.93	2	10.55	2	34.13
3	2.47	3	10.90	3	31.09
5	3.25	5	11.20	5	24.51
7	3.87	7	11.43	7	19.30
10	4.60	10	11.75	10	11.67
15	5.49	15	12.10	15	9.00
20	6.13	20	12.55	20	7.89
30	6.85	30	16.13	30	6.37
40	7.20	40	21.20	40	5.00
50	7.37	50	26.30	50	3.80
60	7.70	60	31.25	60	2.96
70	8.25	70	35.55	70	2.45
80	8.50	80	39.86	80	2.10
90	8.70	90	39.86	90	1.81
100	8.80	100	39.86	100	0.65
120	9.00	120	39.86	120	0.00
AVERAGE YIELD	0.52	AVERAGE YIELD	1.83	AVERAGE YIELD	#DIV/0!
pH	-	pH	-	pH	150
TEMP (c)	-	TEMP (c)	-	TEMP (c)	180
EC (ms/cm)	-	EC (ms/cm)	-	EC (ms/cm)	210

Comments: During the recovery test two water strikes was identified (1) 25.88m and 2) 47.14 m

**CONSTANT DISCHARGE TEST & RECOVERY**

PROJ NO :	KHAMANGA BAY	MAP REFERENCE:	3228CC	PROVINCE:	EASTERN CAPE
BOREHOLE NO:	Bh 11	CO-ORDINATES:		DISTRICT:	AMATOLA
MONITOR BH NO:	Bh 9	LATTITUDE:	32 50' 13.7"	SITE NAME:	KHAMANGA BAY DEVELOPMENT - GAME PARK
MONITOR BH NO:	Bh 10 / 12	LONGITUDE:	28 04' 34.7"	PUMP TYPE:	BP16H
BOREHOLE DEPTH:	64.90	DATUM LEVEL ABOVE CASING (m):	0.28	EXISTING PUMP:	OPEN
WATER LEVEL (m):	13.14	CASING HEIGHT (mag):	0.00	CONTRACTOR:	KHAMANGA
DEPTH OF PUMP (m):	53.80	DAM PUMP INLET (mm):	132.00	PUMP TYPE:	BP16H


<b>TEST STARTED</b>	DATE: 9/6/2003	TIME: 11:30
<b>TEST COMPLETED</b>	DATE:	TIME:
<b>CONSTANT DISCHARGE TEST &amp; RECOVERY</b>	DURATION:	TYPE OF PUMP: BP16H

AND OBSERVATION HOLES IN M:	NR: -	OBSERVATION HOLE 1	NR: -	OBSERVATION HOLE 2	NR: -	OBSERVATION HOLE 3	NR: -
DISTANCE BETWEEN DISCHARGE :							
<b>DISCHARGE BOREHOLE</b>	Distance:		Distance:		Distance:		

TIME (MIN)	DRAW (M)	YIELD (L/S)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	RECOVERY (M)	TIME (MIN)	RECOVERY (M)
------------	----------	-------------	------------	--------------	------------	--------------	------------	--------------	------------	--------------

1	0.89	1	22.33	1		1		1		1
2	1.51	2	22.07	2		2		2		2
3	1.94	3	20.77	3		3		3		3
5	2.65	5	18.22	5		5		5		5
7	3.21	7	15.87	7		7		7		7
10	3.67	10	15.54	10	0.55	10		10		10
15	4.46	15	10.64	15	0.64	15		15		15
20	5.13	20	8.52	20		20		20		20
30	5.93	30	6.13	30	0.66	30		30		30
40	6.25	40	5.2	40		40		40		40
60	6.47	60	4.25	60		60		60		60
90	6.79	90	3.56	90		90		90		90
120	7.00	120	3.12	120		120		120		120
150	7.30	150	2.8	150		150		150		150
180	7.55	180	2.58	180		180		180		180
240	7.55	240	2.41	240		240		240		240
300	7.95	300	2.28	300		300		300		300
360	8.10	360	2.05	360		360		360		360
420	8.40	420	1.91	420		420		420		420
540	8.40	540	1.81	540		540		540		540
600	8.60	600	1.7	600		600		600		600
720	8.77	720	1.73	720		720		720		720
840	9.50	840	1.23	840		840		840		840
960	9.25	960	0.84	960		960		960		960
1080	9.86	1080	0.635	1080		1080		1080		1080
1200	10.50	1200	0.445	1200		1200		1200		1200
1320	11.50	1320	0.153	1320	0.52	1320		1320		1320
1440	11.80	1440	0.08	1440		1440		1440		1440
1560	12.55	1560	0.045	1560		1560		1560		1560
1680	15.25	1680		1680		1680		1680		1680
1800	19.10	1800		1800		1800		1800		1800
1920	20.50	1920		1920		1920		1920		1920
2160	21.90	2160		2160		2160		2160		2160
2400	22.45	2400	0.51	2400		2400		2400		2400
2640	22.53	2640		2640		2640		2640		2640
2880	22.62	2880		2880		2880		2880		2880
3120	22.76	3120		3120		3120		3120		3120
3360	22.82	3360		3360		3360		3360		3360
3600	22.83	3600	0.58	3600		3600		3600		3600
3840	22.95	3840		3840		3840		3840		3840
4080	23.05	4080		4080		4080		4080		4080
4320	23.15	4320		4320		4320		4320		4320
4200		4200		4200		4200		4200		4200
4320		4320		4320		4320		4320		4320
Average yield (l/s):										
4320										
Total time pumped(min):										
4320										
Average yield (l/s):										
0.58										

COMMENTS



Class 2 water

Abstraction 0.3 l/s  
 26 m<sup>3</sup>/day  
 778 m<sup>3</sup>/month


T = 0.48 m<sup>2</sup>/day

S.W.L. = 8.85 m b.g.l.

Q = 0.5 l/s

■ = Drawdown data  
 □ = Recovery data  
 ○ = Monitor borehole data

CONSTANT DISCHARGE TEST & RECOVERY



S.W.L. = 8.85 m b.g.l.

DISCHARGE RATES (Q)

Q1 = 0.39 l/s  
 Q2 = 0.54 l/s  
 Q3 = - l/s  
 Q4 = - l/s  
 Q5 = - l/s

■ = Drawdown data  
 ○ = Recovery data

STEPPED DISCHARGE TEST & RECOVERY

PROJ NO : KHAMANGA BAY	MAP REFERENCE: 3228CC	PROVINCE: EASTERN CAPE
BOREHOLE NO: BH 9	CO-ORDINATES: 32 50' 12.06" LATTITUDE	DISTRICT: AMATOLA
MONITOR BH NO: BH 11	LONGITUDE: 28 04' 33.12"	SITE NAME: KHAMANGA BAY
MONITOR BH NO: BH 12		
BOREHOLE DEPTH (m): 105 m	DATUM LEVEL ABOVE CASING (m): 0.20	EXISTING PUMP: EXIST B/H
WATER LEVEL (m bgl): 8.85	CASING HEIGHT (m): 0.85	CONTRACTOR: KHAMANGA
DEPTH OF PUMP (m): 38.16	DIA PUMP INLET (mm): 180.00	PUMP TYPE: BP16H

STEP & CONSTANT DISCHARGE TEST GRAPHICS



**BOREHOLE TEST RECORD**

CONSULTANT: AD GEO CONSULTANTS CC  
 DISTRICT: AMATOLA  
 PROVINCE: EASTERN CAPE  
 SITE NAME: KHAMANGA BAY DEVELOPMENT - CARAVAN PARK (TREVERS)  
 PROJECT NO: KHAMANGA BAY DEVELOPMENT  
 DATE TESTED: 22/6/2003

MAP REFERENCE: 3228CC  
 CO-ORDINATES:  
 LATITUDE: 32 50' 19.0"  
 LONGITUDE: 28 06' 50.4"  
 BOREHOLE NO: KHAM 6  
 Monitor b/h: KHAM 4  
 Monitor b/h: KHAM 5/7  
 TRANSMISSIVITY VALUE:  
 TYPE INSTALLATION: NEWLY DRILLED BOREHOLE  
 BOREHOLE DEPTH: (mbgl) 60 m

BOREHOLE DEPTH: 60  
 WATER LEVEL (mbgl): 5.48  
 CASING HEIGHT (magl): 0.4  
 DATUM LEVEL ABOVE CASING (m): 0  
 DEPTH OF PUMP(m): 52.5  
 CONTRACTORS: KHAMANGA  
 TEST PUMP TYPE: BP16H  
 EXISTING PUMPTYPE: NEW B/H

COMMENTS:  
 This borehole is located within the dune area 200m from the coast area. Annual rain fall of the area is 900mm. Storage capacity of the fresh water 9600m3.  
 Total of 3 additional boreholes were drilled to monitor the water levels and quality (kham 4, 5 & 7)

DESCRIPTION:	UNIT	QTY	UNIT	QTY
STRAIGHTNESS TEST:	NO	0	M	0
VERTICALLY TEST:	NO	0	M	0
CASING DETECTION:	NO	0	YES/NO	0
STEEL BOREHOLE COVER:	NO	0	NO	0
BOREHOLE MARKING	NO	0	NO	0
SITE CLEANING & FINISHING	NO	0	M	0

# FORM 5 E

## STEP DISCHARGE TEST & RECOVERY

### BOREHOLE TEST RECORD SHEET

PROJ NO :	KHAMANGA BAY	MAP REFERENCE:	3228CC	PROVINCE:	EASTERN CAPE
BOREHOLE NO:	KHAM 6	CO-ORDINATES:	32 50' 19.0"	DISTRICT:	AMATOLA
ALT BH NO:	KHAM 4	LATTITUDE	32 50' 19.0"	SITE NAME:	KHAMANGA BAY DEVELOPMENT - CARAVAN PARK (TREVERS)
ALT BH NO:	0	LONGITUDE:	28 06' 50.4"	EXISTING PUMP:	NEW B/H
BOREHOLE DEPTH (m)	60.00	DATUM LEVEL ABOVE CASING (m):	0	CONTRACTOR:	KHAMANGA
WATER LEVEL (m(bgl)):	5.48	CASING HEIGHT (m(bgl)):	0.4	TEST PUMP TYPE:	BP16H
DEPTH OF PUMP (m):	52.50	DIAM PUMP INLET (mm):	132		

### STEPPED DISCHARGE TEST & RECOVERY

DISCHARGE RATE 1		DISCHARGE RATE 2		DISCHARGE RATE 3	
TIME	YIELD	TIME	YIELD	TIME	YIELD
1	1.18	1	10.08	1	20.72
2	1.95	2	10.25	2	19.29
3	2.55	3	10.40	3	17.94
4	3.58	4	11.00	4	15.30
5	3.58	5	12.05	5	13.58
6	4.38	6	14.55	6	10.91
7	1.00	7	16.52	7	7.29
8	1.06	8	18.57	8	4.86
9	6.59	9	21.68	9	2.88
10	7.53	10	23.55	10	2.18
11	8.57	11	25.50	11	1.79
12	9.18	12	26.13	12	1.52
13	1.04	13	27.40	13	1.25
14	9.81	14	1.83	14	1.16
15	9.65	15	1.83	15	1.05
16	9.81	16	1.83	16	0.80
17	9.81	17	1.83	17	0.57
18	9.81	18	1.83	18	0.45
AVERAGE YIELD	0.99	AVERAGE YIELD	1.83	AVERAGE YIELD	2.40
pH	7.15	pH	7.16	pH	7.16
TEMP (c)	180	TEMP (c)	180	TEMP (c)	180
EC (mS/cm)	118	EC (mS/cm)	121	EC (mS/cm)	120
DISCHARGE RATE 4		DISCHARGE RATE 5		DISCHARGE RATE 6	
TIME	YIELD	TIME	YIELD	TIME	YIELD
1	1.18	1	10.08	1	20.72
2	1.95	2	10.25	2	19.29
3	2.55	3	10.40	3	17.94
4	3.58	4	11.00	4	15.30
5	3.58	5	12.05	5	13.58
6	4.38	6	14.55	6	10.91
7	1.00	7	16.52	7	7.29
8	1.06	8	18.57	8	4.86
9	6.59	9	21.68	9	2.88
10	7.53	10	23.55	10	2.18
11	8.57	11	25.50	11	1.79
12	9.18	12	26.13	12	1.52
13	1.04	13	27.40	13	1.25
14	9.81	14	1.83	14	1.16
15	9.65	15	1.83	15	1.05
16	9.81	16	1.83	16	0.80
17	9.81	17	1.83	17	0.57
18	9.81	18	1.83	18	0.45
AVERAGE YIELD	0.99	AVERAGE YIELD	1.83	AVERAGE YIELD	2.40
pH	7.15	pH	7.16	pH	7.16
TEMP (c)	180	TEMP (c)	180	TEMP (c)	180
EC (mS/cm)	118	EC (mS/cm)	121	EC (mS/cm)	120

DISCHARGE RATE 1		DISCHARGE RATE 2		DISCHARGE RATE 3	
TIME	YIELD	TIME	YIELD	TIME	YIELD
1	1.18	1	10.08	1	20.72
2	1.95	2	10.25	2	19.29
3	2.55	3	10.40	3	17.94
4	3.58	4	11.00	4	15.30
5	3.58	5	12.05	5	13.58
6	4.38	6	14.55	6	10.91
7	1.00	7	16.52	7	7.29
8	1.06	8	18.57	8	4.86
9	6.59	9	21.68	9	2.88
10	7.53	10	23.55	10	2.18
11	8.57	11	25.50	11	1.79
12	9.18	12	26.13	12	1.52
13	1.04	13	27.40	13	1.25
14	9.81	14	1.83	14	1.16
15	9.65	15	1.83	15	1.05
16	9.81	16	1.83	16	0.80
17	9.81	17	1.83	17	0.57
18	9.81	18	1.83	18	0.45
AVERAGE YIELD	0.99	AVERAGE YIELD	1.83	AVERAGE YIELD	2.40
pH	7.15	pH	7.16	pH	7.16
TEMP (c)	180	TEMP (c)	180	TEMP (c)	180
EC (mS/cm)	118	EC (mS/cm)	121	EC (mS/cm)	120

Comments:


**CONSTANT DISCHARGE TEST & RECOVERY**

PROJ NO :	KHAMANGA BAY		MAP REFERENCE:	3228CC		PROVINCE:	EASTERN CAPE		
BORHOLE NO:	KHAM 6		CO-ORDINATES:	LATTITUDE: 32 50' 19.0" LONGITUDE: 28 05' 50.4"		SITE NAME:	KHAMANGA BAY DEVELOPMENT - CARAVAN PARK (TREVERS)		
ALT BH NO:	KHAM 4		DATUM LEVEL ABOVE CASING (m):	0.00		EXISTING PUMP:	NEW BH		
WATER LEVEL (mbgl):	5.48		CASING HEIGHT (magl):	0.40		CONTRACTOR:	KHAMANGA		
DEPTH OF PUMP (m):	52.50		DIAM PUMP INLET (mm):	132.00		PUMP TYPE:	BP16H		
TEST STARTED			TEST COMPLETED			DURATION:			
DATE:	27/06/2008	TIME:		TIME:					
DISTANCE BETWEEN DISCHARGE: OBSERVATION HOLE 1    OBSERVATION HOLE 2    OBSERVATION HOLE 3									
AND OBSERVATION HOLES IN M:    NR: KHAM 4    NR: KHAM 5    NR: KHAM 7									
DISCHARGE BOREHOLE									
TIME	DRAW	YIELD	RECOVERY	RECOVERY	RECOVERY	TIME	RECOVERY	TIME	
(MIN)	DOWN (M)	(L/S)	MIN	(M)	(M)	(MIN)	(M)	(M)	
1	2.29		2	22.33	0.2	3	0.1	5	
2	3.64		2	22.07	0.6	22	0.3	30	
3	4.46		3	20.77	1.3	41	0.67	57	
5	6.30	1.21	5	18.22	0.24	65	1.12	131	
7	7.56		7	15.87	1.96	87	1.35	189	
10	9.13		10	15.54	3.21	126	1.69	264	
15	10.60	1.33	15	10.64	3.75	184	2.86	312	
20	11.85	1.33	20	8.52	4.15	247	2.36	376	
30	13.66		30	6.13	4.49	308	2.57	436	
40	14.77		40	5.2	4.65	373	2.75	493	
60	16.32	1.40	60	4.25	4.56	433	2.84	552	
90	17.08	1.39	90	3.56	4.66	493	2.85	620	
120	18.49	1.39	120	3.12	5.1	551	3.13	671	
180	19.23	1.39	150	2.8	5.27	615	3.16	741	
240	20.26	1.40	180	2.58	5.29	666	3.24	861	
300	20.71	1.40	210	2.41	5.4	736	3.35	982	
600	20.95	1.36	420	1.87	5.8	1213	3.63	1459	
840	21.09	1.42	720	1.23	5.9	1330	3.78	1676	
960	21.25	1.39	960	0.84	6.2	1448	3.87	1699	
1080	21.26	1.43	1200	0.635	6.18	1926	4.05	2061	
1200	21.85	1.39	1440	0.445	6.24	2171	4.21	2312	
1320	22.00	1.43	1680	0.153	6.2	2411	4.2	2541	
1440	22.15	1.41	1920	0.08	6.42	2656	4.15	2781	
1560	22.43	1.42	2160	0.045	6.49	2891	4.34	3011	
1680	22.53	1.39	1810	3272	6.43	3147	4.36	3256	
1800	22.70	1.43	1820	3517	6.48	3377	4.34	3491	
1920	22.98	1.41	1830	3761	6.51	3621	4.4	3736	
2160	23.29	1.42	1840	4006	6.42	3860	4.45	3967	
2400	23.39	1.39	1850	4236	6.65	4101	4.55	1800	
2640	23.48	1.39	1920	4343		4343	4.58	1920	
2880	23.59	1.39	2040			2040		2040	
3120	23.65	1.44	2160			2160		2160	
3360	23.75	1.48	2280			2280		2280	
3600	23.95	1.49	2400			2880		2880	
3840	24.25	1.22	2520			3120		3120	
4080	24.35	1.44	2640			2640		2640	
4320	25.22	1.44	2760			2760		2760	
3121			2880			2880		2880	
4200			4200			4200		4200	
4320			4320			4320		4320	
Total time pumped(min):		4320		W/L		4.57		W/L	
Average yield (l/s):		1.39		W/L		9.18		W/L	
				4320		13.47			

**STEP & CONSTANT DISCHARGE TEST GRAPHICS**


PROJ NO : KHAMANGA BAY	MAP REFERENCE: 32280C	PROVINCE: EASTERN CAPE
BORHOLE NO: KHAM 6	CO-ORDINATES: 32 50' 19.0"	DISTRICT: AMATOLA
MONITOR BH NO: KHAM 4	LATITUDE: 28 06' 50.4"	SITE NAME: KHAMANGA BAY
MONITOR BH NO: KHAM 7, KHAM 5	LONGITUDE: 32 50' 19.0"	
BORHOLE DEPTH (m): 60 m	DATUM LEVEL ABOVE CASING (m): 0.20	EXISTING PUMP: NEWLY DRILLED BORHOLE
WATER LEVEL (m): 8.85	CASING HEIGHT (m): 0.85	CONTRACTOR: KHAMANGA
DEPTH OF PUMP (m): 38.16	DIAM PUMP INLET (mm): 160.00	PUMP TYPE: BPT6H

**STEPPED DISCHARGE TEST & RECOVERY**



■ = Drawdown data  
 ○ = Recovery data  
 DISCHARGE RATES (Q)  
 Q1 = 0.99 l/s  
 Q2 = 1.83 l/s  
 Q3 = 1 l/s  
 Q4 = 1 l/s  
 Q5 = 1 l/s  
 SWL = 8.85 m b.g.l.

**CONSTANT DISCHARGE TEST & RECOVERY**




■ = Drawdown data  
 ○ = Recovery data  
 Q = 1.4 l/s  
 SWL = 8.85 m b.g.l.  
 T = 1 m<sup>2</sup>/day  
 Spec. Cap. = 1 m<sup>2</sup>/day/m

**COMMENTS**


STEP & CONSTANT DISCHARGE TEST GRAPHICS

PROJ NO: KHAMANGA BAY	MAP REFERENCE: 3228CC	PROVINCE: EASTERN CAPE
BOREHOLE NO: KHAM 6	CO-ORDINATES: 32 50' 19.0"	DISTRICT: AMATOLA
MONITOR BH NO: KHAM 4	LATITUDE: 28 05' 50.4"	SITE NAME: KHAMANGA BAY
MONITOR BH NO: KHAM 7, KHAM 5	LONGITUDE: 32 50' 19.0"	
BOREHOLE DEPTH (m): 60 m	DATUM LEVEL ABOVE CASING (m): 0.20	EXISTING PUMP: NEWLY DRILLED BOREHOLE
WATER LEVEL (mgl): 8.85	CASING HEIGHT (mgl): 0.85	CONTRACTOR: KHAMANGA
DEPTH OF PUMP (m): 38.16	DIA PUMP INLET (mm): 180.00	PUMP TYPE: BP16H

MONITORING OF WATER QUALITY ON KHAM 6



TIDE / PUMP EFFECT ON BOREHOLE KHAM 7



COMMENTS

Chemical test results

APPENDIX C

**Chemical analyses of water**

Bh 4 (32° 50' 33.66" / 28° 06' 57.12")  
 George's Place - private borehole  
 Amatole District Municipality

Constituent (mg/l)	Tested	Class	Class 0	Class 1	Class 2	Class 3	Class 4
pH	7.080	0	5-9.5	4.5-5 or 9.5-10	4-4.5 or 10-10.5	3-4 or 10.5-11	< 3 or > 11
EC (ms/m)	129.500	1	70.000	150.000	370.000	520.000	520.000
Turbidity (NTU)	0.700	1	0.100	1.000	20.000	50.000	50.000
Alkalinity	224.000	0	1.000	2.000	10.000	10.000	10.000
Ammonia (as N)	0.800	0	8.000	10.000	20.000	40.000	40.000
Nitrate (as N)	281.000	2	100.000	200.000	600.000	1200.000	1200.000
Chloride (Cl)	81.300	0	200.000	400.000	600.000	1000.000	1000.000
Sulphate (SO4)	196.000	1	100.000	200.000	400.000	1000.000	1000.000
Sodium (Na)	64.500	0	80.000	150.000	300.000	300.000	300.000
Calcium (Ca)	64.500	0	80.000	150.000	300.000	300.000	300.000
Calcium (CaCO3)	161.000	0	200.000	325.000	750.000	750.000	750.000
Calcium (CaCO3)	161.000	0	200.000	325.000	750.000	750.000	750.000
Magnesium (Mg)	35.800	0	70.000	100.000	200.000	400.000	400.000
Magnesium (MgCO3)	147.000	0	242.000	347.000	694.000	1388.000	1388.000
Magnesium (MgCO3)	308.000	2	300.000	300.000	600.000	600.000	600.000
Potassium (K)	3.720	0	23.000	50.000	100.000	500.000	500.000
Fluoride (F)	0.730	1	0.700	1.000	1.500	3.500	3.500
Iron (Fe)	0.060	1	0.050	1.000	5.000	10.000	10.000
Total Count	0	0	100.000	1000.000	1000.000	1000.000	1000.000
Total coliforms (f.col)	0	0	0.000	10.000	100.000	1000.000	1000.000
Faecal coliforms (f.c)	0	0	0.001	1.000	10.000	100.000	100.000
TDS	0	0	450.000	1000.000	2400.000	3400.000	3400.000
Arsenic (As)	0	0	0.010	0.050	0.200	2.000	2.000
Cadmium (Cd)	0	0	0.003	0.005	0.020	0.050	0.050
Copper (Cu)	0	0	1.000	1.300	2.000	15.000	15.000
Manganese (Mn)	0	0	0.100	0.400	4.000	10.000	10.000
Zinc (Zn)	0	0	20.000	20.000	20.000	20.000	20.000

Class of water **2**

Nitrate (as N)\*4.42 = Nitrate (as NO3)

Class 0	Ideal water quality-suitable for lifetime use.
Class 1	Good water quality-suitable for use, rare instances of negative effects.
Class 2	Marginal water quality-conditionally acceptable. Negative effects may occur in some sensitive groups.
Class 3	Poor water quality-unsuitable for use without treatment. Chronic effects may occur.
Class 4	Dangerous water quality-totally unsuitable for use. Acute effects may occur.

Class	Drinking health	Drinking Aesthetic	Food preparation	Bathing	Laundry	Comments
Class 0	No effects.	Waters is pleasing.	No effects.	No effects.	No effects.	No effects, suitable for many generations.
Class 1	Suitable for lifetime use. Rare instances of sub-clinical effects.	Some aesthetic effects may be apparent.	Suitable for lifetime use.	Minor effects on bathing or on bath fixtures.	Minor effects on laundry or on fixtures.	
Class 2	Drinking health	Drinking health	Food preparation	Bathing	Laundry	May be used without health effects by majority of individuals of all ages, but may cause effects in some individuals in sensitive groups. Some effects possible after lifetime use. Poor taste and appearance are noticeable.
Class 3	Drinking health	Drinking Aesthetic	Food preparation	Bathing	Laundry	Poses a risk of chronic health effects, especially in babies, children and the elderly. Bad taste and appearance may lead to rejection of the water. Significant effects on bathing or on bath fixtures.
Class 4	Drinking health	Drinking Aesthetic	Food preparation	Bathing	Laundry	Severe acute health effects, even with short-term use. Taste and appearance will lead to rejection of the water. Severe acute health effects, even with short-term use. Serious effects on bathing or on bath fixtures.

Chemical analyses of water

Borehole No.		Project		District		Amatole District Municipality	
Bh 7 (32° 51' 01.5" / 28° 06' 59.1")		Khamanga Bay Development (Allan' place)					
Class	Tested	Class	Class 0	Class 1	Class 2	Class 3	Class 4
pH	7.050	0	5-9.5	4.5-5.6	9.5-10	4-4.5 or 10-10.5	< 3 or > 11
EC (mS/m)	121,900	1	70,000	150,000	370,000	520,000	520,000
Turbidity (NTU)	0.900	1	0.100	1.000	20.000	50.000	50.000
Alkalinity	266.000						
Ammonia (as N)	0.800	0	1.000	2.000	10.000	10.000	40.000
Nitrate (as N)	0.800	0	6.000	10.000	20.000	40.000	120.000
Chloride (Cl)	214.000	2	100.000	200.000	400.000	1000.000	1200.000
Sulphate (SO4)	70.400	0	200.000	400.000	600.000	1000.000	1000.000
Sodium (Na)	249.000	2	100.000	200.000	400.000	1000.000	1000.000
Calcium (Ca)	22.500	0	60.000	150.000	300.000	300.000	
Calcium (CaCO3)	56.000	0	200.000	375.000	750.000	750.000	
Magnesium (Mg)	17.300	0	70.000	100.000	200.000	400.000	400.000
Magnesium (MgCO3)	71.000	0	242.000	442.000	694.000	1388.000	1388.000
Total hardness (T.H.)	127.000	0	200.000	300.000	600.000	600.000	500.000
Potassium (K)	2.620	0	25.000	40.000	100.000	500.000	500.000
Fluoride (F)	0.490	0	0.700	1.000	1.500	3.500	3.500
Iron (Fe)	0.060	1	0.050	1.000	5.000	10.000	10.000
Total Count		0	100.000	1000.000	1000.000	1000.000	
Total coliforms (T.col)		0	0.000	10.000	100.000	1000.000	1000.000
Faecal coliforms (Fc)		0	0.001	1.000	10.000	100.000	100.000
TDS		0	450.000	1000.000	2400.000	3400.000	3400.000
Arsenic (As)		0	0.010	0.050	0.200	2.000	2.000
Cadmium (Cd)		0	0.003	0.005	0.020	0.050	0.050
Copper (Cu)		0	1.000	1.300	2.000	15.000	15.000
Manganese (Mn)		0	0.100	0.400	4.000	10.000	10.000
Zinc (Zn)		0	30.000	30.000			

Class of water: 2 Nitrate (as N)\*4.42 = Nitrate (as NO3)

Class 0	Ideal water quality-suitable for lifetime use.
Class 1	Good water quality-suitable for use, rare instances of negative effects.
Class 2	Marginal water quality-conditionally acceptable. Negative effects may occur in some sensitive groups.
Class 3	Poor water quality-unsuitable for use without treatment. Chronic effects may occur.
Class 4	Dangerous water quality-totally unsuitable for use. Acute effects may occur.

Class	Drinking health	Drinking Aesthetic	Food preparation	Bathing	Laundry	Comments
Class 0	Drinking health : Waters is pleasing. No effects. No effects.	Drinking Aesthetic : No effects. No effects.	Food preparation : No effects. No effects.	Bathing : No effects. No effects.	Laundry : No effects. No effects.	No effects, suitable for many generations.
Class 1	Drinking health : Suitable for lifetime use. Rare instances of sub-clinical effects.	Drinking Aesthetic : Some aesthetic effects may be apparent. Suitable for lifetime use.	Food preparation : Suitable for lifetime use.	Bathing : Suitable for lifetime use.	Laundry : Suitable for lifetime use.	Minor effects on bathing or on bath fixtures. Minor effects on laundry or on fixtures.
Class 2	Drinking health : May be used without health effects by majority of individuals of all ages, but may cause effects in some individuals in sensitive groups.	Drinking Aesthetic : Some effects possible after lifetime use Poor taste and appearance are noticeable.	Food preparation : May be used without health effects by the majority persons	Bathing : Slight effects on bathing or on bath fixtures.	Laundry : Slight effects on bathing or on bath fixtures.	May be used without health effects by the majority persons Some effects possible after lifetime use Poor taste and appearance are noticeable. May be used without health effects by the majority persons Slight effects on bathing or on bath fixtures. Slight effects on bathing or on bath fixtures.
Class 3	Drinking health : Poses a risk of chronic health effects, especially in babies, children and the elderly.	Drinking Aesthetic : Bad taste and appearance may lead to rejection of the water.	Food preparation : Poses a risk of chronic health effects, especially in children and elderly	Bathing : Significant effects on bathing or on fixtures.	Laundry : Significant effects on laundry or on fixtures.	Poses a risk of chronic health effects, especially in babies, children and the elderly. Bad taste and appearance may lead to rejection of the water. Poses a risk of chronic health effects, especially in children and elderly Significant effects on bathing or on fixtures.
Class 4	Drinking health : Severe acute health effects, even with short-term use.	Drinking Aesthetic : Taste and appearance will lead to rejection of the water.	Food preparation : Severe acute health effects, even with short-term use.	Bathing : Severe acute health effects, even with short-term use.	Laundry : Severe acute health effects, even with short-term use.	Severe acute health effects, even with short-term use. Taste and appearance will lead to rejection of the water. Severe acute health effects, even with short-term use. Serious effects on bathing or on bath fixtures. Serious effects on bathing or on bath fixtures.

Chemical analyses of water

Borehole No.	Project	District	Class	Class of water	Nitrate (as N)*4.42 = Nitrate (as NO3)
No 9 - GAME PARK (32 50' 12.6" / 28 04' 34.44")	KHMANANGA BAY HOUSING DEVELOPMENT	AMATOLA DISTRICT MUNICIPALITY	Class 4	2	
Constituent (mg/l)	Tested	Class	Class 0	Class 1	Class 2
pH	6.740	0	5-9.5	4.5-9.5	4-4.5 or 10-10.5
EC (µs/m)	100,000	1	70,000	150,000	370,000
Turbidity (NTU)	0.800	1	0.100	1.000	20.000
Alkalinity	109,000				
Ammonia (as N)		0	1,000	2,000	10,000
Nitrate (as N)	3,000	0	6,000	10,000	40,000
Chloride (Cl)	219,000	2	100,000	200,000	600,000
Sulphate (SO4)	51,700	0	200,000	400,000	600,000
Sodium (Na)	174,000	1	100,000	200,000	400,000
Calcium (Ca)	12,000	0	80,000	150,000	300,000
Calcium (CaCO3)	30,000	0	200,000	375,000	750,000
Magnesium (Mg)	13,100	0	70,000	100,000	200,000
Magnesium (MgCO3)	54,000	0	242,800	347,000	694,000
Total hardness (TH)	84,000	0	200,000	300,000	600,000
Potassium (K)	1,020	0	25,000	50,000	100,000
Fluoride (F)	0.800	1	0.700	1,000	1,500
Iron (Fe)	0.040	0	0.050	1,000	5,000
Total Count		0	100,000	1,000,000	1,000,000
Total coliforms (T.col)		0	0,000	10,000	100,000
Faecal coliforms (Fc)		0	0,001	1,000	10,000
TDS		0	450,000	1,000,000	2,400,000
Arsenic (As)		0	0.010	0.050	0.200
Cadmium (Cd)		0	0.003	0.005	0.020
Copper (Cu)		0	1,000	1,300	2,000
Manganese (Mn)		0	0.100	0.400	4,000
Zinc (Zn)		0	20,000	9,400	10,000

Class 0	Class 1	Class 2	Class 3	Class 4
Ideal water quality-suitable for lifetime use.	Good water quality-suitable for use, rare instances of negative effects.	Marginal water quality-conditionally acceptable. Negative effects may occur in some sensitive groups.	Poor water quality-unsuitable for use without treatment. Chronic effects may occur.	Dangerous water quality-totally unsuitable for use. Acute effects may occur.

Class 0	Class 1	Class 2	Class 3	Class 4
Drinking health : Drinking Aesthetic : Food preparation : Bathing : Laundry :	Drinking health : Drinking Aesthetic : Food preparation : Bathing : Laundry :	Drinking health : Drinking Aesthetic : Food preparation : Bathing : Laundry :	Drinking health : Drinking Aesthetic : Food preparation : Bathing : Laundry :	Drinking health : Drinking Aesthetic : Food preparation : Bathing : Laundry :
No effects, suitable for many generations. Waters is pleasing. No effects. No effects.	Suitable for lifetime use. Rare instances of sub-clinical effects. Some aesthetic effects may be apparent Suitable for lifetime use. Minor effects on bathing or on bath fixtures.	May be used without health effects by majority of individuals of all ages, but may cause effects in some individuals in sensitive groups. Some effects possible after lifetime use Poor taste and appearance are noticeable. May be used without health or aesthetic effects by the majority persons Slight effects on bathing or on bath fixtures. Slight effects on bathing or on bath fixtures.	Poses a risk of chronic health effects, especially in babies, children and the elderly. Bad taste and appearance may lead to rejection of the water. Poses a risk of chronic health effects, especially in children and elderly	Severe acute health effects, even with short-term use. Taste and appearance will lead to rejection of the water. Severe acute health effects, even with short-term use. Serious effects on bathing or on bath fixtures. Serious effects on bathing or on bath fixtures.

Comments

Chemical analyses of water

Borehole No.	Project	District	Constituent (mg/l)	Tested	Class	Class 1	Class 2	Class 3	Class 4
Bh 11 - GAME PARK (32 5013.7 / 28 0434.7)	KHAMANGA BAY HOUSING DEVELOPMENT	AMATOLA DISTRICT MUNICIPALITY - EASTERN CAPE							
			pH	6.860	0	9.95	4.5 or 8.10	3.4 or 10.5	> 11
			EC (µs/cm)	128.500	1	70.000	150.000	370.000	520.000
			Turbidity (NTU)	0.000	0	0.100	1.000	20.000	50.000
			Alkalinity	208.000	0				
			Ammonia (as N)	1.000	0	2.000	10.000	10.000	
			Nitrate (as N)	2.000	0	6.000	10.000	40.000	40.000
			Chloride (Cl)	200.000	2	200.000	600.000	1200.000	1200.000
			Sulphate (SO4)	62.000	0	200.000	400.000	1000.000	1000.000
			Sodium (Na)	163.000	1	100.000	200.000	400.000	1000.000
			Calcium (Ca)	41.500	0	80.000	300.000	300.000	
			Calcium (CaCO3)	104.000	0	200.000	375.000	750.000	1000.000
			Magnesium (Mg)	27.000	0	70.000	100.000	200.000	400.000
			Magnesium (MgCO3)	111.000	0	242.000	347.000	694.000	1388.000
			Total hardness (T.H.)	215.000	1	208.000	300.000	600.000	600.000
			Potassium (K)	2.700	0	0.700	1.000	1.500	3.500
			Fluoride (F)	1.640	2	0.500	1.000	5.000	10.000
			Iron (Fe)		0	0.050	1.000	10.000	10.000
			Total Count		0	1000.000	1000.000	1000.000	
			Total coliforms (T.col)		0	1000.000	1000.000	1000.000	1000.000
			Faecal coliforms (Fc)		0	1.000	10.000	100.000	100.000
			TDS		0	450.000	1000.000	2400.000	3400.000
			Arsenic (As)		0	0.050	0.050	0.200	0.050
			Cadmium (Cd)		0	0.003	0.006	0.020	0.050
			Copper (Cu)		0	1.000	1.300	2.000	15.000
			Manganese (Mn)		0	0.100	0.400	4.000	10.000
			Zinc (Zn)		0	20.000	20.000		

Class of water 2 Nitrate (as N)\*4.42 = Nitrate (as NO3)

Class 0	Ideal water quality-suitable for lifetime use.
Class 1	Good water quality-suitable for use, rare instances of negative effects.
Class 2	Marginal water quality-conditionally acceptable. Negative effects may occur in some sensitive groups.
Class 3	Poor water quality-unsuitable for use without treatment. Chronic effects may occur.
Class 4	Dangerous water quality-totally unsuitable for use. Acute effects may occur.

Class	Drinking health:	Food preparation:	Bathing:	Laundry:	Drinking Aesthetic:	Comments
Class 0	Drinking health: Suitable for many generations. Waters is pleasing. No effects.	Food preparation: No effects.	Bathing: No effects.	Laundry: No effects.	Drinking Aesthetic: No effects.	
Class 1	Drinking health: Suitable for lifetime use. Rare instances of sub-clinical effects. Some aesthetic effects may be apparent. Suitable for lifetime use.	Food preparation: Suitable for lifetime use.	Bathing: Minor effects on bathing or on bath fixtures.	Laundry: Minor effects on laundry or on fixtures.	Drinking Aesthetic: Minor effects on bathing or on bath fixtures.	
Class 2	Drinking health: May be used without health effects by majority of individuals of all ages, but may cause effects in some individuals in sensitive groups. Some effects possible after lifetime use. Poor taste and appearance are noticeable. May be used without health or aesthetic effects by the majority persons. Slight effects on bathing or on bath fixtures.	Food preparation: May be used without health or aesthetic effects by the majority persons. Slight effects on bathing or on bath fixtures.	Bathing: Slight effects on bathing or on bath fixtures.	Laundry: Slight effects on laundry or on fixtures.	Drinking Aesthetic: Slight effects on bathing or on bath fixtures.	
Class 3	Drinking health: Poses a risk of chronic health effects, especially in babies, children and the elderly. Bad taste and appearance may lead to rejection of the water. Poses a risk of chronic health effects, especially in children and elderly.	Food preparation: Poses a risk of chronic health effects, especially in children and elderly.	Bathing: Significant effects on bathing or on bath fixtures.	Laundry: Significant effects on laundry or on fixtures.	Drinking Aesthetic: Significant effects on bathing or on bath fixtures.	
Class 4	Drinking health: Serious effects on bathing or on bath fixtures. Serious effects on bathing or on bath fixtures. Severe acute health effects, even with short-term use.	Food preparation: Taste and appearance will lead to rejection of the water. Severe acute health effects, even with short-term use.	Bathing: Severe acute health effects, even with short-term use.	Laundry: Severe acute health effects, even with short-term use.	Drinking Aesthetic: Severe acute health effects, even with short-term use.	





Chemical analyses of water

Borehole No.	Project	KHAM 3 (32°51'08.0" / 28°05'59.6") Khamanga Bay Development (Valley east of development site) Amable District Municipality	
Constituent (mg/l)	Tested	Class	Nitrate (as N)*4.42 = Nitrate (as NO3)
pH	6.930	0	4.5 - 8.5
EC (mS/m)	392.000	3	4.5 - 9.5 - 10
Turbidity (NTU)	4.100	2	1.000
Alkalinity	371.000		
Ammonia (as N)	0	0	2.000
Nitrate (as N)	0.800	0	10.000
Chloride (Cl)	1143.000	3	600.000
Sulphate (SO4)	118.000	0	600.000
Sodium (Na)	723.000	3	400.000
Calcium (Ca)	101.000	1	300.000
Calcium (CaCO3)	252.000	1	750.000
Magnesium (Mg)	83.100	1	200.000
Magnesium (MgCO3)	342.000	1	694.000
Total hardness (T.H.)	594.000	2	600.000
Potassium (K)	8.350	0	100.000
Fluoride (F)	1.490	2	1.500
Iron (Fe)	0.390	1	5.000
Total Count	0	0	1000.000
Total coliforms (T.col)	0	0	100.000
Faecal coliforms (Fc)	0	0	10.000
TDS	0	0	450.000
Arsenic (As)	0	0	0.050
Cadmium (Cd)	0	0	0.005
Copper (Cu)	0	0	1.300
Manganese (Mn)	0	0	0.100
Zinc (Zn)	0	0	0.400

Class 0	Class 1	Class 2	Class 3	Class 4
Ideal water quality-suitable for lifetime use.	Good water quality-suitable for use, rare instances of negative effects.	Marginal water quality-conditionally acceptable. Negative effects may occur in some sensitive groups.	Poor water quality-unsuitable for use without treatment. Chronic effects may occur.	Dangerous water quality-totally unsuitable for use. Acute effects may occur.
Drinking health : Drinking Aesthetic : Food preparation : Bathing : Laundry :	Drinking health : Drinking Aesthetic : Food preparation : Bathing : Laundry :	Drinking health : Drinking Aesthetic : Food preparation : Bathing : Laundry :	Drinking health : Drinking Aesthetic : Food preparation : Bathing : Laundry :	Drinking health : Drinking Aesthetic : Food preparation : Bathing : Laundry :
No effects. Waters is pleasing. No effects. No effects.	Suitable for lifetime use. Rare instances of sub-clinical effects. Some aesthetic effects may be apparent. Suitable for lifetime use. Minor effects on bathing or on bath fixtures.	May be used without health effects by majority of individuals of all ages, but may cause effects in some individuals in sensitive groups. Some effects possible after lifetime use Poor taste and appearance are noticeable. May be used without health or aesthetic effects by the majority persons Slight effects on bathing or on bath fixtures.	Poses a risk of chronic health effects, especially in babies, children and the elderly. Bad taste and appearance may lead to rejection of the water. Poses a risk of chronic health effects, especially in children and elderly Significant effects on bathing or on bath fixtures.	Severe acute health effects, even with short-term use. Taste and appearance will lead to rejection of the water. Severe acute health effects, even with short-term use. Serious effects on bathing or on bath fixtures. Serious effects on bathing or on bath fixtures.

Comments

Chemical analyses of water

Borehole No.	Project	KHAM 4 (32°50' 21.2" / 28°06' 49.2") Khamanga Bay Development (Trevors Caravan Park)		Amatole District Municipality	
Class	Tested	Class 0	Class 1	Class 2	Class 3
Constituent (mg/l)					
pH	7.750	5-9.5	4.5-9.5	4-4.5 or 10-10.5	3-4 or 10.5-11
EC (mS/m)	93,500	70,000	150,000	370,000	520,000
Turbidity (NTU)	20,000	0.100	1.000	20.000	50.000
Alkalinity	109,000				
Ammonia (as N)	0	1.000	2.000	10.000	10.000
Nitrate (as N)	0	8.000	10.000	20.000	40.000
Chloride (Cl)	193,000	100,000	200,000	600,000	1,200,000
Sulphate (SO4)	173,000	100,000	200,000	600,000	1,000,000
Sodium (Na)	46,400	30,000	60,000	200,000	400,000
Calcium (Ca)	116,000	30,000	60,000	200,000	400,000
Calcium (CaCO3)	116,000	30,000	60,000	200,000	400,000
Magnesium (Mg)	11,400	7,000	14,000	40,000	80,000
Magnesium (MgCO3)	47,000	29,000	58,000	160,000	320,000
Total hardness (T.H.)	163,000	200,000	300,000	600,000	1,000,000
Potassium (K)	0	25,000	50,000	100,000	500,000
Fluoride (F)	0	0.700	1.000	1.500	3.500
Iron (Fe)	0	0.700	1.000	1.500	3.500
Total Count	0	100,000	1,000,000	1,000,000	
Total coliforms (T.col)	0	0.000	10.000	100.000	1,000.000
Faecal coliforms (Fc)	0	0.001	1.000	10.000	100.000
TDS	0	450,000	1,000,000	2,400,000	3,400,000
Arsenic (As)	0	0.010	0.030	0.200	2.000
Cadmium (Cd)	0	0.002	0.005	0.020	0.050
Copper (Cu)	0	1.000	1.400	2.000	15.000
Manganese (Mn)	0	0.100	0.400	4.000	10.000
Zinc (Zn)	0	0	0	0	0

Class of water  Nitrate (as N)\*4.42 = Nitrate (as NO3)

Class 0	Ideal water quality-suitable for lifetime use.
Class 1	Good water quality-suitable for use, rare instances of negative effects.
Class 2	Marginal water quality-conditionally acceptable. Negative effects may occur in some sensitive groups.
Class 3	Poor water quality-unsuitable for use without treatment. Chronic effects may occur.
Class 4	Dangerous water quality-totally unsuitable for use. Acute effects may occur.

Class	Drinking health	Drinking Aesthetic	Food preparation	Bathing	Laundry	Comments
Class 0	Drinking health : No effects.	Drinking Aesthetic : No effects.	Food preparation : No effects.	Bathing : No effects.	Laundry : No effects.	Waters is pleasing. No effects. Suitable for many generations.
Class 1	Drinking health : Suitable for lifetime use. Rare instances of sub-clinical effects.	Drinking Aesthetic : Some aesthetic effects may be apparent.	Food preparation : Suitable for lifetime use.	Bathing : Minor effects on bathing or on bath fixtures.	Laundry : Minor effects on laundry or on fixtures.	
Class 2	Drinking health : May be used without health effects by majority of individuals of all ages, but may cause effects in some individuals in sensitive groups.	Drinking Aesthetic : Poor taste and appearance are noticeable.	Food preparation : Some effects possible after lifetime use	Bathing : May be used without health or aesthetic effects by the majority persons	Laundry : Slight effects on bathing or on bath fixtures.	
Class 3	Drinking health : Poses a risk of chronic health effects, especially in babies, children and the elderly.	Drinking Aesthetic : Bad taste and appearance may lead to rejection of the water.	Food preparation : Poses a risk of chronic health effects, especially in children and elderly	Bathing : Significant effects on bathing or on bath fixtures.	Laundry : Significant effects on laundry or on fixtures.	
Class 4	Drinking health : Severe acute health effects, even with short-term use.	Drinking Aesthetic : Taste and appearance will lead to rejection of the water.	Food preparation : Severe acute health effects, even with short-term use.	Bathing : Serious effects on bathing or on bath fixtures.	Laundry : Serious effects on bathing or on bath fixtures.	

**Chemical analyses of water**

Borehole No.	Project	KHAM 5 (32°50' 16.1" / 28°06' 48.4")		Khamanga Bay Development (Trevors Caravan Park)		Armatle District Municipality	
Constituent (mg/l)	Tested	Class	Class 0	Class 1	Class 2	Class 3	Class 4
pH	7.690	0	5 - 9.5	4.5 - 9.5	4 - 4.5 or 10 - 10.5	3 - 4 or 10.5 - 11	< 3 or > 11
EC (ms/m)	247.000	2	70.000	150.000	370.000	520.000	520.000
Turbidity (NTU)	106.000	4	0.100	1.000	20.000	50.000	50.000
Alkalinity	199.000						
Ammonia (as N)	0	0	1.000	2.000	10.000	10.000	40.000
Nitrate (as N)	0	0	5.000	10.000	20.000	40.000	40.000
Chloride (Cl)	613.000	3	100.000	200.000	600.000	1200.000	1200.000
Sulphate (SO4)	0	0	200.000	400.000	600.000	1000.000	1000.000
Sodium (Na)	466.000	3	100.000	200.000	400.000	1000.000	1000.000
Calcium (Ca)	97.500	1	80.000	150.000	300.000	300.000	300.000
Calcium (CaCO3)	243.000	1	200.000	375.000	750.000	750.000	400.000
Magnesium (Mg)	58.000	0	70.000	100.000	200.000	400.000	400.000
Magnesium (MgCO3)	239.000	0	247.000	347.000	694.000	1388.000	1388.000
Total hardness (T.H.)	482.000	2	200.000	350.000	600.000	600.000	500.000
Potassium (K)	0	0	25.000	50.000	100.000	500.000	500.000
Fluoride (F)	0	0	0.700	1.000	1.500	3.500	3.500
Iron (Fe)	0	0	0.250	1.000	5.000	10.000	10.000
Total Count	0	0	100.000	1000.000	1000.000	1000.000	1000.000
Total coliforms (T.col)	0	0	0.000	10.000	100.000	1000.000	1000.000
Faecal coliforms (Fc)	0	0	0.001	1.000	10.000	100.000	100.000
TDS	0	0	450.000	1000.000	2400.000	3400.000	3400.000
Arsenic (As)	0	0	0.010	0.050	0.200	2.000	2.000
Cadmium (Cd)	0	0	0.000	0.005	0.020	0.050	0.050
Copper (Cu)	0	0	1.000	1.300	2.000	15.000	15.000
Manganese (Mn)	0	0	0.100	0.400	4.000	10.000	10.000
Zinc (Zn)	0	0	20.000	20.000			

Nitrate (as N)\*4.42 = Nitrate (as NO3)

Class 0	Class 1	Class 2	Class 3	Class 4
Ideal water quality-suitable for lifetime use.	Good water quality-suitable for use, rare instances of negative effects.	Marginal water quality-conditionally acceptable. Negative effects may occur in some sensitive groups.	Poor water quality-unsuitable for use without treatment. Chronic effects may occur.	Dangerous water quality-totally unsuitable for use. Acute effects may occur.

Class 0	Class 1	Class 2	Class 3	Class 4
Drinking health : Drinking Aesthetic : Food preparation : Bathing : Laundry :	Drinking health : Drinking Aesthetic : Food preparation : Bathing : Laundry :	Drinking health : Drinking Aesthetic : Food preparation : Bathing : Laundry :	Drinking health : Drinking Aesthetic : Food preparation : Bathing : Laundry :	Drinking health : Drinking Aesthetic : Food preparation : Bathing : Laundry :
No effects. Waters is pleasing. No effects. No effects.	Suitable for lifetime use. Rare instances of sub-clinical effects. Some aesthetic effects may be apparent. Suitable for lifetime use. Minor effects on bathing or on bath fixtures.	May be used without health effects by majority of individuals of all ages, but may cause effects in some individuals in sensitive groups. Some effects possible after lifetime use Poor taste and appearance are noticeable. May be used without health or aesthetic effects by the majority persons Slight effects on bathing or on bath fixtures.	Poses a risk of chronic health effects, especially in babies, children and the elderly. Bad taste and appearance may lead to rejection of the water. Significant effects on bathing or on bath fixtures.	Severe acute health effects, even with short-term use. Taste and appearance will lead to rejection of the water. Severe acute health effects, even with short-term use. Serious effects on bathing or on bath fixtures.

Comments

Chemical analyses of water

Borehole No.	Project	District	KHAM 6 (32 50' 19.0" / 28 06' 50.4") Khamanga Bay Development - Trevers Caravan park Armatle District Municipality			
Constituent (mg/l)	Tested	Class	Class 1	Class 2	Class 3	Class 4
pH	7.950	0	4.5 - 8.5	4 - 4.5 or 10 - 10.5	3 - 4 or 10.5 - 11	< 3 or > 11
EC (ms/m)	120.100	1	150.000	370.000	520.000	520.000
Turbidity (NTU)	0.000	0	1.000	20.000	50.000	50.000
Alkalinity	133.000	0	1.000	2.000	10.000	10.000
Ammonia (as N)	1.000	0	2.000	10.000	40.000	40.000
Nitrate (as N)	8.000	0	10.000	20.000	40.000	40.000
Chloride (Cl)	267.000	2	100.000	600.000	1200.000	1200.000
Sulphate (SO4)	200.000	0	400.000	600.000	1000.000	1000.000
Sodium (Na)	196.500	1	200.000	400.000	1000.000	1000.000
Calcium (Ca)	42.500	0	80.000	300.000	300.000	300.000
Calcium (CaCO3)	108.000	0	200.000	750.000	750.000	750.000
Magnesium (Mg)	19.100	0	100.000	200.000	400.000	400.000
Magnesium (MgCO3)	79.000	0	200.000	694.000	1388.000	1388.000
Total hardness (T.H.)	185.000	0	300.000	600.000	600.000	600.000
Potassium (K)	26.000	0	50.000	100.000	500.000	500.000
Fluoride (F)	0.700	0	1.000	1.500	3.500	3.500
Iron (Fe)	0.050	0	1.000	5.000	10.000	10.000
Total Count	100.000	0	1000.000	1000.000	1000.000	1000.000
Total coliforms (T.col)	0.000	0	10.000	100.000	1000.000	1000.000
Faecal coliforms (Fc)	0.000	0	1.000	10.000	100.000	100.000
TDS	450.000	0	1000.000	2400.000	3400.000	3400.000
Arsenic (As)	0.010	0	0.050	0.200	2.000	2.000
Cadmium (Cd)	0.003	0	0.005	0.020	0.050	0.050
Copper (Cu)	1.000	0	1.500	2.000	15.000	15.000
Manganese (Mn)	0.100	0	0.400	4.000	10.000	10.000
Zinc (Zn)	0	0	0.200	2.000	20.000	20.000

Class of water 2 Nitrate (as N)\*4.42 = Nitrate (as NO3)

Class 0	Ideal water quality-suitable for lifetime use.
Class 1	Good water quality-suitable for use, rare instances of negative effects.
Class 2	Marginal water quality-conditionally acceptable. Negative effects may occur in some sensitive groups.
Class 3	Poor water quality-unsuitable for use without treatment. Chronic effects may occur.
Class 4	Dangerous water quality-totally unsuitable for use. Acute effects may occur.

Class	Drinking health	Drinking Aesthetic	Food preparation	Bathing	Laundry	Comments
Class 0	Drinking health : No effects. Waters is pleasing.	Drinking Aesthetic : No effects.	Food preparation : No effects.	Bathing : No effects.	Laundry : No effects.	No effects, suitable for many generations.
Class 1	Drinking health : Suitable for lifetime use. Rare instances of sub-clinical effects.	Drinking Aesthetic : Some aesthetic effects may be apparent.	Food preparation : Suitable for lifetime use.	Bathing : Minor effects on bathing or on bath fixtures.	Laundry : Minor effects on laundry or on fixtures.	Suitable for lifetime use. Some aesthetic effects may be apparent. Minor effects on bathing or on bath fixtures.
Class 2	Drinking health : May be used without health effects by majority of individuals of all ages, but may cause effects in some individuals in sensitive groups.	Drinking Aesthetic : Poor taste and appearance are noticeable.	Food preparation : Some effects possible after lifetime use.	Bathing : May be used without health or aesthetic effects by the majority persons.	Laundry : Slight effects on bathing or on bath fixtures.	May be used without health effects by majority of individuals of all ages, but may cause effects in some individuals in sensitive groups. Poor taste and appearance are noticeable. Slight effects on bathing or on bath fixtures.
Class 3	Drinking health : Poses a risk of chronic health effects, especially in babies, children and the elderly.	Drinking Aesthetic : Bad taste and appearance may lead to rejection of the water.	Food preparation : Poses a risk of chronic health effects, especially in children and elderly.	Bathing : Significant effects on bathing or on bath fixtures.	Laundry : Significant effects on laundry or on fixtures.	Poses a risk of chronic health effects, especially in children and elderly. Bad taste and appearance may lead to rejection of the water. Significant effects on bathing or on bath fixtures.
Class 4	Drinking health : Severe acute health effects, even with short-term use.	Drinking Aesthetic : Taste and appearance will lead to rejection of the water.	Food preparation : Severe acute health effects, even with short-term use.	Bathing : Serious effects on bathing or on bath fixtures.	Laundry : Serious effects on bathing or on bath fixtures.	Severe acute health effects, even with short-term use. Taste and appearance will lead to rejection of the water. Severe acute health effects, even with short-term use. Serious effects on bathing or on bath fixtures.

**Detail geological borehole logs**

**APPENDIX D**




CLIENT: KHAMANGA BA' PROJECT : KHAMANGA BAY  
SITE: TARGET AREA 1 DRILLER : DRILLING AFRICA TRUS  
LOG : DANIEL  
DATE STARTED : 3/5/2003

METHOD:  
BOREHOLE NR.: KHAM 1  
GEOH PEG No.: Line 4/50  
WATER LEVEL: 22.31  
LATITUDE: 32° 51' 21.7"  
LONGITUDE: 28° 06' 13.5"  
B/HOLE DEPTH 78  
ALTITUDE:



**BOREHOLE  
DETAIL**


Borehole Diameter (mm)	
Diam:	205
From:	0
To:	14
Diam:	165
From:	14
To:	78



Diam. OD (mm)	178
Thickness	4
Material	Steel
Plain/Part	Plain
From (m):	0.39
To (m):	14

Casing Detail	
Material	Steel
Thickness	4
Plain/Part	Plain
From (m):	0.39
To (m):	14








PERCUSSION DRILLING RECORD  
 CLIENT : KHAMANGA BAY PROJECT : KHAMANGA BAY  
 LOG : DANIEL DATE STARTED : 6/5/2003  
 SITE : TARGET AREA 1 DRILLER : DRILLING AFRICA TRUS  
 BOREHOLE NR. : KHAM 2 GEOPH PEG No.: Line 5/250  
 WATER LEVEL: 9.38 LATITUDE : 32° 51' 11.1"  
 B/HOLE DEPTH: 78 LONGITUDE : 26° 06' 00.9"  
 BLOW YIELD (t): 5 ALTITUDE:

**BOREHOLE  
 CONSTRUCTION  
 DETAIL**

Borehole Diameter (mm)	Diam.	205	165
	From (m):	0	15
To (m):		45	78
		0	15




Casing Detail		LITHOLOGY	
Diam. OD (mm)	Thickness	Material	Material
178	4	Steel	BEAUFORD GROUP, TARKASTAD SUBGROUP, Burgersdorp Formation (Grey, brown, red mudstone, sandstone, Dolerite dykes and sills Bedding plane fractures
178	4	Steel	
0.45	0.45	Plain	
15	15	Plain	



METHOD:  
 BLOW YIELD (t): 5 ALTITUDE:  
 B/HOLE DEPTH: 78 LONGITUDE : 26° 06' 00.9"  
 WATER LEVEL: 9.38 LATITUDE : 32° 51' 11.1"  
 BOREHOLE NR. : KHAM 2 GEOPH PEG No.: Line 5/250

AD GEO CONSULTANTS CC  
 5 High Field Road  
 BEACON BAY, 5205  
 TEL NO: +27 43 7482723  
 FAX NO: +27 43 748 2723



PERCUSSION DRILLING RECORD  
 CLIENT : KHAMANGA BA PROJECT : KHAMANGA BAY  
 SITE : TARGET AREA 1 DRILLER : DRILLING AFRICA TRUS  
 LOG : DANIEL DATE STARTED : 8/5/2003

METHOD:  
 BOREHOLE N. : KHAM 3 GEOP REG No.: Line 6100  
 WATER LEVEL: 8.07 LATITUDE : 32° 51' 08.0"  
 BLOW YIELD (k): 1.67 ALTITUDE: 86 LONGITUDE: 28° 05' 59.5"  
 LITHOLOGY

**BOREHOLE CONSTRUCTION DETAIL**


To (m)	From (m)	Diam	Material
11	0	205	165
86	11		
11	0.47		

**Casting Detail**

To (m)	From (m)	Material	Thickness	Diam. OD (mm)
11	0.47	Plain/Port.	4	178
		Steel		

**Geology:**

BEAUFORD GROUP, TARKASTAD SUBGROUP, Burgersdorp Formation (Grey, brown, red mudstones, sandstone, dolerite dykes and sills)			
Drilling Target: Northern contact of an east - west trending dyke			




AD GEO CONSULTANTS CC  
 5 High Field Road  
 BEACON BAY, 6205  
 TEL NO: +27 43 7482723  
 FAX NO: +27 43 748 2723



PERCUSSION DRILLING RECORD  
 CLIENT: KHAMANGA BAY PROJECT: KHAMANGA BAY  
 SITE: TARGET AREA 2 DRILLER: DRILLING AFRICA TRUST  
 LOG: DANIEL DATE STARTED: 22/05/2003  
 BOREHOLE NO.: KHAM 4  
 GEOPH PEG NO.: Line 2/160  
 LATITUDE: 32° 50' 21.2"  
 LONGITUDE: 28° 06' 49.2"  
 ALTITUDE: 14

METHOD:  
 LITHOLOGY  
 BEAUFORD GROUP, TARKASTAD SUBGROUP,  
 Burgersdorp Formation (Grey, brown, red mudstone,  
 sandstone, dolerite dykes and sills)  
 Bedding plane fractures

BOREHOLE CONSTRUCTION DETAIL		Borehole Diameter (mm)		Casing Detail		Geology	
To (m)	From (m)	Diam	Material	Thickness	Material	From (m)	To (m)
24	0	205	Plain/Perf.	4	Steel	0	24
101	24	165	Plain/Perf.	178	Steel	0	24



AD GEO CONSULTANTS CC  
 5 High Field Road  
 BEACON BAY, 5205  
 TEL NO: +27 43 7482723  
 FAX NO: +27 43 748 2723






PERCUSSION DRILLING RECORD  
 CLIENT: KHAMANGA BA PROJECT : KHAMANGA BAY  
 SITE: TARGET AREA 2 DRILLER : DRILLING AFRICA TRUST  
 LOG : DANIEL DATE STARTED : 26/5/2003

METHOD:  
 BOREHOLE N.: KHAM 5  
 GEOPH PEG NO.: Line # station 200  
 LATTITUDE: 32° 50' 16.1"  
 LONGITUDE: 28° 06' 48.4"  
 ALTITUDE: 028  
 BLOW YIELD: 028  
 BOREHOLE DEPTH: 78  
 WATER LEVEL: 4.57  
 BEAUFORD GROUP, TARKASTAD SUBGROUP,  
 Burgerdorp Formation (Grey, brown, red mudstone,  
 sandstone, dolerite dykes and sills)  
 Geology:  
 Drilling Target:  
 Bedding plane fractures

**BOREHOLE CONSTRUCTION DETAIL**

Borehole Diameter (mm)	
Diam	256
From (m):	6
To (m):	18
Diam, OD (mm)	178
Thickness	4
Material	Steel
Material	Plain/Perf.
From (m):	0.23
To (m):	18



AD GEO CONSULTANTS CC  
 5 High Field Road  
 BEACON BAY, 5205  
 TEL NO: +27 43 7482723  
 FAX NO: +27 43 748 2723



CLIENT : KHAMANGA BAY PROJECT : KHAMANGA BAY  
 LOG : DANIEL DATE STARTED :  
 SITE : TARGET AREA 2 DRILLER : DRILLING AFRICA TRUST

METHOD:  
 BOREHOLE NR: KHAM 6  
 GEOPH PEG NO.:  
 LATTITUDE : 32° 50' 19.0"  
 LONGITUDE : 28° 06' 50.4"  
 BOREHOLE DEPTH: 58  
 BLOW YIELD: 3.06 ALTITUDE:  
 LITHOLOGY

BOREHOLE CONSTRUCTION DETAIL		Casing Detail		LITHOLOGY	
To:	6	To (m):	58	Geology:	BEAUFORD GROUP, TARKASTAD SUBGROUP,
From:	0	From (m):	0		Burgersdorp Formation (Grey, brown, red mudstone,
Diam	256	Material	165		sandstone, Dolerite dykes and sills
	205	Thickness	6		Bedding plane fractures
	205		8		
	205		144		
	58		144		
	6		43		
	0		58		

