


# GROUNDWATER RESOURCE INFORMATION PROJECT EASTERN CAPE PROVINCE

## GROUNDWATER INFORMATION SOURCE REFERENCE SHEET



<b>SOURCE REF NR:</b>	<b>AG038</b>			
	Own Archive	X	Copy attached	X
	Sourced		Copy at source	

**A: SOURCE DESCRIPTION**

District Municipality: \_\_\_\_\_

Local Municipality: \_\_\_\_\_

Institution where Information is held: \_\_\_\_\_

Branch of Institution: \_\_\_\_\_

Contact details: \_\_\_\_\_

Contact person: **JAN MYBURGH**

Contact Tel: **043 7262070**

Contact Email: [easterncape@ages-group.com](mailto:easterncape@ages-group.com)

**B: TYPE OF INFORMATION**

Information format:	Hard copy	X	Data Summary	Electronic Report	Specify Other:
---------------------	-----------	---	--------------	-------------------	----------------

Report / Info Title: **Pump testing evaluation of existing boreholes at Hofmeyr - Eastern Cape Province**

Report Nr: **EC/01/22/HG** Date: **August 2001**

Author Details: **J.AMYBURGH**

Hydrogeologist	X	Govt Dept	Project Manager	Specify Other:
Engineer		Technician	Other	

Captured by: **A VILJOEN** Date: **19/2/2004** Signed: \_\_\_\_\_

**C: GEOHYDROLOGICAL CATEGORIZATION**

Project Type: **X** Source development    **X** Feasibility Study    Sanitation Study

Reference Co-ordinate: \_\_\_\_\_

Specify Other: \_\_\_\_\_

	Latitude	<b>31° 38' 00"</b>	Longitude	<b>25° 48' 00"</b>
Yes	No		Complete	Incomplete
<b>X</b>			<b>X</b>	<b>X</b>
<b>X</b>			<b>X</b>	
<b>X</b>			<b>X</b>	
<b>X</b>			<b>X</b>	
<b>X</b>			<b>X</b>	
<b>X</b>			<b>X</b>	
<b>X</b>			<b>X</b>	

Comments: \_\_\_\_\_

Reviewed by: **F. de Jaan** Date: **4/3/04** Signed: \_\_\_\_\_

**Project report:**

EC/01/22/HG



**Hydrogeological investigation**

---

**Pump Testing Evaluation of existing boreholes at  
HOFMEYR – Eastern Cape Province**

---

**August 2001**

**Project team:**  
J.A. Myburgh,  
F.N. de Jager,

GEOCON COPY

**Project report:**

**EC/01/22/HG**

**Hydrogeological investigation**

---

**Pump Testing Evaluation of existing boreholes  
HOFMEYR – Eastern Cape Province**

---

August 2001

**Conducted on behalf of:**  
**V3 CONSULTING ENGINEERS**  
P.O.Box  
Tecoma  
**PORT ELIZABETH**

Mr. C. Louw  
Tel. No.: (041) 391 8811  
Fax. No.: (041) 364 3798

**Compiled by:**

---

**J.A.Myburgh (BSc Hons)**  
Consulting Hydrogeologist – Pr.Sci.Nat.

<b>Northern Province</b> 120 Marshall Street P.O. Box 2526 PIETERSBURG 0700 Tel. No.:+27 - 15 - 291 1577 Fax. No.:+27 - 15 - 291 1702 e-mail:pietersburg@geocon.co.za	<b>Gauteng Province</b> 66 Paradisi Street, Highveld X8 Postnet, Suite 12, Private Bag X108 CENTURION 0046 Tel. No.:+27 - 12 - 665 3100 Fax. No.:+27 - 12 - 665 2176 e-mail:centurion@geocon.co.za	<b>Eastern Cape Province</b> 8 Sansom Street, Vincent Postnet 203, Private Bag X9063 EAST LONDON 5200 Tel. No.:+27 - 43 - 726 2070 Fax. No.:+27 - 43 - 726 9232 e-mail:eastlondon@geocon.co.za
--	--	---

**Directors: SJ Pretorius, JA Myburgh, F Calitz, JJP Vivier**

Although Southern Africa GeoConsultants (Pty) Ltd exercises due care and diligence in rendering services and preparing documents, Southern Africa GeoConsultants (Pty) Ltd accepts no liability, and the client, by receiving this document, indemnifies Southern Africa GeoConsultants (Pty) Ltd and its directors, managers, agents and employees against all actions, claims, demands, losses, liabilities, costs, damages and expenses arising from or in connection with services rendered, directly or indirectly by Southern Africa GeoConsultants (Pty) Ltd and by the use of the information contained in this document..

This document contains confidential and proprietary information of Southern Africa GeoConsultants (Pty) Ltd. and is protected by copyright in favour of Southern Africa GeoConsultants (Pty) Ltd. and may not be reproduced, or used without the written consent of Southern Africa GeoConsultants (Pty) Ltd that has been obtained beforehand. This document is prepared exclusively for V3 Consulting Engineers and is subject to all confidentiality, copyright and trade secrets, rules, intellectual property law and practices of SOUTH AFRICA.

## Table of contents

1.	INTRODUCTION.....	1
1.1	TERMS OF REFERENCE .....	1
1.2	SCOPE OF INVESTIGATION .....	1
1.3	LOCATION OF STUDY AREA .....	1
1.4	INFORMATION SOURCES .....	1
2.	METHODOLOGY .....	2
2.1	HYDROGEOLOGICAL SURVEY .....	2
2.2	EVALUATION OF EXISTING EQUIPMENT .....	2
2.3	PUMP TESTING .....	2
2.4	CHEMICAL WATER ANALYSES .....	2
3.	RESULTS .....	4
3.1	HYDROGEOLOGICAL SETTING .....	4
3.2	LIAISON .....	4
3.3	BOREHOLE CENSUS .....	5
3.4	EXISTING EQUIPMENT .....	5
3.5	PUMP TESTING .....	5
3.6	WATER CHEMISTRY .....	6
4.	SUMMARY & RECOMMENDATIONS .....	8

# 1. INTRODUCTION

## 1.1 Terms of reference

Southern Africa GeoConsultants (PTY) Ltd – hereafter referred to as GeoCon - was appointed by V3 Consulting Engineers to carry out pump testing of existing boreholes at the town Hofmeyr in the former Stormberg district of the Eastern Cape Province.

This report gives results and recommendations resulting from the execution of potential determinative pump tests at four existing boreholes all of which is located within the boundaries of the study area.

## 1.2 Scope of investigation

GeoCon was appointed to only carry out the requested pump tests – with special reference made in the letter of appointment that “no elaborate test report will be required”, and that “only essential information will suffice”. It was however the opinion of Geocon to carry out the project in a responsible and professional manner within the budget framework – implicating the following inputs:

- Liaison with municipal offices and personnel
- Evaluation of three electrical driven mono pumps and one windmill
- Site evaluation - groundwater potential assessment
- Coordination and supervision of pump testing program
- Analyses of pump testing data
- Assessment of groundwater quality
- Reporting with utilization recommendations

## 1.3 Location of study area

The town Hofmeyr is located approximately 65 kilometers to the north of Cradock. The boreholes concerned are situated about 700 m outside the town next to the R401 gravel road that connects Hofmeyr with Tarkastad. (Figure 1).

## 1.4 Information sources


All information pertaining to the boreholes was obtained from on-site observations and reports from local municipality representative - Mr. Pat Downing.

- Geological information was obtained from the 1:250 000 scale geological map: (3124) Middelburg.
- Topographical information was obtained from the 1:50 000 scale topographical map: 3125DB Hofmeyr.
- Rainfall and water level data of the monitoring borehole HR5 for the last year was obtained from Mr. Downing.

# FIGURE 1: GEOLOGICAL MAP

## HOFMEYR GROUNDWATER INVESTIGATION

Scanned image – not to scale



### Legend

- Dolerite Dyke
- Alluvium
- Calcrete
- Dolerite
- Katberg Formation
- Project Area

Eastern Cape Province  
 8 Sarsen Street, Vincent  
 P.O. Box 203, Private Bag 2003  
 EAST LONDON  
 5200

Tel. No. +27 - 43 - 726 2070  
 Fax No. +27 - 43 - 726 9272  
 email: easton@geon.co.za



## 2. METHODOLOGY

### 2.1 Hydrogeological survey

A field inspection was carried out during which the local geological and hydrogeological conditions were evaluated. This information was required for aquifer definition, pump testing data analyses, recharge potential as well as water quality assessments and long-term sustainability determination.

### 2.2 Evaluation of existing equipment

This was carried out by the appointed pump testing contractor by measuring flow readings at different pressure settings while recording pump revolutions. This information was seen as sufficient to assess the condition of existing equipment as well as the yields available from the pumping equipment.

### 2.3 Pump testing

Pump testing was carried out under the co-ordination and guidance of the hydrogeological consultant. It was the aim of the pump testing exercise to determine the potential at each borehole and tests were adapted according to the yields observed. This resulted in some boreholes being pumped for longer periods than others. The aim at all times was to obtain maximum information regarding the local aquifer within the allowed budget and scope of the appointment.

The appointed pump-testing contractor executed pump testing under the supervision and guidance of the hydrogeological consultant at the existing boreholes. Pump testing was done using a positive displacement mono-type pump being driven by an engine equipped with a gearbox to be able to pump at different rates. Because the boreholes are in use, they were allowed to recover sufficiently before pump testing of the holes commenced.

Initial testing procedures involved calibration testing where no information or inaccurate information regarding the yield of a borehole exists. This was typically followed by a step drawdown test during which the water level response to different abstraction rates was measured. Results from this test were used to determine a safe and adequate rate at which to perform the constant rate drawdown test. The constant rate drawdown test was commenced once the water level has recovered sufficiently.

The water level response to the constant rate drawdown test, as well as the recovery after the test, was used to assess the hydraulic parameters of the aquifer. These results help to determine the safe long-term abstraction rates at each of the tested boreholes.

It must be noted that at least one of the existing boreholes had to remain pumping to maintain the water supply to the town throughout the entire pump testing phase.

Monitoring of boreholes nearest to the pumping borehole, was carried out where seen as feasible.

## 2.4 Chemical Water Analyses

A water sample was taken at the boreholes at the end of the pumping cycle of the last test carried out. Water was analyzed as far as its physical, chemical and microbiological quality is concerned where required.

Results were evaluated using the document:

*Quality of Domestic Water Supplies; Volume 1; Assessment Guide; Second Edition 1998;*  
*Water Research Commission No. TT101/98.*

The Water Quality Assessment Guide defines the following classes:


Class 0	Ideal water quality	Suitable for lifetime use
Class 1	Good water quality	Suitable for use, rare instances of negative effects.
Class 2	Marginal water quality	Conditionally acceptable. Negative effects may occur in some sensitive groups.
Class 3	Poor water quality	Unsuitable for use without treatment. Chronic effects may occur.
Class 4	Dangerous water quality	Totally unsuitable for use. Acute effects may occur.

### 3. RESULTS

#### 3.1 Hydrogeological Setting

According to the geological map the study area is covered by alluvium and underlain by sandstone and mudstone of the Katberg formation of the Tarkastad subgroup that forms part of the Beaufort Group belonging to the Karoo sequence of rocks (Figure 1). The Karoo sequence of rocks typically occurs as a horizontally orientated layered sequence. This sequence had been intruded by Dolerite in the form of sheets and dykes during the late Karoo volcanism. Most boreholes in the project area have been drilled associated with such dolerite dyke intrusions.

Data obtained from the monitoring borehole HR5 indicates that the static groundwater level is continuing to drop regardless of the rainfall in the area. This may be an indication that the local aquifer is being mismanaged. The graph of the rainfall and static water level at HR5 is shown below:



This data is however seen as insufficient to evaluate long term trends and it will be recommended that a more comprehensive monitoring program with data evaluation be implemented.


Four geophysical profiles comprising geomagnetic profiling - were executed in the direct vicinity of the four boreholes concerned. The aim of the geophysical survey was to delineate any geological structures that may influence the characteristics of the local aquifer. Results from the survey in combination with geological mapping indicated the presence of a dolerite dyke that separates boreholes HR1 and HR3 from boreholes HR2 and HR4. This dolerite dyke most probably divides the aquifer into compartments - affecting groundwater flow and recharge. The position of the dolerite dykes concerned are indicated in Figure 2. Geophysical profiles are indicated in Figure 3, and geomagnetic survey data is attached in Appendix D for reference. The prominent magnetic anomaly caused by the dolerite intrusion present is clearly seen in profile 1 for instance.

**FIGURE 2: LOCALITY MAP**

**HOFMEYER GROUNDWATER INVESTIGATION**

*Scanned image – not to scale*

- Legend**
- Borehole and Number
  - Monitoring borehole HRS
  - Dolerite Dyke
  - Other Boreholes




Eastern Cape Province  
8 Smeem Street, Vervet  
Postnet 303, Private Bag 30063  
EAST LONDON  
5200  
T4 No. +27 -43 - 726 2070  
Fax No. +27 -43 - 726 9232  
e-mail: eastlonder@gason.co.za



**FIGURE 3: GEOPHYSICAL MAP**

**HOFMEYR GROUNDWATER INVESTIGATION**

*Scanned image – not to scale*



**Legend**

- Existing Borehole
- Monitoring borehole HR5
- 1 Geophysical profile

Eastern Cape Province  
8 Sanson Street, Vincent  
Postnet 203, Private Bag 75063  
EAST LONDON  
5200  
Tel. No: +27 -43 - 726 2070  
Fax No: +27 -43 - 726 9222  
e-mail: eastlon@geoscon.com



### 3.2 Liaison

The first site visit was made on the 28<sup>th</sup> of June and procedures to be followed were discussed with the representative from the local municipality - Pat Downing. Existing boreholes that had to be tested were indicated and site verification and geological mapping was done. Liaison documentation is attached in Appendix A for reference.

### 3.3 Borehole census

Not forming part of the scope of this appointment – no formal borehole census was carried out outside of the target area. Several other boreholes were however noted in the area and these are indicated in Figure 2. The approximate location of the alternative abstraction zone – marked as “Well Field” in figure 2, is also indicated.

It will be strongly recommended that a regional borehole census be carried out to determine regional abstraction trends and volumes which will most definitely effect the municipal abstraction.

### 3.4 Existing equipment

Of the four boreholes concerned, HR1, HR2 and HR3 was equipped with electrical driven mono pumps, while HR4 was equipped with a windmill in disrepair. The pumphouses in which boreholes HR1 and HR2 is located is build out of brick and in a poor condition whilst borehole HR3 is located in a temporary sink pumphouse that is in a moderate to poor condition. Existing pump houses were destroyed as new pump houses are to be built as part of this project. The windmill (borehole nr. HR4) was non-operational and in poor condition at the time of the testing program. The monitoring borehole HR5 is in a good condition and is located inside a small metal house that is in a good condition.

### 3.5 Pump Testing

Pump testing at the boreholes involved calibration testing, step drawdown, constant rate drawdown and recovery testing.

Some boreholes were used as observation boreholes during the pump testing process.

- **Borehole number HR1** was found to be 48.30m deep with the static water level being at 10.88m. The test pump was installed at 41m – leaving 30.12m of drawdown available for pump testing purposes. Following calibration and step drawdown testing, the maximum yield at pump inlet was observed to be 10.04 l/s. A constant rate test was performed at 9.0 l/s for 48 hours. A drawdown of 12.25m was noted at the end of 48 hours – constituting 41% of the available drawdown. Water level recovery was 90% within 10 hours after pumping ceased. Borehole HR2 was being pumped throughout this test to maintain the water supply to the town at approximately 1.5 l/s. Borehole HR5 was monitored during the test and a drawdown of 0.32m was noted at the end of the 48 hr test.

➤ *It must be noted that an armed robbery took place during the recovery test period at this borehole. The contractor's site personnel were assaulted and their tent and some equipment set alight. All data recorded during this test was lost in the fire and evaluations and recommendations were made based on data recorded by the hydrogeologist throughout the testing procedure. The decision was made that this information is sufficient and that a re-test will not be required. Severe injuries incurred by the site personnel as well as the loss of equipment further made immediate re-testing impossible and water supply to the town had to be re-activated as soon as possible.*

➤ **Borehole number HR2** was found to be 49.07m deep with the static water level being at 10.33m. The test pump was installed at 45m – leaving 34.67m of drawdown available for pump testing purposes. Following calibration and step drawdown testing, a constant rate test was performed at 4.7 l/s for 48 hours. A drawdown of 10.24m was noted at the end of 48 hours – constituting 30% of the available drawdown. Water level recovery was 91% within 10 minutes after pumping ceased. Borehole HR1 was being pumped throughout this test to maintain the water supply to the town at approximately 2.5 l/s. Borehole HR5 was monitored during the test and a drawdown of 1.30m was noted at the end of the 48 hr test.

➤ **Borehole number HR3** was found to be 70.81m deep with the static water level being at 10.54m. The test pump was installed at 60m – leaving 49.46m of drawdown available for pump testing purposes. Following calibration and step drawdown testing, the maximum yield at pump inlet was observed to be 3.08 l/s. A constant rate test was performed at 2.13 l/s for 48 hours. A drawdown of 4.45m was noted at the end of 48 hours – constituting 9% of the available drawdown. Water level recovery was 93% within 1 hour after pumping ceased. Borehole HR1 was being pumped throughout this test to maintain the water supply to the town at approximately 2.5 l/s. Borehole HR5 was monitored during the test and a drawdown of 0.28m was noted at the end of the 48 hr test. Borehole HR4 was monitored during the test and a drawdown of 0.20m was noted at the end of the 48 hr test.

➤ **Borehole number HR4** was found to be 30.60m deep with the static water level being at 10.46m. The test pump was installed at 27m – leaving 16.54m of drawdown available for pump testing purposes. Following calibration and step drawdown testing, the maximum yield at pump inlet was observed to be 2.39 l/s. A constant rate test was performed at 1.8 l/s for 24 hours. A drawdown of 3.61m was noted at the end of 24 hours – constituting 22% of the available drawdown. Water level recovery was 95% within 7 minutes after pumping ceased. Borehole HR1 was being pumped throughout this test to maintain the water supply to the town at approximately 2.5 l/s.

Pump-testing data is given in Appendix B for reference.

### 3.6 Water Chemistry

Water samples taken were analyzed in terms of its microbiological and physical quality with the following results:

Borehole Nr.	DRINKING QUALITY		FOOD PREPARATION	BATHING	LAUNDRY
	Health	Aesthetic			
HR1	2	2	3	3	3
HR2	2	2	3	3	3
HR3	Not analysed	---	---	Future	Monitoring
HR4	2	2	3	3	3

Results were evaluated using the document:

*Quality of Domestic Water Supplies; Volume I; Assessment Guide; Second Edition 1998; Water Research Commission No. TT101/98.*

**Borehole HR1** has water of marginal drinking quality due to the following:

- ❖ *Slight bacteriological contamination*
- ❖ *High turbidity*
- ❖ *Water being hard to very hard*

Lathering of soap can be impaired with scaling of appliances most likely to occur. Chronic effects are possible in sensitive users due to hard water. Turbidity and bacteriological contamination will have to be addressed via appropriate water treatment.

**Borehole HR2** has water of marginal drinking quality due to the following:

- ❖ *Elevated turbidity*
- ❖ *Water being very hard*

Lathering of soap can be impaired with scaling of appliances most likely to occur. Chronic effects are possible in sensitive users due to hard water.

**Borehole HR4** has water of marginal drinking quality due to the following:

- ❖ *Water being very hard*

Lathering of soap can be impaired with scaling of appliances most likely to occur. Chronic effects are possible in sensitive users due to hard water.

Water analyses results is given in Appendix C for reference.

Sampling of borehole HR3 was not seen as necessary due to its proximity to the other boreholes and sufficient data being available for each of the two groundwater compartments present. Sampling of this borehole will however be recommended during the monitoring program.

#### 4. SUMMARY & RECOMMENDATIONS

- ❖ Groundwater potential in the target area is high, and is associated with the fracturing – induced by the dolerite intrusions present.
- ❖ Compartmentalization is possibly caused by the dolerite intrusions present but the dykes are not seen as aquicludes due to the high grade of weathering at shallow depths and shallow groundwater levels. This was confirmed by monitoring both compartments during the pumping process.
- ❖ Indication is that the main water strikes at the boreholes were within the first 20 to 30m from surface. This implicates that water level fluctuations during dry seasons could have an impact on the yield potential at the boreholes concerned.
- ❖ There is concern that the boreholes in this well field are located too close to each other and it will therefore be recommended that no more than one borehole from each compartment is utilized at any time.
- ❖ Water quality has to be evaluated in the light of the water having been used for many years already. There is no major concern in terms of the water quality with appropriate treatment to be considered where necessary.

The following recommendations are given:

- **Borehole HR1** is recommended for usage as main production borehole. The existing equipment in this borehole can be used only if upgrading can result in an abstraction rate not exceeding 4.8 l/s being possible. A pump installation depth of 45m is suitable. It is recommended that this borehole be pumped on a 24 hour cycle for one (1) month during which proper water level monitoring at all monitoring points take place. Evaluation of this data will indicate whether the cycle has to be changed to less than 24hrs. Construction of new pumping houses must address the possibility of contamination from polluted surface water – as noted from chemical water analyses.
- **Borehole HR2** is recommended as the second production borehole with the existing equipment installed in the borehole being suitable – but in need of refurbishment. A pump installation depth of 45m is suitable. An abstraction rate of 2.0 l/s must not be exceeded. This borehole is recommended for abstraction on a limited duty cycle of 8/24 hours. Construction of new pumping houses must address the possibility of contamination from polluted surface water – as noted from chemical water analyses.
- **Borehole nr HR3** is recommended for usage only as monitoring point and emergency/standby borehole in the instance where HR1 is not operational. The current equipment is suitable if refurbished, with an abstraction rate of 2.0 l/s, over a duty cycle of 8 hours, not to be exceeded. A pump installation depth of 60m is suitable.
- **Borehole HR4** is not recommended for equipping and must be used as monitoring borehole together with the Water Affairs borehole. It must be capped and protected for this purpose.
- Only Borehole HR3 will need conduit pipe installed together with the current equipment for monitoring purposes. This borehole together with the Water Affairs borehole as well as HR4 will be sufficient to monitor the different groundwater compartments present.

- It must be stressed that it was not the scope of this investigation to carry out a regional hydrogeological study and that only the four boreholes concerned had to be evaluated. It is of extreme importance that such an investigation be carried out as soon as possible for long term planning purposes and sustainability of the groundwater sources.
- The implementation of an initial weekly monitoring scheme – to be developed into a monthly program – is of utmost importance to monitor the reaction of the aquifer to the recommendations made. This data will have to include water levels, rainfall data as well as abstraction volumes and will have to be reviewed in 6 months time and changes made where necessary.
- A comprehensive water quality analyses – incorporating all boreholes used for municipal water supply, must be carried out before appropriate treatment options are considered.



# APPENDIX A

LIAISON DOCUMENTATION

LIAISON - LOCAL AUTHORITIES

S. A. GeoConsultants (Pty) Ltd

P / Bag X9063, Postnet 203

East London

Tel: 043 - 726 2070



Date:	28 June 2001
District:	
Community:	Hofmeyr
Project:	Hofmeyr Groundwater investigation

Objectives - GeoCon:	
	Borehole survey. First site visit

Objectives - Community:	

Authorities:

Name:	Position:	Signature:	Date:	Remarks:
P DOWNNEY	MUNICIPALITY	<i>[Signature]</i>	28/6/2001	
F.N. DE JAGER	GEOCON	<i>[Signature]</i>	28/6/2001	

# APPENDIX B

## PUMP TESTING DATA










DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1				OBSERVATION BOREHOLE 2				OBSERVATION BOREHOLE 3			
Time (min)	Drawdown (m)	Yield (gal)	Recovery (m)	Time (min)	Drawdown (m)	Recovery (m)	Time (min)	Drawdown (m)	Recovery (m)	Time (min)	Drawdown (m)	Recovery (m)	Time (min)	Drawdown (m)	Recovery (m)
1500				1500				1500					1500		
1560				1560				1560					1560		
1620				1620				1620					1620		
1680				1680				1680					1680		
1740				1740				1740					1740		
1800				1800				1800					1800		
1860				1860				1860					1860		
1920				1920				1920					1920		
1980				1980				1980					1980		
2040				2040				2040					2040		
2100				2100				2100					2100		
2160				2160				2160					2160		
2220				2220				2220					2220		
2280				2280				2280					2280		
2340				2340				2340					2340		
2400				2400				2400					2400		
2460				2460				2460					2460		
2520				2520				2520					2520		
2580				2580				2580					2580		
2640				2640				2640					2640		
2700				2700				2700					2700		
2760				2760				2760					2760		
2820				2820				2820					2820		
2880				2880				2880					2880		

DESCRIPTION:		QUANTITY:	UNIT:
ESTABLISHMENT		Sum	No
INTER HOLE MOVE > 10 km		Km.	No
FROM: SITE NAME:			
BOREHOLE No:			
INTER HOLE MOVE < 10 km:		No.	No
REMOVAL AND RE-ERECTION OF PUMP HOUSE:		No.	No
REMOVAL OF EXISTING EQUIPMENT:		No.	No
RE-INSTALLATION OF EXISTING EQUIPMENT:		No.	No
WORK TIME RATE (REPAIRS):		Hour	Hour
STANDING TIME:		Hour	Hour
LATITUDE:		LONGITUDE:	
DESCRIPTION:		QUANTITY:	UNIT:
STRAIGHTNESS TEST:			No
VERTICALITY TEST:			No
CASING DETECTION:			No
STEEL BOREHOLE COVER:			No
BOREHOLE MARKING:			No
SITE CLEANING / FINISHING:			No
REPORTING & DATA RECORDING:			No
SLUG TEST:			No
LAYFLAT (m):			m
BOREHOLE DEPTH AFTER TEST:			m
BOREHOLE WATERLEVEL AFTER TEST:			m

TEST DESCRIPTION	STEP	1	2	3	4	5	6	TOTAL:	RECOVERY:
CALIBRATION TEST:									
TEST DURATION (Minutes)		15	15	15	15	15	15	(min) (hrs)	(m) (min)
TEST YIELD (l/s)		0.90	2.15	4.12	7.66			60 1.00	0.20 2
DRAWDOWN (m)		0.24	0.59	1.44	4.01			MAXIMUM (l/s) 7.7	
MULTI-RATE / STEP DRAWDOWN:									
TEST DURATION (Minutes)		60	60	60	60			240 4.00	0.22 7
TEST YIELD (l/s)		2.21	4.09	5.90	9.46			MAXIMUM (l/s) 8.5	
DRAWDOWN (m)		0.0	1.37	2.58	5.09			MAXIMUM (m) 5.1	
CONSTANT DISCHARGE TEST									
TEST DURATION (min)	TEST DURATION (hrs)		TEST YIELD (l/s)		DRAWDOWN (m)		RECOVERY: %		
	2960	48.00	3.98	12.25	2.38	56.90	1800	30.20	
OBSERVATION BOREHOLES:		No.	720	1440	2880	>2880 (min)	TOTAL:		

RECOVERY TEST			
TIME TOTAL (hrs):		30.15	
Cal	Steps	CD	Total
2	7	1800	1809
DRAWDOWN TOTALS (CD):			
AVAILABLE	UTIL.	%	
34.1	12.25	35.90	

**BOREHOLE NUMBER: HR1  
CALIBRATION TEST AND RECOVERY**



**TEST INFORMATION**

Date tested	07/08/2001	Water level (mbgl)	10.88	Depth of pump (mbgl)	45
D duration	2880	CD discharge rate	8.980833333	CD drawdown	12.25
available drawdown (m)	34.12	% Recovery after CD	97	% after	1800 min

**CALIBRATION TEST AND RECOVERY**

BOREHOLE NO.:	HR2	PROJECT:	Hofmeyer
ALTERNATIVE NO.:		SITE NAME:	Hofmeyer Town
ALTERNATIVE NO.:		CLIENT:	

BOREHOLE DEPTH (m):	49.07	CASING DEPTH (m):	8.84	PUMP TYPE USED:	BP 22
DEPTH OF PUMP (m):	45.00	CASING HEIGHT (m):	0.00	OPERATOR:	Simon
PUMP INLET DIAMETER (mm):	110.00	CASING ID (mm):	200.00	CONTRACTOR:	AB Pumps
STATIC WATER LEVEL (m):	10.33	DIAMETER LEVEL (m):	0.44	SUPERVISOR:	M Oliver

DISCHARGE RATE 1						DISCHARGE RATE 2						DISCHARGE RATE 3					
DATE	TIME	Yield (l/s)	Time (min)	Recovery (m)	DATE	TIME	Yield (l/s)	Time (min)	Recovery (m)	DATE	TIME	Yield (l/s)	Time (min)	Recovery (m)			
27/07/2001	19H50		1		27/07/2001	20H10		1		27/07/2001	20H25		1				
		0.62	1				2.27	1				3.19	1				
		0.78	2				2.14	2				3.98	2				
		0.78	3				2.14	3				4.34	3				
		0.88	5				2.18	5				4.73	5				
		0.88	7				2.19	7				4.87	7				
		0.89	10				2.22	10				4.91	10				
		0.89	15				2.24	15				5.07	15				

<b>EXISTING EQUIPMENT DETAIL:</b>		20	<b>EXISTING EQUIPMENT DETAIL:</b>		20	<b>EXISTING EQUIPMENT DETAIL:</b>		20
TYPE OF RESERVOIR:	Concrete	40	TYPE OF ENCLOSURE:	None	40	PRESSURE GAUGE MANUFACTURER:		30
RESERVOIR SIZE:	E175	50	MATERIAL OF ENCLOSURE:		50	GAUGE READING (kPa):		40
RESERVOIR CONDITION:	air	60	CONDITION OF ENCLOSURE:		60	MONITORING FACILITY:		50
STAND HEIGHT (m):	Approx. 4m	90	WATER METER MANUFACTURER:		90	MAINTAINED:		60
		100	WATER METER READING:		100			70
		110			110			80
		120			120			90
		150			150			100
								110
								120
								150

DISCHARGE RATE 4						DISCHARGE RATE 5						DISCHARGE RATE 6					
DATE	TIME	Yield (l/s)	Time (min)	Recovery (m)	DATE	TIME	Yield (l/s)	Time (min)	Recovery (m)	DATE	TIME	Yield (l/s)	Time (min)	Recovery (m)			
27/07/2001	20H50		1		27/07/2001			1		27/07/2001			1				
		6.43	1					2					2	15.21			
		7.46	2					3					3	7.17			
		8.95	3					5					5	3.03			
		11.94	5					7					7	1.05			
		14.81	7					10					10	0.59			
		17.41	10					15					15	0.36			
		20.53	15														

<b>EXISTING EQUIPMENT DETAIL:</b>		20	<b>EXISTING EQUIPMENT DETAIL:</b>		20	<b>EXISTING EQUIPMENT DETAIL:</b>		20
PUMP TYPE:	lono pump	40	TYPE OF POWER:	Electric	40	TYPE OF RISER:	Steel	30
UMP MANUFACTURER:	Mono	50	ENGINE MANUFACTURER:		50	CLASS OF RISER:		40
UMP SERIAL No:	GW1301	60	ENGINE MODEL:		60	DIAMETER OF RISER (mm):	100mm	50
		70	ENGINE SERIAL No:		70	CONDITION OF RISER:	Fair	60
		80	ENGINE PULLEY DIAMETER (mm):	134mm	80	SHAFT DIAMETER (mm):	120	70
		90	POWER RATING (kW):	15kW	90	ELEMENT DIAMETER (mm):	150	80
		100	ENGINE CONDITION:	Good	100	ELEMENT STROKE (mm):	240	90
		110			110			100
		120			120			110
		150			150			120
								150
								180
								210
								240

COMMENTS:

- ump room demolish. Electric wiring and motor head servicing and repairs
- Column and rods need to be replaced
- ump lead bearing assembly and top rod to be replaced (pump incorrect installed)
- replace gland packing and seals
- Valve and non-return valve to be replaced

**STEPPED DISCHARGE TEST AND RECOVERY**

BOREHOLE NO.:	HR2	PROJECT:	Holmeyer
ALTERNATIVE NO.:	0	SITE NAME:	Holmeyer Town
BOREHOLE DEPTH (m):	49.07	CASING DEPTH (m):	8.84
DEPTH OF PUMP (m):	45.00	CASING HEIGHT (m):	0.00
PUMP INLET DIAMETER (mm):	110.000	CASING ID (mm):	200.000
STATIC WATER LEVEL (m):	10.33	DATUM LEVEL (m):	0.44
		PUMP TYPE USED:	BP 22
		OPERATOR:	Simon
		CONTRACTOR:	AB Pumps

DISCHARGE RATE 1				DISCHARGE RATE 2				DISCHARGE RATE 3			
DATE	TIME	Yield	Time	DATE	TIME	Yield	Time	DATE	TIME	Yield	Time
(mm)	(mm)	(l/s)	(min)	(mm)	(mm)	(l/s)	(min)	(mm)	(mm)	(l/s)	(min)
27/07/2001	21H15		1	27/07/2001	22H15		1	27/07/2001	23H15		1
			2				2				2
			3				3				3
			4				4				4
			5				5				5
			6				6				6
			7				7				7
			8				8				8
			9				9				9
			10				10				10
			11				11				11
			12				12				12
			13				13				13
			14				14				14
			15				15				15
			16				16				16
			17				17				17
			18				18				18
			19				19				19
			20				20				20
			21				21				21
			22				22				22
			23				23				23
			24				24				24
			25				25				25
			26				26				26
			27				27				27
			28				28				28
			29				29				29
			30				30				30
			31				31				31
			32				32				32
			33				33				33
			34				34				34
			35				35				35
			36				36				36
			37				37				37
			38				38				38
			39				39				39
			40				40				40
			41				41				41
			42				42				42
			43				43				43
			44				44				44
			45				45				45
			46				46				46
			47				47				47
			48				48				48
			49				49				49
			50				50				50
			51				51				51
			52				52				52
			53				53				53
			54				54				54
			55				55				55
			56				56				56
			57				57				57
			58				58				58
			59				59				59
			60				60				60
			61				61				61
			62				62				62
			63				63				63
			64				64				64
			65				65				65
			66				66				66
			67				67				67
			68				68				68
			69				69				69
			70				70				70
			71				71				71
			72				72				72
			73				73				73
			74				74				74
			75				75				75
			76				76				76
			77				77				77
			78				78				78
			79				79				79
			80				80				80
			81				81				81
			82				82				82
			83				83				83
			84				84				84
			85				85				85
			86				86				86
			87				87				87
			88				88				88
			89				89				89
			90				90				90
			91				91				91
			92				92				92
			93				93				93
			94				94				94
			95				95				95
			96				96				96
			97				97				97
			98				98				98
			99				99				99
			100				100				100
			101				101				101
			102				102				102
			103				103				103
			104				104				104
			105				105				105
			106				106				106
			107				107				107
			108				108				108
			109				109				109
			110				110				110
			111				111				111
			112				112				112
			113				113				113
			114				114				114
			115				115				115
			116				116				116
			117				117				117
			118				118				118
			119				119				119
			120				120				120

DISCHARGE RATE 4				DISCHARGE RATE 5				DISCHARGE RATE 6			
DATE	TIME	Yield	Time	DATE	TIME	Yield	Time	DATE	TIME	Yield	Time
(mm)	(mm)	(l/s)	(min)	(mm)	(mm)	(l/s)	(min)	(mm)	(mm)	(l/s)	(min)
27/07/2001	00H15		1	27/07/2001			1	27/07/2001			1
			2				2				2
			3				3				3
			4				4				4
			5				5				5
			6				6				6
			7				7				7
			8				8				8
			9				9				9
			10				10				10
			11				11				11
			12				12				12
			13				13				13
			14				14				14
			15				15				15
			16				16				16
			17				17				17
			18				18				18
			19				19				19
			20				20				20
			21				21				21
			22				22				22
			23				23				23
			24				24				24
			25				25				25
			26				26				26
			27				27				27
			28				28				28
			29				29				29
			30				30				30
			31				31				31
			32				32				32
			33				33				33
			34				34				34
			35				35				35
			36				36				36
			37				37				37
			38				38				38
			39				39				39
			40				40				40
			41				41				41
			42				42				42
			43				43				43
			44				44				44
			45				45				45
			46				46				46
			47				47				47
			48				48				48
			49				49				49
			50				50				50
			51				51				51
			52				52				52
			53				53				53
			54				54				54
			55				55				55
			56				56				56
			57				57				57
			58				58				58
			59				59				59
			60				60				60
			61				61				

**CONSTANT DISCHARGE TEST AND RECOVERY**

BOREHOLE NO.:		HR2		PROJECT		Holmeyer		CLIENT:		0				
ALTERNATIVE NO.:		0		SITE NAME		Holmeyer Town								
DEPTH OF PUMP (mhd):		45.00		PUMP TYPE/USED:		BP 22		OPERATOR:		Simon				
INLET DIAMETER (mm):		110		EXISTING EQUIPMENT:		Mono pump		CONTRACTOR:		AB PUMPS				
TEST DATE:	29/07/2001	TEST DATE:	29/09/2001	TOTAL TIME - PUMPED (min):	2880	TOTAL TEST TIME (min):	2280							
STARTED TIME:	11H30	COMPLETED TIME:	11H30	TOTAL TIME - RECOVERY (min):	1260	AVERAGE YIELD (lit):	4.72							
<b>DISCHARGE BOREHOLE</b>														
CASING HEIGHT (magl):	0.00	No.:	D/WAF	OBSERVATION BOREHOLE 1	No.:	OBSERVATION BOREHOLE 2	No.:	OBSERVATION BOREHOLE 3						
CASING DEPTH (mhd):	8.84	DATUM LEVEL (magl):			DATUM LEVEL (magl):		DATUM LEVEL (magl):							
CASING ID (magl):	200.00	CASING DEPTH (mhd):			CASING DEPTH (mhd):		CASING DEPTH (mhd):							
BOREHOLE DEPTH (mhd):	49.07	BOREHOLE DEPTH:			BOREHOLE DEPTH:		BOREHOLE DEPTH:							
WATER LEVEL (mhd):	10.33	WATER LEVEL:			WATER LEVEL:		WATER LEVEL:							
DATUM LEVEL (magl):	0.44	DISTANCE (m):			DISTANCE (m):		DISTANCE (m):							
Time:		Yield		Recovery		Time	Drawdown		Recovery		Time	Drawdown		Recovery
(min)	(m <sup>3</sup> )	(m <sup>3</sup> )	(m)	(min)	(m)	(min)	(m)	(min)	(m)	(min)	(m)	(m)	(min)	(m)
1	4.25		6.43	1		1		1		1				
2	4.77		3.06	2		2		2		2				
3	5.49		1.82	3		3		3		3				
5	6.35		1.18	5		5		5		5				
7	6.76		4.75	7		7		7		7				
10	7.13		0.90	10		10		10		10				
15	7.43		0.79	15		15		15		15				
20	7.70		0.75	20		20		20		20				
30	8.17		4.75	30		30		30		30				
40	8.41		0.64	40		40		40		40				
60	8.64		0.62	60		60		60		60				
90	8.87		4.74	90		90		90		90				
120	9.02		0.54	120		120		120		120				
150	9.04		0.52	150		150		150		150				
180	9.06		0.50	180		180		180		180				
210	9.10		4.75	210		210		210		210				
240	9.15		0.47	240		240		240		240				
300	9.26		4.69	300		300		300		300				
360	9.30		0.44	360		360		360		360				
420	9.46		4.69	420		420		420		420				
480	9.50		0.43	480		480		480		480				
540	9.54		4.70	540		540		540		540				
600	9.58		0.41	600		600		600		600				
660	9.62		4.70	660		660		660		660				
720	9.64		0.39	720		720		720		720				
780	9.67		4.75	780		780		780		780				
840	9.74		0.38	840		840		840		840				
900	9.78		4.75	900		900		900		900				
960	9.82		0.36	960		960		960		960				
1020	9.90		4.74	1020		1020		1020		1020				
1080	9.94		0.35	1080		1080		1080		1080				
1140	9.98		4.73	1140		1140		1140		1140				
1200	9.99		4.69	1200		1200		1200		1200				
1260	10.02		4.69	1260		1260		1260		1260				
1320	10.05			1320		1320		1320		1320				
1380	10.05		4.69	1380		1380		1380		1380				
1440	10.10		4.75	1440		1440		1440		1440				

DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1				OBSERVATION BOREHOLE 2				OBSERVATION BOREHOLE 3			
Time (min)	Drawdown (m)	Yield (l/s)	Recovery (m)	Time (min)	Drawdown (m)	Recovery (m)	Time (min)	Drawdown (m)	Recovery (m)	Time (min)	Drawdown (m)	Recovery (m)	Time (min)	Drawdown (m)	Recovery (m)
1500	10.12	4.75	1500	1500			1500			1500			1500		
1560	10.14	4.75	1560	1560			1560			1560			1560		
1620	10.14	4.75	1620	1620			1620			1620			1620		
1680	10.14	4.90	1680	1680			1680			1680			1680		
1740	10.15		1740	1740			1740			1740			1740		
1800	10.15	4.85	1800	1800			1800			1800			1800		
1860	10.16		1860	1860			1860			1860			1860		
1920	10.16	4.86	1920	1920			1920			1920			1920		
1980	10.17		1980	1980			1980			1980			1980		
2040	10.17	4.84	2040	2040			2040			2040			2040		
2100	10.18	4.82	2100	2100			2100			2100			2100		
2160	10.18		2160	2160	1.29		2160			2160			2160		
2220	10.19	4.83	2220	2220			2220			2220			2220		
2280	10.19		2280	2280			2280			2280			2280		
2340	10.20	4.84	2340	2340			2340			2340			2340		
2400	10.20		2400	2400			2400			2400			2400		
2460	10.21	4.83	2460	2460			2460			2460			2460		
2520	10.21		2520	2520			2520			2520			2520		
2580	10.22	4.84	2580	2580			2580			2580			2580		
2640	10.22	4.85	2640	2640			2640			2640			2640		
2700	10.23		2700	2700			2700			2700			2700		
2760	10.23	4.84	2760	2760			2760			2760			2760		
2820	10.24		2820	2820			2820			2820			2820		
2880	10.24		2880	2880	1.30		2880			2880			2880		

**DESCRIPTION:** QUANTITY: UNIT:

ESTABLISHMENT: \_\_\_\_\_

INTER HOLE MOVE > 10 km: \_\_\_\_\_ Sum Km.

FROM: SITE NAME: \_\_\_\_\_

BOREHOLE No.: \_\_\_\_\_

INTER HOLE MOVE < 10 km: \_\_\_\_\_ No.

REMOVAL AND RE-ERECTION OF PUMP HOUSE: \_\_\_\_\_ No.

REMOVAL OF EXISTING EQUIPMENT: \_\_\_\_\_ No.

RE-INSTALLATION OF EXISTING EQUIPMENT: \_\_\_\_\_ No.

WORK TIME RATE (REPAIRS): \_\_\_\_\_ Hour

STANDING TIME: \_\_\_\_\_ Hour

LATITUDE: \_\_\_\_\_ LONGITUDE: \_\_\_\_\_

**DESCRIPTION:** QUANTITY: UNIT:

STRAIGHTNESS TEST: \_\_\_\_\_ No

VERTICALITY TEST: \_\_\_\_\_ No

CASING DETECTION: \_\_\_\_\_ No

STEEL BOREHOLE COVER: \_\_\_\_\_ No

BOREHOLE MARKING: \_\_\_\_\_ No

SITE CLEANING / FINISHING: \_\_\_\_\_ No

REPORTING & DATA RECORDING: \_\_\_\_\_ No

SLUG TEST: \_\_\_\_\_ No

LAYFLAT (m): \_\_\_\_\_ m


BOREHOLE DEPTH AFTER TEST: \_\_\_\_\_ m

BOREHOLE WATERLEVEL AFTER TEST: \_\_\_\_\_ m

TEST DESCRIPTION	STEP	1	2	3	4	5	6	TOTAL	RECOVERY:																																																																		
CALIBRATION TEST:	TEST DURATION (minutes)	15	15	15	15	15	15	60	1.00																																																																		
	TEST YIELD (l/s)	1.09	2.22	4.04	6.83			MAXIMUM (l/s) 6.8	0.17																																																																		
MULTI-RATE / STEP DRAWDOWN:	DRAWDOWN (m)	0.99	2.27	5.07	20.53			MAXIMUM (m) 29.5																																																																			
	TEST DURATION (minutes)	60	60	60	60			240	4.00																																																																		
CONSTANT DISCHARGE TEST:	TEST YIELD (l/s)	0.97	2.11	3.32	5.62			MAXIMUM (l/s) 5.6	0.18																																																																		
	DRAWDOWN (m)	0.84	2.05	4.59	13.18			MAXIMUM (m) 13.2	0.18																																																																		
OBSERVATION BOREHOLES:	TEST DURATION (min)	2880	48 00	4 72	1440	2880	10 24	0.33	96 7.8																																																																		
	No. of boreholes	1	720	1440	2880	>2880 (min) n.r.	n.r.	Time	2880																																																																		
<table border="1"> <thead> <tr> <th colspan="3">RECOVERY TEST</th> <th colspan="3">RECOVERY TEST</th> </tr> <tr> <th>TIME TOTAL (hrs):</th> <th>CD</th> <th>Total</th> <th>TIME TOTAL (hrs):</th> <th>CD</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>21.83</td> <td></td> <td>20</td> <td>21.83</td> <td></td> <td>20</td> </tr> <tr> <td></td> <td></td> <td>30</td> <td></td> <td></td> <td>30</td> </tr> <tr> <td></td> <td></td> <td>1260</td> <td></td> <td></td> <td>1260</td> </tr> <tr> <td colspan="3">DRAWDOWN TOTALS (CD):</td> <td colspan="3">DRAWDOWN TOTALS (CD):</td> </tr> <tr> <td>AVAILABLE</td> <td>UTIL.</td> <td>%</td> <td>AVAILABLE</td> <td>UTIL.</td> <td>%</td> </tr> <tr> <td></td> <td></td> <td>34.7</td> <td></td> <td></td> <td>34.7</td> </tr> <tr> <td colspan="3">RECOVERY: _____</td> <td colspan="3">RECOVERY: _____</td> </tr> <tr> <td>(min)</td> <td>(min)</td> <td>(hrs)</td> <td>(min)</td> <td>(min)</td> <td>(hrs)</td> </tr> <tr> <td>2880</td> <td>48 00</td> <td>21 00</td> <td>2880</td> <td>48 00</td> <td>21 00</td> </tr> </tbody> </table>										RECOVERY TEST			RECOVERY TEST			TIME TOTAL (hrs):	CD	Total	TIME TOTAL (hrs):	CD	Total	21.83		20	21.83		20			30			30			1260			1260	DRAWDOWN TOTALS (CD):			DRAWDOWN TOTALS (CD):			AVAILABLE	UTIL.	%	AVAILABLE	UTIL.	%			34.7			34.7	RECOVERY: _____			RECOVERY: _____			(min)	(min)	(hrs)	(min)	(min)	(hrs)	2880	48 00	21 00	2880	48 00	21 00
RECOVERY TEST			RECOVERY TEST																																																																								
TIME TOTAL (hrs):	CD	Total	TIME TOTAL (hrs):	CD	Total																																																																						
21.83		20	21.83		20																																																																						
		30			30																																																																						
		1260			1260																																																																						
DRAWDOWN TOTALS (CD):			DRAWDOWN TOTALS (CD):																																																																								
AVAILABLE	UTIL.	%	AVAILABLE	UTIL.	%																																																																						
		34.7			34.7																																																																						
RECOVERY: _____			RECOVERY: _____																																																																								
(min)	(min)	(hrs)	(min)	(min)	(hrs)																																																																						
2880	48 00	21 00	2880	48 00	21 00																																																																						

**BOREHOLE NUMBER: HR2  
CALIBRATION TEST AND RECOVERY**

Discharge 1:	1.091	Discharge 2:	2.221	Discharge 3:	4.041	Discharge 4:	6.881	Discharge 5:		Discharge 6:	
--------------	-------	--------------	-------	--------------	-------	--------------	-------	--------------	--	--------------	--




- Discharge Rate 1
- Discharge Rate 2
- Discharge Rate 3
- Discharge Rate 4
- Recovery

Drawdown 1:	0.89
Drawdown 2:	2.27
Drawdown 3:	5.07
Drawdown 4:	20.53
Drawdown 5:	0.00
Drawdown 6:	0.00
Duration 1:	15
Duration 2:	15
Duration 3:	15
Duration 4:	15
Duration 5:	
Recovery (m):	0.17
Recovery (min):	20

**STEPPED DISCHARGE TEST AND RECOVERY**


Discharge 1:	0.9725	Discharge 2:	2.108	Discharge 3:	3.321	Discharge 4:	5.61667	Discharge 5:		Discharge 6:	
--------------	--------	--------------	-------	--------------	-------	--------------	---------	--------------	--	--------------	--



- Discharge rate 1
- Discharge rate 2
- Discharge rate 3
- Discharge rate 4
- Recovery
- Step 2
- Step 3
- Step 4

Drawdown 1:	0.84
Drawdown 2:	2.05
Drawdown 3:	4.59
Drawdown 4:	13.18
Drawdown 5:	0.00
Drawdown 6:	
Duration 1:	60
Duration 2:	60
Duration 3:	60
Duration 4:	60
Duration 5:	
Recovery (m):	0.18
Recovery (min):	30

**CONSTANT DISCHARGE TEST AND RECOVERY**



- Constant discharge rate
- Recovery

**TEST INFORMATION**

Date tested	28/07/2001	Water level (mbgl)	10.33	Depth of pump (mbgl)	45
Discharge duration	2880	CD discharge rate	4.72	CD drawdown	10.24
Available drawdown (m)	34.67	% Recovery after CD	97	% after	1260
				min	



**STEPPED DISCHARGE TEST AND RECOVERY**

BOREHOLE NO: **HR3 31250R 0001** PROJECT: **Holmeyer**  
 ALTERNATIVE NO: **0** SITE NAME: **Holmeyer Town**  
 ALTERNATIVE NO: **0** CLIENT: **S A Gaocan**  
 BOREHOLE DEPTH (meters): **70.81** CASING DEPTH (meters): **2.52** PUMP TYPE/USER: **BP22**  
 DEPTH OF PUMP (meters): **60.00** CASING HEIGHT (meters): **0.10** OPERATOR: **Isaac**  
 PUMP INLET DIAMETER (mm): **110.000** CASING ID (mm): **210.000** CONTRACTOR: **AB Pumps**  
 STATIC WATER LEVEL (meters): **10.54** DATE/TIME LEVEL: **0.29**

DISCHARGE RATE 1				DISCHARGE RATE 2				DISCHARGE RATE 3			
DATE	TIME	Yield	Time	DATE	TIME	Yield	Time	DATE	TIME	Yield	Time
19/07/2001	17H40	(l/s)	(min)	19/07/2001	18H40	(l/s)	(min)	19/07/2001	19H40	(l/s)	(min)
1	0.64		3	1	1.92		3	1	3.82		3
2	0.94		5	2	1.96		5	2	4.10		5
3	1.04	0.820	7	3	1.99	1.640	7	3	4.50	2.840	7
5	1.06	0.880	10	5	2.07	2.180	10	4	5.64	2.950	10
7	1.22	0.970	15	7	1.97	2.110	15	7	6.28	3.070	15
10	1.36	1.000	20	10	1.82	2.020	20	10	6.98		20
15	1.40	1.010	30	15	2.04		30	15	7.70	3.060	30
20	1.42	1.000	40	20	3.20	2.010	40	20	8.51		40
30	1.44	1.000	50	30	3.22	2.000	50	30	10.50	3.040	50
40	1.45		60	40	3.24		60	40	11.55	3.050	60
50	1.46	1.010	70	50	3.25	2.000	70	50	12.28		70
60	1.47	1.010	80	60	3.26	2.010	80	60	12.79	3.060	80
70			90	70			90	60			90
80			100	80			100	70			100
90			110	90			110	80			110
100			120	100			120	90			120
110			150	110			150	100			150
120			180	120			180	110			180
			210	210			210	120			210

Average yield: 0.9666667 l/s

Average yield: 1.99625 l/s

Average yield: 3.01 l/s

DISCHARGE RATE 4				DISCHARGE RATE 5				DISCHARGE RATE 6			
DATE	TIME	Yield	Time	DATE	TIME	Yield	Time	DATE	TIME	Yield	Time
19/07/2001		(l/s)	(min)	19/07/2001		(l/s)	(min)	19/07/2001		(l/s)	(min)
1			1	1			1	1			1
2			2	2			2	2			2
3			3	3			3	3			3
5			5	5			5	5			5
7			7	7			7	7			7
10			10	10			10	10			10
15			15	15			15	15			15
20			20	20			20	20			20
30			30	30			30	30			30
40			40	40			40	40			40
50			50	50			50	50			50
60			60	60			60	60			60
70			70	70			70	70			70
80			80	80			80	80			80
90			90	90			90	90			90
100			100	100			100	100			100
110			110	110			110	110			110
120			120	120			120	120			120

Average yield: #DIV/0!

DISCHARGE RATE 4				DISCHARGE RATE 5				DISCHARGE RATE 6			
DATE	TIME	Yield	Time	DATE	TIME	Yield	Time	DATE	TIME	Yield	Time
19/07/2001		(l/s)	(min)	19/07/2001		(l/s)	(min)	19/07/2001		(l/s)	(min)
1			1	1			1	1			1
2			2	2			2	2			2
3			3	3			3	3			3
5			5	5			5	5			5
7			7	7			7	7			7
10			10	10			10	10			10
15			15	15			15	15			15
20			20	20			20	20			20
30			30	30			30	30			30
40			40	40			40	40			40
50			50	50			50	50			50
60			60	60			60	60			60
70			70	70			70	70			70
80			80	80			80	80			80
90			90	90			90	90			90
100			100	100			100	100			100
110			110	110			110	110			110
120			120	120			120	120			120

Average yield: 780

COMMENTS:

**CONSTANT DISCHARGE TEST AND RECOVERY**

BOREHOLE NO.:		HR3		PROJECT:		Holmeyer		CLIENT:		S A Geocoon					
ALTERNATIVE NO.:		0		SITE NAME:		Holmeyer Town									
DEPTH OF PUMP (mhd):		60.00		PUMP TYPE USED:		BP22		OPERATOR:		Isaac					
INLET DIAMETER (mm):		110		EXISTING EQUIPMENT:		Mono PD		CONTRACTOR:		AB Pumps					
TEST DATE:		20/07/2001		TEST COMPLETED DATE:				TOTAL TIME PUMBED (min):		TOTAL TEST TIME (min):					
STARTED TIME:		12H10		COMPLETED TIME:				TOTAL TIME RECOVERY (min):		AVERAGE YIELD (l/s):					
DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1				OBSERVATION BOREHOLE 2				OBSERVATION BOREHOLE 3			
TASING HEIGHT (magh):		0.10		No.:		D/WAF Observation		No.:		Windmill					
CASING DEPTH (mhd):		2.52		DATUM LEVEL (magh):		0.29		DATUM LEVEL (magh):		0.66		DATUM LEVEL (magh):			
CASING ID (mm):		210.00		CASING DEPTH (mhd):				CASING DEPTH (mhd):		3		CASING DEPTH (mhd):			
BOREHOLE DEPTH (mhd):		70.81		BOREHOLE DEPTH:				BOREHOLE DEPTH:		30.6		BOREHOLE DEPTH:			
WATER LEVEL (magh):		10.54		WATER LEVEL:		1.5		WATER LEVEL:		10.46		WATER LEVEL:			
DATUM LEVEL (magh):		0.29		DISTANCE (m):		50		DISTANCE (m):		110		DISTANCE (m):			
Time		Drawdown		Yield		Recovery		Time		Drawdown		Recovery		Time	
(min)		(m)		(t/d)		(m)		(min)		(m)		(m)		(min)	
1		1.78		3.80		1		1		1		1		1	
2		2.51		2.10		2.09		2		2		2		2	
3		2.81		2.22		1.22		3		3		3		3	
4		3.03		2.22		0.52		5		5		5		5	
5		3.50				0.42		7		7		7		7	
6		3.61		2.10		0.37		10		10		10		10	
7		3.80		2.10		0.34		15		15		15		15	
8		3.83		2.10		0.33		20		20		20		20	
9		3.86				0.31		30		30		30		30	
10		3.88				0.30		40		40		40		40	
11		3.90		2.08		0.29		60		60		60		60	
12		3.93				0.29		90		90		90		90	
13		3.96		2.13				120		120		120		120	
14		3.98						150		150		150		150	
15		3.98		2.15				180		180		180		180	
16		3.99						210		210		210		210	
17		3.99						240		240		240		240	
18		4.01		2.14				300		300		300		300	
19		4.03		2.10				360		360		360		360	
20		4.05		2.11				420		420		420		420	
21		4.08		2.12				480		480		480		480	
22		4.13		2.13				540		540		540		540	
23		4.14		2.11				600		600		600		600	
24		4.16		2.14				720		720		720		720	
25		4.18		2.12				840		840		840		840	
26		4.20		2.13				960		960		960		960	
27		4.22		2.14				1080		1080		1080		1080	
28		4.24		2.13				1200		1200		1200		1200	
29		4.27		2.12				1260		1260		1260		1260	
30		4.29		2.13				1320		1320		1320		1320	
31		4.31		2.13				1380		1380		1380		1380	
32		4.33		2.14				1440		1440		1440		1440	
33		4.35		2.12				2880		2880		2880		2880	
34		4.36		2.12				2880		2880		2880		2880	
35		4.36		2.13				2880		2880		2880		2880	
36		4.37		2.14				2880		2880		2880		2880	
37		4.37		2.12				2880		2880		2880		2880	
38		4.37		2.12				2880		2880		2880		2880	



**BOREHOLE NUMBER: HR3  
CALIBRATION TEST AND RECOVERY**


Discharge 1:	1.04	Discharge 2:	1.72	Discharge 3:	3.50	Discharge 4:	6.39	Discharge 5:		Discharge 6:	
Drawdown 1:	1.51	Drawdown 2:	3.30	Drawdown 3:	16.44	Drawdown 4:	50.84	Drawdown 5:	0.00	Drawdown 6:	0.00
Duration 1:	15	Duration 2:	15	Duration 3:	15	Duration 4:	10	Duration 5:		Duration 6:	
Recovery (m):	0.22	Recovery (m):	0.22	Recovery (min):	20						

TIME (t) IN MINUTES

- Discharge Rate 1
- Discharge Rate 2
- Discharge Rate 3
- Discharge Rate 4
- Recovery


Discharge 1:	0.96667	Discharge 2:	1.99625	Discharge 3:	3.01	Discharge 4:		Discharge 5:		Discharge 6:	
Drawdown 1:	1.47	Drawdown 2:	3.26	Drawdown 3:	12.75	Drawdown 4:	0.00	Drawdown 5:	0.00	Drawdown 6:	0.00
Duration 1:	60	Duration 2:	60	Duration 3:	60	Duration 4:	60	Duration 5:	60	Duration 6:	60
Recovery (m):	0.15	Recovery (m):	0.15	Recovery (min):	15						

**STEPPED DISCHARGE TEST AND RECOVERY**



- Discharge rate 1
- Discharge rate 2
- Discharge rate 3
- Recovery
- Step 2
- Step 3

**CONSTANT DISCHARGE TEST AND RECOVERY**



- Constant discharge rate
- Recovery

**TEST INFORMATION**

Date tested	20/07/2001	Water level (mbgl)	10.54	Depth of pump (mbgl)	60
CD duration	0	CD discharge rate	2.13	CD drawdown	4.45
Available drawdown (m)	49.46	% Recovery after CD	93	% after	0
				min	



**STEPPED DISCHARGE TEST AND RECOVERY**

BORERHOLE NO.:	HR4	PROJECT:	217500002	PROJECT:	Hotmeyer
ALTERNATIVE NO.:	0	SITE NAME:		SITE NAME:	Hotmeyer Town
BORERHOLE DEPTH (m):	30.60	CASING DEPTH (m):	3.00	PUMP TYPE USED:	BP 22
DEPTH OF PUMP (m):	27.00	CASING HEIGHT (m):	0.44	OPERATOR:	JOSEPH / ISAAC
PUMP INLET DIAMETER (mm):	0.110	CASING ID (mm):	1.660	CONTRACTOR:	AB PUMPS
STATIC WATER LEVEL (m):	10.46	DATUM LEVEL (m):	0.66		

DISCHARGE RATE 1				DISCHARGE RATE 2				DISCHARGE RATE 3			
DATE	TIME	Time (min)	Recovery (m)	DATE	TIME	Time (min)	Recovery (m)	DATE	TIME	Time (min)	Recovery (m)
24/07/2001	12H30	1	1	24/07/2001	01H30	1	1	24/07/2001		1	
		2	2			2	2			2	
		3	3			3	3			3	
		5	5			5	5			5	
		7	7			7	7			7	
		10	10			10	10			10	
		15	15			15	15			15	
		20	20			20	20			20	
		30	30			30	30			30	
		40	40			40	40			40	
		50	50			50	50			50	
		60	60			60	60			60	
		70	70			70	70			70	
		80	80			80	80			80	
		90	90			90	90			90	
		100	100			100	100			100	
		110	110			110	110			110	
		120	120			120	120			120	
Average yield: 0.6322222				Average yield: 0.9933333				Average yield: 2.055			

DISCHARGE RATE 4				DISCHARGE RATE 5				DISCHARGE RATE 6			
DATE	TIME	Time (min)	Recovery (m)	DATE	TIME	Time (min)	Recovery (m)	DATE	TIME	Time (min)	Recovery (m)
24/07/2001		1	1	24/07/2001		1	1	24/07/2001		1	4.60
		2	2			2	2			2	1.40
		3	3			3	3			3	0.22
		5	5			5	5			5	
		7	7			7	7			7	
		10	10			10	10			10	
		15	15			15	15			15	
		20	20			20	20			20	
		30	30			30	30			30	
		40	40			40	40			40	
		50	50			50	50			50	
		60	60			60	60			60	
		70	70			70	70			70	
		80	80			80	80			80	
		90	90			90	90			90	
		100	100			100	100			100	
		110	110			110	110			110	
		120	120			120	120			120	
Average yield: #DIV/0!				Average yield: 2.40				Average yield: 7.20			

COMMENTS:

360	300	300	360	420	480	540	600	660	720	780
Average yield: 7.20										

**CONSTANT DISCHARGE TEST AND RECOVERY**

BOREHOLE NO. :		HR4		PROJECT		Hofmeyer		CLIENT :		Hofmeyer Town	
ALTERNATIVE NO. :		0		SITENAME		Hofmeyer Town					
DEPTH OF PUMP (mbsl):		27.00		PUMP TYPE USED:		BP 22		OPERATOR:		JOSEPH / ISAAC	
INLET DIAMETER (mm):		0.11		EXISTING EQUIPMENT:		NO		CONTRACTOR:		AB PUMPS	
TEST DATE:		24/07/2001		TEST DATE:		25/07/2001		TOTAL TIME - PUMPED (min):		1440	
STARTED TIME:		05H10		COMPLETED TIME:		05H17		TOTAL TIME RECOVERY (min):		7	
								AVERAGE YIELD (l/hr)		1.78	
DISCHARGE BOREHOLE											
CASING HEIGHT (mbsl):		0.44		No.		OBSERVATION BOREHOLE 1		No.		OBSERVATION BOREHOLE 2	
CASING DEPTH (mbsl):		3.00		DATUM LEVEL (mbsl):				DATUM LEVEL (mbsl):			
CASING ID (mm):		1.65		CASING DEPTH (mbsl):				CASING DEPTH (mbsl):			
BOREHOLE DEPTH (mbsl):		30.60		BOREHOLE DEPTH:				BOREHOLE DEPTH:			
WATER LEVEL (mbsl):		10.46		WATER LEVEL:				WATER LEVEL:			
DATUM LEVEL (mbsl):		0.66		DISTANCE (m):				DISTANCE (m):			
Time		Drawdown		Yield		Recovery		Time		Drawdown	
(min)		(mbsl)		(gsl)		(m)		(min)		(mbsl)	
1	0.94	1.49	0.95	1				1			
2	1.89	1.75	0.34	2				2			
3	2.09	1.51	0.26	3				3			
5	2.29		0.22	5				5			
7	2.69	1.82	0.18	7				7			
10	2.83	1.83		10				10			
15	2.87			15				15			
20	2.90			20				20			
30	2.92	1.81		30				30			
40	2.94			40				40			
60	2.96	1.81		60				60			
90	2.97	1.79		90				90			
120	2.98	1.80		120				120			
150	2.99	1.80		150				150			
180	3.02	1.83		180				180			
210	3.04			210				210			
240	3.06			240				240			
300	3.08	1.82		300				300			
360	3.10	1.80		360				360			
420	3.12			420				420			
480	3.14	1.83		480				480			
540	3.17			540				540			
600	3.19	1.82		600				600			
660	3.22	1.81		720				720			
720	3.25	1.80		840				840			
780	3.28	1.83		960				960			
840	3.31	1.81		1080				1080			
900	3.36	1.80		1200				1200			
960	3.38	1.83		1320				1320			
1020	3.40	1.84		1440				1440			
1080	3.43	1.82		1800				1800			
1140	3.46			2280				2280			
1200	3.49			2880				2880			
1260	3.52										
1320	3.55										
1380	3.57										
1440	3.61										

DISCHARGE BOREHOLE			OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3			
Time (min)	Drawdown (m)	Yield (gal)	Recovery (m)	Time (min)	Drawdown (m)	Recovery (m)	Time (min)	Drawdown (m)	Recovery (m)	Time (min)	Drawdown (m)	Recovery (m)
1500			1500		1500		1500		1500		1500	
1560			1560		1560		1560		1560		1560	
1620			1620		1620		1620		1620		1620	
1680			1680		1680		1680		1680		1680	
1740			1740		1740		1740		1740		1740	
1800			1800		1800		1800		1800		1800	
1860			1860		1860		1860		1860		1860	
1920			1920		1920		1920		1920		1920	
1980			1980		1980		1980		1980		1980	
2040			2040		2040		2040		2040		2040	
2100			2100		2100		2100		2100		2100	
2160			2160		2160		2160		2160		2160	
2220			2220		2220		2220		2220		2220	
2280			2280		2280		2280		2280		2280	
2340			2340		2340		2340		2340		2340	
2400			2400		2400		2400		2400		2400	
2460			2460		2460		2460		2460		2460	
2520			2520		2520		2520		2520		2520	
2580			2580		2580		2580		2580		2580	
2640			2640		2640		2640		2640		2640	
2700			2700		2700		2700		2700		2700	
2760			2760		2760		2760		2760		2760	
2820			2820		2820		2820		2820		2820	
2880			2880		2880		2880		2880		2880	

**DESCRIPTION:** ESTABLISHMENT: QUANTITY: UNIT:

ENTER HOLE MOVE > 10 km: Sum Km.

FROM: SITE NAME: \_\_\_\_\_

BOREHOLE No: \_\_\_\_\_

ENTER HOLE MOVE < 10 km: No.

REMOVAL AND RE-EJECTION OF PUMP HOUSE: No.

REMOVAL OF EXISTING EQUIPMENT: No.

RE-INSTALLATION OF EXISTING EQUIPMENT: No.

WORK TIME RATE (REPAIRS): No.

STANDING TIME: Hour

LATITUDE: \_\_\_\_\_ LONGITUDE: \_\_\_\_\_

**DESCRIPTION:** QUANTITY: UNIT:

STRAIGHTNESS TEST: No.

VERTICALITY TEST: No.

CASING DETECTION: No.

STEEL BOREHOLE COVER: No.

BOREHOLE MARKING: No.

SITE CLEANING / FINISHING: No.

REPORTING & DATA RECORDING: No.

SLUG TEST: No.

LAYFLAT (m): m

BOREHOLE DEPTH AFTER TEST: m

BOREHOLE WATERLEVEL AFTER TEST: m

TEST DESCRIPTION	STEP	1	2	3	4	5	6	TOTAL (min)	RECOVERY (hrs)	RECOVERY (%)
<b>CALIBRATION TEST:</b>										
TEST DURATION (minutes)		15	15	15				45	0.75	0.18
TEST YIELD (l/s)		0.79	1.90	3.49				MAXIMUM (l/s) 3.5		
DRAWDOWN (m)		1.32	4.20	15.20				MAXIMUM (m) 15.2		
<b>MULTI-RATE / STEP DRAWDOWN:</b>										
TEST DURATION (minutes)		60	60	60				180	3.00	0.22
TEST YIELD (l/s)		0.53	0.99	2.06				MAXIMUM (l/s) 2.1		
DRAWDOWN (m)		0.9	1.46	5.32				MAXIMUM (m) 5.3		


RECOVERY TEST		
TIME TOTAL (hrs):	0.28	
Cal Steps	7	Total
	3	7
DRAWDOWN TOTALS (CD):		
AVAILABLE	UTIL-	%
16.5	3.51	21.33

CONSTANT DISCHARGE TEST		
TEST DURATION (min)	1440	
TEST YIELD (l/s)	1.73	
DRAWDOWN (m)	3.51	
RECOVERY (%)	0.18	
RECOVERY (min)	95.01	
TOTAL (hrs)	0.25	

OBSERVATION BOREHOLES:		
No. of boreholes	1440	
TEST DURATION (hrs)	720	
TEST YIELD (l/s)	1.440	
DRAWDOWN (m)	2880	
RECOVERY (min)	>2880	
TOTAL (hrs)	0.30	


**BOREHOLE NUMBER: HR4  
CALIBRATION TEST AND RECOVERY**

Discharge 1:	0.79	Discharge 2:	1.90	Discharge 3:	3.49	Discharge 4:		Discharge 5:		Discharge 6:	
										Drawdown 1:	1.32
										Drawdown 2:	4.20
										Drawdown 3:	16.20
										Drawdown 4:	0.00
										Drawdown 5:	0.00
										Drawdown 6:	0.00
										Duration 1:	15
										Duration 2:	15
										Duration 3:	15
										Duration 4:	15
										Duration 5:	
										Duration 6:	
										Recovery (m):	0.18
										Recovery (min):	7




- Discharge Rate 1
- Discharge Rate 2
- Discharge Rate 3
- Recovery

Discharge 1:	0.63222	Discharge 2:	0.99333	Discharge 3:	2.056	Discharge 4:		Discharge 5:		Discharge 6:	
										Drawdown 1:	0.90
										Drawdown 2:	1.46
										Drawdown 3:	5.32
										Drawdown 4:	0.00
										Drawdown 5:	0.00
										Drawdown 6:	0.00
										Duration 1:	60
										Duration 2:	60
										Duration 3:	60
										Duration 4:	60
										Duration 5:	60
										Duration 6:	60
										Recovery (m):	0.22
										Recovery (min):	3



- Discharge rate 1
- Discharge rate 2
- Discharge rate 3
- Recovery
- Step 2
- Step 3

Discharge 1:	0.63222	Discharge 2:	0.99333	Discharge 3:	2.056	Discharge 4:		Discharge 5:		Discharge 6:	
										Drawdown 1:	0.90
										Drawdown 2:	1.46
										Drawdown 3:	5.32
										Drawdown 4:	0.00
										Drawdown 5:	0.00
										Drawdown 6:	0.00
										Duration 1:	60
										Duration 2:	60
										Duration 3:	60
										Duration 4:	60
										Duration 5:	60
										Duration 6:	60
										Recovery (m):	0.22
										Recovery (min):	3



- Constant discharge rate
- Recovery

**TEST INFORMATION**

Date tested	24/07/2001	Water level (mbgl)	10.46	Depth of pump (mbgl)	
CD duration	1440	CD discharge rate	1.78	CD drawdown	27
Available drawdown (m)	16.54	% Recovery after CD	95	% after	7
				min	3.61

# APPENDIX C

## CHEMICAL WATER ANALYSES

Hofmeyr

Borehole Id

HR1

Date Sampled

01-Aug-01

Drinking water class

2

Sample Number

GC059

Micro-biological properties		Class
Viable organisms		
Faecal coliforms	0.00	0
Total coliforms	15.00	2

Physical Properties	EC	mS / m	1
Electrical Conductivity	EC	110.60	1
Total Dissolved Salts	TDS	mg / l	
pH Value	pH	7.06	0
Turbidity	NTU	3.00	2

Chemical properties	As	mg / l	
Arsenic	As	mg / l	
Cadmium	Cd	mg / l	
Calcium	Ca	mg / l	65.00
Chloride	Cl	mg / l	94.00
Copper	Cu	mg / l	0
Fluoride	F	mg / l	0.25
Iron	Fe	mg / l	0.14
Total Hardness	CaCO <sub>3</sub>	mg / l	351.70
Magnesium	Mg	mg / l	46.00
Manganese	Mn	mg / l	0
Nitrate	N	mg / l	1.30
Nitrite	NO <sub>2</sub>	mg / l	0
Potassium	K	mg / l	4.10
Sodium	Na	mg / l	70.00
Sulphate	SO <sub>4</sub>	mg / l	78.00
Zinc	Zn	mg / l	0

Chemical properties (not required for the classification of domestic drinking water supply)	NH <sub>4</sub>	mg / l	0.09
Ammonia	NH <sub>4</sub>	mg / l	0.09
P - Alkalinity	CaCO <sub>3</sub>	mg / l	269.00
M - Alkalinity	CaCO <sub>3</sub>	mg / l	189.40
Calcium Hardness	CaCO <sub>3</sub>	mg / l	162.30
Magnesium Hardness	CaCO <sub>3</sub>	mg / l	
Carbonate	CaCO <sub>3</sub>	mg / l	
Bicarbonate	HCO <sub>3</sub>	mg / l	
Silica	Si	mg / l	
Phosphor	PO <sub>4</sub> as P	mg / l	

Hofmeyr

Borehole Id

Date Sampled

Drinking water class

Sample Number

HR2

01-Aug-01

2

GC0060

Micro-biological properties		Class
Viable organisms		
Faecal coliforms	0.00	0
Total coliforms	0.00	0

Physical Properties	EC	MS/m	
Electrical Conductivity	EC	132.70	1
Total Dissolved Salts	TDS	mg/l	
pH Value	pH	7.33	0
Turbidity	NTU	6.10	2

Chemical properties	As		
Arsenic	As	mg/l	
Cadmium	Cd	mg/l	
Calcium	Ca	mg/l	73.00
Chloride	Cl	mg/l	134.00
Copper	Cu	mg/l	
Fluoride	F	mg/l	0.10
Iron	Fe	mg/l	0.41
Total Hardness	CaCO <sub>3</sub>	mg/l	417.00
Magnesium	Mg	mg/l	57.00
Manganese	Mn	mg/l	
Nitrate	N	mg/l	2.00
Nitrate	NO <sub>3</sub>	mg/l	
Potassium	K	mg/l	4.30
Sodium	Na	mg/l	98.00
Sulphate	SO <sub>4</sub>	mg/l	98.00
Zinc	Zn	mg/l	0

Chemical properties (not required for the classification of domestic drinking water supply)	NH <sub>4</sub>		
Ammonia	NH <sub>4</sub>	mg/l	0.09
P - Alkalinity	CaCO <sub>3</sub>	mg/l	280.00
M - Alkalinity	CaCO <sub>3</sub>	mg/l	234.70
Calcium Hardness	CaCO <sub>3</sub>	mg/l	182.30
Magnesium Hardness	CaCO <sub>3</sub>	mg/l	
Carbonate	CaCO <sub>3</sub>	mg/l	
Bicarbonate	HCO <sub>3</sub>	mg/l	
Silica	Si	mg/l	
Phosphor	PO <sub>4</sub> as P	mg/l	

Borehole Id

HR4

Date Sampled

25-JUL-01

Drinking water class

2

Sample Number

GC062

Micro-biological properties	Class	
Viable organisms		
Faecal coliforms	0.00	0
Total coliforms	5.00	1

Physical Properties	EC	ms / m	1
Electrical Conductivity	EC	ms / m	121.30
Total Dissolved Salts	TDS	mg / l	
pH Value	pH		6.90
Turbidity		NTU	0.90


Chemical properties			
Arsenic	As	mg / l	
Cadmium	Cd	mg / l	
Calcium	Ca	mg / l	75.00
Chloride	Cl	mg / l	128.00
Copper	Cu	mg / l	
Fluoride	F	mg / l	0.10
Iron	Fe	mg / l	0.01
Total Hardness	CaCO <sub>3</sub>	mg / l	401.40
Magnesium	Mg	mg / l	52.00
Manganese	Mn	mg / l	
Nitrate	N	mg / l	2.10
Nitrate	NO <sub>3</sub>	mg / l	
Potassium	K	mg / l	3.70
Sodium	Na	mg / l	85.00
Sulphate	SO <sub>4</sub>	mg / l	99.00
Zinc	Zn	mg / l	0

Chemical properties (not required for the classification of domestic drinking water supply)			
Ammonia	NH <sub>4</sub>	mg / l	0.09
P - Alkalinity	CaCO <sub>3</sub>	mg / l	275.00
M - Alkalinity	CaCO <sub>3</sub>	mg / l	214.10
Calcium Hardness	CaCO <sub>3</sub>	mg / l	187.30
Magnesium Hardness	CaCO <sub>3</sub>	mg / l	
Carbonate	CaCO <sub>3</sub>	mg / l	
Bicarbonate	HCO <sub>3</sub>	mg / l	
Silica	Si	mg / l	
Phosphor	PO <sub>4</sub> as P	mg / l	


# APPENDIX D

GEOPHYSICAL DATA


# HOFMEYR - Profile 1



### HOFMEYR - Profile 2



### HOFMEYR - Profile 3



MAGNETIC

### HOFMEYR - Profile 4

