


GROUNDWATER RESOURCE INFORMATION PROJECT EASTERN CAPE PROVINCE

GROUNDWATER INFORMATION SOURCE REFERENCE SHEET



SOURCE
REF NR:

AG053	Own Archive	X	Copy attached	X
	Sourced		Copy at source	

A: SOURCE DESCRIPTION

District Municipality:	Amatole	Chris Hanj	X	O.R Tambo
	Ukhahlamba	Cacadu		Alfred Nzo
Local Municipality:	Lukanji			
Institution where Information is held:	AGES EC CC			
Branch of Institution:	EAST LONDON			
Contact details:	Contact person:	JAN MYBURGH		
	Contact Tel:	043 7262070		
	Contact Email:	easterncape@ages-group.com		

B: TYPE OF INFORMATION

Information format:	Hard copy	X	Data Summary		Electronic Report	
	Specify Other:					
Report / Info Title:	Pump testing evaluation of existing boreholes at Sterkstroom Eastern Cape Province					
Report Nr:	EC/02/02/HG	Date:	May 2002			
Author Details:	J.A MYBURGH					
Author's Qualification:	Hydrogeologist	X	Govt Dept		Project Manager	
	Engineer		Technician		Other	
Captured by:	Specify Other:					
	A VILJOEN	Date:	23/2/2004	Signed:	<i>Alipen</i>	

C: GEOHYDROLOGICAL CATEGORIZATION

Project Type	Source development	X	Feasibility Study		Sanitation Study:	
	Specify Other:					
Reference Co-ordinate:	Latitude	S 31° 32' 57"		Longitude	E 26° 32' 58"	
Lithological & Construction Logs	Yes	No	Complete	Incomplete		
Hydrocensus Data	X	X	X			
Pump Testing Data	X		X			
Chemical Water Analysis Data	X		X			
Geohydrological Data <i>Myf</i>	X			X		
Spring Data		X				
Remote Sensing Data		X				
Map Data	X			X		

Comments:

Reviewed by: *J.A. MYBURGH* Date: *27/2/04* Signed: *[Signature]*

Project report:

EC/02/02/HG



Hydrogeological investigation

Pump Testing Evaluation of existing boreholes at
STERKSTROOM – Eastern Cape Province

May 2002

Project team:

J.A. Myburgh,
F.N. De Jager,

SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD

0

GeoCon Copy

Project report:

EC/02/02/HG

Hydrogeological investigation


**Pump Testing Evaluation of existing boreholes
STERKSTROOM – Eastern Cape Province**

May 2002

Conducted on behalf of:
KWEZI V3 ENGINEERS
P.O.Box
Tecoma
PORT ELIZABETH

Mr. C. Louw
Tel. No.: (041) 391 8811
Fax. No.: (041) 364 3798

Compiled by:



J.A. Myburgh (BSc Hons)
Consulting Hydrogeologist – Pr.Sci.Nat.

Limpopo Province

4 Hans van Rensburg Rd
P.O. Box 2526
PIETERSBURG
0700
Tel. No.: +27 - 15 - 291 1577
Fax. No.: +27 - 15 - 291 1702
e-mail: pietersburg@geocon.co.za

Gauteng Province

66 Paradissi Street, Highveld X8
Postnet, Suite 12, Private Bag
X108
CENTURION
0046
Tel. No.: +27 - 12 - 665 3100
Fax. No.: +27 - 12 - 665 2176
e-mail: centurion@geocon.co.za

Eastern Cape Province

8 Sansom Street, Vincent
Postnet 203, Private Bag X9063
EAST LONDON
5200
Tel. No.: +27 - 43 - 726 2070
Fax. No.: +27 - 43 - 726 9232
e-mail: eastlondon@geocon.co.za

Directors: SJ Pretorius, JA Myburgh, F Calitz, JJP Vivier

GEOCON COPY

Although Southern Africa GeoConsultants (Pty) Ltd exercises due care and diligence in rendering services and preparing documents, Southern Africa GeoConsultants (Pty) Ltd accepts no liability, and the client, by receiving this document, indemnifies Southern Africa GeoConsultants (Pty) Ltd and its directors, managers, agents and employees against all actions, claims, demands, losses, liabilities, costs, damages and expenses arising from or in connection with services rendered, directly or indirectly by Southern Africa GeoConsultants (Pty) Ltd and by the use of the information contained in this document..

This document contains confidential and proprietary information of Southern Africa GeoConsultants (Pty) Ltd. and is protected by copyright in favour of Southern Africa GeoConsultants (Pty) Ltd. and may not be reproduced, or used without the written consent of Southern Africa GeoConsultants (Pty) Ltd that has been obtained beforehand. This document is prepared exclusively for Kwezi V3 Engineers and is subject to all confidentiality, copyright and trade secrets, rules, intellectual property law and practices of SOUTH AFRICA.

Table of contents

1. INTRODUCTION	1
1.1 TERMS OF REFERENCE.....	1
1.2 SCOPE OF INVESTIGATION	1
1.3 LOCATION OF STUDY AREA	1
1.4 INFORMATION SOURCES	2
2. METHODOLOGY	3
2.1 HYDROGEOLOGICAL SURVEY	3
2.2 EVALUATION OF EXISTING EQUIPMENT	3
2.3 PUMP TESTING.....	3
2.3.1 Pump testing procedure.....	3
2.3.2 Pump testing analysis.....	3
2.4 CHEMICAL WATER ANALYSES	4
3. RESULTS.....	5
3.1 HYDROGEOLOGICAL SETTING	5
3.2 LIAISON	5
3.3 BOREHOLE CENSUS.....	5
3.4 EXISTING EQUIPMENT	6
3.5 PUMP TESTING	7
3.6 WATER CHEMISTRY.....	9
4. SUMMARY & RECOMMENDATIONS.....	10

List of Figures

- FIGURE 1: Regional Locality Map
FIGURE 2: Regional Geological Map
FIGURE 3: Detailed Site Layout Map

Appendixes

- APPENDIX A – Liaison Documentation
APPENDIX B – Pump Testing Data
APPENDIX C – Chemical Water Analysis Data
APPENDIX D – Detailed Site Locality Map

1. INTRODUCTION

1.1 Terms of reference

Southern Africa GeoConsultants (PTY) Ltd – hereafter referred to as GeoCon - was appointed by Kwezi V3 Engineers to carry out determinative pump testing of existing boreholes at the town Sterkstroom in the Inkwanca Municipality of the Chris Hani District of the Eastern Cape Province.

This report gives results and recommendations resulting from the execution of potential determinative pump tests at six existing boreholes all of which is located within the boundaries of the study area.

1.2 Scope of investigation

GeoCon was appointed to render the following hydrogeological consultation services in the project area:

- Liaison with municipal offices and personnel
- Evaluation of four electrical submersible pumps, one electrical driven mono pump and one open borehole
- Site evaluation - groundwater potential assessment
- Coordination and supervision of pump testing program
- Analyses of pump testing data
- Assessment of groundwater quality
- Reporting with utilization recommendations

1.3 Location of study area

The town Sterkstroom is located approximately 50 kilometers to the northwest of Queenstown (Figure 1). Four of boreholes concerned are situated directly to the north of the town, and two are situated to the east of the town next to the Masaki Township.




Figure 1: Regional Locality Map

1.4 Information sources

All information pertaining to the boreholes was obtained from on-site observations and reports from local municipality representative - Mr. Boeta Geyer.

- Geological information was obtained from the 1:250 000 scale geological map: 3126 - Queenstown.
- Hydrogeological information was obtained from the 1:500 000 scale hydrogeological map: 3126 Queenstown.
- Topographical information was obtained from the 1:50 000 scale topographical map: 3126DA – Sterkstroom.

2. METHODOLOGY

2.1 Hydrogeological survey

Field inspections were carried out during which the local geological and hydrogeological conditions were evaluated. This information was required for aquifer definition, pump testing data analyses, recharge potential as well as water quality assessments and long-term sustainability determination.

2.2 Evaluation of existing equipment

The flow rate at one existing electrical submersible pump was measured to determine the current abstraction rate at the borehole. All the other boreholes were vandalized and it currently in disrepair. Existing pumps in the other holes were sent to RJN Projects in East London for calibration.

2.3 Pump testing

2.3.1 Pump testing procedure

Pump testing was carried out under the co-ordination and guidance of the hydrogeological consultant. It was the aim of the pump testing exercise to determine the potential at each borehole and tests were adapted according to the yields observed. This resulted in some boreholes being pumped for longer periods than others. The aim at all times was to obtain maximum information regarding the local aquifer within the allowed budget and scope of the appointment.

The appointed pump-testing contractor executed pump testing under the supervision and guidance of the hydrogeological consultant at the existing boreholes. Pump testing was done using a positive displacement mono-type pump being driven by an engine equipped with a gearbox to be able to pump at different rates. Because the boreholes are in use, they were allowed to recover sufficiently before pump testing of the holes commenced.

Initial testing procedures involved calibration testing where no information or inaccurate information regarding the yield of a borehole exists. This was typically followed by a step drawdown test during which the water level response to different abstraction rates was measured. Results from this test were used to determine a safe and adequate rate at which to perform the constant rate drawdown test. The constant rate drawdown test was commenced once the water level has recovered sufficiently.

The water level response to the constant rate drawdown test, as well as the recovery after the test, was used to assess the hydraulic parameters of the aquifer. These results help to determine the safe long-term abstraction rates at each of the tested boreholes.

Monitoring of boreholes nearest to the pumping borehole was carried out where seen as feasible.

2.3.2 Pump testing analysis

Two parameters are used to describe the physical properties of the aquifer, namely transmissivity (T) and storativity (S). The first of these two quantifies the rate at which water moves through the aquifer and the latter quantifies the aquifer's ability to release water. These 2 parameters can be determined by means of aquifer tests such as pumping tests. However in order to obtain accurate S values observation borehole water levels must be recorded.

Three different methods were used to determine the T values of the boreholes under investigation. They are:

➤ **Cooper-Jacob analysis**

The Cooper-Jacob method is summarized in Kruseman and De Ridder (1991). This method was actually developed for porous flow aquifers. However if the pumping tests are correctly recorded, the method can be used to obtain information concerning the fractures (early T analyses) and the surrounding rock matrix (late-T analyses).

The pump testing graphs from the Cooper-Jacob analyses are attached in Appendix B for reference.

➤ **FC-analysis**

FC refers to flow characterization of groundwater flow to a borehole. This method of analysis takes into account factors such as the derivatives of drawdown versus time data, boundary information and error propagation. The method has been developed by the Institute for Groundwater Studies (IGS). An in-depth discussion of the method can be found on the IGS website <http://www.uovs.ac.za/igs>.

➤ **Recovery method**

This test provides an indication of the ability of a borehole and groundwater system to recover from the stress of abstraction. This ability can again be analyzed to provide information in regard to the hydraulic properties of the groundwater system and arrive at an optimum yield for the medium to long-term utilization of the borehole. Although referred to as a test, it rather represents a period of monitoring activity following a period of pumping. The rate at which the water level in the tested borehole (or any other borehole affected by the abstraction) recovers towards its starting level (the groundwater rest level before pumping started) is monitored in this period. For more information concerning this method refer to Kruseman and De Ridder (1991).

The values obtained from these methods were then used to fit the step-drawdown data as a means of calibration.

2.4 Chemical Water Analyses

A water sample was taken at the boreholes at the end of the pumping cycle of the last test carried out. Water was analyzed as far as its physical-, chemical- and microbiological quality is concerned.

Results were evaluated using the document:

*Quality of Domestic Water Supplies; Volume 1; Assessment Guide; Second Edition 1998;
Water Research Commission No. TT101/98.*

The Water Quality Assessment Guide defines the following classes:

Colour	Class	Water quality
Blue	0	Ideal – suitable for lifetime use
Green	1	Good – suitable for use, rare instances of negative effects
Yellow	2	Marginal – conditionally acceptable. Negative effects may occur in some
Red	3	Poor – unsuitable for use without treatment. Chronic effects may occur
Purple	4	Dangerous – totally unsuitable for use. Acute effects may occur

3. RESULTS

3.1 Hydrogeological Setting

According to the geological map the study area is covered by alluvium and underlain by sandstone and mudstone of the Burgersdorp formation from the Tarkastad subgroup; and by mudstone, shale, gritty sandstone and occasional coal seams of the Molteno formation. These formations belong to the Karoo sequence of rocks (Figure 2). The sedimentary formations dip at an angle of approximately 4° to the north. The Karoo Sequence has been intruded by Dolerite in the form of sheets and dykes during the late Karoo volcanism.




Figure 2: Regional Geology

According to the hydrogeological map of Queenstown the study area's surface geology is mainly alluvium. Groundwater occurrences are expected in fractured zones with yields varying between 0.5 and 2.0 l/s at successful boreholes. According to the hydrogeological map, Sterkstroom is a large-scale groundwater abstraction area with an estimated annual groundwater usage of between 0.1 and 1 million m³, mainly for domestic purposes.

3.2 Liaison

Two site visits were made on the 10th and 19th of April 2002. Pump testing procedures to be followed were discussed with the representative from the local municipality - Mr B. Geyer. Existing boreholes that had to be tested were indicated and site verification and geological mapping was done. Liaison documentation is attached in Appendix A for reference.

3.3 Borehole census

Not forming part of the scope of this appointment – no formal borehole census was carried out outside of the target area. Other boreholes that were noted in the area and these are indicated in Figure 3.




Figure 3: Detailed Site Layout Map (Geology excluded)

It will be strongly recommended that a regional borehole census be carried out to determine regional abstraction trends and volumes that will most definitely effect the municipal abstraction. This borehole census will include all boreholes in the town as well as surrounding farms.

3.4 Existing equipment

Of the six boreholes concerned, four were equipped with electrical submersible pumps; one with an electrical driven mono pump and one borehole was unequipped. Only one borehole was in a working condition during the testing phase of the project. All the other boreholes were vandalized, switchboxes and pump-houses were broken down. Two of the town boreholes, EC/001/CH and EC/003/CH, were rendered useless by bricks having been thrown down the boreholes.




Photo 1: Borehole EC/003/CH - Vandalized

3.5 Pump Testing

A total of six boreholes were scheduled to be pump tested by the pump testing contractor.

- Borehole EC/001/CH (Sterkstroom 1) could not be tested because it was blocked.
- Borehole EC/002/CH (Sterkstroom 2) was tested successfully.
- Borehole EC/003/CH (Sterkstroom 3) could not be tested because it was blocked.
- Borehole EC/004/CH (Sterkstroom 4) was tested successfully.
- Borehole EC/005/CH (Sterkstroom 5) was tested successfully.
- Borehole EC/006/CH (Sterkstroom 6) was tested successfully.
- Borehole EC/007/CH (Chris Hani) will be tested during a next phase.
- Borehole EC/008/CH (Masaki 1) was tested successfully.
- Borehole EC/009/CH (Masaki 2) was tested successfully.

Results from the pump testing phase were analyzed according to the methods described in Paragraph 2.3.2. Results are summarized in the Project Summary Table below:

Pump testing data and Cooper-Jacob graphs are attached in Appendix B for reference.

WATER EVALUATION

PUMP AND DISCHARGE TEST				RECOVERY TEST				WATER CHEMISTRY	MANAGEMENT RECOMMENDATIONS (8/24 hour duty cycle)			
Drawdown (m)	% Drawdown (of available dd)	Early Time T (m ² /d)	Late Time T (m ² /d)	Duration (min)	% Recovery/pumping time	Residual drawdown (m)	Recover T (m ² /d)	Drinking water class	Abstraction rate (L/s)	Daily volume (m ³ /d)	Pump Inst. Depth (m)	Comments
	15.21	148	19	2880	95	0.29	28.44	Class 2	2.80	30.64	50.00	From fitting step drawdown data T = 120 m ² /d, S = 7e-4. The maximum radius of influence after 6 mnths = 9191m and the average radius of influence after 6 mnths = 3568 m
	7.77	132	38.5	1560	94	0.18	179.8	Class 4	3.50	100.80	40.00	From fitting step drawdown data T = 70 m ² /d, S = 9.1e-4. The maximum radius of influence after 6 mnths = 10340m and the average radius of influence after 6 mnths = 5324.5 m
	70.05	2.8	0.65	1200	94	2.52	4	Class 4	0.12	3.57	65.00	From fitting step drawdown data T = 7 m ² /d, S = 2.3e-4. The maximum radius of influence after 6 mnths = 1423m and the average radius of influence after 6 mnths = 697 m. This hole can alternatively be used as monitoring point if not equipped.
	44.98	10	6.9	1440	93	1.42	3.7	Class 1	0.75	21.60	52.00	From fitting step drawdown data T = 18 m ² /d, S = 1e-4. The maximum radius of influence after 6 mnths = 2985m and the average radius of influence after 6 mnths = 1731.2 m
	47.84	12	4.9	1440	51	5.99	22.5	Class 2	0.50	14.40	65.00	From fitting step drawdown data T = 7 m ² /d, S = 1e-4. The maximum radius of influence after 6 mnths = 2012.5m and the average radius of influence after 6 mnths = 4221.4 m
	72.89	12	1.3	2160	62	7.32	14.3	Class 3	0.30	8.64	50.00	From fitting step drawdown data T = 25 m ² /d, S = 1.7e-4. The maximum radius of influence after 6 mnths = 3600m and the average radius of influence after 6 mnths = 1026 m

4. SUMMARY & RECOMMENDATIONS

- GeoCon was appointed by Kwezi V3 Engineers to carry out a hydrogeological investigation at the town Sterkstroom in the Chris Hani District Municipality. The project resulted in the testing of a total of six town boreholes.
 - The area is covered by alluvium and underlain by sandstone and mudstone of the Burgersdorp formation from the Tarkastad subgroup; and by mudstone, shale, gritty sandstone and occasional coal seams of the Molteno formation. Dolerite intruded into the sedimentary package in the form of dykes, sills and sheets.
 - A total of six town boreholes were scheduled for pump testing. Two of the town boreholes, EC/001/CH and EC/003/CH were completely destroyed by community members, and it was decided to test two other boreholes in the Masaki Township instead.
 - Of the six boreholes that were tested, four were equipped with electrical submersible pumps; one with an electrical driven mono pump and one borehole was unequipped. Only one borehole was in a working condition during the testing phase of the project. All the other boreholes were vandalized.
 - Analysis of the pump testing data indicated that the boreholes are utilizing the same aquifer and that there is a definite interaction between boreholes. Recommendations were made taking this into account.
 - Recommended abstraction rates for the boreholes are indicated in the Project Summary Table. Duty cycles are recommended not to exceed 8 hours of pumping per day, resulting in a total available daily volume of 230 m³.
 - The drinking water quality of the boreholes was found to be marginal to poor. Class 3 and 4 values can be ascribed to the high faecal- and total coliform counts. Total Hardness causes some water from some boreholes to be marginal. It is recommended that the water be chlorinated to minimize the possible health risk posed by drinking of the water.
-
- The implementation of a water level monitoring and groundwater management program is of critical importance to ensure that groundwater remains a long-term sustainable water source for the municipality. The implementation of such a management plan will have to entail a full hydrocensus, to be carried out within a 5 km radius of the town center to identify all boreholes in the area. There is a good possibility that other boreholes in the area are being over exploited and mismanaged. The long-term response of the aquifer to the recommended abstraction rates can thus be evaluated and changes to duty cycles can be made if required.
 - It is recommended that the new low-cost housing development make use of the town's sewerage system to minimize possible groundwater pollution as a result from on-site sanitation.
 - It is recommended that an engineering geological and hydrogeological investigation be conducted at the town's solid waste disposal site due to the proximity of the site to the town boreholes, and the possible pollution hazards posed by this.
-
-

APPENDIX A

LIAISON DOCUMENTATION

S. A. GeoConsultants (Pty) Ltd
 P / Bag X9063, Postnet 203
 East London
 Tel 043 - 726 2070



LIAISON - LOCAL AUTHORITIES

Date: 10 April 2002
 District: CHRIS HANI

Community:
 Project: STERKSTROOM GROUNDWATER INVESTIGATION

Objectives - GeoCon:
 Hydrocensus
 Visit 6 Tamu boreholes to be pup tested.
 Pump testing supervision - site inspection

Objectives - Community:

		Authorities:		Remarks:
Name:	Position:	Signature:	Date:	
F. DE JAGER	GeoCon	<i>[Signature]</i>	10/4/2002	
A.P. Meyer	Storkstroom	<i>[Signature]</i>	10/4/2002	
C. S. J. van der Walt	Testing Conh.	<i>[Signature]</i>	10/4/2002	
T. DE JAGER	GeoCon	<i>[Signature]</i>	19/4/2002	
H. Winter	A. B. lewys	<i>[Signature]</i>	19/04/2002	
H. P. Meyer	Storkstroom	<i>[Signature]</i>	19/04/2002	Soil Boreholes, plant nearby plus.

APPENDIX B

PUMP TESTING DATA

CALIBRATION TEST AND RECOVERY

BOREHOLE NO. :	EC/002/CH	PROJECT:	Sterkstroom Groundwater Development
ALTERNATIVE NO. :		SITE NAME:	Sterkstroom Groundwater Development
ALTERNATIVE NO. :		CLIENT:	Chris Hani District
BOREHOLE DEPTH (mbdl):	54.25	CASING DEPTH (mbdl):	10.28
DEPTH OF PUMP (mbdl):	50.20	CASING HEIGHT (magh):	0.25
PUMP INLET DIAMETER (mm):	165.00	CASING ID (mm):	
STATIC WATER LEVEL (mbdl):	9.90	DATUM LEVEL (maql):	0.59
		PUMP TYPE USED:	P100
		OPERATOR:	Christopher
		CONTRACTOR:	AB Pumps
		SUPERVISOR:	

DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3										
DATE:	10/04/2002		TIME:		16h50		DATE:	10/04/2002		TIME:		17h05		DATE:	10/04/2002		TIME:		17h20	
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	
1	0.03		1		1	0.21		1		1	0.41		1							
2	0.04		2		2	0.27	0.83	2		2	0.43		2							
3	0.07		3		3	0.28		3		3	0.44	1.14	3							
5	0.11	0.31	5		5	0.30	0.83	5		5	0.49		5							
7	0.12		7		7	0.30		7		7	0.66	1.77	7							
10	0.13	0.31	10		10	0.32	0.82	10		10	0.70		10							
15	0.16		15		15	0.34		15		15	0.75		15							

EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20
TYPE OF RESERVOIR:		30	TYPE OF ENCLOSURE:		30	PRESSURE GAUGE MANUFAC		30
		40			40	TURER:		40
RESERVOIR SIZE:		50	MATERIAL OF ENCLOSURE:		50			50
		60			60	GAUGE READING (KpA):		60
RESERVOIR CONITION:		70	CONDITION OF ENCLOSURE:		70			70
		80			80	MONITORING FACILITY:		80
STAND HEIGHT (m):		90	WATER METER MANUFACTURER:		90			90
		100			100	MAINTAINED:		100
		110	WATER METER READING:		110			110
		120			120			120
		150			150			150

DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6										
DATE:	10/04/2002		TIME:		17h35		DATE:	10/04/2002		TIME:		17h50		DATE:	10/04/2002		TIME:		18h05	
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	
1	1.02		1		1	2.02		1		1	2.88		1	1.35						
2	1.07		2		2	2.09	4.11	2		2	4.06	6.42	2	1.05						
3	1.11	2.61	3		3	2.19		3		3	4.63		3	0.85						
5	1.28		5		5	2.24	4.12	5		5	5.15	7.76	5	0.67						
7	1.30	2.62	7		7	2.34		7		7	5.40		7	0.55						
10	1.35		10		10	2.40	4.12	10		10	5.44	7.77	10	0.41						
15	1.40		15		15	2.45		15		15	5.60		15	0.37						

EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20
PUMP TYPE:		30	TYPE OF POWER:		30	TYPE OF RISER:		30
BP9L		40	Electricity		40	Galvanised steel		40
PUMP MANUFACTURER:		50	ENGINE MANUFACTURER:		50	CLASS OF RISER:		50
		60	Geo Machines		60	6		60
PUMP SERIAL No:		70	ENGINE MODEL:		70	DIAMETER OF RISER (mm):		70
		80	Indukie Motors Induction		80	50mm		80
PUMP PULLEY DIAMETER (mm):		90	ENGINE SERIAL No:		90	CONDITION OF RISER:		90
250m		100	LD 5788 / 21		100	Good		100
PUMP INTAKE DEPTH (m):		110	ENGINE PULLEY DIAMETER (mm):		110	SHAFT DIAMETER (mm):		110
28m		120	164 mm		120	16mm		120
PUMP RPM:		150	POWER RATING (kW):		150	ELEMENT DIAMETER (mm):		150
1445			7.5 kw			65mm		180
PUMP CONDITION:			ENGINE CONDITION:			ELEMENT STROKE (mm):		210
Good			Motor Bad			250mm		240

COMMENTS:		300
		420
P100 was too small for the water. Therefor we had to change borth the pipes and the element		480
		540
		600
DID THE BOREHOLE PRODUCE ANY SILT / SAND / GRAVEL ?	YES	660

STEPPED DISCHARGE TEST AND RECOVERY

BOREHOLE NO. :		EC/002/CH		PROJECT:		Sterkstroom Groundwater Development								
ALTERNATIVE NO. :		0		SITE NAME:		Sterkstroom Groundwater Development								
ALTERNATIVE NO. :		0		CLIENT:		Chris Hani District								
BOREHOLE DEPTH (m):		54.25	CASING DEPTH (m):		10.28	PUMP TYPE USED: P100								
DEPTH OF PUMP (m):		50.20	CASING HEIGHT (m):		0.25	OPERATOR: Christopher								
PUMP INLET DIAMETER (mm):		165.000	CASING ID (mm):		0.000	CONTRACTOR: AB Pumps								
STATIC WATER LEVEL (m):		9.90	DATUM LEVEL (m):		0.59									
DISCHARGE RATE 1		Time	Recovery 1	DISCHARGE RATE 2			Time	Recovery 2	DISCHARGE RATE 3			Time	Recovery 3	
DATE: 11/04/2002		(min)	(m)	DATE: 11/04/2002			(min)	(m)	DATE: 11/04/2002			(min)	(m)	
TIME: 11H30		1		TIME: 13H10			1		TIME:			1		
Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	
1	0.51		5	3.73		5			1	7.29		5		
2	0.74		7	4.35	9.210	7			2	9.14	15.550	7		
3	0.81	3.000	10	4.43	8.210	10			3	9.72		10		
5	1.18		15	4.51	8.030	15			4	9.85	15.890	15		
7	1.40	4.030	20	4.60		20			7	9.90	16.040	20		
10	1.51		30	4.68	8.020	30			10	9.96		30		
15	1.57	4.030	40	4.70		40			15	10.49	16.040	40		
20	1.62		50	4.78	8.020	50			20	11.32		50		
30	1.67	4.040	60	4.87		60			30	29.26	16.030	60		
40	1.70		70	4.95	8.030	70			40	38.55		70		
50	1.72	4.030	80	5.07		80			50	P. I. S	13.330	80		
60	1.75		90	5.13	8.020	90			60	P. I. S	12.440	90		
70	1.77	4.030	100	5.18		100			70	P. I. S	12.230	100		
80	1.80		110	5.23	8.020	110			80			110		
90	1.82	4.030	120	5.27		120			90			120		
100	1.84		150	5.32		150			100			150		
110			180			180			110			180		
120			210			210			120			210		
Average yield: 3.88428571		(l/s)	Average yield: 8.195				Average yield: 14.69375							
DISCHARGE RATE 4		Time	Recovery 4	DISCHARGE RATE 5			Time	Recovery 5	DISCHARGE RATE 6			Time	Recovery	
DATE: 11/04/2002		(min)	(m)	DATE: 11/04/2002			(min)	(m)	DATE: 11/04/2002			(min)	(m)	
TIME:		1		TIME:			1		TIME:			1	8.62	
Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	
2			2			2			2			2	7.60	
3			3			3			3			3	6.14	
5			5			5			5			5	5.43	
7			7			7			7			7	3.48	
10			10			10			10			10	2.73	
15			15			15			15			15	1.96	
20			20			20			20			20	1.52	
30			30			30			30			30	1.02	
40			40			40			40			40	0.79	
50			50			50			50			50		
60			60			60			60			60		
70			70			70			70			70		
80			80			80			80			80		
90			90			90			90			90		
100			100			100			100			100		
110			110			110			110			110		
120			120			120			120			120		
Average yield: #DIV/0!										240	150	240		
COMMENTS:								300	180					
								360	210					
								420	240					
								480	300					
								540	360					
								600	420					
								660	480					
								720						
								780						
										Average yield:				
										720				

DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(lit)	(m)	(min)	(m)	(m)	(min)	(m)	(m)	(min)	(m)	(m)
1500	4.95	6.05	0.42	1500			1500			1500		
1560	5.01		0.41	1560			1560			1560		
1620	5.05	6.05	0.40	1620			1620			1620		
1680	5.11		0.39	1680			1680			1680		
1740	5.17	6.05	0.38	1740			1740			1740		
1800	5.22		0.37	1800			1800			1800		
1860	5.28	6.05	0.36	1860			1860			1860		
1920	5.33		0.35	1920			1920			1920		
1980	5.40	6.05	0.34	1980			1980			1980		
2040	5.44		0.33	2040			2040			2040		
2100	5.49	6.05	0.32	2100			2100			2100		
2160	5.54		0.31	2160			2160			2160		
2220	5.59	6.04	0.30	2220			2220			2220		
2280	5.64		0.29	2280			2280			2280		
2340	5.69	6.05		2340			2340			2340		
2400	5.74			2400			2400			2400		
2460	5.79	6.05		2460			2460			2460		
2520	5.84			2520			2520			2520		
2580	5.89	6.04		2580			2580			2580		
2640	5.98			2640			2640			2640		
2700	6.00	6.05		2700			2700			2700		
2760	6.04			2760			2760			2760		
2820	6.08	6.05		2820			2820			2820		
2880	6.13			2880			2880			2880		


DESCRIPTION:	QUANTITY:	UNIT:	S U M M A R Y	DESCRIPTION:	QUANTITY:	UNIT:
ESTABLISHMENT		Sum		STRAIGHTNESS TEST:		No.
INTER HOLE MOVE > 10 km		Km.		VERTICALITY TEST:		No.
FROM: SITE NAME:				CASING DETECTION:		No.
BOREHOLE No:				STEEL BOREHOLE COVER:		No.
INTER HOLE MOVE < 10 km:		No.		BOREHOLE MARKING:		No.
REMOVAL AND RE-ERECTION OF PUMP HOUSE:		No.		SITE CLEANING / FINISHING:		No.
REMOVAL OF EXISTING EQUIPMENT:		No.		REPORTING & DATA RECORDING:		No.
RE-INSTALLATION OF EXISTING EQUIPMENT:		No.		SLUG TEST:		No.
WORK TIME RATE (REPAIRS):		Hour		LAYFLAT (m):		m
STANDING TIME:		Hour	BOREHOLE DEPTH AFTER TEST:		m	
LATITUDE:			BOREHOLE WATERLEVEL AFTER TEST:		m	
LONGITUDE:						

TEST DESCRIPTION	STEP	1	2	3	4	5	6	TOTAL:	RECOVERY:
CALIBRATION TEST:								(min) (hrs)	(m) (min)
TEST DURATION (Minutes)		15	15	15	15	15	15	90 1.50	0.03 80
TEST YIELD (l/s)		0.31	0.83	1.46	2.62	4.12	7.32	MAXIMUM (l/s) 7.3	
DRAWDOWN (m)		0.16	0.34	0.75	1.40	2.45	5.60	MAXIMUM (m) 5.6	
MULTI-RATE / STEP DRAWDOWN:									
TEST DURATION (Minutes)		100	100	70				270 4.50	0.79 40
TEST YIELD (l/s)		3.38	8.20	14.89				MAXIMUM (l/s) 14.7	
DRAWDOWN (m)		1.3	5.32	38.55				MAXIMUM (m) 38.6	
CONSTANT DISCHARGE TEST		TEST DURATION		TEST YIELD	DRAWDOWN	RECOVERY:			
		(min)	(hrs)	(l/s)	(m)	(m)	%	(min)	(hrs)
		2880	48.00	5.79	6.13	0.29	95.27	2280	38.20
OBSERVATION BOREHOLES:	No.	720	1440	2880	>2880 (min)		TOTAL:		
	of boreholes	(min)	(min)	(min)	nr.	Time	(min)	(hrs)	
							3	3.00	

RECOVERY TEST			
TIME TOTAL (hrs):		40.00	
Cal	Steps	CD	Total
80	40	2280	2400
DRAWDOWN TOTALS (CD):			
AVAILABLE	UTIL.	%	
40.3	6.13	15.21	

**BOREHOLE NUMBER: EC/002/CH
CALIBRATION TEST AND RECOVERY**

Discharge 1:	0.31	Discharge 2:	0.83	Discharge 3:	1.46	Discharge 4:	2.62	Discharge 5:	4.12	Discharge 6:	7.3167
--------------	------	--------------	------	--------------	------	--------------	------	--------------	------	--------------	--------




- Discharge Rate 1
- Discharge Rate 2
- Discharge Rate 3
- Discharge Rate 4
- Discharge Rate 5
- Discharge Rate 6
- Recovery

Drawdown 1:	0.16
Drawdown 2:	0.34
Drawdown 3:	0.75
Drawdown 4:	1.40
Drawdown 5:	2.45
Drawdown 6:	5.60
Duration 1:	15
Duration 2:	15
Duration 3:	15
Duration 4:	15
Duration 5:	15
Duration 6:	15
Recovery (m):	0.03
Recovery (min):	80

STEPPED DISCHARGE TEST AND RECOVERY


Discharge 1:	3.88429	Discharge 2:	8.195	Discharge 3:	14.6938	Discharge 4:		Discharge 5:		Discharge 6:	
--------------	---------	--------------	-------	--------------	---------	--------------	--	--------------	--	--------------	--



- Discharge rate 1
- Discharge rate 2
- Discharge rate 3
- Recovery
- Step 2
- Step 3

Drawdown 1:	1.84
Drawdown 2:	5.32
Drawdown 3:	38.55
Drawdown 4:	0.00
Drawdown 5:	0.00
Drawdown 6:	
Duration 1:	100
Duration 2:	100
Duration 3:	70
Duration 4:	
Duration 5:	
Duration 6:	
Recovery (m):	0.79
Recovery (min):	40

CONSTANT DISCHARGE TEST AND RECOVERY




- Constant discharge rate
- Recovery


TEST INFORMATION

Date tested	11/04/2002	Water level (mbgl)	9.90	Depth of pump (mbgl)	50.2
CD duration	2880	CD discharge rate	5.79	CD drawdown	6.13
Available drawdown (m)	40.3	% Recovery after CD	95	% after 2280 min	


BOREHOLE NUMBER: EC/002/CH
CALIBRATION TEST AND RECOVERY



STEPPED DISCHARGE TEST AND RECOVERY



CONSTANT DISCHARGE TEST AND RECOVERY




TEST INFORMATION

Date tested	11/04/2002	Water level (mbgl)	9.90	Depth of pump (mbgl)	50.2
CD duration	2880	CD discharge rate	5.79	CD drawdown	6.13
Available drawdown (m)	40.3	% Recovery after CD	95	% after 2280 min	

COOPER-JACOB ANALASYS GRAPH

EC/002/CH




DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(l/s)	(m)	(min)	(m)	(m)	(min)	(m)	(m)	(min)	(m)	(m)
1500	2.47		0.18	1500			1500			1500		
1560	2.48	2.94	0.16	1560			1560			1560		
1620	2.50			1620			1620			1620		
1680	2.50	2.93		1680			1680			1680		
1740	2.50	2.94		1740			1740			1740		
1800	2.53	2.95		1800			1800			1800		
1860	2.56	2.95		1860			1860			1860		
1920	2.57	2.94		1920			1920			1920		
1980	2.59	2.93		1980			1980			1980		
2040	2.59	2.94		2040			2040			2040		
2100	2.60	2.94		2100			2100			2100		
2160	2.60	2.94		2160			2160			2160		
2220	2.62	2.93		2220			2220			2220		
2280	2.63	2.94		2280			2280			2280		
2340	2.64	2.93		2340			2340			2340		
2400	2.66	2.95		2400			2400			2400		
2460	2.67	2.95		2460			2460			2460		
2520	2.68	2.93		2520			2520			2520		
2580	2.70	2.94		2580			2580			2580		
2640	2.72	2.93		2640			2640			2640		
2700	2.74	2.95		2700			2700			2700		
2760	2.74	2.94		2760			2760			2760		
2820	2.75	2.94		2820			2820			2820		
2880	2.75			2880			2880			2880		

DESCRIPTION:	QUANTITY:	UNIT:		DESCRIPTION:	QUANTITY:	UNIT:
ESTABLISHMENT		Sum	S U M M A R Y	STRAIGHTNESS TEST:		No
INTER HOLE MOVE > 10 km		Km.		VERTICALITY TEST:		No
FROM: SITE NAME:				CASING DETECTION:		No
BOREHOLE No.:				STEEL BOREHOLE COVER:		No
INTER HOLE MOVE < 10 km:		No.		BOREHOLE MARKING:		No
REMOVAL AND RE-ERECTION OF PUMP HOUSE:		No.		SITE CLEANING / FINISHING:		No
REMOVAL OF EXISTING EQUIPMENT:		No.		REPORTING & DATA RECORDING:		No
RE-INSTALLATION OF EXISTING EQUIPMENT:		No.		SLUG TEST:		No
WORK TIME RATE (REPAIRS):		Hour		LAYFLAT (m):		m
STANDING TIME:		Hour		BOREHOLE DEPTH AFTER TEST:		m
LATITUDE:			BOREHOLE WATERLEVEL AFTER TEST:		m	
LONGITUDE:						


TEST DESCRIPTION	STEP	1	2	3	4	5	6	TOTAL	RECOVERY:
CALIBRATION TEST:									
TEST DURATION (Minutes)		15	15	15				(min) (hrs)	(m) (min)
TEST YIELD (l/s)		0.87	4.03	5.52				45 0.75	0.37 10
DRAWDOWN (m)		0.24	2.80	36.33				MAXIMUM (l/s) 6.5	
MULTI-RATE / STEP DRAWDOWN:									
TEST DURATION (Minutes)		100	100	100	100			400 6.67	0.10 240
TEST YIELD (l/s)		0.82	1.68	2.82	4.94			MAXIMUM (l/s) 4.9	
DRAWDOWN (m)		0.5	1.01	2.96	33.46			MAXIMUM (m) 33.5	
CONSTANT DISCHARGE TEST		TEST DURATION		TEST YIELD	DRAWDOWN	RECOVERY:			
		(min)	(hrs)	(l/s)	(m)	(m)	%	(min)	(hrs)
		2880	48.00	2.94	2.75	1.16	94.18	1560	26.00
OBSERVATION BOREHOLES:		No.	720	1440	2880	>2880 (min)			
		of boreholes	(min)	(min)	(min)	nr.	Time	TOTAL:	
								(min) (hrs)	
								3	3.00

RECOVERY TEST			
TIME TOTAL (hrs):		30.17	
Cal	Steps	CD	Total
10	240	1560	1610
DRAWDOWN TOTALS (CD):			
AVAILABLE	UTIL.	%	
35.4	2.75	7.77	


**BOREHOLE NUMBER: EC/004/CH
CALIBRATION TEST AND RECOVERY**



STEPPED DISCHARGE TEST AND RECOVERY



CONSTANT DISCHARGE TEST AND RECOVERY




TEST INFORMATION

Date tested	12/04/2002	Water level (mbgl)	6.24	Depth of pump (mbgl)	41.65
CD duration	2880	CD discharge rate	2.84	CD drawdown	2.75
Available drawdown (m)	35.41	% Recovery after CD	94	% after	1560 min

COOPER-JACOB ANALASYS GRAPH

EC/004/CH



CALIBRATION TEST AND RECOVERY

BOREHOLE NO. :	EC/005/CH	PROJECT:	Sterkstroom Groundwater Development
ALTERNATIVE NO. :		SITE NAME:	Sterkstroom Groundwater Development
ALTERNATIVE NO. :		CLIENT:	Chris Hani District Municipality

BOREHOLE DEPTH (m bdl):	75.40	CASING DEPTH (m bdl):	15.45	PUMP TYPE USED:	BP 22
DEPTH OF PUMP (m bdl):	61.65	CASING HEIGHT (mag):	0.20	OPERATOR:	Christopher
PUMP INLET DIAMETER (mm):		CASING ID (mm):	165.00	CONTRACTOR:	AB Pumps
STATIC WATER LEVEL (m bdl):	5.26	DATUM LEVEL (mag):	0.21	SUPERVISOR:	

DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3										
DATE:	14/04/2002		TIME:		12:00 AM		DATE:	14/04/2002		TIME:		15h15		DATE:	14/04/2002		TIME:		15h30	
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	
1	0.75		1		1	2.64		1		1	5.12		1							
2	1.14		2		2	2.75	0.68	2		2	5.47	1.23	2							
3	1.41	0.46	3		3	2.88		3		3	6.01		3							
5	1.73		5		5	3.32	0.81	5		5	6.64	1.22	5							
7	1.95	0.47	7		7	3.81		7		7	7.19		7							
10	2.19		10		10	4.22	0.82	10		10	7.75	1.23	10							
15	2.48		15		15	4.69		15		15	8.51		15							
EXISTING EQUIPMENT DETAIL:					EXISTING EQUIPMENT DETAIL:					EXISTING EQUIPMENT DETAIL:										
TYPE OF RESERVOIR:					TYPE OF ENCLOSURE:					PRESSURE GAUGE MANUFAC										
30					30					TURER:										
40					40					30										
RESERVOIR SIZE:					MATERIAL OF ENCLOSURE:					50										
50					60					60										
60					CONDITION OF ENCLOSURE:					GAUGE READING (Kpa):										
70					70					70										
80					80					MONITORING FACILITY:										
RESERVOIR CONITION:					WATER METER MANUFACTURER:					90										
90					100					100										
100					110					MAINTAINED:										
STAND HEIGHT (m):					110					110										
110					120					120										
120					150					150										
150					150					150										

DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6										
DATE:	14/04/2002		TIME:		15h45		DATE:	14/04/2002		TIME:				DATE:			TIME:			
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	
1	9.43		1		1	20.45		1		1			1	45.54						
2	10.43	2.28	2		2	23.73	3.05	2		2			2	37.80						
3	11.35		3		3	27.65	3.23	3		3			3	30.37						
5	12.68	2.3	5		5	38.92		5		5			5	17.49						
7	13.78		7		7	56.80	6.82.59	7		7			7	13.11						
10	14.72	2.3	10		10	P. I. S	215	10		10			10	10.88						
15	18.13		15		15	P. I. S		15		15			15	7.79						
EXISTING EQUIPMENT DETAIL:					EXISTING EQUIPMENT DETAIL:					EXISTING EQUIPMENT DETAIL:										
PUMP TYPE:					TYPE OF POWER:					TYPE OF RISER:										
30					30					30										
Franklin Electronic					Electricity					Galvinsed steel										
40					40					40										
PUMP MANUFACTURER:					ENGINE MANUFACTURER:					CLASS OF RISER:										
50					60					6										
60					70					DIAMETER OF RISER (mm):										
PUMP SERIAL No:					ENGINE MODEL:					70										
36982 / 904 460 v 536					80					50mm										
80					90					CONDITION OF RISER:										
PUMP PULLEY DIAMETER (mm):					ENGINE SERIAL No:					100										
90					100					Good										
100					110					SHAFT DIAMETER (mm):										
PUMP INTAKE DEPTH (m):					ENGINE PULLEY DIAMETER (mm):					110										
110					120					120										
120					150					ELEMENT DIAMETER (mm):										
PUMP RPM:					POWER RATING (kW):					150										
150					3.25 kw					30mm										
180					ENGINE CONDITION:					ELEMENT STROKE (mm):										
PUMP CONDITION:					Broken					210										
240					300					0.81										
300					420					0.52										
420					480															
480					540															
540					600															
600					660															
660																				

COMMENTS:

DID THE BOREHOLE PRODUCE ANY SILT / SAND / GRAVEL ?

STEPPED DISCHARGE TEST AND RECOVERY

BOREHOLE NO.:	EC/005/CH	PROJECT:	Sterkstroom Groundwater Development
ALTERNATIVE NO.:	0	SITE NAME:	Sterkstroom Groundwater Development
ALTERNATIVE NO.:	0	CLIENT:	Chris Hani District Municipality
BOREHOLE DEPTH (m):	75.40	CASING DEPTH (m):	15.45
DEPTH OF PUMP (m):	61.65	CASING HEIGHT (m):	0.20
PUMP INLET DIAMETER (mm):	0.000	CASING ID (mm):	165.000
STATIC WATER LEVEL (m):	5.26	DATUM LEVEL (m):	0.21
PUMP TYPE USED:	BP 22		
OPERATOR:	Christopher		
CONTRACTOR:	AB Pumps		

DISCHARGE RATE 1			Time	Recovery 1	DISCHARGE RATE 2			Time	Recovery 2	DISCHARGE RATE 3			Time	Recovery 3
DATE:	15/04/2002		(min)	(m)	DATE:	15/04/2002		(min)	(m)	DATE:	15/04/2002		(min)	(m)
TIME:	08h00		1		TIME:	09h40		1		TIME:			1	
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	
1	1.44		5		1	4.43		5		1	9.23		5	
2	1.98	0.630	7		2	4.64	0.780	7		2	10.41	1.840	7	
3	2.33		10		3	4.83		10		3	10.93	1.750	10	
5	2.91	0.500	15		5	5.21	0.820	15		4	11.47		15	
7	3.33	0.460	20		7	5.47		20		7	12.14	1.650	20	
10	3.20		30		10	5.85	0.820	30		10	12.64		30	
15	3.05	0.450	40		15	6.29		40		15	13.33	1.640	40	
20	3.09		50		20	6.52	0.810	50		20	13.89		50	
30	3.30	0.450	60		30	6.89		60		30	14.62	1.640	60	
40	3.45		70		40	7.21	0.820	70		40	15.94		70	
50	3.61	0.460	80		50	7.45		80		50	17.82	1.640	80	
60	3.74		90		60	7.67	0.820	90		60	19.04		90	
70	3.83	0.450	100		70	7.86		100		70	21.47	1.650	100	
80	3.93		110		80	8.03	0.820	110		80	22.03		110	
90	4.03	0.450	120		90	8.20		120		90	23.41	1.650	120	
100	4.12		150		100	8.31		150		100	24.31		150	
110			180		110			180		110			180	
120			210		120			210		120			210	

Average yield: 0.48125 (l/s) Average yield: 0.81285714 Average yield: 1.6825

DISCHARGE RATE 4			Time	Recovery 4	DISCHARGE RATE 5			Time	Recovery 5	DISCHARGE RATE 6			Time	Recovery
DATE:	15/04/2002		(min)	(m)	DATE:	15/04/2002		(min)	(m)	DATE:	15/04/2002		(min)	(m)
TIME:	13h00		1		TIME:			1		TIME:			1	46.38
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	39.53
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	33.18
1	25.89		5		1			5		1			5	23.47
2	27.73	2.43	7		2			7		2			7	13.30
3	30.69		10		3			10		3			10	10.24
5	35.82	2.57	15		5			15		5			15	11.00
7	40.02		20		7			20		7			20	10.45
10	45.53	2.56	30		10			30		10			30	8.71
15	52.89		40		15			40		15			40	7.58
20	56.80	2.56	50		20			50		20			50	6.75
30	P. I. S	2.17	60		30			60		30			60	6.13
40	P. I. S	1.89	70		40			70		40			70	5.63
50	P. I. S	1.77	80		50			80		50			80	5.20
60			90		60			90		60			90	4.88
70			100		70			100		70			100	4.50
80			110		80			110		80			110	4.19
90			120		90			120		90			120	3.95
100			150		100			150		100			150	3.42
110			180		110			180		110			180	3.05
120			210		120			210		120			210	2.89

Average yield: 2.27857143 240 150 240 2.68 240 2.49

COMMENTS:	300	180	300	2.49
	360	210	360	
	420	240	420	
	480	300	480	
	540	360	540	
	600	420	600	
	660	480	660	
	720			
	780			
		Average yield:	720	

DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(l/s)	(m)	(min)	(m)	(m)	(min)	(m)	(m)	(min)	(m)	(m)
1500				1500			1500			1500		
1560				1560			1560			1560		
1620				1620			1620			1620		
1680				1680			1680			1680		
1740				1740			1740			1740		
1800				1800			1800			1800		
1860				1860			1860			1860		
1920				1920			1920			1920		
1980				1980			1980			1980		
2040				2040			2040			2040		
2100				2100			2100			2100		
2160				2160			2160			2160		
2220				2220			2220			2220		
2280				2280			2280			2280		
2340				2340			2340			2340		
2400				2400			2400			2400		
2460				2460			2460			2460		
2520				2520			2520			2520		
2580				2580			2580			2580		
2640				2640			2640			2640		
2700				2700			2700			2700		
2760				2760			2760			2760		
2820				2820			2820			2820		
2880				2880			2880			2880		


DESCRIPTION:	QUANTITY:	UNIT:	DESCRIPTION:	QUANTITY:	UNIT:
ESTABLISHMENT		Sum	STRAIGHTNESS TEST:		No.
INTER HOLE MOVE > 10 km		Km.	VERTICALITY TEST:		No.
FROM: SITE NAME:			CASING DETECTION:		No.
BOREHOLE No:			STEEL BOREHOLE COVER:		No.
INTER HOLE MOVE < 10 km:		No.	BOREHOLE MARKING:		No.
REMOVAL AND RE-ERECTION OF PUMP HOUSE:		No.	SITE CLEANING / FINISHING:		No.
REMOVAL OF EXISTING EQUIPMENT:		No.	REPORTING & DATA RECORDING:		No.
RE-INSTALLATION OF EXISTING EQUIPMENT:		No.	SLUG TEST:		No.
WORK TIME RATE (REPAIRS):		Hour	LAYFLAT (m):		m
STANDING TIME:		Hour	BOREHOLE DEPTH AFTER TEST:		m
LATITUDE:			BOREHOLE WATERLEVEL AFTER TEST:		m
LONGITUDE:					

TEST DESCRIPTION	STEP	1	2	3	4	5	6	TOTAL	RECOVERY:
CALIBRATION TEST:								(min) (hrs)	(m) (min)
TEST DURATION (Minutes)		15	15	15	15	15		75	1.25
TEST YIELD (l/s)		0.47	0.77	1.23	2.29	73.76		MAXIMUM (l/s)	73.8
DRAWDOWN (m)		2.48	4.69	8.51	18.13	56.80		MAXIMUM (m)	56.3
MULTI-RATE / STEP DRAWDOWN:									
TEST DURATION (Minutes)		100	100	100	20			320	5.33
TEST YIELD (l/s)		0.48	0.81	1.68	2.28			MAXIMUM (l/s)	2.3
DRAWDOWN (m)		4.1	8.31	24.31	56.80			MAXIMUM (m)	56.3
CONSTANT DISCHARGE TEST		TEST DURATION		TEST YIELD	DRAWDOWN	RECOVERY:			
		(min)	(hrs)	(l/s)	(m)	(m)	%	(min)	(hrs)
		1440	24.00	1.27	39.50	2.52	93.82	1200	20.00
OBSERVATION BOREHOLES:	No.	720		1440	2880	>2880 (min)		TOTAL:	
	of boreholes	(min)		(min)	(min)	nr.	Time	(min)	(hrs)
								0	3.00


RECOVERY TEST			
TIME TOTAL (hrs):		32.00	
Cal	Steps	CD	Total
420	300	1200	1920
DRAWDOWN TOTALS (CD):			
AVAILABLE	UTIL-	% ISSED	
56.4	39.50	70.05	

BOREHOLE NUMBER: EC/005/CH


CALIBRATION TEST AND RECOVERY



STEPPED DISCHARGE TEST AND RECOVERY



CONSTANT DISCHARGE TEST AND RECOVERY




TEST INFORMATION

ate tested	15/04/2002	Water level (mbgl)	5.26	Depth of pump (mbgl)	61.65
D duration	1440	CD discharge rate	1.27	CD drawdown	39.5
Available drawdown (m)	56.39	% Recovery after CD	94	% after 1200 min	

COOPER-JACOB ANALASYS GRAPH

EC/005/CH



CALIBRATION TEST AND RECOVERY

BOREHOLE NO.:	EC/006/CH	PROJECT:	Sterkstroom Groundwater Development
ALTERNATIVE NO.:		SITE NAME:	Sterkstroom Groundwater Development
ALTERNATIVE NO.:		CLIENT:	Chris Hani District Municipality
BOREHOLE DEPTH (m bdl):	57.98	CASING DEPTH (m bdl):	4.44
DEPTH OF PUMP (m bdl):	50.20	CASING HEIGHT (magb):	0.21
PUMP INLET DIAMETER (mm):		CASING ID (mm):	165.00
STATIC WATER LEVEL (m bdl):	3.54	DATUM LEVEL (magb):	0.48
		PUMP TYPE USED:	P100
		OPERATOR:	Christopher
		CONTRACTOR:	AB Pumps
		SUPERVISOR:	

DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3										
DATE:	17/04/2002		TIME:		06h45		DATE:	17/04/2002		TIME:		07h00		DATE:	17/04/2002		TIME:		07h15	
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	
1	0.42		1		1	1.80		1		1	3.41		1		1	3.41		1		
2	0.61		2		2	1.67	0.71	2		2	3.84	1.88	2		2	3.84	1.88	2		
3	0.66		3		3	1.82		3		3	4.02		3		3	4.02		3		
5	0.78		5		5	2.03	0.82	5		5	4.37	1.9	5		5	4.37	1.9	5		
7	0.89	0.37	7		7	2.18		7		7	4.65		7		7	4.65		7		
10	1.60		10		10	2.37	0.83	10		10	5.00	1.92	10		10	5.00	1.92	10		
15	1.28	0.37	15		15	2.64		15		15	5.44		15		15	5.44		15		
EXISTING EQUIPMENT DETAIL:					EXISTING EQUIPMENT DETAIL:					EXISTING EQUIPMENT DETAIL:										
TYPE OF RESERVOIR:	30				TYPE OF ENCLOSURE:	30				PRESSURE GAUGE MANUFAC	30									
	40					40				TURER:	40									
RESERVOIR SIZE:	50				MATERIAL OF ENCLOSURE:	50					50									
	60					60				GAUGE READING (Kpa):	60									
RESERVOIR CONITION:	70				CONDITION OF ENCLOSURE:	70					70									
	80					80				MONITORING FACILITY:	80									
STAND HEIGHT (m):	90				WATER METER MANUFACTURER:	90					90									
	100					100				MAINTAINED:	100									
	110				WATER METER READING:	110					110									
	120					120					120									
	150					150					150									

DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6										
DATE:	17/04/2002		TIME:		07h30		DATE:	17/04/2002		TIME:				DATE:			TIME:			
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	
1	6.96		1		1	11.81		1		1	18.24		1		1	18.24		1	18.65	
2	8.06	3.6	2		2	12.59	4.48	2		2	20.48	11.13	2		2	20.48	11.13	2	14.94	
3	8.41		3		3	13.26	5.46	3		3	24.67		3		3	24.67		3	13.30	
5	9.13	3.61	5		5	14.43		5		5	28.75	11.15	5		5	28.75	11.15	5	11.43	
7	9.62		7		7	15.59	5.5	7		7	31.22		7		7	31.22		7	10.09	
10	10.18	3.6	10		10	16.50		10		10	35.80	11.2	10		10	35.80	11.2	10	8.70	
15	10.93		15		15	17.63		15		15	41.34		15		15	41.34		15	7.17	
EXISTING EQUIPMENT DETAIL:					EXISTING EQUIPMENT DETAIL:					EXISTING EQUIPMENT DETAIL:										
PUMP TYPE:	30				TYPE OF POWER:	30				TYPE OF RISER:	30									
	40					40					40									
PUMP MANUFACTURER:	50				ENGINE MANUFACTURER:	50				CLASS OF RISER:	50									
	60					60					60									
PUMP SERIAL No:	70				ENGINE MODEL:	70				DIAMETER OF RISER (mm):	70									
	80					80					80									
PUMP PULLEY DIAMETER (mm):	90				ENGINE SERIAL No:	90				CONDITION OF RISER:	90									
	100					100					100									
PUMP INTAKE DEPTH (m):	110				ENGINE PULLEY DIAMETER (mm):	110				SHAFT DIAMETER (mm):	110									
	120					120					120									
PUMP RPM:	150				POWER RATING (kW):	150				ELEMENT DIAMETER (mm):	150									
											180									
PUMP CONDITION:					ENGINE CONDITION:					ELEMENT STROKE (mm):	210									
											240									
											300									
											360									
											480									
											540									
											600									
											660									

COMMENTS: New borehole

DID THE BOREHOLE PRODUCE ANY SILT / SAND / GRAVEL ? Yes

*** STEPPED DISCHARGE TEST AND RECOVERY**

BOREHOLE NO.:	EC/006/CH	PROJECT:	Sterkstroom Groundwater Development
ALTERNATIVE NO.:	0	SITE NAME:	Sterkstroom Groundwater Development
ALTERNATIVE NO.:	0	CLIENT:	Chris Hani District Municipality
BOREHOLE DEPTH (m bdl):	57.98	CASING DEPTH (m bdl):	4.44
DEPTH OF PUMP (m bdl):	50.20	CASING HEIGHT (magl):	0.21
PUMP INLET DIAMETER (mm):	0.000	CASING ID (mm):	165.000
STATIC WATER LEVEL (m bdl):	3.54	DATUM LEVEL (magl):	0.48
		PUMP TYPE USED:	P100
		OPERATOR:	Christopher
		CONTRACTOR:	AB Pumps

DISCHARGE RATE 1			DISCHARGE RATE 2			DISCHARGE RATE 3		
DATE:	17/04/2002		DATE:	17/04/2002		DATE:	17/04/2002	
TIME:	Time	Recovery 1	TIME:	Time	Recovery 2	TIME:	Time	Recovery 3
	(min)	(m)		(min)	(m)		(min)	(m)
Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield
(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)
1	3.53		1	12.73		1	27.73	
2	4.08	1.800	2	13.52	4.290	2	29.97	8.630
3	4.32		3	14.03	4.770	3	31.70	9.450
5	4.99	2.290	5	15.62	5.000	4	36.44	
7	5.86		7	17.20		7	42.90	10.120
10	6.66	2.530	10	17.57	5.040	10	47.78	
15	7.19		15	18.13		15	P. I. S.	7.890
20	7.75	2.530	20	18.81	5.040	20		7.750
30	8.42		30	19.84		30		7.560
40	8.92	2.530	40	20.77	5.400	40		
50	9.31		50	21.61		50		
60	9.66	2.540	60	22.29	5.040	60		
70	9.89		70	22.79		70		
80	10.12	2.530	80	23.09	5.030	80		
90	10.34		90	23.59		90		
100	10.53		100	24.02		100		
110			110			110		
120			120			120		

Average yield: 2.39285714 (l/s) Average yield: 4.95125 Average yield: 8.5666667

DISCHARGE RATE 4			DISCHARGE RATE 5			DISCHARGE RATE 6		
DATE:	17/04/2002		DATE:	17/04/2002		DATE:	17/04/2002	
TIME:	Time	Recovery 4	TIME:	Time	Recovery 5	TIME:	Time	Recovery
	(min)	(m)		(min)	(m)		(min)	(m)
Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield
(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)
1			1			1		26.54
2			2			2		19.82
3			3			3		18.62
5			5			5		16.80
7			7			7		15.40
10			10			10		13.75
15			15			15		11.82
20			20			20		10.30
30			30			30		9.00
40			40			40		7.62
50			50			50		7.06
60			60			60		6.64
70			70			70		6.17
80			80			80		5.84
90			90			90		5.45
100			100			100		5.16
110			110			110		4.96
120			120			120		4.78
			150			150		4.3
			180			180		3.83
			210			210		3.29
			240			240		2.93
			300			300		
			360			360		
			420			420		
			480			480		
			540			540		
			600			600		
			660			660		
			720			720		
			780			780		

Average yield: #DIV/0!

COMMENTS:

Average yield: 720

DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(l/s)	(m)	(min)	(m)	(m)	(min)	(m)	(m)	(min)	(m)	(m)
1500				1500			1500			1500		
1560				1560			1560			1560		
1620				1620			1620			1620		
1680				1680			1680			1680		
1740				1740			1740			1740		
1800				1800			1800			1800		
1860				1860			1860			1860		
1920				1920			1920			1920		
1980				1980			1980			1980		
2040				2040			2040			2040		
2100				2100			2100			2100		
2160				2160			2160			2160		
2220				2220			2220			2220		
2280				2280			2280			2280		
2340				2340			2340			2340		
2400				2400			2400			2400		
2460				2460			2460			2460		
2520				2520			2520			2520		
2580				2580			2580			2580		
2640				2640			2640			2640		
2700				2700			2700			2700		
2760				2760			2760			2760		
2820				2820			2820			2820		
2880				2880			2880			2880		

DESCRIPTION:	QUANTITY:	UNIT:
ESTABLISHMENT		Sum
INTER HOLE MOVE > 10 km		Km.
FROM: SITE NAME:		
BOREHOLE No:		
INTER HOLE MOVE < 10 km:		No.
REMOVAL AND RE-ERECTION OF PUMP HOUSE:		No.
REMOVAL OF EXISTING EQUIPMENT:		No.
RE-INSTALLATION OF EXISTING EQUIPMENT:		No.
WORK TIME RATE (REPAIRS):		Hour
STANDING TIME:		Hour
LATITUDE:		
LONGITUDE:		

DESCRIPTION:	QUANTITY:	UNIT:
STRAIGHTNESS TEST:		No.
VERTICALITY TEST:		No.
CASING DETECTION:		No.
STEEL BOREHOLE COVER:		No.
BOREHOLE MARKING:		No.
SITE CLEANING / FINISHING:		No.
REPORTING & DATA RECORDING:		No.
SLUG TEST:		No.
LAYFLAT (m):		m
BOREHOLE DEPTH AFTER TEST:		m
BOREHOLE WATERLEVEL AFTER TEST:		m

TEST DESCRIPTION	STEP	1	2	3	4	5	6	TOTAL:	RECOVERY:
CALIBRATION TEST:								(min) (hrs)	(m) (min)
TEST DURATION (Minutes)		15	15	15	15	15	15	90 1 50	1 28 360
TEST YIELD (l/s)		0.37	0.79	1.90	3.60	5.15	11.16	MAXIMUM (l/s) 11.2	
DRAWDOWN (m)		1.50	2.64	5.44	10.93	17.63	41.34	MAXIMUM (m) 41.3	
MULTI-RATE / STEP DRAWDOWN:									
TEST DURATION (Minutes)		100	100	10				210 3 50	2 93 240
TEST YIELD (l/s)		2.39	4.95	8.57				MAXIMUM (l/s) 8.6	
DRAWDOWN (m)		10.5	24.02	47.78				MAXIMUM (m) 47.3	


RECOVERY TEST			
TIME TOTAL (hrs):		34.00	
Cal	Steps	CD	Total
360	240	1440	2040
DRAWDOWN TOTALS (CD):			
AVAILABLE	UTIL-	%	
	ISED		
46.7	20.98	44.96	

CONSTANT DISCHARGE TEST	TEST DURATION		TEST YIELD	DRAWDOWN	RECOVERY:			
	(min)	(hrs)	(l/s)	(m)	(m)	%	(min)	(hrs)
	1440	24.00	3.24	20.98	1.42	93.23	1440	24.00
OBSERVATION BOREHOLES:	No.	720	1440	2880	TOTAL:			
of boreholes	(min)	(min)	(min)	(min)	>2880 (min)	Time (min) (hrs)		
					nr.			
							3	3.00

BOREHOLE NUMBER: EC/006/CH

CALIBRATION TEST AND RECOVERY

Discharge 1:	0.37	Discharge 2:	0.79	Discharge 3:	1.90	Discharge 4:	3.60	Discharge 5:	5.15	Discharge 6:	11.16
--------------	------	--------------	------	--------------	------	--------------	------	--------------	------	--------------	-------




- Discharge Rate 1
- Discharge Rate 2
- Discharge Rate 3
- Discharge Rate 4
- Discharge Rate 5
- Discharge Rate 6
- Recovery

Drawdown 1:	1.60
Drawdown 2:	2.64
Drawdown 3:	5.44
Drawdown 4:	10.93
Drawdown 5:	17.63
Drawdown 6:	41.34
Duration 1:	15
Duration 2:	15
Duration 3:	15
Duration 4:	15
Duration 5:	15
Duration 6:	15
Recovery (m):	1.28
Recovery (min):	360

STEPPED DISCHARGE TEST AND RECOVERY


Discharge 1:	2.39286	Discharge 2:	4.95125	Discharge 3:	8.56667	Discharge 4:		Discharge 5:		Discharge 6:	
--------------	---------	--------------	---------	--------------	---------	--------------	--	--------------	--	--------------	--



- Discharge rate 1
- Discharge rate 2
- Discharge rate 3
- Recovery
- Step 2
- Step 3

Drawdown 1:	10.53
Drawdown 2:	24.02
Drawdown 3:	47.78
Drawdown 4:	0.00
Drawdown 5:	0.00
Drawdown 6:	
Duration 1:	100
Duration 2:	100
Duration 3:	10
Duration 4:	
Duration 5:	
Duration 6:	
Recovery (m):	2.93
Recovery (min):	240

CONSTANT DISCHARGE TEST AND RECOVERY




- Constant discharge rate
- Recovery

TEST INFORMATION

Date tested	17/04/2002	Water level (mbgl)	3.54	Depth of pump (mbgl)	50.2
D duration	1440	CD discharge rate	3.24	CD drawdown	20.98
Available drawdown (m)	46.66	% Recovery after CD	93	% after	1440 min

COOPER-JACOB ANALASYS GRAPH

EC/006/CH



CALIBRATION TEST AND RECOVERY

BOREHOLE NO.:	EC/008/CH	PROJECT:	Sterkstroom Groundwater Development
ALTERNATIVE NO.:		SITE NAME:	Sterkstroom Groundwater Development
ALTERNATIVE NO.:		CLIENT:	Chris Hani District Municipality
BOREHOLE DEPTH (m bdl):	71.23	CASING DEPTH (m bdl):	6.21
DEPTH OF PUMP (m bdl):	48.00	CASING HEIGHT (mag#):	0.60
PUMP (INLET DIAMETER (mm):		CASING ID (mm):	1.65
STATIC WATER LEVEL (m bdl):	22.58	DATUM LEVEL (mag#):	0.26
		PUMP TYPE USED:	BP22
		OPERATOR:	Isaac
		CONTRACTOR:	AB Pumps
		SUPERVISOR:	

DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3						
DATE:	TIME:	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery
(mm)	(m)	(l/s)	(min)	(m)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)
19/04/2002	12h40	1	1.13		1		1	2.99		1		1	5.29		1	
		2	1.65		2		2	3.40		2		2	5.74	1.02	2	
		3	1.94		3		3	3.51	0.6	3		3	6.30	1.66	3	
		5	2.21		5		5	4.08		5		5	7.54		5	
		7	2.41	0.36	7		7	4.42		7		7	8.95		7	
		10	2.56		10		10	4.63	0.61	10		10	9.56	1.65	10	
		15	2.81		15		15	4.83		15		15	10.35		15	

EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20
TYPE OF RESERVOIR:		30	TYPE OF ENCLOSURE:		30	PRESSURE GAUGE MANUFAC		30
		40			40	TURER:		40
RESERVOIR SIZE:		50	MATERIAL OF ENCLOSURE:		50			50
		60			60	GAUGE READING (Kpa):		60
RESERVOIR CONITION:		70	CONDITION OF ENCLOSURE:		70			70
		80			80	MONITORING FACILITY:		80
STAND HEIGHT (m):		90	WATER METER MANUFACTURER:		90			90
		100			100	MAINTAINED:		100
		110	WATER METER READING:		110			110
		120			120			120
		150			150			150

DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6						
DATE:	TIME:	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery
(mm)	(m)	(l/s)	(min)	(m)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)
19/04/2002	13h25	1	11.50		1		1			1		1			1	17.03
		2	12.82		2		2			2		2			2	11.69
		3	14.80	3.98	3		3			3		3			3	9.10
		5	19.95		5		5			5		5			5	6.36
		7	22.91	3.99	7		7			7		7			7	4.97
		10	25.42		10		10			10		10			10	3.82
		15			15		15			15		15			15	2.60

EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20
PUMP TYPE:		30	TYPE OF POWER:		30	TYPE OF RISER:		30
Franklin Electric		40	Electric		40			40
PUMP MANUFACTURER:		50	ENGINE MANUFACTURER:		50	CLASS OF RISER:		50
Jacuzzi		60			60			60
PUMP SERIAL No:		70	ENGINE MODEL:		70	DIAMETER OF RISER (mm):		70
360415 - V44 NfCh256H22		80			80			80
PUMP PULLEY DIAMETER (mm):		90	ENGINE SERIAL No:		90	CONDITION OF RISER:		90
0.41		100			100			100
PUMP INTAKE DEPTH (m):		110	ENGINE PULLEY DIAMETER (mm):		110	SHAFT DIAMETER (mm):		110
43 41		120			120			120
PUMP RPM:		150	POWER RATING (kW):		150	ELEMENT DIAMETER (mm):		150
			2.25 kw 380v					180
PUMP CONDITION:			ENGINE CONDITION:			ELEMENT STROKE (mm):		210
								240

COMMENTS:

P I S =	2.56	300
	2.42	420
	2.37	480
		540
		600
		660

DID THE BOREHOLE PRODUCE ANY SILT / SAND / GRAVEL ?

STEPPED DISCHARGE TEST AND RECOVERY

BOREHOLE NO.:	EC/008/CH	PROJECT:	Sterkstroom Groundwater Development
ALTERNATIVE NO.:	0	SITE NAME:	Sterkstroom Groundwater Development
ALTERNATIVE NO.:	0	CLIENT:	Chris Hani District Municipality
BOREHOLE DEPTH (mdd):	71.23	CASING DEPTH (mdd):	6.21
DEPTH OF PUMP (mdd):	48.00	CASING HEIGHT (magl):	0.60
PUMP INLET DIAMETER (mm):	0.000	CASING ID (mm):	1.650
STATIC WATER LEVEL (mdd):	22.58	DATUM LEVEL (magl):	0.26
		PUMP TYPE USED:	BP22
		OPERATOR:	Isaac
		CONTRACTOR:	AB Pumps

DISCHARGE RATE 1			Time	Recovery 1	DISCHARGE RATE 2			Time	Recovery 2	DISCHARGE RATE 3			Time	Recovery 3
DATE:	19/04/2002		(min):	(m)	DATE:	19/04/2002		(min):	(m)	DATE:	19/04/2002		(min):	(m)
TIME:	14H10				TIME:					TIME:				
Time	Drawdown	Yield			Time	Drawdown	Yield			Time	Drawdown	Yield		
(min):	(m)	(l/s)			(min):	(m)	(l/s)			(min):	(m)	(l/s)		
1	1.34		2		1	8.37		2		1	13.34		2	
2	2.19		3		2	8.64		3		2	14.82	1.970	3	
3	3.31		5		3	8.80	1.040	5		3	16.35	2.030	5	
5	3.98	0.700	7		5	9.13		7		4	18.05		7	
7	4.22	0.660	10		7	9.29		10		7	19.19	2.060	10	
10	4.13		15		10	9.49	1.050	15		10	19.85		15	
15	4.05	0.540	20		15	9.95		20		15	20.46		20	
20	4.21		30		20	10.22	1.030	30		20	20.64	2.040	30	
30	4.44		40		30	10.62		40		30	21.34		40	
40	4.80	0.550	50		40	10.80	1.040	50		40	21.75	2.050	50	
50	4.86		60		50	10.95	1.020	60		50	22.07		60	
60	4.95	0.520	70		60	11.06		70		60	22.64	2.040	70	
70	5.09		80		70	11.21	1.040	80		70	23.09		80	
80	5.19	0.530	90		80	11.37		90		80	23.70	2.030	90	
90	5.26		100		90	11.43	1.030	100		90	24.10		100	
100	5.32		110		100	11.50		110		100	24.80		110	
110			120		110			120		110			120	
120			180		120			180		120			180	
			210					210					210	

Average yield: 0.58333333 (l/s)

Average yield: 1.03571429

Average yield: 2.03142857

DISCHARGE RATE 4			Time	Recovery 4	DISCHARGE RATE 5			Time	Recovery 5	DISCHARGE RATE 6			Time	Recovery
DATE:	19/04/2002		(min):	(m)	DATE:	19/04/2002		(min):	(m)	DATE:	19/04/2002		(min):	(m)
TIME:					TIME:					TIME:				
Time	Drawdown	Yield			Time	Drawdown	Yield			Time	Drawdown	Yield		
(min):	(m)	(l/s)			(min):	(m)	(l/s)			(min):	(m)	(l/s)		
1			2		1			2		1			2	18.28
2			3		2			3		2			3	14.76
3			5		3			5		3			5	12.00
5			7		5			7		5			7	9.42
7			10		7			10		7			10	8.04
10			15		10			15		10			15	6.72
15			20		15			20		15			20	5.60
20			30		20			30		20			30	4.84
30			40		30			40		30			40	4.36
40			50		40			50		40			50	3.78
50			60		50			60		50			60	3.57
60			70		60			70		60			70	3.04
70			80		70			80		70			80	2.72
80			90		80			90		80			90	2.64
90			100		90			100		90			100	2.56
100			110		100			110		100			110	2.49
110			120		110			120		110			120	2.42
120			180		120			180		120			180	2.35
			210					210		150			210	2.28
										180			240	2.21
										210			300	2.14
										240			360	2.07

Average yield: #DIV/0!

COMMENTS:	300	180	300
	360	210	360
	420	240	420
	480	300	480
	540	360	540
	600	420	600
	660	480	660
	720		
	780		
		Average yield:	720

DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(l/s)	(m)	(min)	(m)	(m)	(min)	(m)	(m)	(min)	(m)	(m)
1500				1500			1500			1500		
1560				1560			1560			1560		
1620				1620			1620			1620		
1680				1680			1680			1680		
1740				1740			1740			1740		
1800				1800			1800			1800		
1860				1860			1860			1860		
1920				1920			1920			1920		
1980				1980			1980			1980		
2040				2040			2040			2040		
2100				2100			2100			2100		
2160				2160			2160			2160		
2220				2220			2220			2220		
2280				2280			2280			2280		
2340				2340			2340			2340		
2400				2400			2400			2400		
2460				2460			2460			2460		
2520				2520			2520			2520		
2580				2580			2580			2580		
2640				2640			2640			2640		
2700				2700			2700			2700		
2760				2760			2760			2760		
2820				2820			2820			2820		
2880				2880			2880			2880		

DESCRIPTION:	QUANTITY:	UNIT:
ESTABLISHMENT		Sum
INTER HOLE MOVE > 10 km		Km.
FROM: SITE NAME:		
BOREHOLE No:		
INTER HOLE MOVE < 10 km:		No.
REMOVAL AND RE-ERECTION OF PUMP HOUSE:		No.
REMOVAL OF EXISTING EQUIPMENT:		No.
RE-INSTALLATION OF EXISTING EQUIPMENT:		No.
WORK TIME RATE (REPAIRS):		Hour
STANDING TIME:		Hour
LATITUDE:		
LONGITUDE:		

S
U
M
M
A
R
Y

DESCRIPTION:	QUANTITY:	UNIT:
STRAIGHTNESS TEST:		No
VERTICALITY TEST:		No
CASING DETECTION:		No
STEEL BOREHOLE COVER:		No
BOREHOLE MARKING:		No
SITE CLEANING / FINISHING:		No
REPORTING & DATA RECORDING:		No
SLUG TEST:		No
LAYFLAT (m):		m
BOREHOLE DEPTH AFTER TEST:		m
BOREHOLE WATERLEVEL AFTER TEST:		m

TEST DESCRIPTION	STEP	1	2	3	4	5	6	TOTAL	RECOVERY:
CALIBRATION TEST:								(min) (hrs)	(m) (min)
TEST DURATION (Minutes)		15	15	15	10			55	0 92
TEST YIELD (l/s)		0.36	0.61	1.44	3.99			MAXIMUM (l/s)	4.0
DRAWDOWN (m)		2.81	4.83	10.35	25.42			MAXIMUM (m)	25.4
MULTI-RATE / STEP DRAWDOWN:									
TEST DURATION (Minutes)		100	100	100				300	5 00
TEST YIELD (l/s)		0.58	1.04	2.03				MAXIMUM (l/s)	2.0
DRAWDOWN (m)		5.3	11.50	24.80				MAXIMUM (m)	24.8


RECOVERY TEST			
TIME TOTAL (hrs):		32.00	
Cal	Steps	CD	Total
50	420	1440	1920
DRAWDOWN TOTALS (CD):			
AVAILABLE	UTIL-	%	
	ISED		
25.4	12.16	47.84	

CONSTANT DISCHARGE TEST	TEST DURATION		TEST YIELD	DRAWDOWN	RECOVERY:			
	(min)	(hrs)	(l/s)	(m)	(m)	%	(min)	(hrs)
	1440	24 00	0.77	12.16	5.99	50.74	1440	24 00
OBSERVATION BOREHOLES:	No.	720	1440	2880	>2880 (min)		TOTAL:	
	of boreholes	(min)	(min)	(min)	nr.	Time	(min)	(hrs)
							3	3 00

BOREHOLE NUMBER: EC/008/CH

CALIBRATION TEST AND RECOVERY

Discharge 1:	0.36	Discharge 2:	0.61	Discharge 3:	1.44	Discharge 4:	3.99	Discharge 5:		Discharge 6:	
--------------	------	--------------	------	--------------	------	--------------	------	--------------	--	--------------	--




Discharge Rate 1
Discharge Rate 2
Discharge Rate 3
Discharge Rate 4
Recovery

Drawdown 1:	2.81
Drawdown 2:	4.83
Drawdown 3:	10.35
Drawdown 4:	25.42
Drawdown 5:	0.00
Drawdown 6:	0.00
Duration 1:	15
Duration 2:	15
Duration 3:	15
Duration 4:	10
Duration 5:	
Duration 6:	
Recovery (m):	0.84
Recovery (min):	60

STEPPED DISCHARGE TEST AND RECOVERY


Discharge 1:	0.58333	Discharge 2:	1.03571	Discharge 3:	2.03143	Discharge 4:		Discharge 5:		Discharge 6:	
--------------	---------	--------------	---------	--------------	---------	--------------	--	--------------	--	--------------	--



Discharge rate 1
Discharge rate 2
Discharge rate 3
Recovery
Step 2
Step 3

Drawdown 1:	5.32
Drawdown 2:	11.50
Drawdown 3:	24.80
Drawdown 4:	0.00
Drawdown 5:	0.00
Drawdown 6:	
Duration 1:	100
Duration 2:	100
Duration 3:	100
Duration 4:	
Duration 5:	
Duration 6:	
Recovery (m):	2.07
Recovery (min):	420

CONSTANT DISCHARGE TEST AND RECOVERY




Constant discharge rate
Recovery

TEST INFORMATION

Date tested	19/04/2002	Water level (mbgl)	22.58	Depth of pump (mbgl)	48
Test duration	1440	CD discharge rate	0.71	CD drawdown	12.16
Available drawdown (m)	25.42	% Recovery after CD	51	% after 1440 min	

COOPER-JACOB ANALASYS GRAPH

EC/008/CH



CALIBRATION TEST AND RECOVERY

BOREHOLE NO. :	EC/009/CH	PROJECT :	Sterkstroom Groundwater Development
ALTERNATIVE NO. :		SITE NAME :	Sterkstroom
ALTERNATIVE NO. :		CLIENT :	Chris Hani District Municipality
BOREHOLE DEPTH (mbdl):	53.49	CASING DEPTH (mbdl):	3.80
DEPTH OF PUMP (mbdl):	52.00	CASING HEIGHT (magh):	0.27
PUMP INLET DIAMETER (mm):	800.00	CASING ID (mm):	165.00
STATIC WATER LEVEL (mbdl):	25.40	DATUM LEVEL (magl):	0.46
		PUMP TYPE USED:	BP22
		OPERATOR:	Isaac
		CONTRACTOR:	AB Pumps
		SUPERVISOR:	

DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3										
DATE:	15/04/2002		TIME:		19h15		DATE:	15/04/2002		TIME:		19h30		DATE:	15/04/2002		TIME:		19h45	
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery						
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)						
1	0.64		1		1	1.84		1		1	6.80		1							
2	0.64		2		2	1.98		2		2	7.75		2							
3	0.65	0.76	3		3	2.21	2.47	3		3	9.57	7.12	3							
5	0.75		5		5	2.55		5		5	10.34		5							
7	0.84	0.77	7		7	2.92	2.46	7		7	11.62	7.14	7							
10	0.98		10		10	3.18		10		10	12.70		10							
15	1.03		15		15	3.55		15		15	13.94		15							

EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20
TYPE OF RESERVOIR:	30		TYPE OF ENCLOSURE:	30		PRESSURE GAUGE MANUFAC	30	
	40			40		TURER:	40	
RESERVOIR SIZE:	50		MATERIAL OF ENCLOSURE:	50			50	
	60			60		GAUGE READING (KpA):	60	
RESERVOIR CONITION:	70		CONDITION OF ENCLOSURE:	70			70	
	80			80		MONITORING FACILITY:	80	
STAND HEIGHT (m):	90		WATER METER MANUFACTURER:	90			90	
	100			100		MAINTAINED:	100	
	110		WATER METER READING:	110			110	
	120			120			120	
	150			150			150	

DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6							
DATE:	15/04/2002		TIME:		19h50		DATE:	15/04/2002		TIME:				TIME:			
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery			
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)			
1	17.48		1		1			1		1			1	16.32			
2	19.07		2		2			2		2			2	15.82			
3	20.50	15.04	3		3			3		3			3	13.48			
5	23.94		5		5			5		5			5	12.18			
7	26.12		7		7			7		7			7	11.07			
10	P. I. S.	13.04	10		10			10		10			10	10.10			
15	P. I. S.	12.89	15		15			15		15			15	9.42			

EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20
PUMP TYPE:	30		TYPE OF POWER:	30		TYPE OF RISER:	30	
Franklin Electric	40		Electric	40			40	
PUMP MANUFACTURER:	50		ENGINE MANUFACTURER:	50		CLASS OF RISER:	50	
Jacuzzi	60			60			60	
PUMP SERIAL No:	70		ENGINE MODEL:	70		DIAMETER OF RISER (mm):	70	
33632993 2124-09-0/91	80			80			80	
PUMP PULLEY DIAMETER (mm):	90		ENGINE SERIAL No:	90		CONDITION OF RISER:	90	
80	100			100			100	
PUMP INTAKE DEPTH (m):	110		ENGINE PULLEY DIAMETER (mm):	110		SHAFT DIAMETER (mm):	110	
52.81m	120			120			120	
PUMP RPM:	150		POWER RATING (kw):	150		ELEMENT DIAMETER (mm):	150	
0 2875			7.5 kw				180	
PUMP CONDITION:			ENGINE CONDITION:			ELEMENT STROKE (mm):	210	
							240	

COMMENTS:	300
	420
	480
	540
	600
	660

DID THE BOREHOLE PRODUCE ANY SILT / SAND / GRAVEL ?

CONSTANT DISCHARGE TEST AND RECOVERY

BOREHOLE NO. :		EC/009/CH	PROJECT:		Sterkstroom Groundwater Development	CLIENT:	Chris Hani District Municipality
ALTERNATIVE NO. :		0	SITE NAME:		Sterkstroom		
DEPTH OF PUMP (mbdl):		52.00	PUMP TYPE USED:		BP22	OPERATOR:	Isaac
INLET DIAMETER (mm):		800	EXISTING EQUIPMENT:		Franklin Electric	CONTRACTOR:	AB Pumps
TEST DATE:	16/04/2002	TEST DATE:	19/04/2002	TOTAL TIME - PUMPED (min):	2160	TOTAL TEST TIME (min):	2160
TEST STARTED TIME:	12h30	TEST COMPLETED TIME:	12h30	TOTAL TIME - RECOVERY (min):	2160	AVERAGE YIELD (l/s):	1.81

DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3					
CASING HEIGHT (magl):		0.27		No. :				No. :		EC/008/CH		No. :			
CASING DEPTH (mbdl):		3.80		DATUM LEVEL (magl):				DATUM LEVEL (magl):		0.23		DATUM LEVEL (magl):			
CASING ID (mm):		165.00		CASING DEPTH (mbdl):				CASING DEPTH (mbdl):		3.21		CASING DEPTH (mbdl):			
BOREHOLE DEPTH (mbdl):		53.49		BOREHOLE DEPTH:				BOREHOLE DEPTH:		71.23		BOREHOLE DEPTH:			
WATER LEVEL (mbdl):		25.40		WATER LEVEL:				WATER LEVEL:		22.58		WATER LEVEL:			
DATUM LEVEL (magl):		0.46		DISTANCE (m):				DISTANCE (m):		100		DISTANCE (m):			
Time (min)	Drawdown (m)	Yield (l/s)	Recovery (m)	Time (min)	Drawdown (m)	Recovery (m)	Time (min)	Drawdown (m)	Recovery (m)	Time (min)	Drawdown (m)	Recovery (m)			
1	4.55		15.16	1			1		0.99	1					
2	4.61		12.42	2			2		0.98	2					
3	4.62	0.94	12.40	3			3		0.97	3					
5	4.63		12.34	5			5		0.96	5					
7	4.66		12.21	7			7		0.95	7					
10	4.70	1.85	12.08	10			10		0.94	10					
15	4.92		11.83	15			15		0.93	15					
20	5.42	1.86	11.63	20			20		0.92	20					
30	7.04		11.39	30			30		0.91	30					
40	7.46		11.10	40			40		0.90	40					
60	7.74	1.85	10.95	60			60	0.05	0.89	60					
90	7.99		10.73	90			90		0.88	90					
120	8.24	1.84	10.51	120			120	0.09	0.87	120					
150	8.58		10.29	150			150		0.80	150					
180	8.94	1.86	10.07	180			180	0.10	0.85	180					
210	9.34		9.85	210			210		0.84	210					
240	9.82	1.35	9.53	240			240	0.14	0.83	240					
300	10.24	1.84	9.41	300			300	0.19	0.82	300					
360	10.56	1.83	9.02	360			360	0.22	0.81	360					
420	10.84	1.84	8.84	420			420	0.25	0.79	420					
480	11.00	1.85	8.78	480			480	0.28	0.78	480					
540	11.24	1.84	8.70	540			540	0.31	0.77	540					
600	11.56	1.82	8.62	600			600	0.34	0.76	600					
660	11.89	1.84	8.57	720			660	0.34	0.75	720					
720	12.19	1.85	8.51	840			720	0.37	0.74	840					
780	12.47	1.83	8.45	960			780	0.40	0.73	960					
840	12.73	1.84	8.40	1080			840	0.40	0.73	1080					
900	12.99	1.85	8.36	1200			900	0.46	0.72	1200					
960	13.10	1.84	8.30	1320			960	0.48	0.72	1320					
1020	13.68	1.85	8.26	1440			1020	0.50	0.71	1440					
1080	13.98	1.84	8.23	1800			1080	0.54	0.70	1800					
1140	14.15	1.86	8.19	2280			1140	0.59	0.70	2280					
1200	14.36	1.85	8.05	2880			1200	0.64	0.69	2880					
1260	14.71	1.84	7.96				1260	0.68	0.69						
1320	14.99	1.86	7.97				1320	0.71	0.69						
1380	15.24	1.35	7.88				1380	0.75	0.68						
1440	15.60	1.84	7.84				1440	0.78	0.68						


DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(l/s)	(m)	(min)	(m)	(m)	(min)	(m)	(m)	(min)	(m)	(m)
1500	15.96	1.85	7.79	1500			1500	0.80	0.67	1500		
1560	16.34	1.84	7.75	1560			1560	0.83	0.67	1560		
1620	16.34	1.85	7.71	1620			1620	0.85	0.66	1620		
1680	16.98	1.86	7.67	1680			1680	0.88	0.66	1680		
1740	17.28	1.85	7.63	1740			1740	0.90	0.65	1740		
1800	17.59	1.86	7.52	1800			1800	0.92	0.65	1800		
1860	17.84	1.85	7.48	1860			1860	0.94	0.64	1860		
1920	18.16	1.87	7.45	1920			1920	0.96	0.64	1920		
1980	18.47	1.86	7.41	1980			1980	0.98	0.63	1980		
2040	18.76	1.85	7.38	2040			2040	1.00	0.63	2040		
2100	19.05	1.84	7.35	2100			2100	1.02	0.62	2100		
2160	19.39		7.32	2160			2160	1.04	0.62	2160		
2220				2220			2220			2220		
2280				2280			2280			2280		
2340				2340			2340			2340		
2400				2400			2400			2400		
2460				2460			2460			2460		
2520				2520			2520			2520		
2580				2580			2580			2580		
2640				2640			2640			2640		
2700				2700			2700			2700		
2760				2760			2760			2760		
2820				2820			2820			2820		
2880				2880			2880			2880		

DESCRIPTION:	QUANTITY:	UNIT:	S U M M A R Y	DESCRIPTION:	QUANTITY:	UNIT:	
ESTABLISHMENT		Sum			STRAIGHTNESS TEST:		No
INTER HOLE MOVE > 10 km		Km.			VERTICALITY TEST:		No
FROM: SITE NAME:					CASING DETECTION:		No
BOREHOLE No:					STEEL BOREHOLE COVER:		No
INTER HOLE MOVE < 10 km:		No			BOREHOLE MARKING:		No
REMOVAL AND RE-ERECTION OF PUMP HOUSE:		No			SITE CLEANING / FINISHING:		No
REMOVAL OF EXISTING EQUIPMENT:		No			REPORTING & DATA RECORDING:		No
RE-INSTALLATION OF EXISTING EQUIPMENT:		No			SLUG TEST:		No
WORK TIME RATE (REPAIRS):		Hour			LAYFLAT (m):		m
STANDING TIME:		Hour		BOREHOLE DEPTH AFTER TEST:		m	
LATITUDE:				BOREHOLE WATERLEVEL AFTER TEST:		m	
LONGITUDE:							


TEST DESCRIPTION	STEP							TOTAL:		RECOVERY:		RECOVERY TEST																	
		1	2	3	4	5	6	(min)	(hrs)	(m)	(min)	TIME TOTAL (hrs):	45.50	Cal	Steps	CD	Total												
CALIBRATION TEST:																													
TEST DURATION (Minutes)		15	15	15	7			52	0.87	2.69	150																		
TEST YIELD (l/s)		0.77	2.47	7.13	13.66																								
DRAWDOWN (m)		1.03	3.55	13.94	26.12																								
MULTI-RATE / STEP DRAWDOWN:																													
TEST DURATION (Minutes)		100	100	50				250	4.17	4.09	420																		
TEST YIELD (l/s)		35.32	4.08	6.89																									
DRAWDOWN (m)		7.1	14.01	26.12																									
CONSTANT DISCHARGE TEST		TEST DURATION		TEST YIELD		DRAWDOWN		RECOVERY:																					
		(min)	(hrs)	(l/s)		(m)		(m)		%		(min)		(hrs)															
		2160	36.00	1.81		19.39		7.32		32.25		2160		36.00															
OBSERVATION BOREHOLES:		No.	720	1440		2880		>2880 (min)		TOTAL:																			
		of boreholes	(min)	(min)		(min)		nr.		Time		(min)		(hrs)															
												3		3.00															

BOREHOLE NUMBER: EC/009/CH


CALIBRATION TEST AND RECOVERY



STEPPED DISCHARGE TEST AND RECOVERY



CONSTANT DISCHARGE TEST AND RECOVERY




TEST INFORMATION

Date tested	16/04/2002	Water level (mbgl)	25.40	Depth of pump (mbgl)	52
Test duration	2160	CD discharge rate	1.81	CD drawdown	19.39
Available drawdown (m)	26.6	% Recovery after CD	62	% after 2160 min	

COOPER-JACOB ANALASYS GRAPH

EC/009/CH



APPENDIX C

CHEMICAL WATER ANALYSES

Project	Sterkstroom
Borehole ID	EC/002/CH
Date sampled	12/04/2002
Drinking water class	2 (Total Hardness)
Sample number	GP 464

Parameter	Symbol	Unit	Concentration	Class			
				Drinking water	Food preparation	Bathing	Laundry
Viable organisms		CFU/1ml					
Faecal coliforms		CFU/100 ml	0	0	0	0	0
Total coliforms		CFU/100 ml	0	0	0	0	0

Electrical Conductivity	EC	mS/m	107	1	1	0	0
Total Dissolved Solids	TDS	mg/L	814	1	1	0	0
pH Value	pH		8.4	0	0	0	0

Calcium	Ca	mg/l	62.8	0	0	1	1
Chloride	Cl	mg/l	44	0	0	0	0
Fluoride	F	mg/l	0.5	0	0	0	0
Iron	Fe	mg/l	<0.03	0	0	0	0
Total hardness	CaCo3	mg/l	461	2	3	3	3
Nitrate	N	mg/l	1.3	0	0	0	0
Orthophosphate	P	mg/l	0.6				
Potassium	K	mg/l	9	0	0	0	0
Sodium	Na	mg/l	66.9	0	0	0	0
Sulphate	SO4	mg/l	116	0	0	0	0

Ammonia	N	mg/l	<0.1				
Total alkalinity	CaCO3	mg/l	423				
Bicarbonate	HCO3	mg/l	423				
Carbonate	CO3	mg/l	<10				

Sample date	Sample number	Drinking water	Food preparation	Bathing class	Laundry class
12/04/2002	EC002OT	2	3	3	3

Colour coded classification system (DWAF, 1998)

Colour	Class	Water quality
Blue	0	Ideal – suitable for lifetime use
Green	1	Good – suitable for use, rare instances of negative effects
Yellow	2	Marginal – conditionally acceptable. Negative effects may occur in some
Red	3	Poor – unsuitable for use without treatment. Chronic effects may occur
Purple	4	Dangerous – totally unsuitable for use. Acute effects may occur

Project	Sterkstroom
Borehole ID	EC/004/CH
Date sampled	12/04/2002
Drinking water class	4 (Faecal and Total coliform count)
Sample number	GP 463

Parameter	Symbol	Unit	Concentration	Class			
				Drinking water	Food preparation	Bathing	Laundry
Viable organisms		CFU/1 ml					
Faecal coliforms		CFU/100 ml	30000	4	4	3	3
Total coliforms		CFU/100 ml	35000	4	4	3	3

Electrical Conductivity	EC	mS/m	74	1	1	0	0
Total Dissolved Solids	TDS	mg/L	460	1	1	0	0
pH Value	pH		8.2	0	0	0	0

Calcium	Ca	mg/l	38.8	0	0	1	1
Chloride	Cl	mg/l	27	0	0	0	0
Fluoride	F	mg/l	0.6	0	0	0	0
Iron	Fe	mg/l	<0.03	0	0	0	0
Total hardness	CaCo3	mg/l	461	2	3	3	3
Nitrate	N	mg/l	0.1	0	0	0	0
Orthophosphate	P	mg/l	0.6				
Potassium	K	mg/l	2.1	0	0	0	0
Sodium	Na	mg/l	58.8	0	0	0	0
Sulphate	SO4	mg/l	33	0	0	0	0

Ammonia	N	mg/l	<0.1				
Total alkalinity	CaCO3	mg/l	376				
Bicarbonate	HCO3	mg/l	376				
Carbonate	CO3	mg/l	<10				

Sample date	Sample number	Drinking water	Food preparation	Bathing class	Laundry class
12/04/2002	ECC04OT	4	4	3	3

Colour coded classification system (DWAf, 1998)

Colour	Class	Water quality
Blue	0	Ideal – suitable for lifetime use
Green	1	Good – suitable for use, rare instances of negative effects
Yellow	2	Marginal – conditionally acceptable. Negative effects may occur in some
Red	3	Poor – unsuitable for use without treatment. Chronic effects may occur
Purple	4	Dangerous – totally unsuitable for use. Acute effects may occur

Project	Sterkstroom
Borehole ID	EC/005/CH
Date sampled	26/04/2002
Drinking water class	4 (Total Coliforms)
Sample number	GP 479

Parameter	Symbol	Unit	Concentration	Class			
				Drinking water	Food preparation	Bathing	Laundry
Viable organisms		CFU/1ml					
Faecal coliforms		CFU/100 ml	1000	4	4	3	3
Total coliforms		CFU/100 ml	1300	4	4	3	3

Electrical Conductivity	EC	mS/m	81	1	1	0	0
Total Dissolved Solids	TDS	mg/L	326	0	0	0	0
Turbidity		NTU	<1				
pH Value	pH		8	0	0	0	0

Calcium	Ca	mg/l	13.1	0	0	1	1
Chloride	Cl	mg/l	<3	0	0	0	0
Fluoride	F	mg/l	1	1	1	0	0
Iron	Fe	mg/l	0.43	0	0	0	2
Total hardness	CaCo3	mg/l	57	0	0	1	0
Nitrate	N	mg/l	2.8	0	0	0	0
Orthophosphate	P	mg/l	0.1				
Potassium	K	mg/l	2.6	0	0	0	0
Sodium	Na	mg/l	124.9	1	1	0	0
Sulphate	SO4	mg/l	16	0	0	0	0

Ammonia	N	mg/l	0.3				
Total alkalinity	CaCO3	mg/l	413				
Bicarbonate	HCO3	mg/l	413				
Carbonate	CO3	mg/l	<10				

Sample date	Sample number	Drinking water	Food preparation	Bathing class	Laundry class
26/04/2002	EC005CH	4	4	3	3

Colour coded classification system (DWAF, 1998)

Colour	Class	Water quality
Blue	0	Ideal – suitable for lifetime use
Green	1	Good – suitable for use, rare instances of negative effects
Yellow	2	Marginal – conditionally acceptable. Negative effects may occur in some
Red	3	Poor – unsuitable for use without treatment. Chronic effects may occur
Purple	4	Dangerous – totally unsuitable for use. Acute effects may occur

Project	Sterkstroom
Borehole ID	EC/006/CH
Date sampled	18/04/2002
Drinking water class	1
Sample number	GP 478

Parameter	Symbol	Unit	Concentration	Class			
				Drinking water	Food preparation	Bathing	Laundry
Viable organisms		CFU/1ml					
Faecal coliforms		CFU/100 ml	0	0	0	0	0
Total coliforms		CFU/100 ml	0	0	0	0	0

Electrical Conductivity	EC	mS/m	72	1	1	0	0
Total Dissolved Solids	TDS	mg/L	420	0	0	0	0
Turbidity		NTU	5				
pH Value	pH		8	0	0	0	0

Calcium	Ca	mg/l	50.3	0	0	1	1
Chloride	Cl	mg/l	24	0	0	0	0
Fluoride	F	mg/l	0.7	0	0	0	0
Iron	Fe	mg/l	0.06	0	0	0	1
Total hardness	CaCo3	mg/l	216	1	2	2	2
Nitrate	N	mg/l	0.4	0	0	0	0
Orthophosphate	P	mg/l	4				
Potassium	K	mg/l	2.6	0	0	0	0
Sodium	Na	mg/l	91.4	0	0	0	0
Sulphate	SO4	mg/l	<10	0	0	0	0

Ammonia	N	mg/l	0.2				
Total alkalinity	CaCO3	mg/l	323				
Bicarbonate	HCO3	mg/l	323				
Carbonate	CO3	mg/l	<10				

Sample date	Sample number	Drinking water	Food preparation	Bathing class	Laundry class
26/04/2002	EC006CH	1	2	2	2

Colour coded classification system (DWAf, 1998)

Colour	Class	Water quality
Blue	0	Ideal – suitable for lifetime use
Green	1	Good – suitable for use, rare instances of negative effects
Yellow	2	Marginal – conditionally acceptable. Negative effects may occur in some
Red	3	Poor – unsuitable for use without treatment. Chronic effects may occur
Purple	4	Dangerous – totally unsuitable for use. Acute effects may occur

Project	Sterkstroom
Borehole ID	EC/008/CH
Date sampled	26/04/2002
Drinking water class	2 (Total Coliforms)
Sample number	GP 480

Parameter	Symbol	Unit	Concentration	Class			
				Drinking water	Food preparation	Bathing	Laundry
Viable organisms		CFU/1ml					
Faecal coliforms		CFU/100 ml	0	0	0	0	0
Total coliforms		CFU/100 ml	30	2	2	1	1

Electrical Conductivity	EC	mS/m	51	0	0	0	0
Total Dissolved Solids	TDS	mg/L	472	1	1	0	0
Turbidity		NTU	<1				
pH Value	pH		8	0	0	0	0

Calcium	Ca	mg/l	39	0	0	1	1
Chloride	Cl	mg/l	86	0	0	0	0
Fluoride	F	mg/l	0.3	0	0	0	0
Iron	Fe	mg/l	<0.03	0	0	0	0
Total hardness	CaCo3	mg/l	194	0	1	2	2
Nitrate	N	mg/l	0.2	0	0	0	0
Orthophosphate	P	mg/l	<0.1				
Potassium	K	mg/l	1.3	0	0	0	0
Sodium	Na	mg/l	32	0	0	0	0
Sulphate	SO4	mg/l	<10	0	0	0	0

Ammonia	N	mg/l	<0.1				
Total alkalinity	CaCO3	mg/l	234				
Bicarbonate	HCO3	mg/l	234				
Carbonate	CO3	mg/l	<10				

Sample date	Sample number	Drinking water	Food preparation	Bathing class	Laundry class
26/04/2002	ECC08CH	2	2	2	2

Colour coded classification system (DWAf. 1998)

Colour	Class	Water quality
Blue	0	Ideal – suitable for lifetime use
Green	1	Good – suitable for use. rare instances of negative effects
Yellow	2	Marginal – conditionally acceptable. Negative effects may occur in some
Red	3	Poor – unsuitable for use without treatment. Chronic effects may occur
Purple	4	Dangerous – totally unsuitable for use. Acute effects may occur

Project	Sterkstroom
Borehole ID	EC/009/CH
Date sampled	26/04/2002
Drinking water class	3 (Faecal coliforms)
Sample number	GP 481

Parameter	Symbol	Unit	Concentration	Class			
				Drinking water	Food preparation	Bathing	Laundry
Viable organisms		CFU/1ml					
Faecal coliforms		CFU/100 ml	40	3	3	2	2
Total coliforms		CFU/100 ml	55	2	2	1	1

Electrical Conductivity	EC	mS/m	59	0	0	0	0
Total Dissolved Solids	TDS	mg/L	332	0	0	0	0
Turbidity		NTU	5	2	2	1	1
pH Value	pH		7.9	0	0	0	0

Calcium	Ca	mg/l	17.9	0	0	1	0
Chloride	Cl	mg/l	<3	0	0	0	0
Fluoride	F	mg/l	0.3	0	0	0	0
Iron	Fe	mg/l	<0.03	0	0	0	0
Total hardness	CaCo3	mg/l	79	0	0	1	0
Nitrate	N	mg/l	0.7	0	0	0	0
Orthophosphate	P	mg/l	0.1				
Potassium	K	mg/l	2.6	0	0	0	0
Sodium	Na	mg/l	162.8	1	1	0	0
Sulphate	SO4	mg/l	36	0	0	0	0

Ammonia	N	mg/l	<0.1				
Total alkalinity	CaCO3	mg/l	264				
Bicarbonate	HCO3	mg/l	264				
Carbonate	CO3	mg/l	<10				

Sample date	Sample number	Drinking water	Food preparation	Bathing class	Laundry class
26/04/2002	EC008CH			2	2

Colour coded classification system (WAF, 1998)

Colour	Class	Water quality
Blue	0	Ideal – suitable for lifetime use
Green	1	Good – suitable for use, rare instances of negative effects
Yellow	2	Marginal – conditionally acceptable. Negative effects may occur in some
Red	3	Poor – unsuitable for use without treatment. Chronic effects may occur
Purple	4	Dangerous – totally unsuitable for use. Acute effects may occur

APPENDIX D

PROJECT MAPS

