


**GROUNDWATER RESOURCE INFORMATION PROJECT
EASTERN CAPE PROVINCE**

GROUNDWATER INFORMATION SOURCE REFERENCE SHEET



SOURCE REF NR:	AG101	Own Archive	<input checked="" type="checkbox"/>	Copy attached	<input checked="" type="checkbox"/>
		Sourced		Copy at source	

A: SOURCE DESCRIPTION

District Municipality:	<table border="1"> <tr> <td>Amatole</td> <td></td> <td>Chris Hani</td> <td align="center"><input checked="" type="checkbox"/></td> <td>O.R Tambo</td> <td></td> </tr> <tr> <td>Ukhahlamba</td> <td></td> <td>Cacadu</td> <td></td> <td>Alfred Nzo</td> <td></td> </tr> </table>	Amatole		Chris Hani	<input checked="" type="checkbox"/>	O.R Tambo		Ukhahlamba		Cacadu		Alfred Nzo	
Amatole		Chris Hani	<input checked="" type="checkbox"/>	O.R Tambo									
Ukhahlamba		Cacadu		Alfred Nzo									
Local Municipality:	Engcobo												
Institution where Information is held:	AGES EC CC												
Branch of Institution:	EAST LONDON												
Contact details:	Contact person: JAN MYBURGH												
	Contact Tel: 043 7262070												
	Contact Email: easterncape@ages-group.com												

B: TYPE OF INFORMATION

Information format:	<table border="1"> <tr> <td>Hard copy</td> <td align="center"><input checked="" type="checkbox"/></td> <td>Data Summary</td> <td></td> <td>Electronic Report</td> <td></td> </tr> </table>	Hard copy	<input checked="" type="checkbox"/>	Data Summary		Electronic Report							
Hard copy	<input checked="" type="checkbox"/>	Data Summary		Electronic Report									
	Specify Other:												
Report / Info Title:	Groundwater source definition and feasibility study for the Engcobo local municipality – Chris Hani district municipality – Eastern Cape Province												
Report Nr:	EC/03/26/HG Date: May 2003												
Author Details:	J.A MYBURGH												
Author's Qualification:	<table border="1"> <tr> <td>Hydrogeologist</td> <td align="center"><input checked="" type="checkbox"/></td> <td>Govt Dept</td> <td></td> <td>Project Manager</td> <td></td> </tr> <tr> <td>Engineer</td> <td></td> <td>Technician</td> <td></td> <td>Other</td> <td></td> </tr> </table>	Hydrogeologist	<input checked="" type="checkbox"/>	Govt Dept		Project Manager		Engineer		Technician		Other	
Hydrogeologist	<input checked="" type="checkbox"/>	Govt Dept		Project Manager									
Engineer		Technician		Other									
	Specify Other:												
Captured by:	A VILJOEN Date: 23/2/2004 Signed: <i>Alilper</i>												

C: GEOHYDROLOGICAL CATEGORIZATION

Project Type	<table border="1"> <tr> <td>Source development</td> <td align="center"><input checked="" type="checkbox"/></td> <td>Feasibility Study</td> <td align="center"><input checked="" type="checkbox"/></td> <td>Sanitation Study</td> <td></td> </tr> </table>	Source development	<input checked="" type="checkbox"/>	Feasibility Study	<input checked="" type="checkbox"/>	Sanitation Study			
Source development	<input checked="" type="checkbox"/>	Feasibility Study	<input checked="" type="checkbox"/>	Sanitation Study					
	Specify Other:								
Reference Co-ordinate:	<table border="1"> <tr> <td>Latitude</td> <td>Longitude</td> </tr> <tr> <td>S 31° 40' 00"</td> <td>E 28° 5' 00"</td> </tr> </table>	Latitude	Longitude	S 31° 40' 00"	E 28° 5' 00"				
Latitude	Longitude								
S 31° 40' 00"	E 28° 5' 00"								
Lithological & Construction Logs	<table border="1"> <tr> <td>Yes</td> <td>No</td> <td>Complete</td> <td>Incomplete</td> </tr> <tr> <td align="center"><input checked="" type="checkbox"/></td> <td></td> <td align="center"><input checked="" type="checkbox"/></td> <td></td> </tr> </table>	Yes	No	Complete	Incomplete	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Yes	No	Complete	Incomplete						
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>							
Hydrocensus Data	<table border="1"> <tr> <td>Yes</td> <td>No</td> <td>Complete</td> <td>Incomplete</td> </tr> <tr> <td align="center"><input checked="" type="checkbox"/></td> <td></td> <td></td> <td align="center"><input checked="" type="checkbox"/></td> </tr> </table>	Yes	No	Complete	Incomplete	<input checked="" type="checkbox"/>			<input checked="" type="checkbox"/>
Yes	No	Complete	Incomplete						
<input checked="" type="checkbox"/>			<input checked="" type="checkbox"/>						
Pump Testing Data	<table border="1"> <tr> <td>Yes</td> <td>No</td> <td>Complete</td> <td>Incomplete</td> </tr> <tr> <td align="center"><input checked="" type="checkbox"/></td> <td></td> <td align="center"><input checked="" type="checkbox"/></td> <td></td> </tr> </table>	Yes	No	Complete	Incomplete	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Yes	No	Complete	Incomplete						
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>							
Chemical Water Analysis Data	<table border="1"> <tr> <td>Yes</td> <td>No</td> <td>Complete</td> <td>Incomplete</td> </tr> <tr> <td align="center"><input checked="" type="checkbox"/></td> <td></td> <td align="center"><input checked="" type="checkbox"/></td> <td></td> </tr> </table>	Yes	No	Complete	Incomplete	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Yes	No	Complete	Incomplete						
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>							
Geohydrological Data	<table border="1"> <tr> <td>Yes</td> <td>No</td> <td>Complete</td> <td>Incomplete</td> </tr> <tr> <td align="center"><input checked="" type="checkbox"/></td> <td></td> <td align="center"><input checked="" type="checkbox"/></td> <td></td> </tr> </table>	Yes	No	Complete	Incomplete	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Yes	No	Complete	Incomplete						
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>							
Spring Data	<table border="1"> <tr> <td>Yes</td> <td>No</td> <td>Complete</td> <td>Incomplete</td> </tr> <tr> <td align="center"><input checked="" type="checkbox"/></td> <td></td> <td></td> <td align="center"><input checked="" type="checkbox"/></td> </tr> </table>	Yes	No	Complete	Incomplete	<input checked="" type="checkbox"/>			<input checked="" type="checkbox"/>
Yes	No	Complete	Incomplete						
<input checked="" type="checkbox"/>			<input checked="" type="checkbox"/>						
Remote Sensing Data	<table border="1"> <tr> <td>Yes</td> <td>No</td> <td>Complete</td> <td>Incomplete</td> </tr> <tr> <td align="center"><input checked="" type="checkbox"/></td> <td></td> <td></td> <td align="center"><input checked="" type="checkbox"/></td> </tr> </table>	Yes	No	Complete	Incomplete	<input checked="" type="checkbox"/>			<input checked="" type="checkbox"/>
Yes	No	Complete	Incomplete						
<input checked="" type="checkbox"/>			<input checked="" type="checkbox"/>						
Map Data	<table border="1"> <tr> <td>Yes</td> <td>No</td> <td>Complete</td> <td>Incomplete</td> </tr> <tr> <td align="center"><input checked="" type="checkbox"/></td> <td></td> <td></td> <td align="center"><input checked="" type="checkbox"/></td> </tr> </table>	Yes	No	Complete	Incomplete	<input checked="" type="checkbox"/>			<input checked="" type="checkbox"/>
Yes	No	Complete	Incomplete						
<input checked="" type="checkbox"/>			<input checked="" type="checkbox"/>						

Comments:

Reviewed by: *F. de Jager* Date: *12/3/04* Signed: *[Signature]*

Final Project Report:

EC/03/26/HG




SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD

Hydrogeological investigation

**GROUNDWATER SOURCE DEFINITION AND FEASIBILITY STUDY
FOR THE ENGCOCO LOCAL MUNICIPALITY - CHRIS HANI
DISTRICT MUNICIPALITY- EASTERN CAPE PROVINCE**

July 2003



Project Team:

J.A. Myburgh

T. Mafanya

I. Dennis

T. Zangashe

Hydrogeological investigation

**GROUNDWATER SOURCE DEFINITION AND FEASIBILITY STUDY
FOR THE ENGCOCO LOCAL MUNICIPALITY - CHRIS HANI
DISTRICT MUNICIPALITY- EASTERN CAPE PROVINCE**


25 July 2003

Conducted for the Chris Hani District Municipality – on behalf of:

FST Consulting Engineers and Rural Developers
12 St Matthews Rd
EAST LONDON
5201

Mr. T. Rossouw
Tel. No.: (043) 743 8264
Fax. No.: (043) 743 8269

Compiled by:



J.A. Myburgh (BSc Hons), Consulting Hydrogeologist – Pr.Sci.Nat.

Northern Province	Gauteng Province	Eastern Cape Province
120 Marshall Street	66 Paradissi Street, Highveld X8	10 Sansom Street, Vincent
P.O. Box 2526	Postnet, Suite 12, Private Bag X108	Postnet 205, Private Bag N9063
PIETERSBURG	CENTURION	EAST LONDON
0700	0046	5200
Tel. No. +27 - 15 - 291 1577	Tel. No. +27 - 12 - 665 3100	Tel. No. +27 - 43 - 726 2070
Fax. No. +27 - 15 - 291 1702	Fax. No. +27 - 12 - 665 2176	Fax. No. +27 - 43 - 726 9232
e-mail pietersburg @ geocon.co.za	e-mail centurion @ geocon.co.za	e-mail eastlondon @ geocon.co.za

Directors: SJ Pretorius, JA Myburgh, F Calitz, JJP Vivier

REPRODUCED COPY

This document contains confidential and proprietary information of Southern Africa GeoConsultants (Pty) Ltd. and is protected by copyright in favour of Southern Africa GeoConsultants (Pty) Ltd. and may not be reproduced, or used without the written consent of Southern Africa GeoConsultants (Pty) Ltd. that has been obtained beforehand. This document is prepared exclusively for the Chris Hani District Municipality and is subject to all confidentiality, copyright and trade secrets, rules, intellectual property law and practices of SOUTH AFRICA.

Although Southern Africa GeoConsultants (Pty) Ltd exercises due care and diligence in rendering services and preparing documents, Southern Africa GeoConsultants (Pty) Ltd accepts no liability, and the client, by receiving this document, indemnifies Southern Africa GeoConsultants (Pty) Ltd and its directors, managers, agents and employees against all actions, claims, demands, losses, liabilities, costs, damages and expenses arising from or in connection with services rendered, directly or indirectly by Southern Africa GeoConsultants (Pty) Ltd and by the use of the information contained in this document..

Table of contents

1 INTRODUCTION	5
1.1 PREFACE.....	5
1.2 PROJECT AIMS AND OBJECTIVES	5
2 SITE DESCRIPTION.....	6
2.1 LOCATION	6
2.2 TOPOGRAPHY AND DRAINAGE	6
2.3 PHYSICAL ENVIRONMENT AND CLIMATE.....	7
2.4 SURFACE HYDROLOGY	8
3 DESKTOP STUDY	9
3.1 INFORMATION SOURCES.....	9
3.2 HYDROGEOLOGY	10
3.2.1 Katberg Formation.....	10
3.2.2 Burgersdorp Formation.....	11
3.2.3 Molteno Formation.....	11
3.2.4 Karoo Volcanism.....	11
3.2.5 Alluvium.....	12
3.3 REMOTE SENSING	12
3.4 STRUCTURAL GEOLOGY	12
3.5 PRELIMINARY GROUNDWATER POTENTIAL ZONATION	13
4 POTENTIAL VERIFICATION	15
4.1 REMOTE SENSING.....	15
4.2 BOREHOLE SITING.....	15
4.3 GEOPHYSICAL PROFILING.....	15
4.3.1 Magnetic method	15
4.3.2 Very Low Frequency (VLF) Electromagnetic Profiling.....	16
4.3.3 Electrical Resistivity Profiling.....	16
4.4 BOREHOLE DRILLING	16
4.5 PUMP TESTING AND DATA ANALYSES.....	17
4.6 CHEMICAL WATER ANALYSES	18
4.7 GROUNDWATER BALANCE CALCULATION.....	19
5 RESULTS	20
5.1 EXISTING BOREHOLES	20
5.1.1 Borehole information and pump testing data.....	20
5.1.2 Water quality	20
5.2 RECENTLY DEVELOPED BOREHOLES	21
5.2.1 Borehole information and testing data.....	21

5.2.2	<i>Water quality</i>	21
5.3	NEWLY DEVELOPED BOREHOLES	21
5.3.1	<i>Geophysical survey for groundwater exploration</i>	21
5.3.2	<i>Geological targets and exploration drilling</i>	22
5.3.2.1	North West-South East-trending lineaments.....	22
5.3.2.2	North East-South West trending lineaments.....	22
5.3.2.3	Dolerite ring structures	23
5.3.2.4	Contact between dolerite sill and host rock sediments	23
5.3.3	<i>Pump testing data</i>	23
5.3.4	<i>Water chemistry- newly drilled boreholes</i>	24
5.4	GROUNDWATER POTENTIAL ZONATION	25
5.4.1	<i>Groundwater recharge</i>	25
5.4.2	<i>Surface water-groundwater interaction</i>	26
5.4.3	<i>Lateral groundwater flow across catchment boundaries</i>	28
5.4.4	<i>Groundwater balance and availability</i>	29
5.4.5	<i>Delineation of groundwater potential</i>	32
6	REGIONAL SANITATION PERSPECTIVE	33
7	CONCLUSIONS AND RECOMMENDATIONS	35
8	REFERENCES	37

1 INTRODUCTION

1.1 Preface

Southern Africa GeoConsultants (PTY) Ltd – hereafter referred to as GeoCon- was appointed by the Chris Hani District Municipality to carry out a groundwater feasibility study in association with FST Consulting Engineers as part of a water supply feasibility study for the Engcobo Local Municipality of the Chris Hani District Municipality of the Eastern Cape Province.

This report provides detailed results of the work conducted, is an extension of, and is based on methodologies and approaches followed during the groundwater feasibility studies carried out in the Emalahleni and Lukanji Local Municipalities. Geohydrological work was further carried out in association with SRK Consulting Engineers and Scientists who have been appointed for the Intsika Yethu Local Municipality's geohydrological feasibility study.

1.2 Project aims and objectives

The project aims, objectives and methodologies were defined in a proposal that was initially submitted to the District Municipality and were later defined in coordination with FST.

The objectives of the study were outlined based on two phases namely:

Feasibility Study:

- Desk Study & Data collection
- Lineament Mapping & Recharge evaluations
- Groundwater Potential Assessment
- GIS Map Compilation & reporting
- Collation of all available historical information in the form of reports, databases, etc.
- Consultation with role players that have been involved in the area:
- Study of relevant geological maps, aerial photographs, Satellite Images.
- Compilation of preliminary GIS-based maps indicating areas of high structural intensity (e.g. lineaments), recharge potential, rainfall and terrain accessibility

Verification Phase:

- Feasibility study results evaluation and verification
- Exploration borehole site selection through geophysical surveys
- Investigate and verify defined groundwater potential zones, topography, access to drilling targets, recharge potential and water quality:
- Pump testing of selected existing boreholes
- Identification of drilling targets in the identified groundwater potential zones:
- Exploration drilling under hydrogeological co-ordination and supervision
- Scientific Pump testing and chemical water analyses under hydrogeological co-ordination and supervision
- Classification of villages based on groundwater potential
- Data evaluation and processing - final report compilation

2 SITE DESCRIPTION

2.1 Location

The Engcobo Local Municipality is located on the eastern edge of the Chris Hani District Municipality in the central part of the Eastern Cape Province. The R61 provincial road runs through the study area, linking the Chris Hani District Municipality with the O.R. Tambo District Municipality to the east.

The regional locality of the study area is indicated in the attached MAP 1.

2.2 Topography and drainage

The site is situated at an elevation between 800 – 1400 mamsl. The terrain is characterised by prominent mountain ridges with steep narrow valleys in the north, with more open valley floors and moderately sloping topography towards the south.




Photo 1: Even slopes of open valley floors in foreground with mountainous northern region in the background

The groundwater flow is presumed to mimic topography, with shallow groundwater levels occurring at low-lying areas. Three perennial rivers drain the entire project area namely:

- Mbashe River
- Xuka River
- Mgwali River

These rivers drain water in a southeasterly direction towards the Indian Ocean.

2.3 Physical environment and climate

The Engcobo area is generally defined as a semi arid region and is characterized by cold dry winters and hot humid summers. The rainfall pattern varies seasonally with an average monthly precipitation of approximately 100mm occurring during the summer season. The precipitation decreases quite significantly in winter to an average of approximately 16 mm per month. Average monthly precipitation levels recorded at Engcobo are indicated in Figure 1 below.




Figure 1: Average monthly rainfall for Engcobo - Weather Bureau station 0125880 X Engcobo Prison

The mean annual evaporation for the region ranges between 1300 and 1400 mm per year (Midgley et al. 1994). High temperatures of the region affect the high mean annual evaporation values observed. During summer, temperatures of up to and exceeding 30°C are recorded while in winter a drop in temperatures occurs to approximately 11.5°C and colder. Snowfalls during winter are seldom, occurring on higher grounds, while frost commonly occurs throughout the area. The higher grounds are also characterised by mist and fog in the early morning and late evenings, which are mostly accompanied by drizzle throughout the year with increased humidity as a result. Uneven distribution of precipitation is noted across the area, due to the windward sides of the mountain ridges generally experiencing higher amounts of precipitation than the leeward sides.

2.4 Surface Hydrology

The study area is known for springs occurring in certain parts. These are mainly controlled by the underlying geology where the capping of mountain ridges by dolerite sills and sheets serve as the important structures for spring formation. The springs have been traditionally used as source of water for domestic and livestock purposes in most communities. This has also impacted on the site selection by communities who tend to target foothills for new settlements, where most springs are most likely to occur. Several major rivers flow through the study area. These rivers are partly used for domestic water supply. A number of small stock dams are found in the study area. These surface water sources are presumably linked to local aquifers, and the final water source potential definition in the area will have to address both sources to make feasible and accurate recommendations for regional water supply. Surface water source definition and potential was addressed in the surface water component of the study, under the appointment of FST.

3 DESKTOP STUDY

3.1 Information sources

Several information sources that may lead to better understanding of the region were used. These included the previous studies done by GeoCon and other external reports. The sources of information considered and referred are the following:

- Climatic and surface water information was obtained from:
 - South African Weather Services
 - The report *Surface Water Resources of South Africa 1990*, Midgley D. C. et al, WRC Report 298/5.1/94 and 298/5.2/94, 1994.
 - 1:250 000 scale geological map: 3126 Queenstown and 3128 Umtata
- Geological and geohydrological information was obtained from
 - The 1:250 000 scale geological map: 3126 Queenstown and 3128 Umtata
 - The report *Karoo Aquifers, Their geology, Geometry and physical properties*, Botha et al, WRC Report 487/1/98, 1998
 - The report *Karoo Aquifers, The influence of dolerite sill and ring complexes on the occurrence of groundwater in Karoo Fractured Aquifers: a morpho- tectonic approach*, Chevillier et al, WRC Report 937/1 01, 2001.
- Hydrogeological information was obtained from the 1:500 000 scale hydrogeological map: 3126 Queenstown.
- Regional remote sensing was done using satellite imagery – Landsat Images WRS 170-82, WRD 169-82
- Detailed remote sensing was done using 1:150 000 scale stereoscopic air photography - Job 916 Strip 3, photos 487, 484 and 494 and 1:50 000 scale stereoscopic air photography - Job 983 Strip 12, photos 903, 904; 905, 906 and strip 13, photo 792
- Topographical information was obtained from the following 1:50 000 scale topographical maps
 - 3127DA Cala, second edition, 1982
 - 3127DB Engcobo, second edition, 1981
 - 3127DD Ncora Dam, second edition, 1995
 - 3128AC Xuka Drift, second edition, 1980
 - 3128AD Umnga Flats, second edition, 1982
 - 3128CA All Saints, second edition, 1982
 - 3128CB Baziya, first edition, 1982
 - 3128CC Mjanyana, second edition, 1995
 - 3128CD Clarkbury, second edition, 1995
- Community liaison was used to assess terrain conditions and obtain historical data regarding existing water sources and general terrain conditions
- Pump test evaluation and analyses was done using:

- Kruseman, G.P. and De Ridder, N.A. (1991). *Analysis and Evaluation of Pumping Test Data* International Institute for Land Reclamation and Improvement, PO Box 45, 6700 AA Wageningen, The Netherlands
- Van Tonder G.J. *et al* (2000) *FC-Program (Flow Characteristic Program)*. Institute for Groundwater studies, University of the Orange Free State, Bloemfontein, South Africa
- Water quality assessment was done using the document *Quality of Domestic Water Supplies; Volume 1; Assessment Guide; Second Edition 1998; Water Research Commission No. TT101/98* as well as the recommended limits set in SABS 241 of 1984.

3.2 Hydrogeology

The geology of the Engcobo area comprises the middle part of the stratigraphic sequence of the Karoo Supergroup as indicated in Figure 2. The area is dominated by the sedimentary rocks of the Beaufort and the Stormberg Groups, occurring as indicated in MAP 2.




Figure 2: Stratigraphic succession of formations occurring in the study area

3.2.1 Katberg Formation

The Katberg Formation occurs in the extreme south of the Engcobo district and is characterized by the brownish red and grey mudstones and fine-grained sandstone. The formation is mainly sandstone rich with quartz dominant. The rapid increase in the quartz content at the expense of feldspar in the Katberg Formation would appear to reflect strong uplift and denudation of the Cape Fold Belt, located between the magmatic arc and the Basin. The sediments of the Katberg Formation were probably deposited under fluvial environments. The mode of transportation of the sediments was mainly the meandering and the

braided streams of the Triassic periods. The nature of deposition explains the layered sequence of alternating sandstones and mudstones in the Engcobo area. Groundwater mainly occurs in intergranular and fractured zones.

3.2.2 Burgersdorp Formation

The sediments of the Burgersdorp Formation overlies the Katberg formation and consist of brownish red and grey mudstone and sandstones, with mudstones dominating (70-80% mudstones). During the deposition of these sediments the fluvial conditions of the Triassic Period were still prevalent, marking the deposition of the Burgersdorp Formation. Due to the nature of deposition, the sediments of the Burgersdorp Formation have a layered sequence. In nature, the sediments of the Burgersdorp Formation differ widely. The variation is marked by the presence of coarse to fine-grained sediments, which indicate reworking of the sediments during the time of deposition. Groundwater occurrence is mainly expected in fractured zones and intergranular spaces of the rocks. Where layers of coarse sediments exist, high yielding boreholes can be expected.

3.2.3 Molteno Formation

The sediments of the Molteno Formation consists of the coarse to fine grained buff sandstones with thin pebbly beds with blue and grey mudstone and shale layers with occasional coal seams. The climatic conditions that existed during the deposition of the Burgersdorp Formation were still prevalent during the onset of Molteno Formation. As such, the sediments of the Molteno Formation were deposited under fluvial environments by braided streams, which imply the graded nature of deposition. With regard to groundwater occurrence, the pebbly beds and the coarse grained sandstone of this formation have a relatively high storage capacity.

3.2.4 Karoo Volcanism

The last stages of the Karoo sedimentation were marked by the deposition of the volcanic lavas during the Early Jurassic period. The lavas were deposited in several phases, which marked the occurrence of the geological structures (ring, linear and sheet structures) of the Karoo Sequence. As such, the Burgersdorp Formation is mainly characterised by dykes, ring sheets and sheets while the Molteno Formation is mainly characterised by dykes. This explains the common dolerite ring structures, which form mountains in the Engcobo area. The nature of deposition of these lavas differed tremendously, where linear dykes, ring dykes and dolerite sills occur. When deposition occurred the Basaltic lavas must have followed the zones of weakness, hence the structures seen today. The linear structures can stretch up to the tens of kilometres and their width varies between 1 and 10m. For the dolerite sheet structures the lavas must have followed the bedding planes of the country rock.




Photo 2: Ring type dolerite intrusion north east of Engcobo town

3.2.5 Alluvium

One of the recent Karoo deposits are alluvial and colluvial deposits. These sediments overlie the original Karoo sediments. Although they are not widely spread they serve as important sites for groundwater occurrence. These sediments occur within the study area and are mostly located along riverbeds with distribution as indicated in MAP 2.

3.3 Remote sensing

Satellite imagery and air photography was used to define and delineate structures occurring in the study area. Lineaments are in most cases related to dolerite dyke intrusion and several of the major lineaments could be verified as such with the NW and NE direction as the dominant direction of dolerite dyke intrusion in the study area. Most lineaments in the study area are related to dyke intrusion and no major faults with huge displacements along them were observed. Small scale faulting and fracturing related to dolerite intrusion will however be present throughout the area.

MAP 3 shows the orientation, distribution and density of lineaments in the study area, as observed from the satellite imagery. This was used as an important part of the groundwater potential delineation as well as for target selection for exploration drilling during the verification phase.

3.4 Structural geology

Geological structures (dykes) that were induced during Karoo Volcanism differed in orientation as well as distributions amongst lithological units of the Karoo Supergroup. This implies lithological control as well as stress variations during the time of emplacement. As such several orientation of dykes/ lineaments can be observed in the study area and these include:

- NW trending dykes
- EW trending dykes
- NE trending dykes

➤ NNE trending dykes

In some places the occurrence of these dykes is accompanied by the dolerite ring structures. The ring structures have recently been given attention as major structures for groundwater occurrence. A study by Chavallier et al. (2001) revealed that yields in excess of 60l/s can be obtained if suitable structures are penetrated up to depths of 300m.

The emplacement of the basaltic lavas during Jurassic Period had several effects on the country rocks of the Karoo Supergroup. The effects mainly include:

- Mechanical deformation of the rocks which mainly involved:
 - Dilation of the rock, which was induced laterally by the pressure of intruding magma on the walls of the host rock. In this case shearing and displacement of the host rock is common. Field investigations have also revealed presence of slickensides, which give evidence of shearing.
 - Bending, shearing (depending on the elasticity of the rock) and fracturing of the overburden material due to intruding magma
- Baking and metamorphism of the host rock which improved the matrix potential of the Burgersdorp Formation mudstones

The mechanical deformation obviously has a marked advantage on groundwater occurrence where the fracturing at depth and along prominent and major dykes serves as sites for groundwater occurrence. This is also the case with ring structures where the outer side has been noted to be highly fractured due to intruding magma (Chevallier et al. 2001).

Where the aforementioned structures occur, fracturing and shearing is mostly observed. Such zones generally have a high potential for groundwater occurrence and were targeted during groundwater exploration.

MAP 4 indicates the distribution of all structures observed and derived from remote sensing, as well as dolerite ring structures. This was further used as part of the groundwater potential delineation as well as for target selection for exploration drilling during the verification phase

3.5 Preliminary Groundwater Potential Zonation

Based on desktop study results, preliminary groundwater potential zonation was conducted for the entire Engcobo Local Municipal area. The data used was obtained from various sources, and included information such as borehole yields, lithological drilling logs, pump testing data and water chemistry results. The information was evaluated and a groundwater potential zonation map was compiled to act as a planning tool for groundwater source development and planning purposes. Potential zonation takes into account expected borehole yields and water quality but is mainly determined by long-term sustainability of the underground sources. It has been found that the zone of highest potential can be delineated according to the geometry and occurrence of the outer limbs of the main dolerite ring structure occurring in the study area as well as secondary structures associated with it. Several smaller ring type intrusions also influenced regional potential distribution.

The study area was divided into *HIGH*, *MODERATE* and *LOW* potential zones. Exploration drilling and pump testing of existing boreholes as well as the newly drilled boreholes aims to confirm and better-define the preliminary groundwater potential zonation. This was reported in Geocon report EC 03/13/HG: *Preliminary report on the hydrogeological investigation – Engcobo Local Municipality: February 2003*.

4 POTENTIAL VERIFICATION

4.1 Remote Sensing

Remote sensing of the study area was done using satellite images as well as stereoscopic aerial photography as mentioned in paragraph 3.3. Satellite imagery is processed electronically using computer software to define and delineate prominent regional structures and their orientation. Stereoscopic aerial photography is used to delineate geological contacts and identify possible structures that may have an influence on the local underground water potential. These aerial photographs allow the viewer to see the photographed region three dimensionally. The viewer looks down on the photographed area, and can clearly identify landforms, dolerite dykes, sills and linear features that may predict the existence of possible water-bearing features. Features identified on the aerial photographs are then targeted for geophysical surveying and profiling.

4.2 Borehole siting

The methodology followed during the borehole-siting phase consisted of the following:

- Evaluation of available data - desktop study
- Stereoscopic aerial photo and satellite image investigation and interpretation – identification of structures and target areas
- Field surveys and Hydrogeological mapping – identification of geophysical profile positions
- Geophysical profiling comprising magnetic profiling, Very Low Frequency electromagnetic surveys and electrical resistivity profiling
- Evaluation of geophysical data in relation to surface geological observations
- Site finalisation and marking – liaison with community regarding access of drilling rig and ownership

4.3 Geophysical Profiling

4.3.1 Magnetic method

For the magnetic surveys, a proton magnetometer is the most commonly used instrument in groundwater exploration. Measurements of the magnetic field, taken in the vicinity of geological formations and contacts, show departures from the undisturbed magnetic field of the earth. These changes (called anomalies) could be large or small and could be either an increase or decrease of the earth's field and will depend on the depth of burial, degree and direction of magnetisation and the relationship to the direction of the earth's field at the locality.

The sensor of the proton magnetometer consists of a container of proton-rich fluid usually kerosene around which is wound a coil of wire. The protons act as small spinning magnets. The spin axes precess about the direction of the earth's magnetic field. Under normal circumstances the direction of the spin axes of the numerous protons are randomly oriented and will have no effect on the coil. A current is applied to the coil, creating a strong magnetic field that then aligns all the spin axes in the direction of this field. The current is switched off and the spin axes will then all precess about the direction of the earth's field and together will induce an oscillating voltage in the coil. The frequency of this oscillation will be equal to the precession

rate and is directly proportional to the earth's magnetic field.

The electronic console of the magnetometer provides the current for the coil in the form of a pulse and contains the electronics for measuring and recording the earth's magnetic field directly on a digital display.

These readings are taken at an interval of every 5 m for example, on a straight line and the results of the survey are plotted as profiles as the survey progresses. This gives the operator the opportunity of viewing his data to see where obvious errors have occurred and exactly where a geological feature is located. The slope and shape of the anomaly is used to determine the possible shape and orientation of the structure.

4.3.2 Very Low Frequency (VLF) Electromagnetic Profiling

Like most other so-called electromagnetic methods, the Very Low Frequency method can be used to find steeply dipping structures that differ from their surroundings with regard to the inherent electrical resistance of the rock. This method is thus very well suited for water prospecting in fractured zones.

The low-frequency field that is used is sent out from a radio transmitter. Normally the frequency is between 15 and 30 kHz. When the field emitted by a transmitter strikes a geological body having low electrical resistivity, secondary circuits are created in the body. This is called induction. These secondary currents, in turn, create a secondary magnetic field that is opposed to the original field emitted from the transmitter. Nature is quite conservative because it tries to counteract build-up of the external field by creating its own secondary field in the opposite direction. Only a body having low electrical resistance can create a secondary field.

The VLF instrument records the ratio of the strengths of the vertical and horizontal fields at the ground surface. Since the primary field emitted from the transmitter is horizontal, it is evident that a normal reading (taken where there is no anomaly) will be zero. A deviation from a normal reading is called an anomaly indication. The VLF instrument records these values and automatically constructs a profile similar to that of the magnetometer, indicating the exact position and size of the anomaly.

4.3.3 Electrical Resistivity Profiling

The direct current resistivity method is based on the behaviour of the flow of electrical current in the subsurface. The energy source is artificial which makes it possible to control the depth of investigation.

Horizontal profiling was done in targeted areas and the technique implies that the lateral distribution of electrical resistivity is studied by an electrode array for which the depth of investigation remains relatively constant. Profiling is most effective when lateral changes in resistivity are large. The electrical resistivity method is applied extensively in ground water investigations where it is often used to maximum advantage.

4.4 Borehole Drilling

All boreholes drilled during this project were drilled using the rotary air percussion technique. Drilling was done according to Minimum Standards and Guidelines set out by DWAF, 1997. This resulted in boreholes being drilled using the specified equipment under supervision of the hydrogeological consultant. Casing was installed to stabilise loose shallow formations and was inserted at least 3m into solid formations. Boreholes which can act as future production boreholes were each delivered with a sanitary seal such as to prevent the ingress of surface water and possible contamination of the groundwater source.

The straightness of boreholes was evaluated by means of a dummy test under supervision of the consultant where it was seen as necessary. Boreholes were numbered and marked by means of a metal stake planted 5m north of each borehole.




Photo 3: Boreholes are sealed and marked with a metal stake after completion

4.5 Pump testing and data analyses

Pump testing was carried out under the co-ordination and guidance of the hydrogeological consultant. It was the aim of the pump testing exercise to determine the potential at each borehole and tests were adapted according to the yields observed. This resulted in some boreholes being pumped for longer periods than others. The aim at all times was to obtain maximum information regarding the local aquifer within the allowed budget and scope of the appointment.

Initial testing procedures involved calibration testing where no information or inaccurate information regarding the yield of a borehole exists. This was typically followed by a step drawdown test during which the water level response to different abstraction rates was measured. Results from this test were used to determine a safe and adequate rate at which to perform the constant rate drawdown test. The constant rate drawdown test was commenced once the water level has recovered sufficiently.

The water level response to the constant rate drawdown test, as well as the recovery after the test, was used to assess the hydraulic parameters of the aquifer. These results help to determine the safe long-term abstraction rates at each of the tested boreholes.

Two parameters are used to describe the physical properties of the aquifer, namely transmissivity (T) and storativity (S). The first of these two quantifies the rate at which water moves through the aquifer and the latter quantifies the aquifer's ability to release water.

Different methods are available to determine the T values and other aquifer parameters. For this investigation the *FC-analysis method* was applied. The values obtained were then used to fit the step-drawdown data as a means of calibration.

4.6 Chemical Water Analyses

Water samples were taken at the end of constant rate drawdown tests at boreholes that were pump tested. Samples were analysed as far as physical, chemical and microbiological quality is concerned.

Results were evaluated by using the document: *Quality of Domestic Water Supplies; Volume 1; Assessment Guide; Second Edition 1998; Water Research Commission No. TT101/98* as well as the recommended limits set in SABS 241 of 1984.

This Guide allows the quality of water supplied for domestic use to be assessed by using a simple classification system. The system shows the nature of the effects of water quality on the domestic user for a range of concentration values for those substances commonly encountered in water. The information is presented in a simplified format so that a wide spectrum of users of the Guide will be able to understand the concepts of water quality as it affects the domestic user.

The Water Quality Assessment Guide defines the following classes:

Table 1: Water Quality Assessment Guide

Class 0	Ideal water quality	<i>Suitable for lifetime use</i>
Class 1	Good water quality	<i>Suitable for use, rare instances of negative effects.</i>
Class 2	Marginal water quality	<i>Conditionally acceptable. Negative effects may occur in some sensitive groups.</i>
Class 3	Poor water quality	<i>Unsuitable for use without treatment. Chronic effects may occur</i>
Class 4	Dangerous water quality	<i>Totally unsuitable for use. Acute effects may occur.</i>

4.7 Groundwater Balance Calculation

A water balance model is a quantitative evaluation of water gained or lost from a groundwater system under investigation during a specific period. It is assumed that the change in groundwater stored in the system relates directly to the change in groundwater level within the system, and it can be expressed as:

Equation 1 may be written as:
$$\frac{S\Delta V}{\Delta t} = R_e + I - O - Q$$
 Equation 1

where:

$\Delta V [L^3]$	=	change in groundwater storage within the time increment Δt
$R_e [L^3/T]$	=	natural effective groundwater recharge to aquifer
$I [L^3/T]$	=	natural groundwater Inflow into the system
$O [L^3/T]$	=	natural groundwater Outflow from the system
$Q [L^3/T]$	=	abstraction (including springflow) from the system
$S []$	=	specific yield (S-value)
$\Delta t [T]$	=	time increment

The two entities I and O in Equation 1 can be sub-divided further into the following components:

$I = I_b + I_r + I_{df}$ and $O = O_b + O_r + O_{df}$

where

I_b and O_b = lateral groundwater inflow and outflow over catchment boundaries

I_r and O_r = groundwater inflow and outflow to/from rivers

I_{df} and O_{df} = deep groundwater inflow and outflow over catchment boundaries (= 0 for first approximation because it is difficult to estimate it).

Under the steady-state groundwater flow condition, the change in storage is zero, and Equation 1 can be rewritten as:

$$R_e + I - O - Q = 0$$
 Equation 2

Under steady state conditions (Equation 2), the Potential Allocatable Groundwater for an area is defined as:

Allocatable groundwater = $R_e - I - O$ Equation 3

5 RESULTS

Borehole information was obtained from three different groups of boreholes, namely:

- Existing boreholes reflected on the National Groundwater Database (NGDB) and / or located in zones where insufficient data exists – verified through focussed hydrocensus process.
- Existing boreholes drilled and tested at several recently completed water supply projects carried out by GeoCon in the Engcobo municipal area.
- Newly drilled exploration boreholes – drilled and tested as part of this study.

5.1 EXISTING BOREHOLES

A desktop study evaluation of all boreholes occurring in the study area according to the National Groundwater Database resulted in thirteen boreholes being selected for evaluation. Some of these boreholes were however not reflected in the NGDB but were located through a hydrocensus in specific zones where insufficient data was available. The distribution of these existing boreholes is indicated in MAP 5. The boreholes considered were chosen as to best represent the entire project area. The conditions of existing boreholes were found to be moderate to poor, with some boreholes clogged and others in disrepair. Boreholes with poor construction or where unstable conditions occur were eliminated for the pump-testing phase. The list of all these boreholes is included in the BOREHOLE DATA SUMMARY TABLE, which is attached at the end of this report.

5.1.1 Borehole information and pump testing data

From the thirteen boreholes that were selected for pump testing, only seven could be tested effectively. The constant rate discharge tests varied between 24 and 48 hours depending on yields and aquifer conditions. Five boreholes were tested for a 48-hour period each and the rest were pump tested for 24 hours. The data obtained was then analysed using the FC Method as mentioned, in section 4.5 to evaluate aquifer characteristics and sustainable yields. The results obtained from the FC Method are summarised in the BOREHOLE DATA SUMMARY TABLE. Pump test data is attached in Appendix A for reference.

Boreholes were found to be 55 m deep on average. Transmissivities calculated from pump testing data vary from 8 m²/d to 116 m²/d, probably from fracture zones intersected by these boreholes while transmissivities of between 0.5 m²/d and 18 m²/d were observed during later stages of the constant rate tests – giving an indication of matrix flow capacity. An average sustainable yield of 0.9 l/s over 12/24 hr duty cycles could be calculated for these existing boreholes.

5.1.2 Water quality

Water samples were collected at the end of the constant discharge pump test as part of the pump testing process and sent to the Amatola Water Laboratory to be analysed as far as physical, chemical and microbial qualities are concerned. The results obtained from the analyses are summarised in the BOREHOLE DATA SUMMARY TABLE.

The results obtained from water quality analyses revealed that generally, the groundwater of the Engcobo area varies between class 1 and class 2, i.e. Good to Marginal water quality for domestic purposes. Classes higher than class 2 can also be encountered depending on the problem constituent. The analyses revealed that slight faecal contamination occurs in some boreholes. Hardness and fluoride persist in some boreholes and this can be related to the underlying sediments i.e. sandstone and mudstone.

Treatment measures: Chlorination of water is recommended for those boreholes that are affected by slight faecal contamination to improve the quality of water for domestic purposes.

The water quality data for each borehole evaluated is attached in Appendix B.

5.2 RECENTLY DEVELOPED BOREHOLES

5.2.1 Borehole information and testing data

Data from previous water supply projects that were undertaken by Geocon were incorporated into the study to fill in the gaps where borehole data was insufficient. This resulted in twenty-four boreholes being incorporated into this study to better define the groundwater potential for the entire Engcobo area. Most boreholes drilled were along the ring structures, on the steeply dipping side of the dolerite ring structure, where Nyanga, Eluheweni and Cobosi villages lie. High yielding boreholes have been obtained from this terrain, with yields varying between 2 and 15 l/s. Due to the successful results that were obtained in this region from previous water supply projects, the region was not considered for further evaluation. The list of all these boreholes is included in the BOREHOLE DATA SUMMARY TABLE.

5.2.2 Water quality

The water quality results from the recently drilled boreholes indicate Marginal water quality for Engcobo area, with total hardness being prominent but at marginal values. Regarding bacteriological water quality, only few boreholes showed a problem with faecal coliforms at the marginal range, which may only be problematic to sensitive groups. Chlorination of water prior to use is recommended.

5.3 NEWLY DEVELOPED BOREHOLES

A number of drilling sites were identified within the project area. These were sited in target zones identified for exploration drilling and groundwater source evaluation, based on the following:

- To define potential in zones where no information is available
- To verify potential in similar structures as the structures already successfully explored during recent groundwater development programs where high yielding boreholes were intersected
- To verify potential in smaller, secondary ring-type dolerite intrusions noted east of the main ring structure occurring in the direct vicinity of Engcobo Town
- To verify potential in preliminarily identified low potential zones.

The result was a test in the western portion of the study area where Nkwenkwezi was targeted, while on the eastern and northern portions of the study area Sentube and KwaSandile were targeted. Tyeni, Cefane, Gobhoti and Deberha mainly represented the central and the southern portions of the study area that were investigated.

5.3.1 Geophysical survey for groundwater exploration

Geophysical profiles were executed across targeted structures and lineaments identified during the geological mapping phase using the geophysical techniques described. The profiles varied in length and direction depending on the orientation of the targeted geological structure. A total of nineteen profiles were executed resulting in a total profiling length of 4780m. All anomalies noted from the geophysical profiles

were verified on terrain and drilling sites were finalised using on-site hydrogeological information in conjunction with geophysical data.

A total of ten drilling sites were finalised in different villages, as mentioned in section 5.2, and on various geological structures and geophysical anomalies. Results of the siting phase were reported and discussed with the project engineer before drilling commenced.

Geophysical data is attached in Appendix C for reference.

5.3.2 Geological targets and exploration drilling

Several structures were targeted during the exploration phase for groundwater source evaluation. These included the NW- SE trending lineaments, NE- SW trending lineaments, dolerite ring structures and contacts between dolerite sills structures with sedimentary bedrock. The targets in the sedimentary bedrock were mainly mudstone and sandstone of the Burgersdorp Formation and shale, mudstone and sandstone of the Molteno Formation. Identified and targeted geological structures are indicated in MAP 4 and can be compared to exploration borehole localities indicated in MAP 3.

Ten boreholes were drilled in the project area under the supervision of the hydrogeological consultant. Exploration borehole localities are indicated in Map 3 for which drilling results are summarised in the BOREHOLE DATA SUMMARY TABLE.

Measured airlift yields ranged between 0.1 l/s to 15 l/s. The drilling depth varied widely, depending on the structure targeted and the average depth of 95m was obtained. The water strikes intersected also depended on the structures targeted. As a result the water strikes intersected ranged between 38.5 and 127 m below ground level. Two of the drilled boreholes, EC-T11-003 and EC-T11-005, had very low yields, and were backfilled. From the ten boreholes drilled, six boreholes were developed. Solid and perforated steel casing was installed to the required depths where unstable formations necessitated it. Sanitary seals were installed to prevent the ingress of surface water into boreholes suitable for future utilisation. Drilling was stopped by the hydrogeological consultant, taking into account the drilling budget, results obtained and the borehole yields.

Lithological and construction logs are attached in Appendix D for reference.

Drilling results at each of the targeted geological structures are described in the paragraphs below:

5.3.2.1 North West-South East trending lineaments

Three boreholes were sited on NW-SE trending lineaments. The lineaments targeted included a dolerite dyke, which connects to a dolerite sill at Tyeni village and a fault at Deberha. These structures were targeted within the Burgersdorp Formation. The degree of weathering of the dolerite dyke at Tyeni was noted to be very low, with the structure poorly weathered. The yields obtained from the exploitation of this structure were very low.

Where a fault zone was targeted at Deberha, drilling of the borehole was unsuccessful. Several exploration boreholes were drilled on this structure, none yielding water.

All these boreholes were drilled in an area identified as high groundwater potential zone during desktop studies.

5.3.2.2 North East-South West trending lineaments

A northeast trending structure was evaluated in KwaSandile, where two boreholes were drilled. The first

borehole was sited on a fault zone; the target was a fault running along a northeast trending dyke. The second borehole was sited on the shear zone along a major dolerite dyke. The host bedrock was sediments of the Burgersdorp Formation. Exploration was successful with both boreholes yielding moderate to high flow rates and volumes. These boreholes were drilled in an area identified as having moderate groundwater potential during desktop studies.

5.3.2.3 *Dolerite ring structures*

In the past, dolerite ring structures have been given little attention for groundwater exploration in the province. During the exploration phase, these structures were considered for groundwater development. The two most prominent dolerite ring structures located within the Engcobo local municipal area were targeted. The first was the big dolerite ring structure in the direct vicinity of the town of Engcobo, and was targeted on its dipping side at Gobhoti village. On this structure, one existing borehole was drilled deeper to a depth of approximately 190m after which drilling was stopped due to the hammer being lost in the borehole. The dolerite seemed to be solid throughout the entire depth encountering only low yielding structures.

The second dolerite ring structure was targeted at Sentube village where a borehole was drilled to a final depth of 300m on the dipping side of the dolerite structure. The results obtained from this structure were similar to those obtained at Gobhoti village.

The results obtained from this exploration of dolerite ring structures was then compared to the existing data obtained from the same ring structure but on the steeply dipping side at Nyanga, Eluheweni and Cobosi. The comparison revealed that high yielding boreholes could be obtained on the steeply dipping side of the dolerite ring structure.

5.3.2.4 *Contact between dolerite sill and host rock sediments*

Two boreholes were drilled at Cefane to evaluate the groundwater potential on the contact zone between a dolerite sill and the sedimentary bedrock. The target zone on the dolerite sill was mainly on the periphery where the sill is generally dipping at a steep angle. The boreholes were mainly sited on the sediments of the Burgersdorp Formation. Both boreholes drilled on this target zone had very low yields.

Lithological logs are included in Appendix D for reference.

From the exploration drilling conducted the following can be said:

- Northeast trending lineaments including dolerite dyke yield better results
- East west trending lineaments also yield promising results.
- The outer side/ steeply dipping side of the dolerite ring structure yielded good results
- The inner side/ gently dipping side of the dolerite ring structure yielded very low results.
- Faults not occurring in association with dolerite yielded very low results.
- Where less weathering/ unweathered dolerite dykes were targeted low yield results were obtained.

5.3.3 Pump testing data

The boreholes that were successfully drilled and delivered adequate airlift yields pump tested by the appointed pump-testing contractor under supervision and guidance of the geohydrological consultant. From

the ten boreholes drilled - five boreholes were pump tested. Pump testing results are summarised in the BOREHOLE DATA SUMMARY TABLE

The transmissivity values from newly drilled boreholes suggest high fracture network with less matrix storage, indicated by a drop in Late Time Transmissivity as compared to Early Time Transmissivity. This means low abstraction values as compared to airlift yields obtained to ensure no over abstraction of the boreholes.

The duration of the pump tests varied widely depending on the yields of the boreholes. Constant drawdown tests generally varied between 24 and 48 hour durations at rates varying between 1 and 14 l/s. Long-term sustainability of each borehole was determined by interpreting and evaluating the pump testing data with the Flow Characteristic (FC) Method.

Detailed pump testing data is attached in Appendix A for reference

5.3.4 Water chemistry- newly drilled boreholes

To evaluate the water quality of the newly drilled boreholes, water samples were collected from each pump-tested borehole at the end of the constant drawdown test by the pump testing contractor. Samples were submitted to the Amatola Water Laboratory to be analysed as far as physical, chemical and microbial qualities are concerned. The results obtained from the analyses are summarised in the BOREHOLE DATA SUMMARY TABLE.

The water quality results obtained from newly drilled boreholes correlated well with the results obtained from the existing boreholes. The overall water quality is marginal, with slight changes in some boreholes due to certain increased constituents. Only one borehole EC-T12-004 had a problem with faecal contamination. Water quality results from the nearby river revealed that there is faecal contamination and this is affecting water quality in this borehole. Besides this faecal problem from EC-T12-004 and pH problem from EC-T12-005 the water quality from newly drilled boreholes is good.

Detailed chemical water analysis data is attached in Appendix B for reference.

5.4 Groundwater Potential Zonation

Groundwater potential can be defined as the amount of groundwater of a suitable quality that can be abstracted on a sustainable basis. There are numerous factors that influence the sustainability of an aquifer. This section will discuss some of these factors, however due to data constraints the confidence in the results is not always high.

5.4.1 Groundwater recharge

Groundwater recharge can be defined as water added to an aquifer e.g. from rainfall. Recharge (due to precipitation) or natural discharge (due to evaporation and transpiration) is generally the most prominent component of the water balance equation. Recharge is influenced by many factors, such as precipitation intensity, depth to groundwater, soil type, climatic conditions, vegetation and slope of ground surface. These factors make an accurate estimation of natural groundwater recharge and discharge complex.

An EXCEL-spreadsheet programme, RECHARGE (Van Tonder and Xu, 2000) can be used to determine the net groundwater recharge. RECHARGE is capable of using different methods including the chloride method, saturated volume fluctuation method, cumulative rainfall departure method, isotopes method, and series of qualified guesses. Bredenkamp et al. (1995) gives a detailed discussion of these methods.

The groundwater recharge for the area is calculated using the chloride method. The method is based on the following equation:

$$R_e = \frac{\text{Chloride concentration in rainfall}}{\text{Harmonic mean of Cl concentration in ground water}} \times 100$$

The results of the recharge calculations are shown in Figure 3 below.




Figure 3: Recharge distribution for the study area.

Assumptions made in these calculations are:

- Chloride values in groundwater were obtained from field data and from Woodford and Chevallier (2001).
- Chloride values in rainfall were obtained from Van Tonder and Xu (2000).
- Rainfall data for the quaternary catchments were obtained from FST engineers.

5.4.2 Surface water-groundwater interaction

Surface water bodies can recharge or discharge groundwater. The exchange rate of water is usually controlled by the difference in hydraulic heads (water levels) and resistance of the media between the groundwater and surface water bodies. According to water levels, surface water bodies can be classified:

- *Influent*: The groundwater level is lower than the surface water level, and therefore surface water is recharging groundwater.
- *Effluent*: The groundwater level is higher than surface water level, and therefore groundwater is recharging surface water.
- *Intermittent*: The groundwater level is higher than the bed of the surface water body, but depending on the elevation of the water level, groundwater may recharge the surface water body or the surface water may recharge groundwater.
- *No connection*: The groundwater level is below the surface water level and the two do not influence each other.

In more than 95% of the cases in South Africa, groundwater will flow towards rivers, implying that groundwater is recharging the rivers.

Very little information is available concerning groundwater-surface water interaction within the study area. Therefore it is assumed that the low-flows in the rivers are equivalent to the amount of groundwater entering the river in the form of base flow. A map of the low flows for the study area is shown in the following figure.




Figure 4: Lowflow values in million m³/month for the study area (FST Consulting Engineers)

Where lowflow values were not available baseflow values were obtained from the Institute for Groundwater Studies (Van Tonder, 2003). The amount of groundwater entering the rivers is assumed to be 30% of the baseflow value.

5.4.3 Lateral groundwater flow across catchment boundaries

Groundwater levels in an aquifer usually (in more than 95% of aquifers studied in South Africa) follow surface topography. Using *Bayesian* interpolation, a reliable groundwater contour map can be plotted, using surface topography. From the groundwater contour map areas where groundwater enters or leaves the catchment can be identified. Groundwater fluxes can then be calculated. Due to limited groundwater levels being available for the study area, a water level map from topography and average depth to water level was generated. Figure 5 estimates groundwater levels for the study area.

Table 2: Depth to groundwater

Borehole nr	Depth to groundwater (mbgl)
EC 031 CH	18.12
EC 032 CH	5.03
EC 033 CH	dry
EC 034 CH	dry
EC 035 CH	4.8
EC T11 002	1.76
EC T11 003	9.99
X EC T11 007	13.16
EC T11 008	17.5
EC T12 005	36
EC T12 008	7.53
T32314 3128 CB 00046	3.74
T32333 3127 CB 00031	1.85
X T32396 3128 CA 00041	0.54
T32342B 3128 CH 00013	1.15
T32343 3128 CH 00015	14.34




Figure 5 Groundwater levels for the study area

More than 90% of the horizontal flow within the study area is towards the rivers, therefore for the sake of the water balance only flow towards rivers was taken into account.

5.4.4 Groundwater balance and availability

Using all available data - groundwater balance calculations were considered for the entire study area. The calculations were made based on equation 3 in section 4.7. When the calculation were made the following assumptions were taken into consideration:

- *The amount of water that can be allocated is assuming steady state conditions, therefore the integrity of the resource is taken into account.*
- *The flow across a catchment boundary is not altered, thereby taking adjacent catchments into account.*

- *The flow from/to deeper aquifer systems is assumed zero in the first approximation.*
- *Current groundwater abstraction within the study area is not taken into account.*

The results obtained from the calculations were then presented according to quaternary catchments covering the study area. Such results are summarised in Table 3. A typical Storativity value for Karoo aquifers within the study area is 0.005 (Van Tonder and Dennis, 2000). Assuming the aquifer is 20 m thick, the amount of groundwater that can be released from storage can be calculated (see Table 3)

Catchment ¹	Groundwater recharge (m ³ /d)	Flow to surface water bodies (m ³ /d)	Groundwater available for abstraction (m ³ /d)	Groundwater in storage (Mm ³)
T11C	12040.27397	6766.667	5273.607306	3858
T11D	16810.68493	1021.405	15789.27999	1811
T11E	16107.94521	1361.97	14745.97499	1641
T11F	8670.684932	4166.667	4504.018265	2754
T11G	1607.794521	2437.242	No groundwater available ²	567
T11H	2848.438356	5932.007	No groundwater available ²	1027
T12A	21714.49315	461.5854	21252.90778	2273
T12B	6663.150685	3287.671	3375.479452	2300
T12C	1931.863014	763.9546	1167.90838	660
T12D	2896.689498	1302.289	1594.40012	1016
T12E	2603.232877	1105.73	1497.50312	925
T12F	9924.694064	4931.507	4993.187215	3464
T12G	681.8849315	302.7085	379.1764401	255

Table 3: Results of water balance calculations

¹*The flow towards the surface water bodies exceeds the recharge. Please note that only the section of the catchment within the study area was taken into account in the recharge calculations, and in this section, the flow to the surface water body exceeds the groundwater recharge. However, if the whole catchment were taken into account the groundwater will exceed the flow to the river.*

The availability of groundwater - as defined in the previous section - is defined per quaternary catchment in Figure 6.




Figure 6 Groundwater availability (only sections of quaternary catchments within study area are taken into account)

5.4.5 Delineation of groundwater potential

Final groundwater potential zonation resulted in the study area being divided into four zones, namely very high potential, high potential, moderate potential and low potential. This zonation is the result of refinement of the preliminary potential zonation, which was done during the desk top study phase.

The first aspect considered when refining the preliminary zones is groundwater availability. On this basis the sections of T11G and T11H are assigned low potential areas, as their recharge area does not fall within the study area. Although the catchments to the north of the study area (T11D, T11E and T12A) receive the highest rainfall – groundwater abstraction is difficult in the northern parts of the catchments because of the steep terrain and inaccessibility as can be seen in MAP 3.

Once the zones were defined according to groundwater availability, highest potential areas were identified according to geology, dolerite intrusion, faulting as well as slopes. The recharge in flat open valleys is normally higher.

The final potential zonation of the area is delineated in MAP 6.

Potential per delineated zone was applied to the specific villages occurring in these zones and all villages are listed according to the groundwater potential defined in the attached VILLAGE GROUNDWATER POTENTIAL TABLE.

In this table potential and cost estimates for source development have been based on the following:

Potential	Drilling attempts to deliver one production borehole	Expected Production Borehole Yield (l/s – over 12/24 hr duty cycle)
Very High	3	2.3
High	3	1.7
Moderate	4	0.8
Low	4	0.4

Table 4: Village based groundwater potential – as per MAP 6

6 REGIONAL SANITATION PERSPECTIVE

According to the Aquifer Classification Map of South Africa, the Engcobo District is located in an area that is classified as a *MINOR* aquifer. Although the national classification defines it as such - the aquifer is not currently fully utilised and its potential defined. The local value of the aquifer as determined by this study, is seen as *HIGH*. High yielding boreholes drilled in recent water supply programs in the study area, as well as during this study confirm this general high potential. A large percentage of community water demand can be met from utilising local groundwater sources. General chemical water quality is good but influences from poor borehole construction; animal waste and poor sanitation practises have caused contamination of groundwater sources in places. Protection of the aquifer at abstraction points is therefore seen as important.

In the light of the available physiographic information, the study area can be divided into the following landforms (i.e.: areas with similar topography, drainage regime and geological character) according to the systems devised by the National Data Bank for Roads of the Council for Scientific and Industrial Research (CSIR):

- Ridge crests
- Concave side slopes
- Convex side slopes
- Pediment slopes

Areas underlain by dolerite is expected to be covered by hillwash composed of silty sand to sandy clay exhibiting a stiff and moderately dense consistency and an intact structure that is micro-shattered. Hillwash generally extends from the surface to a depth of approximately 0.5m. The hillwash is usually ferruginised. A weakly developed pebble marker horizon is usually present. This layer is generally composed of abundant ferricrete nodules in a matrix of silty sand with scattered angular and sub-rounded sandstone and dolerite gravel and cobbles. The transported material is generally underlain by residual dolerite.

Areas underlain by sedimentary formations are generally found to be covered by hillwash composed of silty sand and clayey sand with a dense to moderately dense consistency and intact structure that extends from the surface to a depth of approximately 1m. The hillwash becomes increasingly ferruginised from this depth. The transported material is generally underlain by residual sandstone, siltstone or mudstone.

Excavatability plays an important role in the determination of the type of sanitation system that will be implemented. Pit latrines are generally required to be excavated to a depth ranging between 1.50 and 2.00 metres (ideally 1.80 m), into a suitable permeable soil at the base while a septic tank system requires at least 2.00 metres of suitable permeable soil from the surface to the base, implying depths in excess of 2.00 metres. It is expected in general for pits to be excavated to a depth ranging between 0.5 and 2.5 m, after which bedrock with a very soft rock to soft rock consistency will be encountered. The sidewalls of pits are expected to remain stable in general with collapse possibly occurring in specific problematic zones.

Static water levels noted in the Engcobo area vary from 1 to 36 m below surface with artesian boreholes known to occur in places. Springs are most prominent in the northern mountainous part of the area and surface water-groundwater interaction is prominent. Influence from on-site-sanitation practises is therefore likely.

The following flag-situations can occur in the Engcobo area and must be taken note of:

- ❑ The base of some pit latrines can be in fractured and weathered bedrock at some villages – especially towards the north
- ❑ Shallow depths to the groundwater table can be expected closer to valley floors and near dolerite contact zones
- ❑ Contaminated surface and spring water can influence groundwater quality
- ❑ The formation of contaminated perched groundwater within slightly permeable soil material is likely
- ❑ The ponding of contaminated water at the surface in the vicinity of water abstraction points and sanitation systems is likely due to local soil characteristics.
- ❑ Water abstraction points – if not protected – will promote contamination from animal waste and activity around these points.
- ❑ Ferruginised soil material is expected over the majority of the study area, which is indicative of perched groundwater conditions.

Evaluating the project area according to the Groundwater Protocol's Risk Assessment Table, it is seen that in general, a *POSSIBLE RISK* exists as far as ground water pollution is concerned throughout most of the study area.

Due to the classification of the terrain as a zone of *POSSIBLE RISK*, the following approach will have to be taken to reduce this *possible risk*:

- ❑ Detailed hydrogeological surveys per village will be required to delineate sensitive zones and make site-specific recommendations
- ❑ Alterations to existing and to-be-installed on-site systems might be required
- ❑ Alterations to existing borehole supplies might be required
- ❑ Zones where future groundwater sources can be developed must be protected
- ❑ Zones where pollution of the shallow aquifer is possible due to perched groundwater and seepage into pits must be defined
- ❑ Zones where pollution of the deep fractured aquifer is possible due to pit latrines being excavated in shallow bedrock must be delineated
- ❑ Localised rock outcrops have to be avoided by moving pit latrine sites.
- ❑ Excavation is recommended to take place beyond the bottom of impermeable hardpan ferricrete (when encountered) so that the pit base is in more permeable ground. It is recommended that the ferricrete be removed within at least a 1-metre radius of the pit and replaced with a suitably impermeable material. Alternatively the pit could be lined.
- ❑ Pit opening must be protected such that no surface water is allowed to enter the hole.
- ❑ No pit latrine should be excavated into fractured bedrock. If this is unavoidable, the specific pit should be lined to prevent the possible pollution of the local aquifer.

7 CONCLUSIONS AND RECOMMENDATIONS

Based on results of the groundwater feasibility and groundwater potential verification studies carried out as part of the Engcobo Water Services Feasibility Study, the following can be concluded:

- The groundwater potential of the Engcobo Local Municipality is presently under-utilised due to local aquifers not having been developed optimally, poor condition of existing borehole equipment and misperceptions regarding groundwater – its origins, recharge and potential.
- Literature reviewed and results from previous studies have indicated that groundwater data for the Engcobo Local Municipality is insufficient to define exact groundwater potential variations and occurrences
- The objectives of the study were outlined based on two phases namely a feasibility desk-top phase, followed by a verification phase involving borehole drilling and testing
- The geology of the Engcobo area comprises the middle part of the stratigraphic sequence of the Karoo Supergroup, comprising sedimentary rocks intruded by dolerite during late Karoo volcanism.
- The dominant geological formation in the Engcobo study area is the Burgersdorp formation that is relatively mudstone rich, with the second most important formation being the Molteno formation that has a higher sandstone component and therefore theoretically of higher groundwater potential. It is however the effect, abundance as well as type of dolerite intrusion that is the determining factor when assessing the groundwater potential in the study area.
- Ring-shaped dolerite intrusions are common. Ring-shaped structures can be delineated from satellite imagery and is of high importance when defining groundwater potential
- Groundwater quality data is insufficient to delineate potential based on expected water classes. The groundwater can however be described as a Calcium Magnesium Bicarbonate water with sodium enrichment, indicative of active groundwater circulation. In general - Good Water Quality (Class 1) to Marginal water quality (Class 2) is expected throughout the study area at groundwater sources.
- Groundwater potential can be defined as the amount of groundwater of a suitable quality that can be abstracted on a sustainable basis. Numerous factors influence the sustainability and potential of an aquifer. In this study – recharge, water balance, surface-groundwater interaction, groundwater storage and flow directions as well as calculations of aquifer hydraulic parameters were taken into account in conjunction with hydrogeology and exploration results to define groundwater potential.
- A groundwater potential zonation map was compiled which is intended to act as a planning tool for source development and planning purposes in the Engcobo Local Municipality. Regional potential was applied to individual villages and site-specific observations were added to characterise villages into four classes, namely Low, Moderate, High and Very High Potential villages. Data is presented in table format where potential is coupled to each village and related to source development factors and costs
- Sustainable borehole yields ranging from 0.5 l/s to over 2.0 l/s (over 12-hr pumping cycles) can be used for water supply estimations in the Engcobo area.

- Based on a water demand of 25 l/c/d, the largest percentage of villages in the Engcobo area can be supplied from a single borehole source. Groundwater development costs for villages vary from an estimated R140 000 where one production borehole needs to be delivered at a very high potential village to up to approximately R300 000 and more to develop a groundwater source at a low potential village with a large population.
- The regional sanitation perspective for the Engcobo area revolves around the high local value of the aquifers present.
- Static water levels noted in the Engcobo area vary from 1m to 36m below surface with artesian boreholes known to occur in places. Springs are most prominent in the northern mountainous part of the area and surface water-groundwater interaction is prominent. Influence from on-site-sanitation practises is therefore likely
- General chemical water quality is good but influences from poor borehole construction: animal waste and poor sanitation practises have caused contamination of groundwater sources in places. Protection of the local aquifers is therefore seen as important

The following is recommended to further verify the results of this study as well as to utilise surplus funds available under the hydrogeological component of the study:


- Spring evaluation in northern mountainous zone
- Further definition and verification of high yielding boreholes drilled in the northern zone during exploration drilling – an area initially thought to be of low potential
- Extension of the proposed regional sanitation survey
- Regional water quality assessment

8 REFERENCES


- An Explanation of the 1: 500 000 General Hydrogeological Map Queenstown 3126. The Department of Water Affairs & Forestry, M.C. Smart 1998.
- An Explanation of a Set of National Groundwater Maps, JR Vegter. 1995.
- Regional Characterisation and Mapping of Karoo Aquifer Systems - an integrated approach using a geographical information systems and satellite image processing, WRC Report K653, Water Research Commission, Pretoria, 218p. Woodford, A.C. and Chevallier, L. (2001).
- Influence of dolerite sill and ring-complexes on the occurrence of groundwater in Karoo Aquifers: a morpho-tectonic approach, WRC Report K937, ISBN 1.86845.708.7, Water Research Commission, Pretoria, 146p. Chevallier, L., Woodford, A.C. and Goedhart, M., 2001:
- Quality of Domestic Water Supplies - Volume 1 - Assessment Guide, Second Edition, 1998. WRC Report TT101/98 (DWAF, WRC and DOH).
- Chris Hani District Municipality Draft Water Services Development Plan, ARCUS GIBB et al. September 2001.
- Groundwater Source definition and investigation in the Chris Hani District Municipality, Eastern Cape Province – Lukanji & Emalaheni Local Municipalities: Combined report No. 298434/1. SRK Consulting & Southern Africa Geoconsultants Pty Ltd. Apr 2002
- Surface Water Resources of South Africa 1990, Midgley D. C. et al. WRC Report 298/5.1/94 and 298/5.2/94, 1994.
- Karoo Aquifers, Their geology, Geometry and physical properties, Botha et al. WRC Report 487/1/98, 1998

PROJECT: CHRIS HANI GROUNDWATER STUDY - ENGCOBO LOCAL MUNICIPALITY

Map 1: Regional locality





PROJECT: CHRIS HANI GROUNDWATER STUDY - ENGCOBO LOCAL MUNICIPALITY
 Map 2: Geology




LEGEND

- Engcobo Local Municipality
- Major Towns
- Major Roads
- Dolerite dyke
- Geological Formations
- Quaternary Deposit - Alluvium
- Dolerite sheet
- Moltenc
- Burgersdorp
- Katberg




PROJECT: CHRIS HANI GROUNDWATER STUDY - ENGCOBO LOCAL MUNICIPALITY
Map 3: Remote Sensing - Satellite Image




LEGEND
— Engcobo Local Municipality
- - - Major Towns
— Major Roads

7000 0 7000 14000 Meters



PROJECT: CHRIS HANI GROUNDWATER STUDY - ENGCOBO LOCAL MUNICIPALITY
Map 4: Structural Geological Map



PROJECT: CHRIS HANI GROUNDWATER STUDY - ENGCOCO LOCAL MUNICIPALITY
 Borehole Distribution

27°40'


27°50'

28°00'
28

28°10'

28°20'

28°30'





31°30'

31°40'

31°50'

LEGEND

- ▭ Engcobo Local Municipality
- ▬ Major Roads
- ▬ Major Towns
- Boreholes
 - Recently developed and evaluated
 - Existing evaluated
 - Newly drilled exploration
 - National groundwater database (NGDB)
 - Other



27 40

27 50


28
28°00'

28°10'

28°20'



28°30'

PROJECT: CHRIS HANI GROUNDWATER STUDY - ENGCOBO LOCAL MUNICIPALITY
 Map 6: Groundwater Potential Zonation



LEGEND

- Engcobo Local Municipality
- Major Towns
- Major Roads
- Groundwater potential
- Very High
- High
- Moderate
- Low
- Groundwater Potential Zones**
- Very high (> 2.3 l/s over 12/24 hrs)
- High (1.7 l/s over 12/24 hrs)
- Moderate (0.8 l/s over 12/24 hrs)
- Low (< 0.4 l/s over 12/24 hrs)



APPENDIX A

PUMP TESTING DATA

CALIBRATION TEST AND RECOVERY

BOREHOLE NO.:	EC/T11/001	PROJECT:	ENCGOBO FEASIBILITY STUDY
ALTERNATIVE NO.:		SITE NAME:	XIBENI VILLAGE
ALTERNATIVE NO.:		CLIENT:	CHRIS HANI DISTRICT MUN
BOREHOLE DEPTH (mbdl):	97.50	CASING DEPTH (mbdl):	5.95
DEPTH OF PUMP (mbdl):	86.70	CASING HEIGHT (magl):	0.21
PUMP INLET DIAMETER (mm):	100.00	CASING ID (mm):	
STATIC WATER LEVEL (mbdl):	1.40	DATUM LEVEL (magl):	0.43
		PUMP TYPE USED:	P 100
		OPERATOR:	JOHANNES
		CONTRACTOR:	AB PUMPS
		SUPERVISOR:	H VORSTER

DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3						
DATE:	TIME:	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery
		(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)
02/04/2003	18H40	1	0.73		1		1	2.10		1		1	4.27	2.40	1	
		2	0.94	0.72	2		2	2.81	1.59	2		2	5.43		2	
		3	1.08	0.71	3		3	2.86	1.6	3		3	6.15		3	
		5	1.16		5		5	2.98		5		5	8.50	3.01	5	
		7	1.23	0.72	7		7	3.10	1.59	7		7	9.74	3	7	
		10	1.27		10		10	3.19		10		10	10.95	3.01	10	
		15	1.34		15		15	3.28		15		15	12.40		15	

EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20
TYPE OF RESERVOIR:		30	TYPE OF ENCLOSURE:		30	PRESSURE GAUGE MANUFAC	30	
		40			40	TURER:	40	
RESERVOIR SIZE:		50	MATERIAL OF ENCLOSURE:		50		50	
		60			60	GAUGE READING (KpA):	60	
RESERVOIR CONITION:		70	CONDITION OF ENCLOSURE:		70		70	
		80			80	MONITORING FACILITY:	80	
STAND HEIGHT (m):		90	WATER METER MANUFACTURER:		90		90	
		100			100	MAINTAINED:	100	
		110	WATER METER READING:		110		110	
		120			120		120	
		150			150		150	

DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6						
DATE:	TIME:	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery
		(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)
02/04/2003	19H25	1	13.39		1		1	44.60		1		1			1	72.13
		2	14.85	3.74	2		2	47.37	5.02	2		2			2	60.04
		3	16.82		3		3	51.56		3		3			3	51.11
		5	20.34	4.15	5		5	64.31	5.01	5		5			5	30.72
		7	27.30	4.16	7		7	71.02	5.01	7		7			7	20.33
		10	33.92		10		10	85.98		10		10			10	10.15
		15	43.08		15		15	85.98	PI 3.21	15		15			15	5.40

EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20
PUMP TYPE:		30	TYPE OF POWER:		30	TYPE OF RISER:	30	
		40			40		40	
PUMP MANUFACTURER:		50	ENGINE MANUFACTURER:		50	CLASS OF RISER:	50	
		60			60		60	
PUMP SERIAL No:		70	ENGINE MODEL:		70	DIAMETER OF RISER (mm):	70	
		80			80		80	
PUMP PULLEY DIAMETER (mm):		90	ENGINE SERIAL No:		90	CONDITION OF RISER:	90	
		100			100		100	
PUMP INTAKE DEPTH (m):		110	ENGINE PULLEY DIAMETER (mm):		110	SHAFT DIAMETER (mm):	110	
		120			120		120	
PUMP RPM:		150	POWER RATING (kW):		150	ELEMENT DIAMETER (mm):	150	
							180	
PUMP CONDITION:			ENGINE CONDITION:			ELEMENT STROKE (mm):	210	
							240	

COMMENTS:		300
		420
		480
		540
		600
DID THE BOREHOLE PRODUCE ANY SILT / SAND / GRAVEL ? NO		660

STEPPED DISCHARGE TEST AND RECOVERY

BOREHOLE NO. :	EC/T11/001	PROJECT:	ENCGOBO FEASIBILITY STUDY		
ALTERNATIVE NO. :	0	SITE NAME:	XIBENI VILLAGE		
ALTERNATIVE NO. :	0	CLIENT:	CHRIS HANI DISTRICT MUN		
BOREHOLE DEPTH (mbdl):	97.50	CASING DEPTH (mbdl):	5.95	PUMP TYPE USED:	P 100
DEPTH OF PUMP (mbdl):	86.70	CASING HEIGHT (magl):	0.21	OPERATOR:	JOHANNES
PUMP INLET DIAMETER (mm):	100.000	CASING ID (mm):	0.000	CONTRACTOR:	AB PUMPS
STATIC WATER LEVEL (mbdl):	1.40	DATUM LEVEL (magl):	0.43		

DISCHARGE RATE 1			Time	Recovery 1	DISCHARGE RATE 2			Time	Recovery 2	DISCHARGE RATE 3			Time	Recovery 3
DATE:	03/04/2003		(min)	(m)	DATE:	03/04/2003		(min)	(m)	DATE:	03/04/2003		(min)	(m)
TIME:	06H20		1		TIME:	08H00		1		TIME:	09H40		1	
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	
1	1.33		5		1	3.32		5		1	8.32		5	
	1.67	0.730	7		2	3.48	1.260	7		2	10.18	2.450	7	
	1.79		10		3	3.69		10		3	11.61		10	
5	2.05	0.800	15		5	3.90		15		4	14.55	3.010	15	
	2.21	0.810	20		7	6.14	1.520	20		7	15.74		20	
0	2.36		30		10	6.43	1.510	30		10	20.19	3.030	30	
15	2.44		40		15	6.66		40		15	23.54		40	
20	2.52		50		20	6.85		50		20	25.67		50	
0	2.61	0.800	60		30	6.97	1.520	60		30	28.63	3.010	60	
40	2.78		70		40	7.12		70		40	30.39	3.030	70	
50	2.78	0.800	80		50	7.21	1.510	80		50	31.20		80	
0	2.81		90		60	7.34	1.520	90		60	32.14		90	
0	2.86	0.810	100		70	7.41		100		70	32.78	3.030	100	
80	2.91	0.800	110		80	7.48	1.510	110		80	33.13		110	
0	2.95		120		90	7.57		120		90	33.71		120	
00	2.95		150		100	7.64		150		100	34.18		150	
110			180		110			180		110			180	
420			210		120			210		120			210	

Average yield: 0.79285714 (l/s)

Average yield: 1.47857143

Average yield: 2.92566667

DISCHARGE RATE 4			Time	Recovery 4	DISCHARGE RATE 5			Time	Recovery 5	DISCHARGE RATE 6			Time	Recovery
DATE:	03/04/2003		(min)	(m)	DATE:	03/04/2003		(min)	(m)	DATE:	03/04/2003		(min)	(m)
TIME:			1		TIME:			1		TIME:			1	23.07
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	12.90
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	8.89
			5		1			5		1			5	5.12
			7		2			7		2			7	3.95
3			10		3			10		3			10	3.51
			15		5			15		5			15	3.34
			20		7			20		7			20	3.17
10			30		10			30		10			30	2.92
15			40		15			40		15			40	2.78
20			50		20			50		20			50	2.53
30			60		30			60		30			60	2.42
40			70		40			70		40			70	2.31
50			80		50			80		50			80	2.22
50			90		60			90		60			90	2.15
70			100		70			100		70			100	2.07
80			110		80			110		80			110	1.99
90			120		90			120		90			120	1.92
100			150		100			150		100			150	1.77
110			180		110			180		110			180	1.65
20			210		120			210		120			210	1.57
								240		150			240	1.42

Average yield: #DIV/0!

COMMENTS:		300		180		300
		360		210		360
		420		240		420
		480		300		480
		540		360		540
		600		420		600
		660		480		660
		780				720

Average yield:


DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(#)	(%)	(min)	(m)	(%)	(min)	(m)	(%)	(min)	(m)	(%)
4500	11.78		1.85	1500			1500			1500		
560	11.87	1.63	1.83	1560			1560			1560		
1620	11.92		1.80	1620			1620			1620		
1680	11.86		1.72	1680			1680			1680		
1740	11.99		1.69	1740			1740			1740		
1800	12.02	1.64	1.65	1800			1800			1800		
1860	12.07	1.65	1.60	1860			1860			1860		
1920	12.14		1.57	1920			1920			1920		
1980	12.17		1.53	1980			1980			1980		
2040	12.20		1.50	2040			2040			2040		
2100	12.22		1.48	2100			2100			2100		
2160	12.25		1.46	2160			2160			2160		
2220	12.27	1.64	1.44	2220			2220			2220		
2280	12.30		1.42	2280			2280			2280		
2340	12.33		1.39	2340			2340			2340		
2400	12.36	1.64	1.36	2400			2400			2400		
2460	12.38		1.33	2460			2460			2460		
2520	12.38	1.63	1.30	2520			2520			2520		
2580	12.41		1.27	2580			2580			2580		
2640	12.43		1.25	2640			2640			2640		
2700	12.45	1.64	1.23	2700			2700			2700		
2760	12.49		1.19	2760			2760			2760		
2820	12.52	1.64	1.17	2820			2820			2820		
2880	12.54		1.16	2880			2880			2880		

DESCRIPTION:	QUANTITY:	UNIT:	S U M M A R Y	DESCRIPTION:	QUANTITY:	UNIT:	
ESTABLISHMENT		Sum			STRAIGHTNESS TEST:	1	No
INTER HOLE MOVE > 10 km	43	Km.			VERTICALITY TEST:	0	No
FROM: SITE NAME: HIGHVIEW STORE					CASING DETECTION:	1	No
BOREHOLE No:					STEEL BOREHOLE COVER:	1	No
INTER HOLE MOVE < 10 km:		No.			BOREHOLE MARKING:	1	No
REMOVAL AND RE-ERECTION OF PUMP HOUSE:	0	No.			SITE CLEANING / FINISHING:	1	No
REMOVAL OF EXISTING EQUIPMENT:	0	No.			REPORTING & DATA RECORDING:	1	No
RE-INSTALLATION OF EXISTING EQUIPMENT:	0	No.			SLUG TEST:	0	No
WORK TIME RATE (REPAIRS):	0	Hour			LAYFLAT (m):	50	m
STANDING TIME:	0	Hour		BOREHOLE DEPTH AFTER TEST:	97.5	m	
LATITUDE:				BOREHOLE WATERLEVEL AFTER TEST:	1.96	m	
LONGITUDE:							


TEST DESCRIPTION	STEP	TOTAL:					RECOVERY:		RECOVERY TEST					
		1	2	3	4	5	(min)	(hrs)	(m)	(min)	TIME TOTAL (hrs):	53.33		
CALIBRATION TEST:														
TEST DURATION (Minutes)		15	15	15	15	15	75	1.25	0.96	80	Cal	Steps	CD	Total
TEST YIELD (l/s)		0.72	1.59	2.96	4.02	5.01	MAXIMUM (l/s) 5.0				50	240	2880	3200
DRAWDOWN (m)		1.34	3.28	12.40	43.08	85.98	MAXIMUM (m) 86.0				DRAWDOWN TOTALS (CD):			
MULTI-RATE / STEP DRAWDOWN:											AVAILABLE	UTIL-	%	
TEST DURATION (Minutes)		100	100	100			300	5.00	1.42	240	ISED			
TEST YIELD (l/s)		0.79	1.48	2.93			MAXIMUM (l/s) 2.9				95.3	12.54	14.70	
DRAWDOWN (m)		3.3	7.64	34.18			MAXIMUM (m) 34.2							
CONSTANT DISCHARGE TEST		TEST DURATION		TEST YIELD	DRAWDOWN	RECOVERY:								
		(min)	(hrs)	(l/s)	(m)	(m)	%	(min)	(hrs)					
		2880	48.00	1.63	12.54	1.16	30.75	2880	48.00					
OBSERVATION BOREHOLES:		No.	720	1440	2880	>2880 (min)		TOTAL:						
		of boreholes	(min)	(min)	(min)	nr.	Time	(min)	(hrs)					
										0	0.00			

BOREHOLE NUMBER: EC/T11/001


CALIBRATION TEST AND RECOVERY



STEPPED DISCHARGE TEST AND RECOVERY



CONSTANT DISCHARGE TEST AND RECOVERY



TEST INFORMATION

Date tested	03/04/2003	Water level (mbgl)	1.40	Depth of pump (mbgl)	86.7
Duration	2880	CD discharge rate	1.63	CD drawdown	12.54
Stable drawdown (m)	85.3	% Recovery after CD	91	% after 2880 min	

CALIBRATION TEST AND RECOVERY

BOREHOLE NO. :	EC/T11/002	PROJECT:	ENCGOBO FEASIBILITY STUDY
ALTERNATIVE NO. :	T 32342 T32342 B	SITE NAME:	QOTHA
ALTERNATIVE NO. :	32342A 0013	CLIENT:	CHRIS HANI DISTRICT MUN
BOREHOLE DEPTH (mbdl):	48.12	CASING DEPTH (mbdl):	6.78
DEPTH OF PUMP (mbdl):	44.70	CASING HEIGHT (magl):	0.50
PUMP INLET DIAMETER (mm):	100.00	CASING ID (mm):	165.00
STATIC WATER LEVEL (mbdl):	1.02	DATUM LEVEL (magl):	0.13
		PUMP TYPE USED:	BP 22 M
		OPERATOR:	ABRAHAM
		CONTRACTOR:	AB PUMPS
		SUPERVISOR:	H VORSTER

DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3				
DATE	01/04/2003	TIME	14H20		DATE	01/04/2003	TIME	14H35		DATE	01/04/2003	TIME	14H50	
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)
1	0.60		1		1	1.70		1		1	4.27		1	
2	0.85		2		2	2.02		2		2	4.64		2	
3	1.01	0.3	3		3	2.15		3		3	5.37		3	
5	1.15		5		5	2.31	0.71	5		5	6.18	1.51	5	
7	1.22		7		7	3.04		7		7	6.62	1.51	7	
10	1.32	0.3	10		10	3.27	0.7	10		10	6.97		10	
15	1.36		15		15	3.41		15		15	7.21	1.51	15	

EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20
TYPE OF RESERVOIR:	30	TYPE OF ENCLOSURE:	30	PRESSURE GAUGE MANUFAC	30
	40		40	TURER:	40
RESERVOIR SIZE:	50	MATERIAL OF ENCLOSURE:	50		50
	60		60	GAUGE READING (KpA):	60
RESERVOIR CONITION:	70	CONDITION OF ENCLOSURE:	70		70
	80		80	MONITORING FACILITY:	80
STAND HEIGHT (m):	90	WATER METER MANUFACTURER:	90		90
	100		100	MAINTAINED:	100
	110	WATER METER READING:	110		110
	120		120		120
	150		150		150

DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 5				
DATE	01/04/2003	TIME	15H05		DATE	01/04/2003	TIME	15H20		DATE		TIME		
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)
1	8.09		1		1	15.12		1		1			1	34.50
2	9.38		2		2	18.71	4.01	2		2			2	23.33
3	10.09	2.4	3		3	21.71	5.07	3		3			3	13.51
5	11.46		5		5	26.26		5		5			5	5.09
7	12.16	2.4	7		7	34.82		7		7			7	3.72
10	13.56		10		10	41.04	5.07	10		10			10	3.15
15	14.04		15		15	44.29		15		15			15	2.77

EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20
PUMP TYPE:	30	TYPE OF POWER:	30	TYPE OF RISER:	30
WINDMILL	40		40		40
PUMP MANUFACTURER:	50	ENGINE MANUFACTURER:	50	CLASS OF RISER:	50
	60		60		60
PUMP SERIAL No:	70	ENGINE MODEL:	70	DIAMETER OF RISER (mm):	70
	80		80		80
PUMP PULLEY DIAMETER (mm):	90	ENGINE SERIAL No:	90	CONDITION OF RISER:	90
	100		100		100
PUMP INTAKE DEPTH (m):	110	ENGINE PULLEY DIAMETER (mm):	110	SHAFT DIAMETER (mm):	110
	120		120		120
PUMP RPM:	150	POWER RATING (kW):	150	ELEMENT DIAMETER (mm):	150
					180
PUMP CONDITION:		ENGINE CONDITION:		ELEMENT STROKE (mm):	210
POOR					240

COMMENTS:	300
	420
	480
	540
	600
DID THE BOREHOLE PRODUCE ANY SILT / SAND / GRAVEL ?	660

STEPPED DISCHARGE TEST AND RECOVERY

BOREHOLE NO. :	EC/T11/002	PROJECT:	ENCGOBO FEASIBILITY STUDY
ALTERNATIVE NO. :	T 32342	SITE NAME:	QOTHA
ALTERNATIVE NO. :	0	CLIENT:	CHRIS HANI DISTRICT MUN
BOREHOLE DEPTH (m bdl):	48.12	CASING DEPTH (m bdl):	6.78
PUMP TYPE USED:	BP 22 M		
DEPTH OF PUMP (m bdl):	44.70	CASING HEIGHT (magl):	0.50
OPERATOR:	ABRAHAM		
PUMP INLET DIAMETER (mm):	100.000	CASING ID (mm):	165.000
CONTRACTOR:	AB PUMPS		
STATIC WATER LEVEL (m bdl):	1.76	DATUM LEVEL (magl):	0.13

DISCHARGE RATE 1			Time	Recovery 1	DISCHARGE RATE 2			Time	Recovery 2	DISCHARGE RATE 3			Time	Recovery 3
DATE:	01/04/2003		(min)	(m)	DATE:	01/04/2003		(min)	(m)	DATE:	01/04/2003		(min)	(m)
TIME:	17H20		1		TIME:	19H00		1		TIME:	20H40		1	
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	
1	3.44		5		1	11.14		5		1	27.72		5	
	3.96	0.880	7		2	12.59		7		2	29.65	3.870	7	
	4.40		10		3	13.47		10		3	31.94	4.010	10	
5	5.97	1.510	15		5	16.44	3.110	15		4	34.16		15	
	6.78		20		7	18.29		20		7	36.34	4.010	20	
0	7.47		30		10	20.41	3.110	30		10	41.15		30	
15	7.57	1.510	40		15	22.17		40		15	44.29		40	
30	7.69		50		20	22.92	3.110	50		16	44.29	PI 2.57	50	
40	8.28		60		30	23.60		60		18	44.29	PI 2.22	60	
50	8.93	1.500	70		40	24.03	3.110	70		20	44.29	PI 2.10	70	
60	9.31		80		50	24.12		80		50			80	
70	9.49	1.510	90		60	24.53		90		60			90	
80	9.56		100		70	25.31	3.100	100		70			100	
90	9.63	1.510	110		80	26.16		110		80			110	
100	9.79		120		90	26.52	3.110	120		90			120	
110	9.92		150		100	26.70		150		100			150	
120			180		110			180		110			180	
			210		120			210		120			210	
Average yield: 1.40333333 (l/s)			Average yield: 3.10833333			Average yield: 3.96333333								

DISCHARGE RATE 4			Time	Recovery 4	DISCHARGE RATE 5			Time	Recovery 5	DISCHARGE RATE 6			Time	Recovery
DATE:	01/04/2003		(min)	(m)	DATE:	01/04/2003		(min)	(m)	DATE:	01/04/2003		(min)	(m)
TIME:			1		TIME:			1		TIME:			1	37.50
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	27.45
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	18.30
			5		1			5		1			5	10.57
			7		2			7		2			7	8.93
3			10		3			10		3			10	7.59
5			15		5			15		5			15	7.11
			20		7			20		7			20	6.89
10			30		10			30		10			30	6.49
15			40		15			40		15			40	6.17
20			50		20			50		20			50	5.91
30			60		30			60		30			60	5.68
40			70		40			70		40			70	5.59
50			80		50			80		50			80	5.38
60			90		60			90		60			90	5.17
70			100		70			100		70			100	4.99
80			110		80			110		80			110	4.78
90			120		90			120		90			120	4.53
100			150		100			150		100			150	4.44
110			180		110			180		110			180	4.31
120			210		120			210		120			210	4.23
Average yield: #DIV/0!														

COMMENTS:		240	150	240
		300	180	300
		360	210	360
		420	240	420
		480	300	480
		540	360	540
		600	420	600
		660	480	660
		780		780
			Average yield:	720

DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(l/s)	(m)	(min)	(m)	(m)	(min)	(m)	(m)	(min)	(m)	(m)
1500				1500			1500			1500		
1560				1560			1560			1560		
1620				1620			1620			1620		
1680				1680			1680			1680		
1740				1740			1740			1740		
1800				1800			1800			1800		
1860				1860			1860			1860		
1920				1920			1920			1920		
1980				1980			1980			1980		
2040				2040			2040			2040		
2100				2100			2100			2100		
2160				2160			2160			2160		
2220				2220			2220			2220		
2280				2280			2280			2280		
2340				2340			2340			2340		
2400				2400			2400			2400		
2460				2460			2460			2460		
2520				2520			2520			2520		
2580				2580			2580			2580		
2640				2640			2640			2640		
2700				2700			2700			2700		
2760				2760			2760			2760		
2820				2820			2820			2820		
2880				2880			2880			2880		


DESCRIPTION:	QUANTITY:	UNIT:	S U M M A R Y	DESCRIPTION:	QUANTITY:	UNIT:
ESTABLISHMENT	1	Sum		STRAIGHTNESS TEST:		No
INTER HOLE MOVE > 10 km		Km.		VERTICALITY TEST:	0	No
FROM: SITE NAME: BASE				CASING DETECTION:	1	No
BOREHOLE No:				STEEL BOREHOLE COVER:	1	No
INTER HOLE MOVE < 10 km:		No.		BOREHOLE MARKING:	1	No
REMOVAL AND RE-ERECTION OF PUMP HOUSE:		No.		SITE CLEANING / FINISHING:	1	No
REMOVAL OF EXISTING EQUIPMENT:	1	No.		REPORTING & DATA RECORDING:	1	No
RE-INSTALLATION OF EXISTING EQUIPMENT:	1	No.		SLUG TEST:	0	No
WORK TIME RATE (REPAIRS):		Hour		LAYFLAT (m):	50	m
STANDING TIME:		Hour	BOREHOLE DEPTH AFTER TEST:	48.11	m	
LATITUDE:			BOREHOLE WATERLEVEL AFTER TEST:	1.87	m	
LONGITUDE:						

TEST DESCRIPTION	STEP						TOTAL:	RECOVERY:		RECOVERY TEST							
		1	2	3	4	5		6	(min)	(hrs)	(m)	(min)	TIME TOTAL (hrs):	28.67			
CALIBRATION TEST:										(min)	(hrs)	(m)	(min)	Cal	Steps	CD	Total
TEST DURATION (Minutes)		15	15	15	15	15	75	1.25	1.78	70	70	210	1440	1720	DRAWDOWN TOTALS (CD):		
TEST YIELD (l/s)		0.30	0.71	1.51	2.40	4.72	MAXIMUM (l/s)		4.7	AVAILABLE		UTILISED		%			
DRAWDOWN (m)		1.36	3.41	7.21	14.04	44.29	MAXIMUM (m)		44.3	43.7		9.64		22.37			
MULTI-RATE / STEP DRAWDOWN:										215		3.58		4.23		210	
TEST DURATION (Minutes)		100	100	15			215		3.58	4.23		210					
TEST YIELD (l/s)		1.40	3.11	3.96			MAXIMUM (l/s)		4.0								
DRAWDOWN (m)		3.9	26.70	44.29			MAXIMUM (m)		44.3								
CONSTANT DISCHARGE TEST		TEST DURATION		TEST YIELD		DRAWDOWN		RECOVERY:									
		(min)	(hrs)	(l/s)		(m)		(m)		%		(min)		(hrs)			
		1440	24.00	1.33		9.64		1.37		88.30		1440		24.00			
OBSERVATION BOREHOLES:		No.		720		1440		2880		>2880 (min)		TOTAL:					
		of boreholes		(min)		(min)		(min)		nr.		Time		(min) (hrs)			
												0		2.00			

BOREHOLE NUMBER: EC/T11/002

CALIBRATION TEST AND RECOVERY


Discharge 1: 0.30 | Discharge 2: 0.71 | Discharge 3: 1.51 | Discharge 4: 2.40 | Discharge 5: 4.72 | Discharge 6:



Drawdown 1:	1.36
Drawdown 2:	3.41
Drawdown 3:	7.21
Drawdown 4:	14.04
Drawdown 5:	44.29
Drawdown 6:	0.00
Duration 1:	15
Duration 2:	15
Duration 3:	15
Duration 4:	15
Duration 5:	15
Duration 6:	
Recovery (m):	1.78
Recovery (min):	70


STEPPED DISCHARGE TEST AND RECOVERY

Discharge 1: 1.40333 | Discharge 2: 3.10833 | Discharge 3: 3.96333 | Discharge 4: | Discharge 5: | Discharge 6:



Drawdown 1:	9.92
Drawdown 2:	26.70
Drawdown 3:	44.29
Drawdown 4:	0.00
Drawdown 5:	0.00
Drawdown 6:	
Duration 1:	100
Duration 2:	100
Duration 3:	15
Duration 4:	
Duration 5:	
Duration 6:	
Recovery (m):	4.23
Recovery (min):	210

CONSTANT DISCHARGE TEST AND RECOVERY



— Constant discharge rate
— Recovery

TEST INFORMATION

Date tested	02/04/2003	Water level (mbgl)	1.02	Depth of pump (mbgl)	44.7
CD duration	1440	CD discharge rate	1.03	CD drawdown	9.64
Available drawdown (m)	43.68	% Recovery after CD	89	% after 1440 min	

STEPPED DISCHARGE TEST AND RECOVERY

BOREHOLE NO. :	EC/T12/003	PROJECT:	ENCGOBO FEASIBILITY STUDY		
ALTERNATIVE NO. :	0	SITE NAME:	QUNENE		
ALTERNATIVE NO. :	0	CLIENT:	CHRIS HANI DISTRICT MUN		
BOREHOLE DEPTH (m bdl):	54.52	CASING DEPTH (m bdl):	7.45	PUMP TYPE USED:	BP 22
DEPTH OF PUMP (m bdl):	50.70	CASING HEIGHT (magl):	0.22	OPERATOR:	SIMON
PUMP INLET DIAMETER (mm):	100.000	CASING ID (mm):	0.000	CONTRACTOR:	AB PUMPS
STATIC WATER LEVEL (m bdl):	9.99	DATUM LEVEL (magl):	0.16		

DISCHARGE RATE 1			Time	Recovery 1	DISCHARGE RATE 2			Time	Recovery 2	DISCHARGE RATE 3			Time	Recovery 3
DATE:	06/04/2003		(min)	(m)	DATE:	06/04/2003		(min)	(m)	DATE:	06/04/2003		(min)	(m)
TIME:	06H20		1		TIME:	08H00		1		TIME:	09H40		1	
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	
1	0.64		5		1	4.73		5		1	8.85		5	
	0.91	1.280	7		2	5.23		7		2	9.20		7	
	1.54		10		3	5.98	3.960	10		3	10.42	5.200	10	
5	2.02	2.040	15		5	7.85		15		4	12.15		15	
	2.75		20		7	8.10	4.010	20		7	13.72	6.130	20	
	3.11		30		10	8.35		30		10	14.54		30	
15	3.24	2.030	40		15	8.52		40		15	15.08		40	
20	3.29		50		20	8.60	4.010	50		20	15.34	6.130	50	
30	3.39		60		30	8.62		60		30	15.44		60	
40	3.44		70		40	8.75		70		40	15.67		70	
50	3.51	2.040	80		50	8.81	4.010	80		50	15.89		80	
60	3.59		90		60	8.82		90		60	15.94	6.130	90	
70	3.60		100		70	8.83		100		70	16.06		100	
80	3.64	2.040	110		80	8.84	4.010	110		80	16.28		110	
90	3.68		120		90	8.84		120		90	16.43	6.130	120	
100	3.74		150		100	8.85		150		100	16.47		150	
110			180		110			180		110			180	
120			210		120			210		120			210	
Average yield: 1.886			(l/s)		Average yield: 4					Average yield: 5.944				

DISCHARGE RATE 4			Time	Recovery 4	DISCHARGE RATE 5			Time	Recovery 5	DISCHARGE RATE 6			Time	Recovery
DATE:	06/04/2003		(min)	(m)	DATE:	06/04/2003		(min)	(m)	DATE:	06/04/2003		(min)	(m)
TIME:	11H20		1		TIME:			1		TIME:			1	15.47
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	8.23
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	5.08
	17.25		5		1			5		1			5	1.79
	18.27	6.54	7		2			7		2			7	0.93
3	19.06		10		3			10		3			10	0.76
5	19.35	7.02	15		5			15		5			15	0.66
	20.09		20		7			20		7			20	0.58
10	21.58		30		10			30		10			30	0.54
15	22.54		40		15			40		15			40	0.44
20	22.61	7.02	50		20			50		20			50	0.40
30	23.77		60		30			60		30			60	0.38
40	24.24		70		40			70		40			70	
50	24.68		80		50			80		50			80	
60	25.41	7.02	90		60			90		60			90	
70	25.58		100		70			100		70			100	
80	25.61		110		80			110		80			110	
90	25.70	7.02	120		90			120		90			120	
100	25.87		150		100			150		100			150	
110			180		110			180		110			180	
120			210		120			210		120			210	
Average yield: 6.924														

COMMENTS:		240		150		240		150		240		150		240
		300		180		300		180		300		180		300
		360		210		360		210		360		210		360
		420		240		420		240		420		240		420
		480		300		480		300		480		300		480
		540		360		540		360		540		360		540
		600		420		600		420		600		420		600
		660		480		660		480		660		480		660
		720				720				720				720
					Average yield:									

DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(l/s)	(m)	(min)	(m)	(m)	(min)	(m)	(m)	(min)	(m)	(m)
1500	10.66	4.03		1500			1500			1500		
1560	10.69			1560			1560			1560		
1620	10.74	4.01		1620			1620			1620		
1680	10.77			1680			1680			1680		
1740	10.82	4.02		1740			1740			1740		
1800	10.83	4.03		1800			1800			1800		
1860	10.91			1860			1860			1860		
1920	11.06			1920			1920			1920		
1980	11.11	4.02		1980			1980			1980		
2040	11.15			2040			2040			2040		
2100	11.20			2100			2100			2100		
2160	11.24	4.01		2160			2160			2160		
2220	11.28			2220			2220			2220		
2280	11.31			2280			2280			2280		
2340	11.35	4.02		2340			2340			2340		
2400	11.39			2400			2400			2400		
2460	11.43			2460			2460			2460		
2520	11.51	4.01		2520			2520			2520		
2580	11.67			2580			2580			2580		
2640	11.87			2640			2640			2640		
2700	12.04	4.02		2700			2700			2700		
2760	12.12			2760			2760			2760		
2820	12.21	4.02		2820			2820			2820		
2880	12.34			2880			2880			2880		

DESCRIPTION:	QUANTITY:	UNIT:
ESTABLISHMENT		Sum
INTER HOLE MOVE > 10 km	16	Km.
FROM: SITE NAME: QULUQU		
BOREHOLE No: T 32349		
INTER HOLE MOVE < 10 km:	0	No.
REMOVAL AND RE-ERECTION OF PUMP HOUSE:	0	No.
REMOVAL OF EXISTING EQUIPMENT:	1	No.
RE-INSTALLATION OF EXISTING EQUIPMENT:	1	No.
WORK TIME RATE (REPAIRS):	0	Hour
STANDING TIME:	0	Hour
LATITUDE:		
LONGITUDE:		

DESCRIPTION:	QUANTITY:	UNIT:
STRAIGHTNESS TEST:	1	No.
VERTICALITY TEST:	0	No.
CASING DETECTION:	1	No.
STEEL BOREHOLE COVER:	1	No.
BOREHOLE MARKING:	1	No.
SITE CLEANING / FINISHING:	1	No.
REPORTING & DATA RECORDING:	1	No.
SLUG TEST:	0	No.
LAYFLAT (m):	50	m
BOREHOLE DEPTH AFTER TEST:	54.51	m
BOREHOLE WATERLEVEL AFTER TEST:	20.01	m


TEST DESCRIPTION	STEP	1	2	3	4	5	6	TOTAL:	RECOVERY:
								(min) (hrs)	(m) (min)
CALIBRATION TEST:									
TEST DURATION (Minutes)		15	15	15	15	15		75 1.25	0.00 60
TEST YIELD (l/s)		0.50	1.20	3.43	4.97	6.85		MAXIMUM (l/s) 8.4	
DRAWDOWN (m)		0.66	1.35	3.38	3.97	19.41		MAXIMUM (m) 19.4	
MULTI-RATE / STEP DRAWDOWN:									
TEST DURATION (Minutes)		100	100	100	100			400 6.67	0.38 60
TEST YIELD (l/s)		1.99	4.00	5.94	6.92			MAXIMUM (l/s) 6.9	
DRAWDOWN (m)		3.7	9.85	16.47	25.37			MAXIMUM (m) 25.9	

RECOVERY TEST			
TIME TOTAL (hrs):	3.50		
Cal	Steps	CD	Total
60	60	90	210
DRAWDOWN TOTALS (CD):			
AVAILABLE	UTIL-	%	
	ISED		
40.7	12.34	30.31	


CONSTANT DISCHARGE TEST	TEST DURATION		TEST YIELD	DRAWDOWN	RECOVERY:			
	(min)	(hrs)	(l/s)	(m)	(m)	%	(min)	(hrs)
	2880	48.00	4.01	12.34	2.21	98.30	90	1.50
OBSERVATION BOREHOLES:	No.	720	1440	2880	>2880 (min)		TOTAL:	
	of boreholes	(min)	(min)	(min)	nr.	Time	(min)	(hrs)

BOREHOLE NUMBER: EC/T12/003


CALIBRATION TEST AND RECOVERY



STEPPED DISCHARGE TEST AND RECOVERY



CONSTANT DISCHARGE TEST AND RECOVERY



INFORMATION					
Date tested	08/04/2003	Water level (mbgl)	9.99	Depth of pump (mbgl)	50.7
Duration	2880	CD discharge rate	4.01	CD drawdown	12.34
Stable drawdown (m)	40.71	% Recovery after CD	98	% after	90 min

CALIBRATION TEST AND RECOVERY

BOREHOLE NO. :	EC/T11/007	PROJECT:	ENCGOBO FEASIBILITY STUDY
ALTERNATIVE NO. :		SITE NAME:	ENCGOBO
TERNATIVE NO. :		CLIENT:	CHRIS HANI DISTRICT MUNICIPALITY
BOREHOLE DEPTH (m bdl):	75.02	CASING DEPTH (m bdl):	40.46
DEPTH OF PUMP (m bdl):	62.80	CASING HEIGHT (magl):	0.32
PUMP INLET DIAMETER (mm):	100.00	CASING ID (mm):	165.00
STATIC WATER LEVEL (m bdl):	13.16	DATUM LEVEL (magl):	0.15
		PUMP TYPE USED:	P 150
		OPERATOR:	JOHANNES
		CONTRACTOR:	AB PUMPS
		SUPERVISOR:	H VORSTER

DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3										
DATE:	10/05/2003		TIME:		10H10		DATE:	10/05/2003		TIME:		10H25		DATE:	10/05/2003		TIME:		10H40	
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	{m}	{l/s}	{min}	{m}	{min}	{m}	{l/s}	{min}	{m}	{min}	{m}	{l/s}	{min}	{m}	{min}	{m}	{l/s}	{min}	{m}	
1	0.35		1		1	1.10	2.06	1		1	1.85	1.85	1		1			1		
	0.49	1.34	2		2	1.12	2.12	2		2	2.02	2.02	2		2			2		
	0.52		3		3	1.17		3		3	2.37	2.37	3		3			3		
5	0.66	1.3	5		5	1.25	2.11	5		5	2.50	2.5	5		5			5		
	0.71		7		7	1.30		7		7	2.56	2.56	7		7			7		
10	0.80	1.32	10		10	1.36	2.12	10		10	2.75	2.75	10		10			10		
15	0.92		15		15	1.44		15		15	3.06	3.06	15		15			15		

EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20
TYPE OF RESERVOIR:	30	TYPE OF ENCLOSURE:	30	PRESSURE GAUGE MANUFAC	30
	40		40	TURER:	40
RESERVOIR SIZE:	50	MATERIAL OF ENCLOSURE:	50		50
	60		60	GAUGE READING (Kpa):	60
RESERVOIR CONITION:	70	CONDITION OF ENCLOSURE:	70		70
	80		80	MONITORING FACILITY:	80
STAND HEIGHT (m):	90	WATER METER MANUFACTURER:	90		90
	100		100	MAINTAINED:	100
	110	WATER METER READING:	110		110
	120		120		120
	150		150		150

DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6										
DATE:	10/05/2003		TIME:		10H55		DATE:	10/05/2003		TIME:		11H10		DATE:	10/05/2003		TIME:			
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	{m}	{l/s}	{min}	{m}	{min}	{m}	{l/s}	{min}	{m}	{min}	{m}	{l/s}	{min}	{m}	{min}	{m}	{l/s}	{min}	{m}	
1	4.51		1		1	8.54	13.94	1		1			1		1			1	8.99	
2	5.15	8.38	2		2	9.89		2		2			2		2			2	6.63	
3	5.47		3		3	10.40	14.71	3		3			3		3			3	5.42	
5	5.95	8.4	5		5	11.98		5		5			5		5			5	4.85	
7	6.27		7		7	13.03	14.7	7		7			7		7			7	4.81	
10	6.61	8.39	10		10	13.76		10		10			10		10			10	3.90	
15	6.99		15		15	15.73		15		15			15		15			15	3.42	

EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20
PUMP TYPE:	30	TYPE OF POWER:	30	TYPE OF RISER:	30
NONE	40		40		40
PUMP MANUFACTURER:	50	ENGINE MANUFACTURER:	50	CLASS OF RISER:	50
	60		60		60
PUMP SERIAL No:	70	ENGINE MODEL:	70	DIAMETER OF RISER (mm):	70
	80		80		80
PUMP PULLEY DIAMETER (mm):	90	ENGINE SERIAL No:	90	CONDITION OF RISER:	90
	100		100		100
PUMP INTAKE DEPTH (m):	110	ENGINE PULLEY DIAMETER (mm):	110	SHAFT DIAMETER (mm):	110
	120		120		120
PUMP RPM:	150	POWER RATING (kW):	150	ELEMENT DIAMETER (mm):	150
					180
PUMP CONDITION:		ENGINE CONDITION:		ELEMENT STROKE (mm):	210
					240
					300
					420
					480
					540
					600
					660

COMMENTS:

DOES THE BOREHOLE PRODUCE ANY SILT / SAND / GRAVEL ?

STEPPED DISCHARGE TEST AND RECOVERY

BOREHOLE NO. :	EC/T11/007	PROJECT:	ENCGOBO FEASIBILITY STUDY		
ALTERNATIVE NO. :	0	SITE NAME:	ENCGOBO		
ALTERNATIVE NO. :	0	CLIENT:	CHRIS HANI DISTRICT MUNICIPALITY		
BOREHOLE DEPTH (m bdt):	75.02	CASING DEPTH (m bdt):	40.46	PUMP TYPE USED:	P 150
DEPTH OF PUMP (m bdt):	62.80	CASING HEIGHT (magl):	0.32	OPERATOR:	JOHANNES
PUMP INLET DIAMETER (mm):	100.000	CASING ID (mm):	165.000	CONTRACTOR:	AB PUMPS
STATIC WATER LEVEL (m bdt):	14.08	DATUM LEVEL (magl):	0.15		

DISCHARGE RATE 1			Time	Recovery 1	DISCHARGE RATE 2			Time	Recovery 2	DISCHARGE RATE 3			Time	Recovery 3
DATE:	10/05/2003		(min)	(m)	DATE:	10/05/2003		(min)	(m)	DATE:	10/05/2003		(min)	(m)
TIME:	13H00		1		TIME:	14H40		1		TIME:	16H20		1	
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	
1	1.53		5		1	6.12		5		1	8.95		5	
	1.87	4.380	7		2	6.85	8.600	7		2	9.10	10.940	7	
	2.45		10		3	7.12		10		3	9.54		10	
5	2.89		15		5	7.45	7.130	15		4	10.76		15	
	3.07	4.110	20		7	7.67		20		7	11.42	11.250	20	
	3.29		30		10	7.69	7.120	30		10	12.12		30	
15	3.58	4.100	40		15	7.72		40		15	12.93		40	
20	3.79		50		20	7.76	7.130	50		20	13.94	11.270	50	
	4.13		60		30	7.83		60		30	15.00		60	
40	4.38	4.120	70		40	7.87	7.130	70		40	17.07	11.260	70	
50	4.61		80		50	7.94	7.120	80		50	19.24		80	
	4.83		90		60	8.02		90		60	22.45		90	
80	5.01	4.100	100		70	8.05		100		70	24.40	11.280	100	
	5.16		110		80	8.14	7.140	110		80	27.18		110	
70	5.28	4.120	120		90	8.23	7.130	120		90	29.21	11.270	120	
100	5.40		150		100	8.39		150		100	32.04		150	
110			180		110			180		110			180	
120			210		120			210		120			210	
Average yield: 4.155			(l/s)		Average yield: 7.3125					Average yield: 11.2116667				

DISCHARGE RATE 4			Time	Recovery 4	DISCHARGE RATE 5			Time	Recovery 5	DISCHARGE RATE 6			Time	Recovery
DATE:	10/05/2003		(min)	(m)	DATE:	10/05/2003		(min)	(m)	DATE:	10/05/2003		(min)	(m)
TIME:			1		TIME:			1		TIME:			1	19.20
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	13.59
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	11.00
			5		1			5		1			5	10.28
			7		2			7		2			7	9.44
3			10		3			10		3			10	9.12
			15		5			15		5			15	8.91
			20		7			20		7			20	8.59
10			30		10			30		10			30	8.05
15			40		15			40		15			40	7.36
20			50		20			50		20			50	6.88
30			60		30			60		30			60	6.49
40			70		40			70		40			70	6.08
50			80		50			80		50			80	5.72
60			90		60			90		60			90	5.33
70			100		70			100		70			100	5.04
80			110		80			110		80			110	4.47
90			120		90			120		90			120	4.03
100			150		100			150		100			150	3.15
110			180		110			180		110			180	2.59
120			210		120			210		120			210	2.01
Average yield: #DIV/0!													240	1.41

COMMENTS:	300	180	300
	360	210	360
	420	240	420
	480	300	480
	540	360	540
	600	420	600
	660	480	660
	720		
	780		
		Average yield:	720

DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(l/s)	(m)	(min)	(m)	(m)	(min)	(m)	(m)	(min)	(m)	(m)
1500				1500			1500			1500		
1560				1560			1560			1560		
1620				1620			1620			1620		
1680				1680			1680			1680		
1740				1740			1740			1740		
1800				1800			1800			1800		
1860				1860			1860			1860		
1920				1920			1920			1920		
1980				1980			1980			1980		
2040				2040			2040			2040		
2100				2100			2100			2100		
2160				2160			2160			2160		
2220				2220			2220			2220		
2280				2280			2280			2280		
2340				2340			2340			2340		
2400				2400			2400			2400		
2460				2460			2460			2460		
2520				2520			2520			2520		
2580				2580			2580			2580		
2640				2640			2640			2640		
2700				2700			2700			2700		
2760				2760			2760			2760		
2820				2820			2820			2820		
2880				2880			2880			2880		

DESCRIPTION:	QUANTITY:	UNIT:	S U M M A R Y	DESCRIPTION:	QUANTITY:	UNIT:	
ESTABLISHMENT		Sum		S U M M A R Y	STRAIGHTNESS TEST:	1	No
ENTER HOLE MOVE > 10 km		Km			VERTICALITY TEST:	0	No
FROM: SITE NAME:					CASING DETECTION:	1	No
BOREHOLE No:					STEEL BOREHOLE COVER:	1	No
ENTER HOLE MOVE < 10 km:		1 No			BOREHOLE MARKING:	1	No
REMOVAL AND RE-ERECTION OF PUMP HOUSE:		0 No			SITE CLEANING / FINISHING:	1	No
REMOVAL OF EXISTING EQUIPMENT:		0 No			REPORTING & DATA RECORDING:	1	No
RE-INSTALLATION OF EXISTING EQUIPMENT:		0 No			SLUG TEST:	0	No
WORK TIME RATE (REPAIRS):		0 Hour			LAYFLAT (m):	50	m
STANDING TIME:		0 Hour			BOREHOLE DEPTH AFTER TEST:	75.02	m
LATITUDE:					BOREHOLE WATERLEVEL AFTER TEST:	19.84	m
LONGITUDE:							


TEST DESCRIPTION	STEP	1	2	3	4	5	6	TOTAL:	RECOVERY:
CALIBRATION TEST:								(min) (hrs)	(m) (min)
TEST DURATION (Minutes)		15	15	15	15	15		75	1.25
TEST YIELD (l/s)		1.32	2.10	2.44	3.39	14.45		MAXIMUM (l/s)	14.5
DRAWDOWN (m)		0.92	1.44	3.05	6.99	15.73		MAXIMUM (m)	15.7
MULTI-RATE / STEP DRAWDOWN:									
TEST DURATION (Minutes)		100	100	100				300	5.00
TEST YIELD (l/s)		4.15	7.31	11.21				MAXIMUM (l/s)	11.2
DRAWDOWN (m)		5.4	8.39	32.04				MAXIMUM (m)	32.0

RECOVERY TEST			
TIME TOTAL (hrs):		29.50	
Cal	Steps	CD	Total
90	240	1440	1770
DRAWDOWN TOTALS (CD):			
AVAILABLE	UTIL-	%	
	ISED		
49.6	28.30	57.01	


CONSTANT DISCHARGE TEST	TEST DURATION		TEST YIELD	DRAWDOWN	RECOVERY:			
	(min)	(hrs)	(l/s)	(m)	(m)	%	(min)	(hrs)
	440	24.00	5.11	28.30	4.10	35.51	1440	24.00
OBSERVATION BOREHOLES:	No.	720	1440	2880	>2880 (min)	TOTAL:		
	of boreholes	(min)	(min)	(min)	nr.	Time	(min)	(hrs)
							0	0.00

BOREHOLE NUMBER: ECT11/007


CALIBRATION TEST AND RECOVERY



STEPPED DISCHARGE TEST AND RECOVERY



CONSTANT DISCHARGE TEST AND RECOVERY



TEST INFORMATION

Date tested	11/05/2003	Water level (mbgl)	13.16	Depth of pump (mbgl)	62.8
CD duration	1440	CD discharge rate	6.11	CD drawdown	28.3
Available drawdown (m)	49.64	% Recovery after CD	86	% after 1440 min	

CALIBRATION TEST AND RECOVERY

BOREHOLE NO. :	EC/T11/008	PROJECT:	ENGCOBO FEASIBILITY STUDY		
ALTERNATIVE NO. :		SITE NAME:	KWA-SANDILE		
ALTERNATIVE NO. :		CLIENT:	CHRIS HANI DISTRICT MUNICIPALITY		
BOREHOLE DEPTH (mbdl):	60.66	CASING DEPTH (mbdl):	18.15	PUMP TYPE USED:	P 100
DEPTH OF PUMP (mbdl):	56.50	CASING HEIGHT (magl):	0.35	OPERATOR:	PIETER MUNYAI
PUMP INLET DIAMETER (mm):	165.00	CASING ID (mm):	170.00	CONTRACTOR:	AB PUMPS
STATIC WATER LEVEL (mbdl):	17.50	DATUM LEVEL (magl):	0.19	SUPERVISOR:	CJ VAN DER WALT

DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3										
DATE:	17/05/2003		TIME:		09H35		DATE:	17/05/2003		TIME:		09H50		DATE:	17/05/2003		TIME:		10H05	
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	
1	0.16		1		1	0.62	0.68	1		1	1.03		1							
2	0.18		2		2	0.67		2		2	1.05	0.94	2							
3	0.27	0.66	3		3	0.72	0.8	3		3	1.08	1.12	3							
5	0.41		5		5	0.80		5		5	1.20		5							
7	0.45		7		7	0.88		7		7	1.35	1.15	7							
10	0.47	0.65	10		10	0.95	0.81	10		10	1.57		10							
15	0.54		15		15	1.00		15		15	1.68		15							

EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20
TYPE OF RESERVOIR:	30	TYPE OF ENCLOSURE:	30	PRESSURE GAUGE MANUFACTURER:	30
	40		40		40
RESERVOIR SIZE:	50	MATERIAL OF ENCLOSURE:	50	GAUGE READING (KpA):	60
	60		60		70
RESERVOIR CONITION:	70	CONDITION OF ENCLOSURE:	70	MONITORING FACILITY:	80
	80		80		90
STAND HEIGHT (m):	90	WATER METER MANUFACTURER:	90	MAINTAINED:	100
	100		100		110
	110	WATER METER READING:	110		120
	120		120		150
	150		150		

DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6										
DATE:	17/05/2003		TIME:		10H20		DATE:	17/05/2003		TIME:		10H35		DATE:	17/05/2003		TIME:		10H50	
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	
1	1.76		1		1	2.80		1		1	5.02		1	7.40						
2	1.80	1.7	2		2	3.01		2		2	5.27	5.07	2	6.86						
3	1.92	1.68	3		3	3.40	3.58	3		3	5.51		3	6.49						
5	2.05	2.03	5		5	3.68		5		5	5.80		5	5.96						
7	2.19		7		7	4.01	3.6	7		7	6.56	7.03	7	5.42						
10	2.39	2.05	10		10	4.35		10		10	7.15	7.05	10	4.86						
15	2.73		15		15	4.85		15		15	8.00		15	4.04						

EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20
PUMP TYPE:	30	TYPE OF POWER:	30	TYPE OF RISER:	30
	40		40		40
PUMP MANUFACTURER:	50	ENGINE MANUFACTURER:	50	CLASS OF RISER:	50
	60		60		60
PUMP SERIAL No:	70	ENGINE MODEL:	70	DIAMETER OF RISER (mm):	70
	80		80		80
PUMP PULLEY DIAMETER (mm):	90	ENGINE SERIAL No:	90	CONDITION OF RISER:	90
	100		100		100
PUMP INTAKE DEPTH (m):	110	ENGINE PULLEY DIAMETER (mm):	110	SHAFT DIAMETER (mm):	110
	120		120		120
PUMP RPM:	150	POWER RATING (kW):	150	ELEMENT DIAMETER (mm):	150
					180
PUMP CONDITION:		ENGINE CONDITION:		ELEMENT STROKE (mm):	210
					240

COMMENTS:	300
	420
	480
	540
	600
DID THE BOREHOLE PRODUCE ANY SILT / SAND / GRAVEL ?	660

STEPPED DISCHARGE TEST AND RECOVERY

OREHOLE NO.:	EC/T11/008	PROJECT:	ENGCOCO FEASIBILITY STUDY
ALTERNATIVE NO.:	0	SITE NAME:	KWA-SANDILE
ALTERNATIVE NO.:	0	CLIENT:	CHRIS HANI DISTRICT MUNICIPALITY
OREHOLE DEPTH (m bdl):	60.66	CASING DEPTH (m bdl):	18.15
DEPTH OF PUMP (m bdl):	56.50	CASING HEIGHT (magl):	0.35
PUMP INLET DIAMETER (mm):	165.000	CASING ID (mm):	170.000
STATIC WATER LEVEL (m bdl):	18.25	DATUM LEVEL (magl):	0.19
		PUMP TYPE USED:	P 100
		OPERATOR:	PIETER MUNYAI
		CONTRACTOR:	AB PUMPS

DISCHARGE RATE 1			Time	Recovery 1	DISCHARGE RATE 2			Time	Recovery 2	DISCHARGE RATE 3			Time	Recovery 3
DATE:	17/05/2003		(min)	(m)	DATE:	17/05/2003		(min)	(m)	DATE:	17/05/2003		(min)	(m)
TIME:	13H00		1		TIME:	14H40		1		TIME:	16H20		1	
Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield
(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)
1	0.15		5	2.18		5	4.68		1	4.68		5		
	0.26		7	2.30	1.990	7	4.80	3.640	2	4.80	3.640	7		
	0.30	0.860	10	2.39		10	4.94		3	4.94		10		
5	0.53		15	2.50	2.040	15	5.19	4.080	4	5.19	4.080	15		
	0.68	1.090	20	2.63		20	5.57		7	5.57		20		
0	0.82		30	2.80		30	6.02		10	6.02		30		
15	1.06	1.100	40	3.10	2.050	40	6.46	4.070	15	6.46	4.070	40		
20	1.11		50	3.29		50	6.95		20	6.95		50		
30	1.22	1.100	60	3.62		60	7.54		30	7.54		60		
40	1.34		70	3.85	2.030	70	8.04	4.060	40	8.04	4.060	70		
50	1.43		80	4.03		80	8.45		50	8.45		80		
60	1.56	1.090	90	4.20		90	8.83		60	8.83		90		
70	1.73		100	4.34	2.050	100	9.14	4.070	70	9.14	4.070	100		
80	1.86	1.070	110	4.44		110	9.37		80	9.37		110		
90	1.94		120	4.53	2.040	120	9.63	4.060	90	9.63	4.060	120		
100	2.03		150	4.62		150	9.85		100	9.85		150		
110			180			180			110			180		
120			210			210			120			210		
Average yield: 1.05166667			(l/s)	Average yield: 2.03333333				Average yield: 3.99666667						

DISCHARGE RATE 4			Time	Recovery 4	DISCHARGE RATE 5			Time	Recovery 5	DISCHARGE RATE 6			Time	Recovery
DATE:	17/05/2003		(min)	(m)	DATE:	17/05/2003		(min)	(m)	DATE:	17/05/2003		(min)	(m)
TIME:	18H00		1		TIME:			1		TIME:			1	14.53
Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield
(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)
2			5			5			2			5		
3			7			7			3			7		
1	10.02		10			10			10			10		11.87
2	10.11	6.85	15			15			15			15		10.69
3	10.29		20			20			20			20		9.73
5	10.55	7.09	30			30			30			30		7.92
7	10.70		40			40			40			40		7.36
10	11.10		50			50			50			50		6.81
15	11.54	7.08	60			60			60			60		6.24
20	12.01		70			70			70			70		5.67
30	12.59		80			80			80			80		5.12
40	13.09	7.09	90			90			90			90		4.50
50	13.57		100			100			100			100		3.96
60	13.90		110			110			110			110		3.44
70	14.22	7.08	120			120			120			120		2.80
80	14.49		150			150			150			150		2.46
90	14.74	7.06	180			180			180			180		2.1
100	14.97		210			210			210			210		1.39
Average yield: 7.04166667														

COMMENTS:	300	180	240	1
	360	210	300	0.64
	420	240	360	0.39
	480	300	420	0.25
	540	360	480	
	600	420	540	
	660	480	600	
	720		660	
	780		720	

DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(l/s)	(m)	(min)	(m)	(m)	(min)	(m)	(m)	(min)	(m)	(m)
1500	26.49	8.06		1500			1500			1500		
1560	26.51			1560			1560			1560		
1620	26.52	8.03		1620			1620			1620		
1680	26.53			1680			1680			1680		
1740	26.55	8.04		1740			1740			1740		
1800	26.57			1800			1800			1800		
1860	26.60	8.05		1860			1860			1860		
1920	26.66			1920			1920			1920		
1980	26.69	8.04		1980			1980			1980		
2040	26.71			2040			2040			2040		
2100	26.74	8.03		2100			2100			2100		
2160	26.77			2160			2160			2160		
2220	26.78	8.04		2220			2220			2220		
2280	26.80			2280			2280			2280		
2340	26.82	8.05		2340			2340			2340		
2400	26.84			2400			2400			2400		
2460	26.87	8.05		2460			2460			2460		
2520	26.90			2520			2520			2520		
2580	26.90			2580			2580			2580		
2640	26.91	8.03		2640			2640			2640		
2700	26.92			2700			2700			2700		
2760	26.92			2760			2760			2760		
2820	26.93	8.05		2820			2820			2820		
2880	26.94			2880			2880			2880		

DESCRIPTION:	QUANTITY:	UNIT:
ESTABLISHMENT		Sum
INTER HOLE MOVE > 10 km	1	Km
FROM: SITE NAME: NKONDLO		
BOREHOLE No: T 32396		
INTER HOLE MOVE < 10 km:	38	No.
REMOVAL AND RE-ERECTION OF PUMP HOUSE:	0	No.
REMOVAL OF EXISTING EQUIPMENT:	0	No.
RE-INSTALLATION OF EXISTING EQUIPMENT:	0	No.
WORK TIME RATE (REPAIRS):	0	Hour
STANDING TIME:	0	Hour
LATITUDE:		
LONGITUDE:		


DESCRIPTION:	QUANTITY:	UNIT:
STRAIGHTNESS TEST:	0	No.
VERTICALITY TEST:	0	No.
CASING DETECTION:	1	No.
STEEL BOREHOLE COVER:	1	No.
BOREHOLE MARKING:	1	No.
SITE CLEANING / FINISHING:	1	No.
REPORTING & DATA RECORDING:	1	No.
SLUG TEST:	0	No.
LAYFLAT (m):	100	m
BOREHOLE DEPTH AFTER TEST:	60.66	m
BOREHOLE WATERLEVEL AFTER TEST:	18.66	m

TEST DESCRIPTION	STEP	1	2	3	4	5	6	TOTAL:	RECOVERY:
CALIBRATION TEST:								(min) (hrs)	(m) (min)
TEST DURATION (Minutes)		15	15	15	15	15	15	90	1.50
TEST YIELD (l/s)		0.66	0.76	1.07	1.87	3.59	6.38	MAXIMUM (l/s)	6.4
DRAWDOWN (m)		0.54	1.00	1.68	2.73	4.85	8.00	MAXIMUM (m)	9.0
MULTI-RATE / STEP DRAWDOWN:									
TEST DURATION (Minutes)		100	100	100	100			400	6.67
TEST YIELD (l/s)		1.05	2.03	4.00	7.04			MAXIMUM (l/s)	7.0
DRAWDOWN (m)		2.0	4.82	9.85	14.97			MAXIMUM (m)	15.0
CONSTANT DISCHARGE TEST		TEST DURATION		TEST YIELD	DRAWDOWN		RECOVERY:		
		(min)	(hrs)	(l/s)	(m)		(m)	%	(min) (hrs)
		2880	48.00	7.34	26.94		0.75	97.22	1260 21.00
OBSERVATION BOREHOLES:		No.	720	1440	2880		>2880 (min)		
		of boreholes	(min)	(min)	(min)		nr.	Time	TOTAL: (min) (hrs)
									0 0.00


RECOVERY TEST			
TIME TOTAL (hrs):		29.67	
Cal	Steps	CD	Total
100	420	1260	1780
DRAWDOWN TOTALS (CD):			
AVAILABLE	UTIL-	%	
	ISED		
39.0	26.94	69.08	

BOREHOLE NUMBER: EC/T11/008


CALIBRATION TEST AND RECOVERY



STEPPED DISCHARGE TEST AND RECOVERY



CONSTANT DISCHARGE TEST AND RECOVERY



TEST INFORMATION

Date tested	18/05/2003	Water level (mbgl)	17.50	Depth of pump (mbgl)	56.5
CD duration	2880	CD discharge rate	7.64	CD drawdown	26.94
Available drawdown (m)	39	% Recovery after CD	97	% after 1260 min	

CALIBRATION TEST AND RECOVERY

BOREHOLE NO.:	EC/T12/004	PROJECT:	ENCGOBO FEASIBILITY STUDY
ALTERNATIVE NO.:		SITE NAME:	NKWENKWEZI
ALTERNATIVE NO.:		CLIENT:	CHRIS HANI DISTRICT MUNICIPALITY
BOREHOLE DEPTH (m bdl):	81.15	CASING DEPTH (m bdl):	13.20
DEPTH OF PUMP (m bdl):	42.15	CASING HEIGHT (magl):	0.36
PUMP INLET DIAMETER (mm):	100.00	CASING ID (mm):	165.00
STATIC WATER LEVEL (m bdl):	6.25	DATUM LEVEL (magl):	0.18
		PUMP TYPE USED:	BP 65
		OPERATOR:	PIETER MUNYAI
		CONTRACTOR:	AB PUMPS
		SUPERVISOR:	H VORSTER

DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3				
DATE	TIME				DATE	TIME				DATE	TIME			
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)
1			1		1			1		1			1	
2			2		2			2		2			2	
3			3		3			3		3			3	
5			5		5			5		5			5	
7			7		7			7		7			7	
10			10		10			10		10			10	
15			15		15			15		15			15	

EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20
TYPE OF RESERVOIR:	30		TYPE OF ENCLOSURE:	30		PRESSURE GAUGE MANUFAC	30	
	40			40		TURER:	40	
RESERVOIR SIZE:	50		MATERIAL OF ENCLOSURE:	50			50	
	60			60		GAUGE READING (KpA):	60	
RESERVOIR CONITION:	70		CONDITION OF ENCLOSURE:	70			70	
	80			80		MONITORING FACILITY:	80	
STAND HEIGHT (m):	90		WATER METER MANUFACTURER:	90			90	
	100			100		MAINTAINED:	100	
	110		WATER METER READING:	110			110	
	120			120			120	
	150			150			150	

DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 5				
DATE	TIME				DATE	TIME				DATE	TIME			
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)
1			1		1			1		1			1	
2			2		2			2		2			2	
3			3		3			3		3			3	
5			5		5			5		5			5	
7			7		7			7		7			7	
10			10		10			10		10			10	
15			15		15			15		15			15	

EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20
PUMP TYPE:	30		TYPE OF POWER:	30		TYPE OF RISER:	30	
	40			40			40	
PUMP MANUFACTURER:	50		ENGINE MANUFACTURER:	50		CLASS OF RISER:	50	
	60			60			60	
PUMP SERIAL No:	70		ENGINE MODEL:	70		DIAMETER OF RISER (mm):	70	
	80			80			80	
PUMP PULLEY DIAMETER (mm):	90		ENGINE SERIAL No:	90		CONDITION OF RISER:	90	
	100			100			100	
PUMP INTAKE DEPTH (m):	110		ENGINE PULLEY DIAMETER (mm):	110		SHAFT DIAMETER (mm):	110	
	120			120			120	
PUMP RPM:	150		POWER RATING (kW):	150		ELEMENT DIAMETER (mm):	150	
							180	
PUMP CONDITION:			ENGINE CONDITION:			ELEMENT STROKE (mm):	210	
							240	

COMMENTS:	300
	420
	480
	540
	600
DID THE BOREHOLE PRODUCE ANY SILT / SAND / GRAVEL ?	660

STEPPED DISCHARGE TEST AND RECOVERY

BOREHOLE NO. :	EC/T12/004	PROJECT:	ENCGOBO FEASIBILITY STUDY		
ALTERNATIVE NO. :	0	SITE NAME:	NKWENKWEZI		
ALTERNATIVE NO. :	0	CLIENT:	CHRIS HANI DISTRICT MUNICIPALITY		
BOREHOLE DEPTH (m bdl):	81.15	CASING DEPTH (m bdl):	13.20	PUMP TYPE USED:	BP 65
DEPTH OF PUMP (m bdl):	42.15	CASING HEIGHT (magl):	0.36	OPERATOR:	PIETER MUNYAI
PUMP INLET DIAMETER (mm):	100.000	CASING ID (mm):	165.000	CONTRACTOR:	AB PUMPS
STATIC WATER LEVEL (m bdl):	6.25	DATUM LEVEL (magl):	0.18		

DISCHARGE RATE 1			Time	Recovery 1	DISCHARGE RATE 2			Time	Recovery 2	DISCHARGE RATE 3			Time	Recovery 3
DATE:	31/05/2003		(min)	(m)	DATE:	31/05/2003		(min)	(m)	DATE:	31/05/2003		(min)	(m)
TIME:	12H45		1		TIME:	14H25		1		TIME:	16H05		1	
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	
1	0.35		5		1	6.52	8.890	5		1	14.48	15.900	5	
	0.51	3.680	7		2	6.78		7		2	15.73		7	
	0.65	4.890	10		3	6.82	9.800	10		3	16.19	16.320	10	
5	1.41		15		5	7.03		15		4	17.08		15	
7	1.65	5.280	20		7	7.27	10.200	20		7	17.83	17.200	20	
10	1.95		30		10	8.03		30		10	18.33		30	
15	2.35	5.290	40		15	8.44		40		15	19.21		40	
20	2.66		50		20	9.00	10.190	50		20	20.02	17.210	50	
30	3.19		60		30	9.70		60		30	21.08		60	
40	3.57	5.270	70		40	10.62		70		40	22.10		70	
50	3.96		80		50	11.13	10.210	80		50	22.83	17.200	80	
60	4.28		90		60	11.62		90		60	23.62		90	
70	4.57	5.290	100		70	12.18		100		70	24.32		100	
80	4.80		110		80	12.61	10.200	110		80	24.94	17.220	110	
90	5.15	5.270	120		90	13.04		120		90	25.62		120	
100	5.31		150		100	13.52		150		100	26.19		150	
110			180		110			180		110			180	
120			210		120			210		120			210	
Average yield: 4.99571429			(l/s)		Average yield: 9.915					Average yield: 16.3416667				

DISCHARGE RATE 4			Time	Recovery 4	DISCHARGE RATE 5			Time	Recovery 5	DISCHARGE RATE 6			Time	Recovery
DATE:	31/05/2003		(min)	(m)	DATE:	31/05/2003		(min)	(m)	DATE:	31/05/2003		(min)	(m)
TIME:			1		TIME:			1		TIME:			1	20.46
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	19.32
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	18.64
			5		1			5		1			5	18.02
			7		2			7		2			7	17.15
3			10		3			10		3			10	16.76
5			15		5			15		5			15	15.47
			20		7			20		7			20	14.73
10			30		10			30		10			30	13.49
15			40		15			40		15			40	12.53
20			50		20			50		20			50	11.47
30			60		30			60		30			60	10.85
40			70		40			70		40			70	10.34
50			80		50			80		50			80	9.99
60			90		60			90		60			90	9.48
70			100		70			100		70			100	8.99
80			110		80			110		80			110	8.71
90			120		90			120		90			120	8.44
100			150		100			150		100			150	8.16
110			180		110			180		110			180	7.97
120			210		120			210		120			210	7.79
Average yield: #DIV/0!														

COMMENTS:		240	150	240	180	300	7.03
		300		360		420	
		360		420		480	
		420		480		540	
		480		540		600	
		540		600		660	
		600		660		720	
		660		720			
		720		780		780	
Average yield:							

DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(l/s)	(m)	(min)	(m)	(m)	(min)	(m)	(m)	(min)	(m)	(m)
1500	19.85	8.40	5.02	1500			1500			1500		
1560	20.10		4.89	1560			1560			1560		
1620	20.13		4.68	1620			1620			1620		
1680	20.17	8.42	4.49	1680			1680			1680		
1740	20.21		4.30	1740			1740			1740		
1800	20.25		4.16	1800			1800			1800		
1860	20.29		4.03	1860			1860			1860		
1920	20.32	8.43	3.92	1920			1920			1920		
1980	20.35	8.42	3.84	1980			1980			1980		
2040	20.39		3.76	2040			2040			2040		
2100	20.42		3.68	2100			2100			2100		
2160	20.45		3.59	2160			2160			2160		
2220	20.48	8.44	3.46	2220			2220			2220		
2280	20.79		3.35	2280			2280			2280		
2340	20.86		3.24	2340			2340			2340		
2400	20.89	8.41	3.14	2400			2400			2400		
2460	21.06		3.04	2460			2460			2460		
2520	21.20		2.95	2520			2520			2520		
2580	21.37	8.43	2.86	2580			2580			2580		
2640	21.39		2.75	2640			2640			2640		
2700	21.46		2.61	2700			2700			2700		
2760	21.51	8.40	2.53	2760			2760			2760		
2820	21.53		2.44	2820			2820			2820		
2880	21.76		2.32	2880			2880			2880		


DESCRIPTION:	QUANTITY:	UNIT:	DESCRIPTION:	QUANTITY:	UNIT:
ESTABLISHMENT	0	Sum	STRAIGHTNESS TEST:	1	No
INTER HOLE MOVE > 10 km	0	Km	VERTICALITY TEST:	0	No
FROM: SITE NAME:			CASING DETECTION:	1	No
BOREHOLE No.:			STEEL BOREHOLE COVER:	1	No
INTER HOLE MOVE < 10 km:	1	No	BOREHOLE MARKING:	1	No
REMOVAL AND RE-ERECTION OF PUMP HOUSE:	0	No	SITE CLEANING / FINISHING:	1	No
REMOVAL OF EXISTING EQUIPMENT:	0	No	REPORTING & DATA RECORDING:	1	No
RE-INSTALLATION OF EXISTING EQUIPMENT:	0	No	SLUG TEST:	0	No
WORK TIME RATE (REPAIRS):	0	Hour	LAYFLAT (m):	100	m
STANDING TIME:	0	Hour	BOREHOLE DEPTH AFTER TEST:	81.15	m
LATITUDE:			BOREHOLE WATERLEVEL AFTER TEST:	10.32	m
LONGITUDE:					

TEST DESCRIPTION	STEP	1	2	3	4	5	6	TOTAL:	RECOVERY:
CALIBRATION TEST:									
TEST DURATION (Minutes)								(min) (hrs)	(m) (min)
TEST YIELD (l/s)								0 9.00	0.00
DRAWDOWN (m)								MAXIMUM (l/s) 0.0	
								MAXIMUM (m)	
MULTI-RATE / STEP DRAWDOWN:									
TEST DURATION (Minutes)	100	100	100					300 5.00	7.03 300
TEST YIELD (l/s)	5.00	9.92	16.84					MAXIMUM (l/s) 16.8	
DRAWDOWN (m)	5.31	13.52	26.19					MAXIMUM (m) 26.2	
CONSTANT DISCHARGE TEST									
	TEST DURATION		TEST YIELD		DRAWDOWN		RECOVERY:		
	(min)	(hrs)	(l/s)		(m)		(m)	% (min) (hrs)	
	2880	48.00	8.90		21.76		2.32	89.34 2880 48.00	
OBSERVATION BOREHOLES:									
	No.	720	1440		2880		>2880 (min)		
	of boreholes	(min)	(min)		(min)		nr.	TOTAL: (min) (hrs)	
							Time	0 0.00	


RECOVERY TEST			
TIME TOTAL (hrs):		53.00	
Cal	Steps	CD	Total
0	300	2880	3180
DRAWDOWN TOTALS (CD):			
AVAILABLE	UTIL-	%	
	ISED		
35.9	21.76	60.61	

BOREHOLE NUMBER: EC/T12/004


CALIBRATION TEST AND RECOVERY



STEPPED DISCHARGE TEST AND RECOVERY



CONSTANT DISCHARGE TEST AND RECOVERY



TEST INFORMATION

Date tested	01/06/2003	Water level (mbgl)	6.25	Depth of pump (mbgl)	42.15
CD duration	2880	CD discharge rate	8.90	CD drawdown	21.76
Available drawdown (m)	35.9	% Recovery after CD	89	% after 2880 min	

CALIBRATION TEST AND RECOVERY

BOREHOLE NO. :	EC/T12/005	PROJECT:	ENGCOBO FEASIBILITY STUDY
ALTERNATIVE NO. :		SITE NAME:	GOBOTI
ALTERNATIVE NO. :		CLIENT:	CHRIS HANI DISTRICT MUNICIPALITY
BOREHOLE DEPTH (m bdl):	190.02	CASING DEPTH (m bdl):	26.50
DEPTH OF PUMP (m bdl):	122.70	CASING HEIGHT (magl):	0.55
PUMP INLET DIAMETER (mm):	100.00	CASING ID (mm):	170.00
STATIC WATER LEVEL (m bdl):	36.01	DATUM LEVEL (magl):	0.29
		PUMP TYPE USED:	P 150
		OPERATOR:	PIETER MUNYAI
		CONTRACTOR:	AB PUMPS
		SUPERVISOR:	CJ VAN DER WALT

DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3										
DATE:	21/05/2003		TIME:		19H25		DATE:	21/05/2003		TIME:		19H40		DATE:	21/05/2003		TIME:		19H55	
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	{l/s}	{min}	(m)	(min)	(m)	{l/s}	(min)	(m)	(min)	(m)	{l/s}	(min)	(m)	(min)	(m)	{l/s}	(min)	(m)	
1	1.40		1		1	19.16		1		1	26.13		1		1	26.13		1		
2	3.23		2		2	20.04	0.69	2		2	28.70	1.02	2		2	28.70	1.02	2		
3	5.11	0.52	3		3	20.92		3		3	31.09		3		3	31.09		3		
5	8.84	0.53	5		5	21.94	0.81	5		5	33.54	1.05	5		5	33.54	1.05	5		
7	10.21		7		7	22.56		7		7	35.70		7		7	35.70		7		
10	15.51	0.52	10		10	23.77	0.83	10		10	38.39	1.04	10		10	38.39	1.04	10		
15	19.14		15		15	24.59		15		15	40.91		15		15	40.91		15		

EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20
TYPE OF RESERVOIR:		30	TYPE OF ENCLOSURE:		30	PRESSURE GAUGE MANUFAC		30
		40			40	TURER:		40
RESERVOIR SIZE:		50	MATERIAL OF ENCLOSURE:		50			50
		60			60	GAUGE READING (Kpa):		60
RESERVOIR CONITION:		70	CONDITION OF ENCLOSURE:		70			70
		80			80	MONITORING FACILITY:		80
STAND HEIGHT (m):		90	WATER METER MANUFACTURER:		90			90
		100			100	MAINTAINED:		100
		110	WATER METER READING:		110			110
		120			120			120
		150			150			150

DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6										
DATE:	21/05/2003		TIME:		20H10		DATE:	21/05/2003		TIME:		20H25		DATE:	21/05/2003		TIME:		20H40	
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	{l/s}	(min)	(m)	(min)	(m)	{l/s}	(min)	(m)	(min)	(m)	{l/s}	(min)	(m)	(min)	(m)	{l/s}	(min)	(m)	
1	41.84	1.21	1		1	57.97		1		1	81.14	1.88	1		1	81.14	1.88	1	75.35	
2	42.39		2		2	59.15	1.52	2		2	82.13		2		2	82.13		2	69.19	
3	44.25		3		3	62.38		3		3	83.52	1.9	3		3	83.52	1.9	3	66.01	
5	45.98	1.3	5		5	65.03	1.72	5		5	85.13		5		5	85.13		5	56.83	
7	50.16		7		7	69.42		7		7	85.13	PI 1.34	7		7	85.13	PI 1.29	7	50.56	
10	52.00	1.31	10		10	73.67	1.73	10		10	85.13	PI 1.29	10		10	85.13	PI 1.09	10	40.64	
15	56.16		15		15	78.50		15		15	85.13	PI 1.09	15		15	85.13		15	29.54	

EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20
PUMP TYPE:		30	TYPE OF POWER:		30	TYPE OF RISER:		30
		40			40			40
PUMP MANUFACTURER:		50	ENGINE MANUFACTURER:		50	CLASS OF RISER:		50
		60			60			60
PUMP SERIAL No:		70	ENGINE MODEL:		70	DIAMETER OF RISER (mm):		70
		80			80			80
PUMP PULLEY DIAMETER (mm):		90	ENGINE SERIAL No:		90	CONDITION OF RISER:		90
		100			100			100
PUMP INTAKE DEPTH (m):		110	ENGINE PULLEY DIAMETER (mm):		110	SHAFT DIAMETER (mm):		110
		120			120			120
PUMP RPM:		150	POWER RATING (kW):		150	ELEMENT DIAMETER (mm):		150
								180
PUMP CONDITION:			ENGINE CONDITION:			ELEMENT STROKE (mm):		210
								240

COMMENTS:		300
		420
		480
		540
		600
DID THE BOREHOLE PRODUCE ANY SILT / SAND / GRAVEL ?		660

STEPPED DISCHARGE TEST AND RECOVERY

BOREHOLE NO. :	EC/T12/005		PROJECT:	ENGCOBO FEASIBILITY STUDY	
ALTERNATIVE NO. :	0		SITE NAME:	GOBOTI	
ALTERNATIVE NO. :	0		CLIENT:	CHRIS HANI DISTRICT MUNICIPALITY	
BOREHOLE DEPTH (mbdl):	190.02	CASING DEPTH (mbdl):	26.50	PUMP TYPE USED:	P 150
DEPTH OF PUMP (mbdl):	122.70	CASING HEIGHT (magl):	0.55	OPERATOR:	PIETER MUNYAI
PUMP INLET DIAMETER (mm):	100.000	CASING ID (mm):	170.000	CONTRACTOR:	AB PUMPS
STATIC WATER LEVEL (mbdl):	36.01	DATUM LEVEL (magl):	0.29		

DISCHARGE RATE 1			Time	Recovery 1	DISCHARGE RATE 2			Time	Recovery 2	DISCHARGE RATE 3			Time	Recovery 3
DATE:	22/05/2003		(min)	(m)	DATE:	22/05/2003		(min)	(m)	DATE:	22/05/2003		(min)	(m)
TIME:	08H20		1		TIME:	10H00		1		TIME:	11H40		1	
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	
1	0.99		5		1	13.48		5		1	36.12		5	
	2.03	0.650	7		2	13.94	0.770	7		2	36.67	1.240	7	
	3.00		10		3	14.96		10		3	38.68		10	
5	3.39	0.510	15		5	16.70	0.790	15		4	42.16	1.560	15	
	4.67	0.400	20		7	18.02		20		7	45.46		20	
0	5.23		30		10	21.29	0.800	30		10	53.00	1.630	30	
15	6.81	0.420	40		15	23.28		40		15	63.46		40	
20	7.53		50		20	26.59	0.810	50		20	69.74	1.610	50	
30	7.83		60		30	29.70		60		30	76.12		60	
40	8.30	0.410	70		40	31.83		70		40	78.75	1.620	70	
50	9.73		80		50	33.13	0.800	80		50	79.65		80	
60	10.45	0.420	90		60	33.71		90		60	79.87	1.600	90	
70	11.95		100		70	34.13		100		70	84.79		100	
80	12.29	0.400	110		80	34.56	0.810	110		80	85.08		110	
90	12.70		120		90	35.04		120		90	85.08	PI 1.34	120	
100	13.45		150		100	35.64		150		100	85.08	PI 1.15	150	
110			180		110			180		110	85.08	PI 1.09	180	
120			210		120			210		120			210	

Average yield: 0.45857143 (l/s)

Average yield: 0.79666667 (l/s)

Average yield: 1.54333333 (l/s)

DISCHARGE RATE 4			Time	Recovery 4	DISCHARGE RATE 5			Time	Recovery 5	DISCHARGE RATE 6			Time	Recovery
DATE:	22/05/2003		(min)	(m)	DATE:	22/05/2003		(min)	(m)	DATE:	22/05/2003		(min)	(m)
TIME:			1		TIME:			1		TIME:			1	76.35
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	70.16
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	64.84
			5		1			5		1			5	56.33
			7		2			7		2			7	47.35
3			10		3			10		3			10	41.02
5			15		5			15		5			15	29.93
			20		7			20		7			20	21.89
10			30		10			30		10			30	13.66
15			40		15			40		15			40	8.59
20			50		20			50		20			50	6.78
30			60		30			60		30			60	6.06
40			70		40			70		40			70	5.54
50			80		50			80		50			80	5.12
60			90		60			90		60			90	4.67
70			100		70			100		70			100	4.41
80			110		80			110		80			110	4.15
90			120		90			120		90			120	
100			150		100			150		100			150	
110			180		110			180		110			180	
120			210		120			210		120			210	

Average yield: #DIV/0!

COMMENTS:	300	180	300
	360	210	360
	420	240	420
	480	300	480
	540	360	540
	600	420	600
	660	480	660
	780		780
		Average yield:	720

DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(l/s)	(m)	(min)	(m)	(m)	(min)	(m)	(m)	(min)	(m)	(m)
1500				1500			1500			1500		
1560				1560			1560			1560		
1620				1620			1620			1620		
1680				1680			1680			1680		
1740				1740			1740			1740		
1800				1800			1800			1800		
1860				1860			1860			1860		
1920				1920			1920			1920		
1980				1980			1980			1980		
2040				2040			2040			2040		
2100				2100			2100			2100		
2160				2160			2160			2160		
2220				2220			2220			2220		
2280				2280			2280			2280		
2340				2340			2340			2340		
2400				2400			2400			2400		
2460				2460			2460			2460		
2520				2520			2520			2520		
2580				2580			2580			2580		
2640				2640			2640			2640		
2700				2700			2700			2700		
2760				2760			2760			2760		
2820				2820			2820			2820		
2880				2880			2880			2880		

DESCRIPTION:	QUANTITY:	UNIT:
ESTABLISHMENT	0	Sum
ENTER HOLE MOVE > 10 km	65	Km.
FROM: SITE NAME: KVASANDILE		
BOREHOLE No: EC/T11/008		
ENTER HOLE MOVE < 10 km:	0	No.
REMOVAL AND RE-ERECTION OF PUMP HOUSE:	0	No.
REMOVAL OF EXISTING EQUIPMENT:	0	No.
RE-INSTALLATION OF EXISTING EQUIPMENT:	0	No.
WORK TIME RATE (REPAIRS):	0	Hour
STANDING TIME:	0	Hour
LATITUDE: S 31° 43' 30.4"	LONGITUDE: E 28° 04' 25.7"	


DESCRIPTION:	QUANTITY:	UNIT:
STRAIGHTNESS TEST:	1	No
VERTICALITY TEST:	0	No
CASING DETECTION:	1	No
STEEL BOREHOLE COVER:	1	No
BOREHOLE MARKING:	1	No
SITE CLEANING / FINISHING:	1	No
REPORTING & DATA RECORDING:	1	No
SLUG TEST:	0	No
LAYFLAT (m):	100	m
BOREHOLE DEPTH AFTER TEST:	190.02	m
BOREHOLE WATERLEVEL AFTER TEST:	37.41	m

TEST DESCRIPTION	STEP							TOTAL:		RECOVERY:	
		1	2	3	4	5	6	(min)	(hrs)	(m)	(min)
CALIBRATION TEST:								90	1 50	2 70	90
TEST DURATION (Minutes)		15	15	15	15	15	15				
TEST YIELD (l/s)		0.52	0.78	1.04	1.27	1.66	1.89	MAXIMUM (l/s)	1.9		
DRAWDOWN (m)		19.14	24.59	40.91	56.16	78.50	85.13	MAXIMUM (m)	85.1		
MULTI-RATE / STEP DRAWDOWN:											
TEST DURATION (Minutes)		100	100	110				310	5 17	4 15	110
TEST YIELD (l/s)		0.46	0.80	1.54				MAXIMUM (l/s)	1.5		
DRAWDOWN (m)		13.5	35.64	85.08				MAXIMUM (m)	85.1		


RECOVERY TEST			
TIME TOTAL (hrs):		6.83	
Cal	Steps	CD	Total
90	110	210	410
DRAWDOWN TOTALS (CD):			
AVAILABLE	UTIL-	%	
	ISED		
96.7	21.29	24.68	

CONSTANT DISCHARGE TEST	TEST DURATION		TEST YIELD	DRAWDOWN	RECOVERY:				
	(min)	(hrs)	(l/s)	(m)	(m)	%	(min)	(hrs)	
	1440	24 00	0.53	21.29	0.00	100.00	210	3 50	
OBSERVATION BOREHOLES:	No.	720	1440	2880	TOTAL:				
of boreholes	(min)	(min)	(min)	(min)	>2880 (min)	nr.	Time	(min)	(hrs)
								3	0 30


BOREHOLE NUMBER: EC/T12/005
CALIBRATION TEST AND RECOVERY



STEPPED DISCHARGE TEST AND RECOVERY



CONSTANT DISCHARGE TEST AND RECOVERY



TEST INFORMATION

Date tested	22/05/2003	Water level (mbgl)	36.01	Depth of pump (mbgl)	122.7
CD duration	1440	CD discharge rate	0.53	CD drawdown	21.29
Available drawdown (m)	86.69	% Recovery after CD	100	% after	210 min

CALIBRATION TEST AND RECOVERY

BOREHOLE NO. :	EC/T12/008	PROJECT:	ENGOBO FEASIBILITY STUDY		
ALTERNATIVE NO. :		SITE NAME:	CLARKBURY		
ALTERNATIVE NO. :		CLIENT:	CHRIS HANI DISTRICT MUNICIPALITY		
BOREHOLE DEPTH (mbdl):	50.28	CASING DEPTH (mbdl):	26.15	PUMP TYPE USED:	BP 40
DEPTH OF PUMP (mbdl):	44.80	CASING HEIGHT (magl):	0.45	OPERATOR:	PIETER MUNYAI
PUMP INLET DIAMETER (mm):	100.00	CASING ID (mm):	170.00	CONTRACTOR:	AB PUMPS
STATIC WATER LEVEL (mbdl):	7.53	DATUM LEVEL (magl):	0.17	SUPERVISOR:	H VORSTER

DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3										
DATE:	30/04/2003		TIME:		09H20		DATE:	30/04/2003		TIME:		09H35		DATE:	30/04/2003		TIME:		09H50	
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	
1	0.16		1		1	0.35		1		1	0.58	3.78	1							
2	0.16		2		2	0.37	2.05	2		2	0.62	4.09	2							
3	0.21		3		3	0.39		3		3	0.66		3							
5	0.23	1.5	5		5	0.42	2.04	5		5	0.74	4.1	5							
7	0.25		7		7	0.44		7		7	0.81		7							
10	0.31	1.51	10		10	0.44	2.05	10		10	0.84	4.11	10							
15	0.33		15		15	0.45		15		15	0.90		15							

EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20
TYPE OF RESERVOIR:	30		TYPE OF ENCLOSURE:	30		PRESSURE GAUGE MANUFAC	30	
	40			40		TURER:	40	
RESERVOIR SIZE:	50		MATERIAL OF ENCLOSURE:	50			50	
	60			60		GAUGE READING (KpA):	60	
RESERVOIR CONITION:	70		CONDITION OF ENCLOSURE:	70			70	
	80			80		MONITORING FACILITY:	80	
STAND HEIGHT (m):	90		WATER METER MANUFACTURER:	90			90	
	100			100		MAINTAINED:	100	
	110		WATER METER READING:	110			110	
	120			120			120	
	150			150			150	

DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6										
DATE:	30/04/2003		TIME:		10H05		DATE:	30/04/2003		TIME:		10H20		DATE:			TIME:			
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	
1	0.96	5.88	1		1	1.36	7.29	1		1	1.54		1							
2	1.02	6.28	2		2	1.42	8.19	2		2	1.56	9.28	2							
3	1.03		3		3	1.43		3		3	1.59	10.39	3							
5	1.06	6.29	5		5	1.44	8.21	5		5	1.61	10.41	5							
7	1.08		7		7	1.45		7		7	1.64		7							
10	1.10	6.27	10		10	1.46	8.2	10		10	1.68	10.4	10							
15	1.16		15		15	1.52		15		15	1.77		15							

EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20	EXISTING EQUIPMENT DETAIL:		20
PUMP TYPE:	30		TYPE OF POWER:	30		TYPE OF RISER:	30	
HANDPUMP	40			40			40	
PUMP MANUFACTURER:	50		ENGINE MANUFACTURER:	50		CLASS OF RISER:	50	
	60			60			60	
PUMP SERIAL No:	70		ENGINE MODEL:	70		DIAMETER OF RISER (mm):	70	
242 HP37	80			80			80	
PUMP PULLEY DIAMETER (mm):	90		ENGINE SERIAL No:	90		CONDITION OF RISER:	90	
	100			100			100	
PUMP INTAKE DEPTH (m):	110		ENGINE PULLEY DIAMETER (mm):	110		SHAFT DIAMETER (mm):	110	
39 68	120			120			120	
PUMP RPM:	150		POWER RATING (kW):	150		ELEMENT DIAMETER (mm):	150	
							180	
PUMP CONDITION:			ENGINE CONDITION:			ELEMENT STROKE (mm):	210	
							240	
COMMENTS:							300	
							420	
							480	
							540	
							600	
							660	

DID THE BOREHOLE PRODUCE ANY SILT / SAND / GRAVEL ?

STEPPED DISCHARGE TEST AND RECOVERY

BOREHOLE NO. :	EC/T12/008	PROJECT:	ENCGOBO FEASIBILITY STUDY		
ALTERNATIVE NO. :	0	SITE NAME:	CLARKBURY		
ALTERNATIVE NO. :	0	CLIENT:	CHRIS HANI DISTRICT MUNICIPALITY		
BOREHOLE DEPTH (m bdl):	50.28	CASING DEPTH (m bdl):	26.15	PUMP TYPE USED:	BP 40
DEPTH OF PUMP (m bdl):	44.80	CASING HEIGHT (magl):	0.45	OPERATOR:	PIETER MUNYAI
PUMP INLET DIAMETER (mm):	100.000	CASING ID (mm):	170.000	CONTRACTOR:	AB PUMPS
STATIC WATER LEVEL (m bdl):	7.53	DATUM LEVEL (magl):	0.17		

DISCHARGE RATE 1			Time	Recovery 1	DISCHARGE RATE 2			Time	Recovery 2	DISCHARGE RATE 3			Time	Recovery 3
DATE:	30/04/2003		(min)	(m)	DATE:	30/04/2003		(min)	(m)	DATE:	30/04/2003		(min)	(m)
TIME:	11H50		1		TIME:	13H30		1		TIME:			1	
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	
1	0.17		5		1	0.74	5.740	5		1			5	
2	0.19		7		2	0.77	7.160	7		2			7	
3	0.23		10		3	0.83		10		3			10	
5	0.28	3.590	15		5	0.94	7.150	15		4			15	
7	0.35		20		7	1.02		20		7			20	
10	0.41	3.600	30		10	1.09	7.170	30		10			30	
15	0.45		40		15	1.16		40		15			40	
20	0.47		50		20	1.24		50		20			50	
30	0.50	3.580	60		30	1.28	7.160	60		30			60	
40	0.53		70		40	1.32		70		40			70	
50	0.56		80		50	1.38		80		50			80	
60	0.57	3.560	90		60	1.41	7.150	90		60			90	
70	0.58		100		70	1.45		100		70			100	
80	0.60		110		80	1.50		110		80			110	
90	0.62	3.570	120		90	1.53		120		90			120	
100	0.65		150		100			150		100			150	
110			180		110			180		110			180	
120			210		120			210		120			210	
Average yield: 3.58			(l/s)		Average yield: 6.92166667					Average yield: #DIV/0!				

DISCHARGE RATE 4			Time	Recovery 4	DISCHARGE RATE 5			Time	Recovery 5	DISCHARGE RATE 6			Time	Recovery
DATE:	30/04/2003		(min)	(m)	DATE:	30/04/2003		(min)	(m)	DATE:	30/04/2003		(min)	(m)
TIME:			1		TIME:			1		TIME:			1	
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	
1			5		1			5		1			5	
2			7		2			7		2			7	
3			10		3			10		3			10	
5			15		5			15		5			15	
7			20		7			20		7			20	
10			30		10			30		10			30	
15			40		15			40		15			40	
20			50		20			50		20			50	
30			60		30			60		30			60	
40			70		40			70		40			70	
50			80		50			80		50			80	
60			90		60			90		60			90	
70			100		70			100		70			100	
80			110		80			110		80			110	
90			120		90			120		90			120	
100			150		100			150		100			150	
110			180		110			180		110			180	
120			210		120			210		120			210	
Average yield: #DIV/0!										Average yield: #DIV/0!				

COMMENTS:	240	150	240	180	300
	300	180	300	210	360
	360	210	360	240	420
	420	240	420	300	480
	480	300	480	360	540
	540	360	540	420	600
	600	420	600	480	660
	660	480	660		
	720		720		
	780		780		
		Average yield:			720

DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(l/s)	(m)	(min)	(m)	(m)	(min)	(m)	(m)	(min)	(m)	(m)
1500	6.12	10.50	3.29	1500			1500			1500		
1560	6.29		3.25	1560			1560			1560		
1620	6.38	10.51	3.18	1620			1620			1620		
1680	6.45		3.14	1680			1680			1680		
1740	6.53	10.50	3.10	1740			1740			1740		
1800	6.62		3.07	1800			1800			1800		
1860	6.68	10.51	3.04	1860			1860			1860		
1920	6.74		3.02	1920			1920			1920		
1980	6.81	10.52	3.00	1980			1980			1980		
2040	6.88		2.97	2040			2040			2040		
2100	6.99	10.50	2.94	2100			2100			2100		
2160	7.06		2.91	2160			2160			2160		
2220	7.14	10.51	2.88	2220			2220			2220		
2280	7.28		2.86	2280			2280			2280		
2340	7.36	10.50	2.83	2340			2340			2340		
2400	7.45		2.80	2400			2400			2400		
2460	7.56	10.51	2.78	2460			2460			2460		
2520	7.60		2.75	2520			2520			2520		
2580	7.64	10.50	2.73	2580			2580			2580		
2640	7.70		2.71	2640			2640			2640		
2700	7.76	10.51	2.69	2700			2700			2700		
2760	7.80		2.65	2760			2760			2760		
2820	7.86	10.50	2.62	2820			2820			2820		
2880	7.91		2.59	2880			2880			2880		

DESCRIPTION:	QUANTITY:	UNIT:
ESTABLISHMENT	0	Sum
INTER HOLE MOVE > 10 km	20	Km.
FROM: SITE NAME: BASE		
BOREHOLE No:		
INTER HOLE MOVE < 10 km:		No.
REMOVAL AND RE-ERECTION OF PUMP HOUSE:	1	No.
REMOVAL OF EXISTING EQUIPMENT:	1	No.
RE-INSTALLATION OF EXISTING EQUIPMENT:	1	No.
WORK TIME RATE (REPAIRS):	0	Hour
STANDING TIME:	0	Hour
LATITUDE: S 31 47' 01.8"	LONGITUDE: E 028 16' 26.1"	

DESCRIPTION:	QUANTITY:	UNIT:
STRAIGHTNESS TEST:	0	No.
VERTICALITY TEST:	0	No.
CASING DETECTION:	1	No.
STEEL BOREHOLE COVER:	1	No.
BOREHOLE MARKING:	1	No.
SITE CLEANING / FINISHING:	1	No.
REPORTING & DATA RECORDING:	1	No.
SLUG TEST:	0	No.
LAYFLAT (m):	100	m
BOREHOLE DEPTH AFTER TEST:	50.28	m
BOREHOLE WATERLEVEL AFTER TEST:	10.12	m


TEST DESCRIPTION	STEP							TOTAL:		RECOVERY:	
		1	2	3	4	5	6	(min)	(hrs)	(m)	(min)
CALIBRATION TEST:											
TEST DURATION (Minutes)		15	15	15	15	15	15	90	1.50	0.00	
TEST YIELD (l/s)		1.51	2.05	4.02	6.18	7.97	10.12	MAXIMUM (l/s) 10.1			
DRAWDOWN (m)		0.33	0.45	0.90	1.16	1.52	1.77	MAXIMUM (m) 1.8			
MULTI-RATE / STEP DRAWDOWN:											
TEST DURATION (Minutes)		100	90					190	3.17	0.00	
TEST YIELD (l/s)		3.58	6.92					MAXIMUM (l/s) 6.9			
DRAWDOWN (m)		0.7	1.53					MAXIMUM (m) 1.5			

RECOVERY TEST			
TIME TOTAL (hrs):		48.00	
Cal	Steps	CD	Total
0	0	2880	2880
DRAWDOWN TOTALS (CD):			
AVAILABLE	UTIL-	%	
	ISED		
37.3	7.91	21.22	


CONSTANT DISCHARGE TEST	TEST DURATION		TEST YIELD	DRAWDOWN	RECOVERY:			
	(min)	(hrs)	(l/s)	(m)	(m)	%	(min)	(hrs)
	2880	48.00	10.39	7.91	2.59	67.26	2880	48.00
OBSERVATION BOREHOLES:	No.	720	1440	2880	>2880 (min)		TOTAL:	
	of boreholes	(min)	(min)	(min)	nr.	Time	(min)	(hrs)
							0	0.00

BOREHOLE NUMBER: EC/T12/008


CALIBRATION TEST AND RECOVERY



STEPPED DISCHARGE TEST AND RECOVERY



CONSTANT DISCHARGE TEST AND RECOVERY



TEST INFORMATION

Date tested	03/05/2003	Water level (mbgl)	7.53	Depth of pump (mbgl)	44.8
CD duration	2880	CD discharge rate	10.39	CD drawdown	7.91
Available drawdown (m)	37.27	% Recovery after CD	67	% after 2880 min	

CALIBRATION TEST AND RECOVERY

BOREHOLE NO. :	EC/T12/008	PROJECT:	ENCGOBO FEASIBILITY STUDY		
ALTERNATIVE NO. :		SITE NAME:	CLARKBURY		
ALTERNATIVE NO. :		CLIENT:	CHRIS HANI DISTRICT MUNICIPALITY		
BOREHOLE DEPTH (mbdl):	50.28	CASING DEPTH (mbdl):	26.15	PUMP TYPE USED:	P 100
DEPTH OF PUMP (mbdl):	44.50	CASING HEIGHT (magl):	0.45	OPERATOR:	PIETER MUNYAI
PUMP INLET DIAMETER (mm):	100.00	CASING ID (mm):	170.00	CONTRACTOR:	AB PUMPS
STATIC WATER LEVEL (mbdl):	7.53	DATUM LEVEL (magl):	0.17	SUPERVISOR:	H VORSTER

DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3				
DATE:	TIME:				DATE:	TIME:				DATE:	TIME:			
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)
29/04/03	14H50				29/04/03	15H05				29/04/03	15H20			
1	0.06		1		1	0.10	0.65	1		1	0.19		1	
2	0.06		2		2	0.11		2		2	0.22	1.6	2	
3	0.07	0.45	3		3	0.12	0.72	3		3	0.26		3	
5	0.07		5		5	0.14		5		5	0.29	1.63	5	
7	0.08	0.46	7		7	0.14	0.73	7		7	0.32		7	
10	0.09	0.45	10		10	0.16		10		10	0.34	1.62	10	
15	0.09		15		15	0.17		15		15	0.36		15	

EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20
TYPE OF RESERVOIR:	30	TYPE OF ENCLOSURE:	30	PRESSURE GAUGE MANUFACTURER:	30
	40		40		40
RESERVOIR SIZE:	50	MATERIAL OF ENCLOSURE:	50	GAUGE READING (KpA):	60
	60		60		70
RESERVOIR CONITION:	70	CONDITION OF ENCLOSURE:	70	MONITORING FACILITY:	80
	80		80		90
STAND HEIGHT (m):	90	WATER METER MANUFACTURER:	90	MAINTAINED:	100
	100		100		110
	110	WATER METER READING:	110		120
	120		120		150
	150		150		

DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6				
DATE:	TIME:				DATE:	TIME:				DATE:	TIME:			
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)
29/04/03	15H35				29/04/03	15H50				29/04/03	16H05			
1	0.38		1		1	0.72		1		1	1.22		1	0.84
2	0.45		2		2	0.79	5.5	2		2	1.26		2	0.70
3	0.48	3	3		3	0.84		3		3	1.27	7.47	3	0.64
5	0.52		5		5	0.93	5.52	5		5	1.29		5	0.52
7	0.59	3.01	7		7	1.15		7		7	1.31	7.49	7	0.46
10	0.64		10		10	1.18	5.51	10		10	1.38		10	0.41
15	0.69		15		15	1.18		15		15	1.43		15	0.33

EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20
PUMP TYPE:	30	TYPE OF POWER:	30	TYPE OF RISER:	30
HANDPUMP	40		40		40
PUMP MANUFACTURER:	50	ENGINE MANUFACTURER:	50	CLASS OF RISER:	50
	60		60		60
PUMP SERIAL No:	70	ENGINE MODEL:	70	DIAMETER OF RISER (mm):	70
242 HP37	80		80		80
PUMP PULLEY DIAMETER (mm):	90	ENGINE SERIAL No:	90	CONDITION OF RISER:	90
	100		100		100
PUMP INTAKE DEPTH (m):	110	ENGINE PULLEY DIAMETER (mm):	110	SHAFT DIAMETER (mm):	110
39.68	120		120		120
PUMP RPM:	150	POWER RATING (kW):	150	ELEMENT DIAMETER (mm):	150
					180
PUMP CONDITION:		ENGINE CONDITION:		ELEMENT STROKE (mm):	210
					240

COMMENTS:	300
	420
	480
	540
	600
DID THE BOREHOLE PRODUCE ANY SILT / SAND / GRAVEL ?	660

STEPPED DISCHARGE TEST AND RECOVERY

BOREHOLE NO. :	EC/T12/008	PROJECT:	ENCGOBO FEASIBILITY STUDY
ALTERNATIVE NO. :	0	SITE NAME:	CLARKBURY
ALTERNATIVE NO. :	0	CLIENT:	CHRIS HANI DISTRICT MUNICIPALITY

BOREHOLE DEPTH (mbdl):	50.28	CASING DEPTH (mbdl):	26.15	PUMP TYPE USED:	P 100
DEPTH OF PUMP (mbdl):	44.50	CASING HEIGHT (magl):	0.45	OPERATOR:	PIETER MUNYAI
PUMP INLET DIAMETER (mm):	100.000	CASING ID (mm):	170.000	CONTRACTOR:	AB PUMPS
STATIC WATER LEVEL (mbdl):	7.53	DATUM LEVEL (magl):	0.17		

DISCHARGE RATE 1			Time	Recovery 1	DISCHARGE RATE 2			Time	Recovery 2	DISCHARGE RATE 3			Time	Recovery
DATE:	30/04/2003		(min)	(m)	DATE:	30/04/2003		(min)	(m)	DATE:	30/04/2003		(min)	(m)
TIME:	11H50		1		TIME:	13H30		1		TIME:			1	
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	
1	0.17		5		1	0.74	5.740	5		1			5	
2	0.19		7		2	0.77	7.160	7		2			7	
3	0.23		10		3	0.83		10		3			10	
5	0.28	3.590	15		5	0.94	7.150	15		4			15	
7	0.35		20		7	1.02		20		7			20	
10	0.41	3.600	30		10	1.09	7.170	30		10			30	
15	0.45		40		15	1.16		40		15			40	
20	0.47		50		20	1.24		50		20			50	
30	0.50	3.580	60		30	1.28	7.160	60		30			60	
40	0.53		70		40	1.32		70		40			70	
50	0.56		80		50	1.38		80		50			80	
60	0.57	3.560	90		60	1.41	7.150	90		60			90	
70	0.58		100		70	1.45		100		70			100	
80	0.60		110		80	1.50		110		80			110	
90	0.62	3.570	120		90	1.53		120		90			120	
100	0.65		150		100			150		100			150	
110			180		110			180		110			180	
120			210		120			210		120			210	
Average yield: 3.58			(l/s)		Average yield: 6.92166667					Average yield: #DIV/0!				

DISCHARGE RATE 4			Time	Recovery 4	DISCHARGE RATE 5			Time	Recovery 5	DISCHARGE RATE 6			Time	Recovery
DATE:	30/04/2003		(min)	(m)	DATE:	30/04/2003		(min)	(m)	DATE:	30/04/2003		(min)	(m)
TIME:			1		TIME:			1		TIME:			1	
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	
1			5		1			5		1			5	
2			7		2			7		2			7	
3			10		3			10		3			10	
5			15		5			15		5			15	
7			20		7			20		7			20	
10			30		10			30		10			30	
15			40		15			40		15			40	
20			50		20			50		20			50	
30			60		30			60		30			60	
40			70		40			70		40			70	
50			80		50			80		50			80	
60			90		60			90		60			90	
70			100		70			100		70			100	
80			110		80			110		80			110	
90			120		90			120		90			120	
100			150		100			150		100			150	
110			180		110			180		110			180	
120			210		120			210		120			210	
Average yield: #DIV/0!										Average yield: #DIV/0!				

COMMENTS:		300		300
		360		360
		420		420
		480		480
		540		540
		600		600
		660		660
		780		780
Average yield:				720


DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(l/s)	(m)	(min)	(m)	(m)	(min)	(m)	(m)	(min)	(m)	(m)
1500	6.12	10.50	3.29	1500			1500			1500		
1560	6.29		3.25	1560			1560			1560		
1620	6.38	10.51	3.18	1620			1620			1620		
1680	6.45		3.14	1680			1680			1680		
1740	6.53	10.50	3.10	1740			1740			1740		
1800	6.62		3.07	1800			1800			1800		
1860	6.68	10.51	3.04	1860			1860			1860		
1920	6.74		3.02	1920			1920			1920		
1980	6.81	10.52	3.00	1980			1980			1980		
2040	6.88		2.97	2040			2040			2040		
2100	6.99	10.50	2.94	2100			2100			2100		
2160	7.06		2.91	2160			2160			2160		
2220	7.14	10.51	2.88	2220			2220			2220		
2280	7.28		2.86	2280			2280			2280		
2340	7.36	10.50	2.83	2340			2340			2340		
2400	7.45		2.80	2400			2400			2400		
2460	7.56	10.51	2.78	2460			2460			2460		
2520	7.60		2.75	2520			2520			2520		
2580	7.64	10.50	2.73	2580			2580			2580		
2640	7.70		2.71	2640			2640			2640		
2700	7.76	10.51	2.69	2700			2700			2700		
2760	7.80		2.65	2760			2760			2760		
2820	7.86	10.50	2.62	2820			2820			2820		
2880	7.91		2.59	2880			2880			2880		

DESCRIPTION:	QUANTITY:	UNIT:	S U M M A R Y	DESCRIPTION:	QUANTITY:	UNIT:
ESTABLISHMENT	0	Sum		STRAIGHTNESS TEST:	0	No
INTER HOLE MOVE > 10 km	20	Km.		VERTICALITY TEST:	0	No
FROM: SITE NAME: BASE				CASING DETECTION:	1	No
BOREHOLE No:				STEEL BOREHOLE COVER:	1	No
INTER HOLE MOVE < 10 km:		No		BOREHOLE MARKING:	1	No
REMOVAL AND RE-ERECTION OF PUMP HOUSE:	1	No		SITE CLEANING / FINISHING:	1	No
REMOVAL OF EXISTING EQUIPMENT:	1	No		REPORTING & DATA RECORDING:	1	No
RE-INSTALLATION OF EXISTING EQUIPMENT:	1	No		SLUG TEST:	0	No
WORK TIME RATE (REPAIRS):	0	Hour		LAYFLAT (m):	100	m
STANDING TIME:	0	Hour	BOREHOLE DEPTH AFTER TEST:	50.28	m	
LATITUDE: S 31 47' 01.8"	LONGITUDE: E 028 16' 26.1"		BOREHOLE WATERLEVEL AFTER TEST:	10.12	m	


TEST DESCRIPTION	STEP	1	2	3	4	5	6	TOTAL:	RECOVERY:	RECOVERY TEST					
								(min) (hrs)	(m) (min)	TIME TOTAL (hrs): 49.67					
CALIBRATION TEST:										Cal	Steps	CD	Total		
TEST DURATION (Minutes)		15	15	15	15	15	15	90	1.50	0.19		100	0	2880	2880
TEST YIELD (l/s)		0.45	0.70	1.62	3.01	5.51	7.48	MAXIMUM (l/s)	7.5	DRAWDOWN TOTALS (CD):					
DRAWDOWN (m)		0.09	0.17	0.36	0.69	1.18	1.43	MAXIMUM (m)	1.4	AVAILABLE	UTIL-	%			
MULTI-RATE / STEP DRAWDOWN:										37.0	7.91	21.40			
TEST DURATION (Minutes)		100	90					190	3.17	0.30					
TEST YIELD (l/s)		3.58	6.92					MAXIMUM (l/s)	6.9						
DRAWDOWN (m)		0.7	1.53					MAXIMUM (m)	1.5						
CONSTANT DISCHARGE TEST	TEST DURATION		TEST YIELD		DRAWDOWN		RECOVERY:								
	(min)	(hrs)	(l/s)	(m)	(m)	(m)	%	(min)	(hrs)						
	2880	48.00	10.39	7.91	2.59	67.06	2880	48.00							
OBSERVATION BOREHOLES:	No.	720	1440	2880	>2880 (min)		TOTAL:								
	of boreholes	(min)	(min)	(min)	nr.	Time	(min)	(hrs)							
							0	0.00							

BOREHOLE NUMBER: ECT/12/008


CALIBRATION TEST AND RECOVERY



STEPPED DISCHARGE TEST AND RECOVERY



CONSTANT DISCHARGE TEST AND RECOVERY



TEST INFORMATION

Date tested	03/05/2003	Water level (mbgl)	7.53	Depth of pump (mbgl)	44.5
CD duration	2880	CD discharge rate	10.39	CD drawdown	7.91
Available drawdown (m)	36.97	% Recovery after CD	67	% after 2880 min	

CALIBRATION TEST AND RECOVERY

BOREHOLE NO. :		EC/T12/009		PROJECT:		ENCGOBO FEASIBILITY STUDY					
ALTERNATIVE NO. :				SITE NAME:		TYENI					
ALTERNATIVE NO. :				CLIENT:		CHRIS HANI DISTRICT MUNICIPALITY					
BOREHOLE DEPTH (mbdl):		69.88		CASING DEPTH (mbdl):		11.07		PUMP TYPE USED:		P 75 H	
DEPTH OF PUMP (mbdl):		38.50		CASING HEIGHT (magl):		0.32		OPERATOR:		JAN MUDAU	
PUMP INLET DIAMETER (mm):		100.00		CASING ID (mm):		180.00		CONTRACTOR:		AB PUMPS	
STATIC WATER LEVEL (mbdl):		9.54		DATUM LEVEL (magl):		0.30		SUPERVISOR:		H VORSTER	

DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3				
DATE:	TIME:				DATE:	TIME:				DATE:	TIME:			
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)
1			1		1			1		1			1	
2			2		2			2		2			2	
3			3		3			3		3			3	
5			5		5			5		5			5	
7			7		7			7		7			7	
10			10		10			10		10			10	
15			15		15			15		15			15	

EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20
TYPE OF RESERVOIR:	30	TYPE OF ENCLOSURE:	30	PRESSURE GAUGE MANUFACTURER:	30
	40		40		40
RESERVOIR SIZE:	50	MATERIAL OF ENCLOSURE:	50		50
	60		60	GAUGE READING (KpA):	60
RESERVOIR CONITION:	70	CONDITION OF ENCLOSURE:	70		70
	80		80	MONITORING FACILITY:	80
STAND HEIGHT (m):	90	WATER METER MANUFACTURER:	90		90
	100		100	MAINTAINED:	100
	110	WATER METER READING:	110		110
	120		120		120
	150		150		150

DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6				
DATE:	TIME:				DATE:	TIME:				DATE:	TIME:			
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)
1			1		1			1		1			1	
2			2		2			2		2			2	
3			3		3			3		3			3	
5			5		5			5		5			5	
7			7		7			7		7			7	
10			10		10			10		10			10	
15			15		15			15		15			15	

EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20
PUMP TYPE:	30	TYPE OF POWER:	30	TYPE OF RISER:	30
	40		40		40
PUMP MANUFACTURER:	50	ENGINE MANUFACTURER:	50	CLASS OF RISER:	50
	60		60		60
PUMP SERIAL No:	70	ENGINE MODEL:	70	DIAMETER OF RISER (mm):	70
	80		80		80
PUMP PULLEY DIAMETER (mm):	90	ENGINE SERIAL No:	90	CONDITION OF RISER:	90
	100		100		100
PUMP INTAKE DEPTH (m):	110	ENGINE PULLEY DIAMETER (mm):	110	SHAFT DIAMETER (mm):	110
	120		120		120
PUMP RPM:	150	POWER RATING (kW):	150	ELEMENT DIAMETER (mm):	150
					180
PUMP CONDITION:		ENGINE CONDITION:		ELEMENT STROKE (mm):	210
					240
COMMENTS:					300
					420
					480
					540
					600
DID THE BOREHOLE PRODUCE ANY SILT / SAND / GRAVEL ?					660

STEPPED DISCHARGE TEST AND RECOVERY

BOREHOLE NO. :	EC/T12/009	PROJECT:	ENCGOBO FEASIBILITY STUDY		
ALTERNATIVE NO. :	0	SITE NAME:	TYENI		
ALTERNATIVE NO. :	0	CLIENT:	CHRIS HANI DISTRICT MUNICIPALITY		
BOREHOLE DEPTH (mbdl):	69.88	CASING DEPTH (mbdl):	11.07	PUMP TYPE USED:	P 75 H
DEPTH OF PUMP (mbdl):	38.50	CASING HEIGHT (magl):	0.32	OPERATOR:	JAN MUDAU
PUMP INLET DIAMETER (mm):	100.000	CASING ID (mm):	180.000	CONTRACTOR:	AB PUMPS
STATIC WATER LEVEL (mbdl):	9.54	DATUM LEVEL (magl):	0.30		

DISCHARGE RATE 1			Time	Recovery 1	DISCHARGE RATE 2			Time	Recovery 2	DISCHARGE RATE 3			Time	Recovery 3
DATE:	03/06/2003		(min)	(m)	DATE:	03/06/2003		(min)	(m)	DATE:	03/06/2003		(min)	(m)
TIME:	11H40		1		TIME:	13H20		1		TIME:	15H00		1	
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	
1	0.57		5		1	2.61		5		1	5.67		5	
2	0.81	0.220	7		2	2.94		7		2	6.18		7	
3	0.97		10		3	3.30	0.620	10		3	7.14	1.530	10	
5	1.16	0.320	15		5	3.52		15		4	8.89	1.450	15	
7	1.33		20		7	3.68	0.600	20		7	9.94	1.310	20	
10	1.53	0.340	30		10	4.14		30		10	10.66		30	
15	1.70		40		15	4.40	0.640	40		15	11.24	1.330	40	
20	1.80	0.310	50		20	4.60		50		20	11.85		50	
30	1.92		60		30	4.74	0.630	60		30	12.68	1.360	60	
40	2.01	0.330	70		40	4.83		70		40	13.45		70	
50	2.09		80		50	4.92	0.610	80		50	13.94	1.340	80	
60	2.13	0.330	90		60	4.96	0.590	90		60	14.24		90	
70	2.16		100		70	5.10	0.630	100		70	14.41	1.350	100	
80	2.19	0.320	110		80	5.16		110		80	14.60		110	
90	2.23		120		90	5.22	0.630	120		90	14.79	1.320	120	
100	2.29	0.340	150		100	5.33		150		100	15.02		150	
110			180		110			180		110			180	
120			210		120			210		120			210	
Average yield: 0.31375			(l/s)		Average yield: 0.61875					Average yield: 1.37375				

DISCHARGE RATE 4			Time	Recovery 4	DISCHARGE RATE 5			Time	Recovery 5	DISCHARGE RATE 6			Time	Recovery
DATE:	03/06/2003		(min)	(m)	DATE:	03/06/2003		(min)	(m)	DATE:	03/06/2003		(min)	(m)
TIME:	16H40		1		TIME:			1		TIME:			1	24.69
Time	Drawdown	Yield	2		Time	Drawdown		2		Time	Drawdown	Yield	2	21.25
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	18.56
1	16.05		5		1			5		1			5	14.66
2	17.08		7		2			7		2			7	11.29
3	19.44	2.70	10		3			10		3			10	6.47
5	23.36	2.65	15		5			15		5			15	3.50
7	25.74		20		7			20		7			20	2.68
10	28.89	2.63	30		10			30		10			30	2.08
15	28.89	PI 2.24	40		15			40		15			40	1.70
20	28.89	PI 2.10	50		20			50		20			50	1.45
30	28.89	PI 2.03	60		30			60		30			60	1.32
40			70		40			70		40			70	1.15
50			80		50			80		50			80	1.02
60			90		60			90		60			90	0.94
70			100		70			100		70			100	0.87
80			110		80			110		80			110	0.81
90			120		90			120		90			120	0.75
100			150		100			150		100			150	0.62
110			180		110			180		110			180	0.53
120			210		120			210		120			210	0.47
Average yield: 2.66													240	0.42

COMMENTS:	300	180	300	0.34
	360	210	360	0.26
	420	240	420	
	480	300	480	
	540	360	540	
	600	420	600	
	660	480	660	
	720		720	
	780		780	
		Average yield:		

DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(l/s)	(m)	(min)	(m)	(m)	(min)	(m)	(m)	(min)	(m)	(m)
1500				1500			1500			1500		
1560				1560			1560			1560		
1620				1620			1620			1620		
1680				1680			1680			1680		
1740				1740			1740			1740		
1800				1800			1800			1800		
1860				1860			1860			1860		
1920				1920			1920			1920		
1980				1980			1980			1980		
2040				2040			2040			2040		
2100				2100			2100			2100		
2160				2160			2160			2160		
2220				2220			2220			2220		
2280				2280			2280			2280		
2340				2340			2340			2340		
2400				2400			2400			2400		
2460				2460			2460			2460		
2520				2520			2520			2520		
2580				2580			2580			2580		
2640				2640			2640			2640		
2700				2700			2700			2700		
2750				2760			2760			2760		
2820				2820			2820			2820		
2880				2880			2880			2880		

DESCRIPTION:	QUANTITY:	UNIT:
ESTABLISHMENT	0	Sum
INTER HOLE MOVE > 10 km	0	Km.
FROM: SITE NAME:		
BOREHOLE No:		
INTER HOLE MOVE < 10 km:	1	No.
REMOVAL AND RE-ERECTION OF PUMP HOUSE:	0	No.
REMOVAL OF EXISTING EQUIPMENT:	0	No.
RE-INSTALLATION OF EXISTING EQUIPMENT:	0	No.
WORK TIME RATE (REPAIRS):	0	Hour
STANDING TIME:	0	Hour
LATITUDE:		
LONGITUDE:		

DESCRIPTION:	QUANTITY:	UNIT:
STRAIGHTNESS TEST:	0	No.
VERTICALITY TEST:	0	No.
CASING DETECTION:	1	No.
STEEL BOREHOLE COVER:	1	No.
BOREHOLE MARKING:	1	No.
SITE CLEANING / FINISHING:	1	No.
REPORTING & DATA RECORDING:	1	No.
SLUG TEST:	0	No.
LAYFLAT (m):	100	m
BOREHOLE DEPTH AFTER TEST:	69.86	m
BOREHOLE WATERLEVEL AFTER TEST:	9.02	m


TEST DESCRIPTION	STEP	1	2	3	4	5	6	TOTAL:	RECOVERY:
								(min) (hrs)	(m) (min)
CALIBRATION TEST:								0	0.00
TEST DURATION (Minutes)									0.00
TEST YIELD (l/s)								MAXIMUM (l/s)	0.0
DRAWDOWN (m)								MAXIMUM (m)	
MULTI-RATE / STEP DRAWDOWN:									
TEST DURATION (Minutes)	100	100	100	10				310	5.17
TEST YIELD (l/s)	0.31	0.62	1.37	2.66				MAXIMUM (l/s)	2.7
DRAWDOWN (m)	2.3	5.33	15.02	28.99	0.00			MAXIMUM (m)	28.9

RECOVERY TEST			
TIME TOTAL (hrs):		30.00	
Cal	Steps	CD	Total
0	360	1440	1800
DRAWDOWN TOTALS (CD):			
AVAILABLE	UTIL-	%	
	ISED		
29.0	5.46	22.31	


CONSTANT DISCHARGE TEST	TEST DURATION		TEST YIELD	DRAWDOWN	RECOVERY:			
	(min)	(hrs)	(l/s)	(m)	(m)	%	(min)	(hrs)
	1440	24.00	0.54	5.46	0.12	98.14	1440	24.00
OBSERVATION BOREHOLES:	No.	720	1440	2880	>2880 (min)		TOTAL:	
	of boreholes	(min)	(min)	(min)	nr.	Time	(min)	(hrs)
							0	0.00

BOREHOLE NUMBER: EC/T12/009


CALIBRATION TEST AND RECOVERY



STEPPED DISCHARGE TEST AND RECOVERY



CONSTANT DISCHARGE TEST AND RECOVERY



TEST INFORMATION

Date tested	04/06/2003	Water level (mbgl)	9.54	Depth of pump (mbgl)	38.5
CD duration	1440	CD discharge rate	0.64	CD drawdown	6.46
Available drawdown (m)	28.96	% Recovery after CD	98	% after	1440 min

CALIBRATION TEST AND RECOVERY

BOREHOLE NO. :	T 32314	PROJECT:	ENCGOBO FEASIBILITY STUDY
ALTERNATIVE NO. :		SITE NAME:	NGQOBONCO
ALTERNATIVE NO. :		CLIENT:	CHRIS HANI DISTRICT MUNICIPALITY
BOREHOLE DEPTH (m bdl):	34.19	CASING DEPTH (m bdl):	3.85
DEPTH OF PUMP (m bdl):	27.00	CASING HEIGHT (magl):	0.30
PUMP INLET DIAMETER (mm):	100.00	CASING ID (mm):	165.00
STATIC WATER LEVEL (m bdl):	3.74	DATUM LEVEL (magl):	0.28
		PUMP TYPE USED:	BP 22
		OPERATOR:	PIETER MUNYAI
		CONTRACTOR:	AB PUMPS
		SUPERVISOR:	H VORSTER

DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3										
DATE:	02/05/2003		TIME:		16H05		DATE:	02/05/2003		TIME:		16H20		DATE:	02/05/2003		TIME:		16H35	
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	
1	0.88		1		1	1.58		1		1	2.42	0.65	1							
2	0.91		2		2	1.67	0.4	2		2	2.66		2							
3	1.17		3		3	1.83		3		3	2.93	0.84	3							
5	1.33	0.27	5		5	2.00	0.41	5		5	3.24		5							
7	1.36		7		7	2.04		7		7	4.55	0.85	7							
10	1.38	0.25	10		10	2.10	0.42	10		10	4.98		10							
15	1.40		15		15	2.22		15		15	5.40		15							

EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20
TYPE OF RESERVOIR:	30	TYPE OF ENCLOSURE:	30	PRESSURE GAUGE MANUFAC	30
	40		40	TURER:	40
RESERVOIR SIZE:	50	MATERIAL OF ENCLOSURE:	50		50
	60		60	GAUGE READING (KpA):	60
RESERVOIR CONITION:	70	CONDITION OF ENCLOSURE:	70		70
	80		80	MONITORING FACILITY:	80
STAND HEIGHT (m):	90	WATER METER MANUFACTURER:	90		90
	100		100	MAINTAINED:	100
	110	WATER METER READING:	110		110
	120		120		120
	150		150		150

DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6										
DATE:	02/05/2003		TIME:		16H50		DATE:	02/05/2003		TIME:		17H05		DATE:			TIME:			
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	
1	5.65		1		1	11.69		1		1			1	16.95						
2	5.82	0.93	2		2	12.24	2.09	2		2			2	11.47						
3	5.97		3		3	13.56	2.71	3		3			3	6.64						
5	6.09	1.61	5		5	16.25		5		5			5	4.34						
7	6.50		7		7	21.47		7		7			7	2.97						
10	7.61	1.64	10		10	24.13	2.12	10		10			10	1.33						
15	11.26		15		15	24.13	PI 2.19	15		15			15	1.15						

EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20
PUMP TYPE:	30	TYPE OF POWER:	30	TYPE OF RISER:	30
WINDMILL	40		40	CYLINDER	40
PUMP MANUFACTURER:	50	ENGINE MANUFACTURER:	50	CLASS OF RISER:	50
	60		60		60
PUMP SERIAL No:	70	ENGINE MODEL:	70	DIAMETER OF RISER (mm):	70
MW 200 12T014KT198	80		80	3 08	80
PUMP PULLEY DIAMETER (mm):	90	ENGINE SERIAL No:	90	CONDITION OF RISER:	90
	100		100	BAD	100
PUMP INTAKE DEPTH (m):	110	ENGINE PULLEY DIAMETER (mm):	110	SHAFT DIAMETER (mm):	110
24 65	120		120	90	120
PUMP RPM:	150	POWER RATING (kW):	150	ELEMENT DIAMETER (mm):	150
					180
PUMP CONDITION:		ENGINE CONDITION:		ELEMENT STROKE (mm):	210
					240

COMMENTS:	300
	420
	480
	540
	600
DID THE BOREHOLE PRODUCE ANY SILT / SAND / GRAVEL ?	660

STEPPED DISCHARGE TEST AND RECOVERY

BOREHOLE NO.:	T 32314	PROJECT:	ENCGOBO FEASIBILITY STUDY		
ALTERNATIVE NO.:	0	SITE NAME:	NGQOBONCO		
ALTERNATIVE NO.:	0	CLIENT:	CHRIS HANI DISTRICT MUNICIPALITY		
BOREHOLE DEPTH (mbdl):	34.19	CASING DEPTH (mbdl):	3.85	PUMP TYPE USED:	BP 22
DEPTH OF PUMP (mbdl):	27.00	CASING HEIGHT (magl):	0.30	OPERATOR:	PIETER MUNYAI
PUMP INLET DIAMETER (mm):	100.000	CASING ID (mm):	165.000	CONTRACTOR:	AB PUMPS
STATIC WATER LEVEL (mbdl):	3.74	DATUM LEVEL (magl):	0.28		

DISCHARGE RATE 1			Time	Recovery 1	DISCHARGE RATE 2			Time	Recovery 2	DISCHARGE RATE 3			Time	Recovery 3
DATE:	03/05/2003		(min)	(m)	DATE:	03/05/2003		(min)	(m)	DATE:	03/05/2003		(min)	(m)
TIME:	06H30		1		TIME:	08H10		1		TIME:	09H50		1	
Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield
(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)
1	1.18		5	3.11		1	5.61		5			5		
2	1.77	0.450	7	3.28		2	6.69	1.160	7			7		
3	1.98		10	3.33	0.610	3	7.40		10			10		
5	2.00	0.350	15	3.43		4	7.87	1.250	15			15		
7	2.01		20	3.52		7	8.24		20			20		
10	2.02	0.340	30	3.55		10	8.58		30			30		
15	2.09		40	3.60	0.600	15	8.93	1.240	40			40		
20	2.15	0.340	50	3.63		20	9.11		50			50		
30	2.32		60	3.67	0.600	30	9.33	1.260	60			60		
40	2.52	0.350	70	3.75		40	9.45		70			70		
50	2.61		80	3.80		50	9.60	1.250	80			80		
60	2.65	0.330	90	3.84	0.610	60	9.80		90			90		
70	2.73		100	3.87		70	9.87		100			100		
80	2.75		110	3.88		80	9.90	1.260	110			110		
90	2.77	0.360	120	3.90	0.620	90	9.95		120			120		
100	2.78		150	3.93		100	9.97		150			150		
110			180			180			180			180		
120			210			210			210			210		
Average yield: 0.36			(l/s)	Average yield: 0.608			Average yield: 1.23666667							

DISCHARGE RATE 4			Time	Recovery 4	DISCHARGE RATE 5			Time	Recovery 5	DISCHARGE RATE 6			Time	Recovery
DATE:	03/05/2003		(min)	(m)	DATE:	03/05/2003		(min)	(m)	DATE:	03/05/2003		(min)	(m)
TIME:			1		TIME:			1		TIME:			1	6.44
Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield	Time	Drawdown	Yield
(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)	(min)	(m)	(l/s)
2			2			2			2			2		4.65
3			3			3			3			3		3.50
5			5			5			5			5		2.46
7			7			7			7			7		2.04
10			10			10			10			10		1.54
15			15			15			15			15		1.30
20			20			20			20			20		1.13
30			30			30			30			30		0.87
40			40			40			40			40		0.74
50			50			50			50			50		0.60
60			60			60			60			60		0.54
70			70			70			70			70		0.45
80			80			80			80			80		0.40
90			90			90			90			90		0.36
100			100			100			100			100		0.34
110			110			110			110			110		0.33
120			120			120			120			120		0.29
150			150			150			150			150		0.22
180			180			180			180			180		
210			210			210			210			210		
Average yield: #DIV/0!														

COMMENTS:	300	180	300
	360	210	360
	420	240	420
	480	300	480
	540	360	540
	600	420	600
	660	480	660
	720		
	780		
		Average yield	720

DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(l/s)	(m)	(min)	(m)	(m)	(min)	(m)	(m)	(min)	(m)	(m)
1500				1500			1500			1500		
1560				1560			1560			1560		
1620				1620			1620			1620		
1680				1680			1680			1680		
1740				1740			1740			1740		
1800				1800			1800			1800		
1860				1860			1860			1860		
1920				1920			1920			1920		
1980				1980			1980			1980		
2040				2040			2040			2040		
2100				2100			2100			2100		
2160				2160			2160			2160		
2220				2220			2220			2220		
2280				2280			2280			2280		
2340				2340			2340			2340		
2400				2400			2400			2400		
2460				2460			2460			2460		
2520				2520			2520			2520		
2580				2580			2580			2580		
2640				2640			2640			2640		
2700				2700			2700			2700		
2760				2760			2760			2760		
2820				2820			2820			2820		
2880				2880			2880			2880		

DESCRIPTION:	QUANTITY:	UNIT:
ESTABLISHMENT		Sum
INTER HOLE MOVE > 10 km	21	Km.
FROM: SITE NAME: CLAREBURY		
BOREHOLE No:		
INTER HOLE MOVE < 10 km:		No.
REMOVAL AND RE-ERECTION OF PUMP HOUSE:	1	No.
REMOVAL OF EXISTING EQUIPMENT:	1	No.
RE-INSTALLATION OF EXISTING EQUIPMENT:	1	No.
WORK TIME RATE (REPAIRS):	0	Hour
STANDING TIME:	0	Hour
LATITUDE: S31 32' 40.9"	LONGITUDE: E 028 15' 50.9"	

DESCRIPTION:	QUANTITY:	UNIT:
STRAIGHTNESS TEST:	0	No
VERTICALITY TEST:	0	No
CASING DETECTION:	1	No
STEEL BOREHOLE COVER:	3	No
BOREHOLE MARKING:	1	No
SITE CLEANING / FINISHING:	1	No
REPORTING & DATA RECORDING:	1	No
SLUG TEST:	0	No
LAYFLAT (m):	100	m
BOREHOLE DEPTH AFTER TEST:	34.17	m
BOREHOLE WATERLEVEL AFTER TEST:	3.76	m


TEST DESCRIPTION	STEP	1	2	3	4	5	6	TOTAL:	RECOVERY:
CALIBRATION TEST:								(min) (hrs)	(m) (min)
TEST DURATION (Minutes)		15	15	15	15	10		70 1.17	0.33 70
TEST YIELD (l/s)		0.25	0.41	0.78	1.39	2.31		MAXIMUM (l/s) 2.3	
DRAWDOWN (m)		1.40	2.22	5.40	11.26	24.13		MAXIMUM (m) 24.1	
MULTI-RATE / STEP DRAWDOWN:									
TEST DURATION (Minutes)		100	100	100				300 5.00	0.22 150
TEST YIELD (l/s)		0.36	0.61	1.24				MAXIMUM (l/s) 1.2	
DRAWDOWN (m)		2.8	3.93	9.97				MAXIMUM (m) 10.0	

RECOVERY TEST			
TIME TOTAL (hrs):		25.67	
Cal	Steps	CD	Total
70	150	1320	1540
DRAWDOWN TOTALS (CD):			
AVAILABLE	UTIL-ISED	%	
23.3	8.39	36.07	


CONSTANT DISCHARGE TEST	TEST DURATION		TEST YIELD	DRAWDOWN	RECOVERY:			
	(min)	(hrs)	(l/s)	(m)	(m)	%	(min)	(hrs)
	1440	24.00	0.94	8.39	0.04	99.52	1320	22.00
OBSERVATION BOREHOLES:	No. of boreholes	720	1440	2880	>2880 (min)		TOTAL:	
		(min)	(min)	(min)	nr.	Time	(min)	(hrs)
							3	0.10

BOREHOLE NUMBER: T 32314


CALIBRATION TEST AND RECOVERY



STEPPED DISCHARGE TEST AND RECOVERY



CONSTANT DISCHARGE TEST AND RECOVERY



INFORMATION

Date tested	03/05/2003	Water level (mbgl)	3.74	Depth of pump (mbgl)	27
Duration	1440	CD discharge rate	0.94	CD drawdown	8.39
Stable drawdown (m)	23.26	% Recovery after CD	100	% after	1320 min

CALIBRATION TEST AND RECOVERY

BOREHOLE NO. :	T32333	PROJECT:	ENGOBO FEASIBILITY STUDY
ALTERNATIVE NO. :		SITE NAME:	QOBA JUNIOR PRIMARY SCHOOL
ALTERNATIVE NO. :		CLIENT:	CHRIS HANI DISTRICT MUN
BOREHOLE DEPTH (mbdl):	34.22	CASING DEPTH (mbdl):	PUMP TYPE USED: P 100
DEPTH OF PUMP (mbdl):	32.70	CASING HEIGHT (magl):	OPERATOR: SELAKI
PUMP INLET DIAMETER (mm):	100.00	CASING ID (mm):	CONTRACTOR: AB PUMPS
STATIC WATER LEVEL (mbdl):	1.85	DATUM LEVEL (magl):	SUPERVISOR: H VORSTER

DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3										
DATE:	22/05/2003		TIME:		17H30		DATE:	22/05/2003		TIME:		17H45		DATE:	22/05/2003		TIME:		18H00	
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	
	0.45		1		1	3.24		1		1	5.09		1							
2	0.83	0.46	2		2	3.59	0.86	2		2	5.72	1.49	2							
	1.03		3		3	3.85		3		3	6.15		3							
	1.53		5		5	4.09	1.08	5		5	6.98	1.55	5							
7	1.92	0.45	7		7	4.15		7		7	7.48		7							
10	2.45		10		10	4.30	1.07	10		10	7.73	1.53	10							
5	2.54		15		15	4.43		15		15	7.95		15							

EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20
TYPE OF RESERVOIR:	30	TYPE OF ENCLOSURE:	30	PRESSURE GAUGE MANUFAC	30
RESERVOIR SIZE:	40	MATERIAL OF ENCLOSURE:	40	TURER:	40
RESERVOIR CONITION:	50	CONDITION OF ENCLOSURE:	50	GAUGE READING (KPa):	50
STAND HEIGHT (m):	60	WATER METER MANUFACTURER:	60	MONITORING FACILITY:	60
	70	WATER METER READING:	70		70
	80		80		80
	90		90		90
	100		100	MAINTAINED:	100
	110		110		110
	120		120		120
	150		150		150

DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 6										
DATE:	22/05/2003		TIME:		18H15		DATE:	22/05/2003		TIME:		18H30		DATE:	22/05/2003		TIME:		18H45	
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	
7	8.74		1		1	11.59		1		1	14.76	3.18	1					1	20.76	
2	9.72	2.04	2		2	12.12	2.38	2		2	15.33		2					2	13.60	
	10.38	2.02	3		3	12.49		3		3	19.72	5.1	3					3	8.21	
	10.47		5		5	13.22	2.4	5		5	20.93		5					5	3.87	
7	10.67	2.04	7		7	13.65	2.42	7		7	26.04	5.09	7					7	2.20	
10	10.87		10		10	14.09		10		10	29.45		10					10	1.57	
5	10.91		15		15	14.35		15		15	29.45	PI 3.51	15					15	1.23	

EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20
PUMP TYPE:	30	TYPE OF POWER:	30	TYPE OF RISER:	30
WINDMILL	40	ENGINE MANUFACTURER:	40	CLASS OF RISER:	40
PUMP MANUFACTURER:	50	ENGINE MODEL:	50	DIAMETER OF RISER (mm):	50
PUMP SERIAL No:	60	ENGINE SERIAL No:	60	CONDITION OF RISER:	60
PUMP PULLEY DIAMETER (mm):	70	ENGINE PULLEY DIAMETER (mm):	70	SHAFT DIAMETER (mm):	70
PUMP INTAKE DEPTH (m):	80	POWER RATING (kW):	80	ELEMENT DIAMETER (mm):	80
PUMP RPM:	90	ENGINE CONDITION:	90	ELEMENT STROKE (mm):	90
PUMP CONDITION:	100		100		100
BROKEN	110		110		110
COMMENTS:	120		120		120
	150		150		150
					180
					210
					240
					300
					420
					480
					540
					600
DID THE BOREHOLE PRODUCE ANY SILT / SAND / GRAVEL ?					660

STEPPED DISCHARGE TEST AND RECOVERY

BOREHOLE NO.:	T32333	PROJECT:	ENGCOCO FEASIBILITY STUDY		
ALTERNATIVE NO.:	0	SITE NAME:	QOBA JUNIOR PRIMARY SCHOOL		
ALTERNATIVE NO.:	0	CLIENT:	CHRIS HANI DISTRICT MUN		
BOREHOLE DEPTH (mbdl):	34.22	CASING DEPTH (mbdl):	0.00	PUMP TYPE USED:	P 100
DEPTH OF PUMP (mbdl):	32.70	CASING HEIGHT (magl):	0.00	OPERATOR:	SELAKI
PUMP INLET DIAMETER (mm):	100.000	CASING ID (mm):	0.000	CONTRACTOR:	AB PUMPS
STATIC WATER LEVEL (mbdl):	1.85	DATUM LEVEL (magl):	0.00		

DISCHARGE RATE 1			Time	Recovery 1	DISCHARGE RATE 2			Time	Recovery 2	DISCHARGE RATE 3			Time	Recovery 3	
DATE:	23/05/2003		(min)	(m)	DATE:	23/05/2003		(min)	(m)	DATE:	23/05/2003		(min)	(m)	
TIME:	07H15		1		TIME:	08H55		1		TIME:	10H35		1		
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		
1	1.62		5		1	5.74		5		1	7.64		5		
2	1.74	1.040	7		2	5.98		7		2	10.54	2.090	7		
3	1.89	1.030	10		3	6.09	1.510	10		3	10.77		10		
5	2.27		15		5	6.81		15		4	10.91		15		
7	2.86		20		7	7.36	1.520	20		7	11.34	2.070	20		
10	3.58		30		10	7.69	1.500	30		10	11.79		30		
15	4.19	1.050	40		15	7.90		40		15	12.09		40		
20	4.66	1.040	50		20	7.97		50		20	12.13	2.050	50		
30	4.74		60		30	8.00	1.470	60		30	12.29		60		
40	4.86		70		40	8.12		70		40	12.40		70		
50	4.96		80		50	8.19		80		50	12.45	2.080	80		
60	5.01	1.030	90		60	8.31	1.500	90		60	12.52		90		
70	5.06	1.050	100		70	8.34		100		70	12.63		100		
80	5.09		110		80	8.38		110		80	12.70		110		
90	5.12	1.040	120		90	8.41	1.510	120		90	12.80	2.090	120		
100	5.15		150		100	8.43		150		100	12.84		150		
110			180		110			180		110			180		
120			210		120			210		120			210		
Average yield: 1.04			(l/s)		Average yield: 1.5016667					Average yield: 2.076					
DISCHARGE RATE 4			Time	Recovery 4	DISCHARGE RATE 5			Time	Recovery 5	DISCHARGE RATE 6			Time	Recovery	
DATE:	23/05/2003		(min)	(m)	DATE:	23/05/2003		(min)	(m)	DATE:	23/05/2003		(min)	(m)	
TIME:	12H15		1		TIME:			1		TIME:			1	18.45	
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	13.50	
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	9.11	
1	13.64		5		1			5		1			5	4.76	
3	14.45	2.39	7		2			7		2			7	3.62	
5	14.78		10		3			10		3			10	3.08	
7	15.94	2.58	15		5			15		5			15	2.76	
10	16.77		20		7			20		7			20	2.58	
15	16.92		30		10			30		10			30	2.36	
20	17.27	2.56	40		15			40		15			40	1.97	
30	17.58		50		20			50		20			50	1.84	
40	19.06		60		30			60		30			60	1.73	
50	20.06	2.56	70		40			70		40			70	1.66	
60	20.58		80		50			80		50			80	1.58	
70	21.39	2.57	90		60			90		60			90	1.52	
80	22.05		100		70			100		70			100	1.46	
90	22.57		110		80			110		80			110	1.40	
100	23.38	2.58	120		90			120		90			120	1.35	
110	23.91	2.54	150		100			150		100			150	1.23	
120			180		110			180		110			180	1.14	
			210		120			210		120			210		
Average yield: 2.54															
COMMENTS:													300	180	
													360	210	
													420	240	
													480	300	
													540	360	
													600	420	
													660	480	
													720		
													780		
													Average yield:		720

DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
{min}	{m}	{l/s}	{m}	{min}	{m}	{m}	{min}	{m}	{m}	{min}	{m}	{m}
1500	19.37	2.08	1.30	1500			1500			1500		
1560	19.68		1.27	1560			1560			1560		
1620	19.79	2.04	1.24	1620			1620			1620		
1680	20.21		1.21	1680			1680			1680		
1740	20.42	2.12	1.18	1740			1740			1740		
1800	20.63		1.14	1800			1800			1800		
1860	20.84	2.06	1.11	1860			1860			1860		
1920	20.92		1.08	1920			1920			1920		
1980	21.53	2.08	1.05	1980			1980			1980		
2040	21.92		1.03	2040			2040			2040		
2100	22.09	2.14	1.01	2100			2100			2100		
2160	22.18		0.99	2160			2160			2160		
2220	22.30	2.07	0.97	2220			2220			2220		
2280	22.46		0.95	2280			2280			2280		
2340	22.59	2.11	0.93	2340			2340			2340		
2400	23.45		0.91	2400			2400			2400		
2460	23.73	2.09	0.89	2460			2460			2460		
2520	24.06		0.87	2520			2520			2520		
2580	24.41	2.10	0.85	2580			2580			2580		
2640	24.99		0.83	2640			2640			2640		
2700	25.28	2.07	0.81	2700			2700			2700		
2760	25.34		0.79	2760			2760			2760		
2820	26.72		0.77	2820			2820			2820		
2880	27.52	2.13	0.75	2880			2880			2880		

DESCRIPTION:	QUANTITY:	UNIT:
ESTABLISHMENT	0	Sum
INTER HOLE MOVE > 10 km	35	Km
FROM: SITE NAME:		
BOREHOLE No:		
INTER HOLE MOVE < 10 km:	35	No.
REMOVAL AND RE-ERECTION OF PUMP HOUSE:	1	No.
REMOVAL OF EXISTING EQUIPMENT:	1	No.
RE-INSTALLATION OF EXISTING EQUIPMENT:	1	No.
WORK TIME RATE (REPAIRS):	0	Hour
STANDING TIME:	0	Hour
LATITUDE: S 31° 44' 44.3"	LONGITUDE: E 027° 54' 13.6"	

DESCRIPTION:	QUANTITY:	UNIT:
STRAIGHTNESS TEST:	0	No.
VERTICALITY TEST:	0	No.
CASING DETECTION:	1	No.
STEEL BOREHOLE COVER:	0	No.
BOREHOLE MARKING:	1	No.
SITE CLEANING / FINISHING:	1	No.
REPORTING & DATA RECORDING:	1	No.
SLUG TEST:	0	No.
LAYFLAT (m):	100	m
BOREHOLE DEPTH AFTER TEST:	34.2	m
BOREHOLE WATERLEVEL AFTER TEST:	1.84	m

TEST DESCRIPTION	STEP	1	2	3	4	5	6	TOTAL:	RECOVERY:
CALIBRATION TEST:								(min) (hrs)	(m) (min)
TEST DURATION (Minutes)		15	15	15	15	15	10	85 1.42	0.50 90
TEST YIELD (l/s)		0.46	1.00	1.52	2.03	2.40	4.46	MAXIMUM (l/s) 4.5	
DRAWDOWN (m)		2.54	4.43	7.95	10.91	14.35	29.45	MAXIMUM (m) 29.5	
MULTI-RATE / STEP DRAWDOWN:									
TEST DURATION (Minutes)		100	100	100	100			400 6.67	1.14 180
TEST YIELD (l/s)		1.24	1.50	2.08	2.54			MAXIMUM (l/s) 2.5	
DRAWDOWN (m)		5.2	8.43	12.84	23.91			MAXIMUM (m) 23.9	


RECOVERY TEST			
TIME TOTAL (hrs):		52.50	
Cal	Steps	CD	Total
90	180	2880	3150
DRAWDOWN TOTALS (CD):			
AVAILABLE	UTIL-	%	
	ISED		
30.9	27.50	39.21	

CONSTANT DISCHARGE TEST	TEST DURATION		TEST YIELD	DRAWDOWN	RECOVERY:			
	(min)	(hrs)	(l/s)	(m)	(m)	%	(min)	(hrs)
	2880	48.00	3.09	27.52	0.75	47.27	2880	48.00
OBSERVATION BOREHOLES:	No.	720	1440	2880	>2880 (min)	TOTAL:		
	of boreholes	(min)	(min)	(min)	nr.	Time	(min)	(hrs)
							3	0.00

BOREHOLE NUMBER: T32333

CALIBRATION TEST AND RECOVERY

Discharge 1:	0.46	Discharge 2:	1.00	Discharge 3:	1.52	Discharge 4:	2.03	Discharge 5:	2.40	Discharge 6:	4.4567
--------------	------	--------------	------	--------------	------	--------------	------	--------------	------	--------------	--------




- Discharge Rate 1
- Discharge Rate 2
- Recovery
- Discharge Rate 3
- Discharge Rate 4
- Discharge Rate 5
- Discharge Rate 6

Drawdown 1:	2.54
Drawdown 2:	4.43
Drawdown 3:	7.95
Drawdown 4:	10.91
Drawdown 5:	14.35
Drawdown 6:	29.45
Duration 1:	15
Duration 2:	15
Duration 3:	15
Duration 4:	15
Duration 5:	15
Duration 6:	10
Recovery (m):	0.50
Recovery (min):	90

STEPPED DISCHARGE TEST AND RECOVERY


Discharge 1:	1.04	Discharge 2:	1.50167	Discharge 3:	2.076	Discharge 4:	2.54	Discharge 5:		Discharge 6:	
--------------	------	--------------	---------	--------------	-------	--------------	------	--------------	--	--------------	--



- Discharge rate 1
- Discharge rate 2
- Discharge rate 3
- Discharge rate 4
- Recovery
- Step 2
- Step 3
- Step 4

Drawdown 1:	5.15
Drawdown 2:	8.43
Drawdown 3:	12.84
Drawdown 4:	23.91
Drawdown 5:	0.00
Drawdown 6:	
Duration 1:	100
Duration 2:	100
Duration 3:	100
Duration 4:	100
Duration 5:	
Duration 6:	
Recovery (m):	1.14
Recovery (min):	180

CONSTANT DISCHARGE TEST AND RECOVERY



- Constant discharge rate
- Recovery

INFORMATION

Date tested	23/05/2003	Water level (mbgl)	1.85	Depth of pump (mbgl)	32.7
Test duration	2880	CD discharge rate	2.09	CD drawdown	27.52
Stable drawdown (m)	30.85	% Recovery after CD	97	% after 2880 min	

CALIBRATION TEST AND RECOVERY

BOREHOLE NO. :	EC/T11/007	PROJECT:	ENCOBO FEASIBILITY STUDY
ALTERNATIVE NO. :	T32396	SITE NAME:	NKONDLO
ALTERNATIVE NO. :		CLIENT:	CHRIS HANI DISTRICT MUNICIPALITY
BOREHOLE DEPTH (mbdl):	65.90	CASING DEPTH (mbdl):	5.84
DEPTH OF PUMP (mbdl):	57.30	CASING HEIGHT (magl):	0.24
PUMP INLET DIAMETER (mm):	100.00	CASING ID (mm):	180.00
STATIC WATER LEVEL (mbdl):	0.54	DATUM LEVEL (magl):	0.48
		PUMP TYPE USED:	BP 40
		OPERATOR:	PIETER MUNYAI
		CONTRACTOR:	AB PUMPS
		SUPERVISOR:	CJ VAN DER WALT

DISCHARGE RATE 1					DISCHARGE RATE 2					DISCHARGE RATE 3																			
DATE:	09/05/2003				TIME:	12H30				DATE:	09/05/2003				TIME:	12H45				DATE:	09/05/2003				TIME:	13H00			
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery					
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)					
1	0.63		1		1	1.33		1		1	3.06		1		1	3.06		1		1									
2	0.68		2		2	1.49		2		2	3.48		2		2	3.48		2		2									
3	0.70	1.07	3		3	1.60	1.82	3		3	3.95		3		3	3.95		3		3									
5	0.75		5		5	1.74		5		5	4.54	3.45	5		5	4.54	3.45	5		5									
7	0.79	1.06	7		7	1.75	1.8	7		7	4.70		7		7	4.70		7		7									
10	0.82		10		10	1.80		10		10	4.78	3.46	10		10	4.78	3.46	10		10									
15	0.85		15		15	1.85		15		15	4.94		15		15	4.94		15		15									

EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20
TYPE OF RESERVOIR:	30	TYPE OF ENCLOSURE:	30	PRESSURE GAUGE MANUFACTURER:	30
RESERVOIR SIZE:	40	MATERIAL OF ENCLOSURE:	40	GAUGE READING (KpA):	40
RESERVOIR CONITION:	50	CONDITION OF ENCLOSURE:	50	MONITORING FACILITY:	50
STAND HEIGHT (m):	60	WATER METER MANUFACTURER:	60	MAINTAINED:	60
	70	WATER METER READING:	70		70
	80		80		80
	90		90		90
	100		100		100
	110		110		110
	120		120		120
	150		150		150

DISCHARGE RATE 4					DISCHARGE RATE 5					DISCHARGE RATE 5																			
DATE:	09/05/2003				TIME:	13H15				DATE:	09/05/2003				TIME:	13H30				DATE:	09/05/2003				TIME:	13H45			
Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery	Time	Drawdown	Yield	Time	Recovery					
(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)	(min)	(m)	(l/s)	(min)	(m)					
1	5.12		1		1	16.18		1		1	32.90		1		1	32.90		1		1	48.80								
2	5.43	3.89	2		2	17.68	5.87	2		2	35.40	6.46	2		2	35.40	6.46	2		2	30.90								
3	8.38	4.4	3		3	19.35		3		3	41.70		3		3	41.70		3		3	16.54								
5	9.92	4.42	5		5	21.20	5.85	5		5	47.82	6.47	5		5	47.82	6.47	5		5	3.87								
7	11.72		7		7	23.75		7		7	55.74		7		7	55.74		7		7	1.99								
10	12.57	4.43	10		10	25.47		10		10	56.84		10		10	56.84		10		10	1.65								
15	14.30		15		15	30.28		15		15	56.84	PI 4.85	15		15	56.84	PI 4.85	15		15	1.38								

EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20	EXISTING EQUIPMENT DETAIL:	20
PUMP TYPE:	30	TYPE OF POWER:	30	TYPE OF RISER:	30
PUMP AND PUMP	40	ENGINE MANUFACTURER:	40	CLASS OF RISER:	40
PUMP MANUFACTURER:	50	ENGINE MODEL:	50	DIAMETER OF RISER (mm):	50
PUMP SERIAL No:	60	ENGINE SERIAL No:	60	CONDITION OF RISER:	60
PUMP PULLEY DIAMETER (mm):	70	ENGINE PULLEY DIAMETER (mm):	70	SHAFT DIAMETER (mm):	70
PUMP INTAKE DEPTH (m):	80	POWER RATING (kw):	80	ELEMENT DIAMETER (mm):	80
	90	ENGINE CONDITION:	90	ELEMENT STROKE (mm):	90
	100		100		100
	110		110		110
	120		120		120
	150		150		150

COMMENTS:	240
	300
	420
	480
	540
	600
	660

DID THE BOREHOLE PRODUCE ANY SILT / SAND / GRAVEL ?

STEPPED DISCHARGE TEST AND RECOVERY

WELL BOREHOLE NO. :	EC/T11/007	PROJECT:	ENGCOCO FEASIBILITY STUDY
ALTERNATIVE NO. :	T32396	SITE NAME:	NKONDLO
ALTERNATIVE NO. :	0	CLIENT:	CHRIS HANI DISTRICT MUNICIPALITY

BOREHOLE DEPTH (mbdl):	65.90	CASING DEPTH (mbdl):	5.84	PUMP TYPE USED:	BP 40
DEPTH OF PUMP (mbdl):	57.30	CASING HEIGHT (magl):	0.24	OPERATOR:	PIETER MUNYAI
PUMP INLET DIAMETER (mm):	100.000	CASING ID (mm):	180.000	CONTRACTOR:	AB PUMPS
STATIC WATER LEVEL (mbdl):	1.49	DATUM LEVEL (magl):	0.48		

DISCHARGE RATE 1			Time	Recovery 1	DISCHARGE RATE 2			Time	Recovery 2	DISCHARGE RATE 3			Time	Recovery 3
DATE:	09/05/2003		(min)	(m)	DATE:	09/05/2003		(min)	(m)	DATE:	09/05/2003		(min)	(m)
TIME:	14H30		1		TIME:	16H10		1		TIME:	17H50		1	
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	
1	1.54		5		1	5.15	2.910	5		1	13.60	3.890	5	
	1.76	1.270	7		2	5.77		7		2	14.20		7	
	1.97		10		3	6.47		10		3	14.68	4.450	10	
5	2.15	1.550	15		5	7.08	3.170	15		4	16.82	4.510	15	
	2.20		20		7	7.57		20		7	18.80		20	
	2.45	1.570	30		10	7.91		30		10	22.00	4.530	30	
15	3.00		40		15	8.27	3.150	40		15	24.01		40	
20	3.10		50		20	8.41		50		20	27.25		50	
	3.16	1.570	60		30	8.92		60		30	30.90	4.520	60	
30	3.21		70		40	9.38	3.160	70		40	34.56		70	
50	3.24		80		50	9.70		80		50	38.10		80	
	3.31	1.550	90		60	10.70		90		60	46.00	4.500	90	
	3.36		100		70	10.80	3.150	100		70	49.60		100	
80	3.40		110		80	11.12		110		80	53.41		110	
	3.44	1.560	120		90	11.50	3.170	120		90	55.80		120	
100	3.49		150		100	11.75		150		100	55.80	PI 4.31	150	
110			180		110			180		110	55.80	PI 3.79	180	
120			210		120			210		120	55.80	PI 3.50	210	
Average yield: 1.51166667 l/s					Average yield: 3.11833333 l/s					Average yield: 4.4 l/s				

DISCHARGE RATE 4			Time	Recovery 4	DISCHARGE RATE 5			Time	Recovery 5	DISCHARGE RATE 6			Time	Recovery
DATE:	09/05/2003		(min)	(m)	DATE:	09/05/2003		(min)	(m)	DATE:	09/05/2003		(min)	(m)
TIME:			1		TIME:			1		TIME:			1	36.91
Time	Drawdown	Yield	2		Time	Drawdown	Yield	2		Time	Drawdown	Yield	2	20.33
(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3		(min)	(m)	(l/s)	3	10.12
			5		1			5		1			5	6.15
			7		2			7		2			7	4.00
3			10		3			10		3			10	3.68
			15		5			15		5			15	3.65
			20		7			20		7			20	3.61
70			30		10			30		10			30	3.47
15			40		15			40		15			40	3.20
			50		20			50		20			50	3.10
50			60		30			60		30			60	2.99
40			70		40			70		40			70	2.90
			80		50			80		50			80	2.83
			90		60			90		60			90	2.74
70			100		70			100		70			100	2.68
			110		80			110		80			110	2.63
			120		90			120		90			120	2.57
100			150		100			150		100			150	2.49
110			180		110			180		110			180	2.4
20			210		120			210		120			210	2.31
Average yield: #DIV/0!								240		150			240	2.2

COMMENTS:		300	180	300	2.09
		360	210	360	
		420	240	420	
		480	300	480	
		540	360	540	
		600	420	600	
		660	480	660	
		720		720	
		780		780	Average yield: 720

DISCHARGE BOREHOLE				OBSERVATION BOREHOLE 1			OBSERVATION BOREHOLE 2			OBSERVATION BOREHOLE 3		
Time	Drawdown	Yield	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery	Time	Drawdown	Recovery
(min)	(m)	(%)	(m)	(min)	(m)	(m)	(min)	(m)	(m)	(min)	(m)	(m)
1500	11.82	2.04	2.76	1500			1500			1500		
1560	12.01		2.70	1560			1560			1560		
1620	12.56	2.02	2.64	1620			1620			1620		
1680	13.12		2.56	1680			1680			1680		
1740	13.66	2.00	2.50	1740			1740			1740		
1800	13.99		2.42	1800			1800			1800		
1860	14.33	2.00	2.35	1860			1860			1860		
1920	14.75	2.01	2.28	1920			1920			1920		
1980	15.66	2.00	2.22	1980			1980			1980		
2040	16.57		2.15	2040			2040			2040		
2100	17.48	2.01	2.09	2100			2100			2100		
2160	17.98		2.04	2160			2160			2160		
2220	18.64	2.00	1.98	2220			2220			2220		
2280	19.22		1.93	2280			2280			2280		
2340	19.80	2.01	1.87	2340			2340			2340		
2400	20.38		1.81	2400			2400			2400		
2460	20.97		1.76	2460			2460			2460		
2520	21.55	2.00	1.70	2520			2520			2520		
2580	22.14		1.65	2580			2580			2580		
2640	22.73		1.59	2640			2640			2640		
2700	23.31	2.02	1.53	2700			2700			2700		
2760	23.90		1.48	2760			2760			2760		
2820	24.50	2.01	1.42	2820			2820			2820		
2880	25.12		1.37	2880			2880			2880		

DESCRIPTION:	QUANTITY:	UNIT:
ESTABLISHMENT	0	Sum
INTER HOLE MOVE > 10 km	45	Km.
FROM: SITE NAME: CLARKBURY		
BOREHOLE No: EC/T12/008		
INTER HOLE MOVE < 10 km:	0	No.
REMOVAL AND RE-ERECTION OF PUMP HOUSE:	1	No.
REMOVAL OF EXISTING EQUIPMENT:	1	No.
RE-INSTALLATION OF EXISTING EQUIPMENT:	1	No.
WORK TIME RATE (REPAIRS):	0	Hour
STANDING TIME:	0	Hour
LATITUDE: S 31° 39' 45.7"	LONGITUDE: E 028° 14' 09.2"	

DESCRIPTION:	QUANTITY:	UNIT:
STRAIGHTNESS TEST:	0	No.
VERTICALITY TEST:	0	No.
CASING DETECTION:	1	No.
STEEL BOREHOLE COVER:	1	No.
BOREHOLE MARKING:	1	No.
SITE CLEANING / FINISHING:	0	No.
REPORTING & DATA RECORDING:	1	No.
SLUG TEST:	0	No.
LAYFLAT (m):	100	m
BOREHOLE DEPTH AFTER TEST:	65.84	m
BOREHOLE WATERLEVEL AFTER TEST:	2.6	m


TEST DESCRIPTION	STEP	STEP						TOTAL:		RECOVERY:	
		1	2	3	4	5	6	(min)	(hrs)	(m)	(min)
CALIBRATION TEST:											
TEST DURATION (Minutes)		15	15	15	15	15	10	85	1.42	0.95	20
TEST YIELD (l/s)		1.07	1.81	3.46	4.29	5.86	6.47	MAXIMUM (l/s) 6.5			
DRAWDOWN (m)		0.85	1.85	4.94	14.30	30.28	56.84	MAXIMUM (m) 56.8			
MULTI-RATE / STEP DRAWDOWN:											
TEST DURATION (Minutes)		100	100	120				320	5.33	2.09	300
TEST YIELD (l/s)		1.51	3.12	4.40				MAXIMUM (l/s) 4.4			
DRAWDOWN (m)		3.5	11.75	55.80				MAXIMUM (m) 55.8			

RECOVERY TEST			
TIME TOTAL (hrs):		48.00	
Cal	Steps	CD	Total
20	300	2880	2880
DRAWDOWN TOTALS (CD):			
AVAILABLE	UTIL-	% ISED	
56.8	25.12	44.25	


CONSTANT DISCHARGE TEST	TEST DURATION		TEST YIELD	DRAWDOWN	RECOVERY:			
	(min)	(hrs)	(l/s)	(m)	(m)	%	(min)	(hrs)
	2880	48.00	2.00	25.12	1.37	94.55	2880	48.00
OBSERVATION BOREHOLES:	No.	720	1440	2880	>2880 (min)		TOTAL:	
	of boreholes	(min)	(min)	(min)	nr.	Time	(min)	(hrs)
							3	3.00

BOREHOLE NUMBER: EC/T11/007


CALIBRATION TEST AND RECOVERY



STEPPED DISCHARGE TEST AND RECOVERY



CONSTANT DISCHARGE TEST AND RECOVERY



TEST INFORMATION

Date tested	10/05/2003	Water level (mbgl)	0.54	Depth of pump (mbgl)	57.3
CD duration	2880	CD discharge rate	2.00	CD drawdown	25.12
Available drawdown (m)	56.76	% Recovery after CD	95	% after	2880 min

APPENDIX B

CHEMICAL WATER ANALYSES DATA

Chris Hani Groundwater Study - Phase 2

Borehole Id

T32314 3128 CB

Date Sampled

7-May-03 00046

Drinking water class

2

Sample Number

15363

			Class
Micro-biological properties	Viabie organisms		0
	Faecal coliforms	1.00	2
	Total coliforms	1.00	1

Physical Properties	Electrical Conductivity	EC	mS / m	60.00	0
	Total Dissolved Salts	TDS	mg / l	303.00	0
	pH Value	pH		7.29	0
	Turbidity		NTU	0.31	1

Chemical properties	Arsenic	As	mg / l		0
	Cadmium	Cd	mg / l		0
	Calcium	Ca	mg / l	37.00	0
	Chloride	Cl	mg / l	55.00	0
	Copper	Cu	mg / l		0
	Fluoride	F	mg / l	0.24	0
	Iron	Fe	mg / l	0.10	1
	Total Hardness	CaCO ₃	mg / l	170.00	0
	Magnesium	Mg	mg / l	19.00	0
	Manganese	Mn	mg / l		0
	Nitrate	N	mg / l	0.65	0
	Nitrate	NO ₃	mg / l		0
	Potassium	K	mg / l	0.95	0
	Sodium	Na	mg / l	50.00	0
	Sulphate	SO ₄	mg / l	2.00	0
Zinc	Zn	mg / l		0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia	NH ₄	mg / l	0.01	
	P - Alkalinity	CaCO ₃	mg / l		
	M - Alkalinity	CaCO ₃	mg / l	229.00	
	Calcium Hardness	CaCO ₃	mg / l	92.00	
	Magnesium Hardness	CaCO ₃	mg / l	78.00	
	Carbonate	CaCO ₃	mg / l		
	Bicarbonate	HCO ₃	mg / l		
	Silica	Si	mg / l		
	Phosphor	PO ₄ as P	mg / l		

Chris Hani Groundwater Study - Phase 2

Borehole Id EC-T12-008
 Date Sampled 7-May-03
 Drinking water class 1
 Sample Number 15364

			Class
Micro-biological properties	Viable organisms		0
	Faecal coliforms	0.00	1
	Total coliforms	0.00	1

Physical Properties	Electrical Conductivity	EC	mS / m	93.00	1
	Total Dissolved Salts	TDS	mg / l	467.00	1
	pH Value	pH		7.06	0
	Turbidity		NTU	0.66	1

Chemical properties	Arsenic	As	mg / l		0
	Cadmium	Cd	mg / l		0
	Calcium	Ca	mg / l	63.00	0
	Chloride	Cl	mg / l	112.00	1
	Copper	Cu	mg / l		0
	Fluoride	F	mg / l	0.47	0
	Iron	Fe	mg / l	0.10	1
	Total Hardness	CaCO ₃	mg / l	281.00	1
	Magnesium	Mg	mg / l	30.00	1
	Manganese	Mn	mg / l		0
	Nitrate	N	mg / l	1.80	0
	Nitrate	NO ₃	mg / l		0
	Potassium	K	mg / l	0.87	0
	Sodium	Na	mg / l	65.00	0
Sulphate	SO ₄	mg / l	16.00	0	
Zinc	Zn	mg / l		0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia	NH ₄	mg / l	0.01	
	P - Alkalinity	CaCO ₃	mg / l		
	M - Alkalinity	CaCO ₃	mg / l	275.00	
	Calcium Hardness	CaCO ₃	mg / l	157.00	
	Magnesium Hardness	CaCO ₃	mg / l	124.00	
	Carbonate	CaCO ₃	mg / l		
	Bicarbonate	HCO ₃	mg / l		
	Silica	Si	mg / l		
Phosphor	PO ₄ as P	mg / l			

Chris Hani Groundwater Study - Phase 2

Borehole Id EC/T11/003
 Date Sampled 11-Apr-03
 Drinking water class 4
 Sample Number 15026

			Class
Micro-biological properties	Viabie organisms		0
	Faecal coliforms	14000.00	4
	Total coliforms	25000.00	4

Physical Properties	Electrical Conductivity	EC	mS / m	194.00	2
	Total Dissolved Salts	TDS	mg / l	971.00	1
	pH Value	pH		7.38	0
	Turbidity		NTU	0.32	1

Chemical properties	Arsenic	As	mg / l		0
	Cadmium	Cd	mg / l		0
	Calcium	Ca	mg / l	61.00	0
	Chloride	Cl	mg / l	403.00	2
	Copper	Cu	mg / l		0
	Fluoride	F	mg / l	0.73	1
	Iron	Fe	mg / l	0.14	1
	Total Hardness	CaCO ₃	mg / l	346.00	2
	Magnesium	Mg	mg / l	47.00	1
	Manganese	Mn	mg / l		0
	Nitrate	N	mg / l	7.60	1
	Nitrate	NO ₃	mg / l		0
	Potassium	K	mg / l	9.40	0
	Sodium	Na	mg / l	196.00	1
Sulphate	SO ₄	mg / l	35.00	0	
Zinc	Zn	mg / l		0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia	NH ₄	mg / l	0.10	
	P - Alkalinity	CaCO ₃	mg / l		
	M - Alkalinity	CaCO ₃	mg / l	297.00	
	Calcium Hardness	CaCO ₃	mg / l	152.00	
	Magnesium Hardness	CaCO ₃	mg / l	194.00	
	Carbonate	CaCO ₃	mg / l		
	Bicarbonate	HCO ₃	mg / l		
	Silica	Si	mg / l		
Phosphor	PO ₄ as P	mg / l			

Chris Hani Groundwater Study - Phase 2

3127DB00031
T32333 Qoba J.P. School

Borehole Id

Date Sampled

30-May-03

Drinking water class

2

Sample Number

15748

Micro-biological properties			Class
	Viable organisms		0
	Faecal coliforms	3.00	2
Total coliforms	9.00	1	

Physical Properties	Electrical Conductivity	EC	mS / m	26.00	0
	Total Dissolved Salts	TDS	mg / l	129.00	0
	pH Value	pH		7.15	0
	Turbidity		NTU	0.68	1

Chemical properties	Arsenic	As	mg / l		0
	Cadmium	Cd	mg / l		0
	Calcium	Ca	mg / l	13.00	0
	Chloride	Cl	mg / l	54.00	0
	Copper	Cu	mg / l		0
	Fluoride	F	mg / l	0.25	0
	Iron	Fe	mg / l	0.26	2
	Total Hardness	CaCO ₃	mg / l	59.00	3
	Magnesium	Mg	mg / l	8.90	0
	Manganese	Mn	mg / l		0
	Nitrate	N	mg / l	0.22	0
	Nitrate	NO ₃	mg / l		0
	Potassium	K	mg / l	0.80	0
	Sodium	Na	mg / l	22.00	0
Sulphate	SO ₄	mg / l	17.00	0	
Zinc	Zn	mg / l		0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia	NH ₄	mg / l		
	P - Alkalinity	CaCO ₃	mg / l	102.00	
	M - Alkalinity	CaCO ₃	mg / l		
	Calcium Hardness	CaCO ₃	mg / l	32.00	
	Magnesium Hardness	CaCO ₃	mg / l	37.00	
	Carbonate	CaCO ₃	mg / l		
	Bicarbonate	HCO ₃	mg / l		
	Silica	Si	mg / l		
	Phosphor	PO ₄ as P	mg / l		

Dalasile Police Station

Borehole Id EC/T11/001
 Date Sampled 9-Apr-03
 Drinking water class 4
 Sample Number 14983

			Class
Micro-biological properties	Viability organisms		0
	Faecal coliforms	0.00	1
	Total coliforms	2.00	1

Physical Properties	Electrical Conductivity	EC	mS / m	50.00	0
	Total Dissolved Salts	TDS	mg / l	251.00	0
	pH Value	pH		8.40	0
	Turbidity		NTU	1.40	2

Chemical properties	Arsenic	As	mg / l		0
	Cadmium	Cd	mg / l		0
	Calcium	Ca	mg / l	6.00	0
	Chloride	Cl	mg / l	56.00	0
	Copper	Cu	mg / l		0
	Fluoride	F	mg / l	3.70	4
	Iron	Fe	mg / l	0.21	2
	Total Hardness	CaCO ₃	mg / l	21.00	0
	Magnesium	Mg	mg / l	1.40	0
	Manganese	Mn	mg / l		0
	Nitrate	N	mg / l	0.10	0
	Nitrate	NO ₃	mg / l		0
	Potassium	K	mg / l	0.21	0
	Sodium	Na	mg / l	91.00	0
Sulphate	SO ₄	mg / l	3.20	0	
Zinc	Zn	mg / l		0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia	NH ₄	mg / l	0.08	
	P - Alkalinity	CaCO ₃	mg / l	162.00	
	M - Alkalinity	CaCO ₃	mg / l		
	Calcium Hardness	CaCO ₃	mg / l	15.00	
	Magnesium Hardness	CaCO ₃	mg / l	5.80	
	Carbonate	CaCO ₃	mg / l		
	Bicarbonate	HCO ₃	mg / l		
	Silica	Si	mg / l		
	Phosphor	PO ₄ as P	mg / l		

Mhlopekezi

Borehole Id EC/T11/002
 Date Sampled 09/04/03
 Drinking water class 2
 Sample Number 14984

			Class
Micro-biological properties	Viable organisms		0
	Faecal coliforms	7.00	2
	Total coliforms	19.00	2

Physical Properties	Electrical Conductivity	EC	mS / m	73.00	1
	Total Dissolved Salts	TDS	mg / l	366.00	0
	pH Value	pH		7.49	0
	Turbidity		NTU	0.25	1

Chemical properties	Arsenic	As	mg / l		0
	Cadmium	Cd	mg / l		0
	Calcium	Ca	mg / l	69.00	0
	Chloride	Cl	mg / l	56.00	0
	Copper	Cu	mg / l		0
	Fluoride	F	mg / l	0.35	0
	Iron	Fe	mg / l	0.10	1
	Total Hardness	CaCO ₃	mg / l	304.00	2
	Magnesium	Mg	mg / l	32.00	1
	Manganese	Mn	mg / l		0
	Nitrate	N	mg / l	3.10	0
	Nitrate	NO ₃	mg / l		0
	Potassium	K	mg / l	0.76	0
	Sodium	Na	mg / l	32.00	0
Sulphate	SO ₄	mg / l	14.00	0	
Zinc	Zn	mg / l		0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia	NH ₄	mg / l	0.08	
	P - Alkalinity	CaCO ₃	mg / l	228.00	
	M - Alkalinity	CaCO ₃	mg / l		
	Calcium Hardness	CaCO ₃	mg / l	172.00	
	Magnesium Hardness	CaCO ₃	mg / l	122.00	
	Carbonate	CaCO ₃	mg / l		
	Bicarbonate	HCO ₃	mg / l		
	Silica	Si	mg / l		
	Phosphor	PO ₄ as P	mg / l		

Borehole Id
 Date Sampled
 Drinking water class

EC-T12-004
 10-Jun-03
 2

Sample Number

15926

			Class
Micro-biological properties	Viable organisms		0
	Faecal coliforms	7.00	2
	Total coliforms	13.00	2

Physical Properties	Electrical Conductivity	EC	mS / m	29.00	0
	Total Dissolved Salts	TDS	mg / l	145.00	0
	pH Value	pH		7.44	0
	Turbidity		NTU	0.59	1

Chemical properties	Arsenic	As	mg / l		0
	Cadmium	Cd	mg / l		0
	Calcium	Ca	mg / l	22.00	0
	Chloride	Cl	mg / l	45.00	0
	Copper	Cu	mg / l		0
	Fluoride	F	mg / l	0.63	0
	Iron	Fe	mg / l	0.15	1
	Total Hardness	CaCO ₃	mg / l	99.00	0
	Magnesium	Mg	mg / l	8.30	0
	Manganese	Mn	mg / l		0
	Nitrate	N	mg / l	0.24	0
	Nitrate	NO ₃	mg / l		0
	Potassium	K	mg / l	0.58	0
	Sodium	Na	mg / l	23.00	0
Sulphate	SO ₄	mg / l	2.00	0	
Zinc	Zn	mg / l		0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia	NH ₄	mg / l	0.04	
	P - Alkalinity	CaCO ₃	mg / l	96.00	
	M - Alkalinity	CaCO ₃	mg / l		
	Calcium Hardness	CaCO ₃	mg / l	55.00	
	Magnesium Hardness	CaCO ₃	mg / l	34.00	
	Carbonate	CaCO ₃	mg / l		
	Bicarbonate	HCO ₃	mg / l		
	Silica	Si	mg / l		
Phosphor	PO ₄ as P	mg / l			

Borehole Id
 Date Sampled
 Drinking water class

EC-T12-009
 10-Jun-03
 1

Sample Number

15927

			Class
Micro-biological properties	Viable organisms		0
	Faecal coliforms	0.00	1
	Total coliforms	0.00	1

Physical Properties	Electrical Conductivity	EC	mS / m	83.00	1
	Total Dissolved Salts	TDS	mg / l	414.00	0
	pH Value	pH		7.23	0
	Turbidity		NTU	0.37	1

Chemical properties	Arsenic	As	mg / l		0
	Cadmium	Cd	mg / l		0
	Calcium	Ca	mg / l	58.00	0
	Chloride	Cl	mg / l	115.00	1
	Copper	Cu	mg / l		0
	Fluoride	F	mg / l	0.56	0
	Iron	Fe	mg / l	0.18	1
	Total Hardness	CaCO ₃	mg / l	243.00	1
	Magnesium	Mg	mg / l	25.00	0
	Manganese	Mn	mg / l		0
	Nitrate	N	mg / l	0.73	0
	Nitrate	NO ₃	mg / l		0
	Potassium	K	mg / l	1.10	0
	Sodium	Na	mg / l	79.00	0
	Sulphate	SO ₄	mg / l	15.00	0
Zinc	Zn	mg / l		0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia	NH ₄	mg / l	0.12	
	P - Alkalinity	CaCO ₃	mg / l	302.00	
	M - Alkalinity	CaCO ₃	mg / l		
	Calcium Hardness	CaCO ₃	mg / l	145.00	
	Magnesium Hardness	CaCO ₃	mg / l	103.00	
	Carbonate	CaCO ₃	mg / l		
	Bicarbonate	HCO ₃	mg / l		
	Silica	Si	mg / l		
	Phosphor	PO ₄ as P	mg / l		

Nkondlo

3128CIA06041

Borehole Id

T32396

Date Sampled

15/05/2003

Drinking water class

2

Sample Number

15534

			Class
Micro-biological properties	Viable organisms		0
	Faecal coliforms	0.00	1
	Total coliforms	0.00	1

Physical Properties	Electrical Conductivity	EC	mS / m	66.00	0
	Total Dissolved Salts	TDS	mg / l	329.00	0
	pH Value	pH		8.29	0
	Turbidity		NTU	1.50	2

Chemical properties	Arsenic	As	mg / l		0
	Cadmium	Cd	mg / l		0
	Calcium	Ca	mg / l	9.70	0
	Chloride	Cl	mg / l	92.00	0
	Copper	Cu	mg / l		0
	Fluoride	F	mg / l	1.20	2
	Iron	Fe	mg / l	0.09	1
	Total Hardness	CaCO ₃	mg / l	34.00	0
	Magnesium	Mg	mg / l	2.50	0
	Manganese	Mn	mg / l		0
	Nitrate	N	mg / l	0.10	0
	Nitrate	NO ₃	mg / l		0
	Potassium	K	mg / l	0.35	0
	Sodium	Na	mg / l	123.00	1
	Sulphate	SO ₄	mg / l	2.00	0
Zinc	Zn	mg / l		0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia	NH ₄	mg / l		
	P - Alkalinity	CaCO ₃	mg / l		
	M - Alkalinity	CaCO ₃	mg / l	235.00	
	Calcium Hardness	CaCO ₃	mg / l	24.00	
	Magnesium Hardness	CaCO ₃	mg / l	10.00	
	Carbonate	CaCO ₃	mg / l		
	Bicarbonate	HCO ₃	mg / l		
	Silica	Si	mg / l		
	Phosphor	PO ₄ as P	mg / l		

KwaSandile

Borehole Id EC-T11-007
 Date Sampled 15/05/2003
 Drinking water class 2
 Sample Number 15535

Micro-biological properties			Class
	Viable organisms		0
	Faecal coliforms	6.00	2
Total coliforms	11.00	2	

Physical Properties	Electrical Conductivity	EC	mS / m	39.00	0
	Total Dissolved Salts	TDS	mg / l	195.00	0
	pH Value	pH		7.34	0
	Turbidity		NTU	5.30	2

Chemical properties	Arsenic	As	mg / l		0
	Cadmium	Cd	mg / l		0
	Calcium	Ca	mg / l	31.00	0
	Chloride	Cl	mg / l	14.00	0
	Copper	Cu	mg / l		0
	Fluoride	F	mg / l	0.66	0
	Iron	Fe	mg / l	0.43	2
	Total Hardness	CaCO ₃	mg / l	135.00	0
	Magnesium	Mg	mg / l	14.00	0
	Manganese	Mn	mg / l		0
	Nitrate	N	mg / l	2.00	0
	Nitrate	NO ₃	mg / l		0
	Potassium	K	mg / l	0.80	0
	Sodium	Na	mg / l	24.00	0
	Sulphate	SO ₄	mg / l	2.00	0
Zinc	Zn	mg / l		0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia	NH ₄	mg / l		
	P - Alkalinity	CaCO ₃	mg / l		
	M - Alkalinity	CaCO ₃	mg / l	197.00	
	Calcium Hardness	CaCO ₃	mg / l	77.00	
	Magnesium Hardness	CaCO ₃	mg / l	58.00	
	Carbonate	CaCO ₃	mg / l		
	Bicarbonate	HCO ₃	mg / l		
	Silica	Si	mg / l		
	Phosphor	PO ₄ as P	mg / l		

#REF!

Borehole Id

EC-T11-008

Date Sampled

22/05/2003

Drinking water class

2

Sample Number

15638

Micro-biological properties			Class
	Viable organisms		0
Faecal coliforms	0.00	1	
Total coliforms	2.00	1	

Physical Properties	Electrical Conductivity	EC	mS / m	35.00	0
	Total Dissolved Salts	TDS	mg / l	173.00	0
	pH Value	pH		7.57	0
	Turbidity		NTU	0.55	1

Chemical properties	Arsenic	As	mg / l		0
	Cadmium	Cd	mg / l		0
	Calcium	Ca	mg / l	27.00	0
	Chloride	Cl	mg / l	67.00	0
	Copper	Cu	mg / l		0
	Fluoride	F	mg / l	0.08	0
	Iron	Fe	mg / l	0.48	2
	Total Hardness	CaCO ₃	mg / l	121.00	0
	Magnesium	Mg	mg / l	13.00	0
	Manganese	Mn	mg / l		0
	Nitrate	N	mg / l	2.40	0
	Nitrate	NO ₃	mg / l		0
	Potassium	K	mg / l	0.77	0
	Sodium	Na	mg / l	23.00	0
	Sulphate	SO ₄	mg / l	4.70	0
Zinc	Zn	mg / l		0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia	NH ₄	mg / l		
	P - Alkalinity	CaCO ₃	mg / l		
	M - Alkalinity	CaCO ₃	mg / l	173.00	
	Calcium Hardness	CaCO ₃	mg / l	67.00	
	Magnesium Hardness	CaCO ₃	mg / l	54.00	
	Carbonate	CaCO ₃	mg / l		
	Bicarbonate	HCO ₃	mg / l		
	Silica	Si	mg / l		
	Phosphor	PO ₄ as P	mg / l		

Gobhoti

Borehole Id EC-T12-005
 Date Sampled 27/05/2003
 Drinking water class 3
 Sample Number 15724

Micro-biological properties			Class
	Viabie organisms		0
	Faecal coliforms	0.00	1
Total coliforms	0.00	1	

Physical Properties	Electrical Conductivity	EC	mS / m	16.00	0
	Total Dissolved Salts	TDS	mg / l	79.00	0
	pH Value	pH		9.98	2
	Turbidity		NTU	0.55	1

Chemical properties	Arsenic	As	mg / l		0
	Cadmium	Cd	mg / l		0
	Calcium	Ca	mg / l	2.50	0
	Chloride	Cl	mg / l	17.00	0
	Copper	Cu	mg / l		0
	Fluoride	F	mg / l	1.70	3
	Iron	Fe	mg / l	0.09	1
	Total Hardness	CaCO ₃	mg / l	5.30	0
	Magnesium	Mg	mg / l	0.04	0
	Manganese	Mn	mg / l		0
	Nitrate	N	mg / l	0.01	0
	Nitrate	NO ₃	mg / l		0
	Potassium	K	mg / l	0.14	0
	Sodium	Na	mg / l	31.00	0
Sulphate	SO ₄	mg / l	2.00	0	
Zinc	Zn	mg / l		0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia	NH ₄	mg / l		
	P - Alkalinity	CaCO ₃	mg / l		
	M - Alkalinity	CaCO ₃	mg / l	34.00	
	Calcium Hardness	CaCO ₃	mg / l	6.20	
	Magnesium Hardness	CaCO ₃	mg / l	0.10	
	Carbonate	CaCO ₃	mg / l		
	Bicarbonate	HCO ₃	mg / l		
	Silica	Si	mg / l		
	Phosphor	PO ₄ as P	mg / l		

Chris Hani

Borehole Id EC-T12-004
 Date Sampled 23-Jul-03
 Drinking water class 2
 Sample Number 16698

		Class	
Micro-biological properties	Viable organisms		0
	Faecal coliforms	1.00	2
	Total coliforms	1.00	1

Physical Properties	Electrical Conductivity	EC	mS / m	0
	Total Dissolved Salts	TDS	mg / l	0
	pH Value	pH		0
	Turbidity		NTU	0

Chemical properties	Arsenic	As	mg / l	0
	Cadmium	Cd	mg / l	0
	Calcium	Ca	mg / l	0
	Chloride	Cl	mg / l	0
	Copper	Cu	mg / l	0
	Fluoride	F	mg / l	0
	Iron	Fe	mg / l	0
	Total Hardness	CaCO ₃	mg / l	0
	Magnesium	Mg	mg / l	0
	Manganese	Mn	mg / l	0
	Nitrate	N	mg / l	0
	Nitrate	NO ₃	mg / l	0
	Potassium	K	mg / l	0
	Sodium	Na	mg / l	0
Sulphate	SO ₄	mg / l	0	
Zinc	Zn	mg / l	0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia	NH ₄	mg / l	
	P - Alkalinity	CaCO ₃	mg / l	
	M - Alkalinity	CaCO ₃	mg / l	
	Calcium Hardness	CaCO ₃	mg / l	
	Magnesium Hardness	CaCO ₃	mg / l	
	Carbonate	CaCO ₃	mg / l	
	Bicarbonate	HCO ₃	mg / l	
	Silica	Si	mg / l	
	Phosphor	PO ₄ as P	mg / l	

- | | | |
|---------|-------------------------|---|
| Class 0 | Ideal water quality | Suitable for lifetime use |
| Class 1 | Good water quality | Suitable for use. rare instances of negative effects |
| Class 2 | Marginal water quality | Conditionally acceptable. Negative effects may occur in some sensitive groups |
| Class 3 | Poor water quality | Unsuitable for use without treatment. Chronic effects may occur |
| Class 4 | Dangerous water quality | Totally unsuitable for use. Acute effects may occur |

Chris Hani

Borehole Id
Date Sampled
Drinking water class

EC-T11-007

23-Jul-03

1

Sample Number

16699

Micro-biological properties	Viable organisms		Class
	Faecal coliforms		
	Total coliforms		
	0.00		0
	0.00		1

Physical Properties	Electrical Conductivity EC		Class
	Total Dissolved Salts TDS		
	pH Value pH		
	Turbidity		
	mS / m		0
	mg / l		0
	NTU		0

Chemical properties	Arsenic		Class
	Cadmium		
	Calcium		
	Chloride		
	Copper		
	Fluoride		
	Iron		
	Total Hardness		
	Magnesium		
	Manganese		
	Nitrate		
	Nitrate		
	Potassium		
	Sodium		
	Sulphate		
	Zinc		
		As	
	Cd	mg / l	0
	Ca	mg / l	0
	Cl	mg / l	0
	Cu	mg / l	0
	F	mg / l	0
	Fe	mg / l	0
	CaCO ₃	mg / l	0
	Mg	mg / l	0
	Mn	mg / l	0
	N	mg / l	0
	NO ₃	mg / l	0
	K	mg / l	0
	Na	mg / l	0
	SO ₄	mg / l	0
	Zn	mg / l	0

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia		Class
	P - Alkalinity		
	M - Alkalinity		
	Calcium Hardness		
	Magnesium Hardness		
	Carbonate		
	Bicarbonate		
	Silica		
Phosphor			
	NH ₄	mg / l	
	CaCO ₃	mg / l	
	CaCO ₃	mg / l	
	CaCO ₃	mg / l	
	CaCO ₃	mg / l	
	CaCO ₃	mg / l	
	HCO ₃	mg / l	
	Si	mg / l	
	PO ₄ as P	mg / l	

- Class 0 Ideal water quality
- Class 1 Good water quality
- Class 2 Marginal water quality
- Class 3 Poor water quality
- Class 4 Dangerous water quality

- Suitable for lifetime use
- Suitable for use, rare instances of negative effects.
- Conditionally acceptable. Negative effects may occur in some sensitive groups.
- Unsuitable for use without treatment. Chronic effects may occur.
- Totally unsuitable for use. Acute effects may occur.

Chris Hani

Borehole Id EC-035-CH
 Date Sampled 23-Jul-03
 Drinking water class 2
 Sample Number 16700

			Class
Micro-biological properties	Viability organisms		0
	Faecal coliforms	3.00	2
	Total coliforms	4.00	1

Physical Properties	Electrical Conductivity	EC	mS / m	0
	Total Dissolved Salts	TDS	mg / l	0
	pH Value	pH		0
	Turbidity		NTU	0

Chemical properties	Arsenic	As	mg / l	0
	Cadmium	Cd	mg / l	0
	Calcium	Ca	mg / l	0
	Chloride	Cl	mg / l	0
	Copper	Cu	mg / l	0
	Fluoride	F	mg / l	0
	Iron	Fe	mg / l	0
	Total Hardness	CaCO ₃	mg / l	0
	Magnesium	Mg	mg / l	0
	Manganese	Mn	mg / l	0
	Nitrate	N	mg / l	0
	Nitrate	NO ₃	mg / l	0
	Potassium	K	mg / l	0
	Sodium	Na	mg / l	0
Sulphate	SO ₄	mg / l	0	
Zinc	Zn	mg / l	0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia	NH ₄	mg / l	
	P - Alkalinity	CaCO ₃	mg / l	
	M - Alkalinity	CaCO ₃	mg / l	
	Calcium Hardness	CaCO ₃	mg / l	
	Magnesium Hardness	CaCO ₃	mg / l	
	Carbonate	CaCO ₃	mg / l	
	Bicarbonate	HCO ₃	mg / l	
	Silica	Si	mg / l	
	Phosphor	PO ₄ as P	mg / l	

- | | | |
|---------|-------------------------|--|
| Class 0 | Ideal water quality | Suitable for lifetime use |
| Class 1 | Good water quality | Suitable for use, rare instances of negative effect |
| Class 2 | Marginal water quality | Conditionally acceptable. Negative effects may occur in some sensitive groups. |
| Class 3 | Poor water quality | Unsuitable for use without treatment. Chronic effects may occur. |
| Class 4 | Dangerous water quality | Totally unsuitable for use. Acute effects may occur. |

Chris Hani

Borehole Id EC-035-CH
 Date Sampled 23-Jul-03
 Drinking water class 2
 Sample Number 16700

			Class
Micro-biological properties	Viability organisms		0
	Faecal coliforms	3.00	2
	Total coliforms	4.00	1
Physical Properties	Electrical Conductivity EC	mS / m	0
	Total Dissolved Salts TDS	mg / l	0
	pH Value pH		0
	Turbidity	NTU	0
Chemical properties	Arsenic As	mg / l	0
	Cadmium Cd	mg / l	0
	Calcium Ca	mg / l	0
	Chloride Cl	mg / l	0
	Copper Cu	mg / l	0
	Fluoride F	mg / l	0
	Iron Fe	mg / l	0
	Total Hardness CaCO ₃	mg / l	0
	Magnesium Mg	mg / l	0
	Manganese Mn	mg / l	0
	Nitrate N	mg / l	0
	Nitrate NO ₃	mg / l	0
	Potassium K	mg / l	0
	Sodium Na	mg / l	0
	Sulphate SO ₄	mg / l	0
Zinc Zn	mg / l	0	
Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia NH ₄	mg / l	
	P - Alkalinity CaCO ₃	mg / l	
	M - Alkalinity CaCO ₃	mg / l	
	Calcium Hardness CaCO ₃	mg / l	
	Magnesium Hardness CaCO ₃	mg / l	
	Carbonate CaCO ₃	mg / l	
	Bicarbonate HCO ₃	mg / l	
	Silica Si	mg / l	
	Phosphor PO ₄ as P	mg / l	

Class 0	Ideal water quality	Suitable for lifetime use
Class 1	Good water quality	Suitable for use, rare instances of negative effect
Class 2	Marginal water quality	Conditionally acceptable. Negative effects may occur in some sensitive groups
Class 3	Poor water quality	Unsuitable for use without treatment. Chronic effects may occur
Class 4	Dangerous water quality	Totally unsuitable for use. Acute effects may occur

Chris Hani

Borehole Id EC-T11-007
 Date Sampled 23-Jul-03
 Drinking water class 1
 Sample Number 16699

			Class
Micro-biological properties	Viable organisms		0
	Faecal coliforms	0.00	1
	Total coliforms	0.00	1

Physical Properties	Electrical Conductivity	EC	mS / m	0
	Total Dissolved Salts	TDS	mg / l	0
	pH Value	pH		0
	Turbidity		NTU	0

Chemical properties	Arsenic	As	mg / l	0
	Cadmium	Cd	mg / l	0
	Calcium	Ca	mg / l	0
	Chloride	Cl	mg / l	0
	Copper	Cu	mg / l	0
	Fluoride	F	mg / l	0
	Iron	Fe	mg / l	0
	Total Hardness	CaCO ₃	mg / l	0
	Magnesium	Mg	mg / l	0
	Manganese	Mn	mg / l	0
	Nitrate	N	mg / l	0
	Nitrate	NO ₃	mg / l	0
	Potassium	K	mg / l	0
	Sodium	Na	mg / l	0
	Sulphate	SO ₄	mg / l	0
Zinc	Zn	mg / l	0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia	NH ₄	mg / l	
	P - Alkalinity	CaCO ₃	mg / l	
	M - Alkalinity	CaCO ₃	mg / l	
	Calcium Hardness	CaCO ₃	mg / l	
	Magnesium Hardness	CaCO ₃	mg / l	
	Carbonate	CaCO ₃	mg / l	
	Bicarbonate	HCO ₃	mg / l	
	Silica	Si	mg / l	
	Phosphor	PO ₄ as P	mg / l	

- | | | |
|---------|-------------------------|---|
| Class 0 | Ideal water quality | Suitable for lifetime use |
| Class 1 | Good water quality | Suitable for use, rare instances of negative effects. |
| Class 2 | Marginal water quality | Conditionally acceptable. Negative effects may occur in some sensitive groups |
| Class 3 | Poor water quality | Unsuitable for use without treatment. Chronic effects may occur |
| Class 4 | Dangerous water quality | Totally unsuitable for use. Acute effects may occur |

Chris Hani

Borehole Id

EC-T12-003

Date Sampled

23-Jul-03

Drinking water class

1

Sample Number

16701

			Class
Micro-biological properties	Viable organisms		0
	Faecal coliforms	0.00	1
	Total coliforms	2.00	1

Physical Properties	Electrical Conductivity	EC	mS / m	0
	Total Dissolved Salts	TDS	mg / l	0
	pH Value	pH		0
	Turbidity		NTU	0

Chemical properties	Arsenic	As	mg / l	0
	Cadmium	Cd	mg / l	0
	Calcium	Ca	mg / l	0
	Chloride	Cl	mg / l	0
	Copper	Cu	mg / l	0
	Fluoride	F	mg / l	0
	Iron	Fe	mg / l	0
	Total Hardness	CaCO ₃	mg / l	0
	Magnesium	Mg	mg / l	0
	Manganese	Mn	mg / l	0
	Nitrate	N	mg / l	0
	Nitrate	NO ₃	mg / l	0
	Potassium	K	mg / l	0
	Sodium	Na	mg / l	0
Sulphate	SO ₄	mg / l	0	
Zinc	Zn	mg / l	0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia	NH ₄	mg / l	
	P - Alkalinity	CaCO ₃	mg / l	
	M - Alkalinity	CaCO ₃	mg / l	
	Calcium Hardness	CaCO ₃	mg / l	
	Magnesium Hardness	CaCO ₃	mg / l	
	Carbonate	CaCO ₃	mg / l	
	Bicarbonate	HCO ₃	mg / l	
	Silica	Si	mg / l	
	Phosphor	PO ₄ as P	mg / l	

Chris Hani

Borehole Id River EL303
 Date Sampled 23-Jul-03
 Drinking water class 3
 Sample Number 16702

			Class
Micro-biological properties	Viabie organisms		0
	Faecal coliforms	18.00	3
	Total coliforms	43.00	2

Physical Properties	Electrical Conductivity	EC	mS / m		0
	Total Dissolved Salts	TDS	mg / l		0
	pH Value	pH			0
	Turbidity		NTU		0

Chemical properties	Arsenic	As	mg / l		0
	Cadmium	Cd	mg / l		0
	Calcium	Ca	mg / l		0
	Chloride	Cl	mg / l		0
	Copper	Cu	mg / l		0
	Fluoride	F	mg / l		0
	Iron	Fe	mg / l		0
	Total Hardness	CaCO ₃	mg / l		0
	Magnesium	Mg	mg / l		0
	Manganese	Mn	mg / l		0
	Nitrate	N	mg / l		0
	Nitrate	NO ₃	mg / l		0
	Potassium	K	mg / l		0
	Sodium	Na	mg / l		0
Sulphate	SO ₄	mg / l		0	
Zinc	Zn	mg / l		0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammônia	NH ₄	mg / l		
	P - Alkalinity	CaCO ₃	mg / l		
	M - Alkalinity	CaCO ₃	mg / l		
	Calcium Hardness	CaCO ₃	mg / l		
	Magnesium Hardness	CaCO ₃	mg / l		
	Carbonate	CaCO ₃	mg / l		
	Bicarbonate	HCO ₃	mg / l		
	Silica	Si	mg / l		
Phosphor	PO ₄ as P	mg / l			

Chris Hani

Borehole Id

River EL303

Date Sampled

23-Jul-03

Drinking water class

3

Sample Number

16702

			Class
Micro-biological properties	Viable organisms		0
	Faecal coliforms	18.00	3
	Total coliforms	43.00	2

Physical Properties	Electrical Conductivity	EC	mS / m		0
	Total Dissolved Salts	TDS	mg / l		0
	pH Value	pH			0
	Turbidity		NTU		0

Chemical properties	Arsenic	As	mg / l		0
	Cadmium	Cd	mg / l		0
	Calcium	Ca	mg / l		0
	Chloride	Cl	mg / l		0
	Copper	Cu	mg / l		0
	Fluoride	F	mg / l		0
	Iron	Fe	mg / l		0
	Total Hardness	CaCO ₃	mg / l		0
	Magnesium	Mg	mg / l		0
	Manganese	Mn	mg / l		0
	Nitrate	N	mg / l		0
	Nitrate	NO ₃	mg / l		0
	Potassium	K	mg / l		0
	Sodium	Na	mg / l		0
Sulphate	SO ₄	mg / l		0	
Zinc	Zn	mg / l		0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammônia	NH ₄	mg / l		
	P - Alkalinity	CaCO ₃	mg / l		
	M - Alkalinity	CaCO ₃	mg / l		
	Calcium Hardness	CaCO ₃	mg / l		
	Magnesium Hardness	CaCO ₃	mg / l		
	Carbonate	CaCO ₃	mg / l		
	Bicarbonate	HCO ₃	mg / l		
	Silica	Si	mg / l		
	Phosphor	PO ₄ as P	mg / l		

Chris Hani

Borehole Id EC-T12-003
 Date Sampled 23-Jul-03
 Drinking water class 1
 Sample Number 16701

			Class
Micro-biological properties	Viability organisms		0
	Faecal coliforms	0.00	1
	Total coliforms	2.00	1

Physical Properties	Electrical Conductivity	EC	mS / m	0
	Total Dissolved Salts	TDS	mg / l	0
	pH Value	pH		0
	Turbidity		NTU	0


Chemical properties	Arsenic	As	mg / l	0
	Cadmium	Cd	mg / l	0
	Calcium	Ca	mg / l	0
	Chloride	Cl	mg / l	0
	Copper	Cu	mg / l	0
	Fluoride	F	mg / l	0
	Iron	Fe	mg / l	0
	Total Hardness	CaCO ₃	mg / l	0
	Magnesium	Mg	mg / l	0
	Manganese	Mn	mg / l	0
	Nitrate	N	mg / l	0
	Nitrate	NO ₃	mg / l	0
	Potassium	K	mg / l	0
	Sodium	Na	mg / l	0
Sulphate	SO ₄	mg / l	0	
Zinc	Zn	mg / l	0	

Chemical properties (not required for the classification of domestic drinking water supply)	Ammonia	NH ₄	mg / l	
	P - Alkalinity	CaCO ₃	mg / l	
	M - Alkalinity	CaCO ₃	mg / l	
	Calcium Hardness	CaCO ₃	mg / l	
	Magnesium Hardness	CaCO ₃	mg / l	
	Carbonate	CaCO ₃	mg / l	
	Bicarbonate	HCO ₃	mg / l	
	Silica	Si	mg / l	
	Phosphor	PO ₄ as P	mg / l	


APPENDIX C

GEOPHYSICAL PROFILING DATA

CHRIS HANI GROUNDWATER STUDY - PHASE 2
Profile 1 - Cefani
Magnetic & Resistivity Profiling (Wenner Configuration) 20/40m Spacing




CHRIS HANI GROUNDWATER STUDY - PHASE 2
 Etyeni - Profile 1
 Magnetic & Resistivity Profiling (Wenner Configuration)




--- MAGNETIC — RESISTIVITY


CHRIS HANI GROUNDWATER STUDY - PHASE 2
 Kwa Sandile Profile 1
 Magnetic & Resistivity Profiling (Wenner Configuration)




CHRIS HANI GROUNDWATER STUDY - PHASE 2
 Kwasandile - Profile 3
 Magnetic & Resistivity Profiling (Wenner Configuration)




CHRIS HANI GROUNDWATER STUDY - PHASE 2
 Nkwenkwezi- Profile 1
 Magnetic & Resistivity Profiling (Wenner Configuration)




CHRIS HANI GROUNDWATER STUDY - PHASE 2
 Nkwenkwezi Profile 3
 Magnetic & Resistivity Profiling (Wenner Configuration)




CHRIS HANI GROUNDWATER STUDY - PHASE 2
 Sentube - Profile1 (10/20m Spacing)
 Magnetic & Resistivity Profiling (Wenner Configuration)




CHRIS HANI GROUNDWATER STUDY - PHASE 2
Sentube- Profile 1 (30/60m spacing)
Magnetic & Resistivity Profiling (Wenner Configuration)



CHRIS HANI GROUNDWATER STUDY - PHASE 2
 Sentube - Profile 3
 Magnetic & Resistivity Profiling (Wenner Configuration)



CHRIS HANI GROUNDWATER STUDY - PHASE 2
Profile 1
Magnetic & Resistivity Profiling (Wenner Configuration)



APPENDIX D

LITHOLOGICAL & CONSTRUCTION
DRILLING LOGS

SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD
 8 SANSON STREET
 VINCENT
 EAST LONDON

TEL NO: 043 726 2070
 FAX NO: 043 726 9232



BOREHOLE CONSTRUCTION & LITHOLOGY

BOREHOLE NO: 202-0019 PROJECT: Chris Hani Groundwater Study - Phase 2
 WATER LEVEL: DRILLER: BJ Cilliers LATITUDE:
 BLOW YIELD: DATE STARTED: 4/9/03 LONGITUDE:

BOREHOLE CONSTRUCTION	Apparent Water Quality:	Casing thickness:	mm	WATER STRIKE	DEPTH	S.W.L	PENETRATION RATE (min)	DEPTH	PROFILE	MATERIAL DESCRIPTION
CONSTRUCT	Casing depth:	m	m	(l/s)	(m)	(m)		(m)		
120	120						0	120		
125	125	165mm						125		5
130	130							130		10
135	135							135		15
140	140							140		20
145	145	165mm						145		25
150	150							150		30
155	155							155		35
160	160							160		40
165	165	165mm						165		45
170	170	EOH 159m						170		50
175	175							175		55
180	180							180		60
185	185							185		65
190	190							190		70
195	195							195		75
200	200							200		80
205	205							205		85
210	210							210		90
215	215							215		
220	220							220		


SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD
 9 SANSOM STREET
 VINCENT
 EAST LONDON

TEL NO: 043 726 2070
 FAX NO: 043 726 9232



BOREHOLE CONSTRUCTION & LITHOLOGY

BOREHOLE NO: EC-T11-003 PROJECT: Chris Hani Groundwater Study - Phase 2
 WATER LEVEL: DRILLER: BJ Cilliers LATITUDE: 28°12'16.6"E
 BLOW YIELD: 0.5l/s DATE STARTED: 4/14/03 LONGITUDE: 31°42'38.9"S



SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD
 8 SANSON STREET
 VINCENT
 EAST LONDON

TEL NO: 043 726 2070
 FAX NO: 043 726 9232



BOREHOLE CONSTRUCTION & LITHOLOGY

BOREHOLE NO: EC-T11-003 Cont. PROJECT: Chris Hani Groundwater Study - Phase 2
 WATER LEVEL: DRILLER: BJ Cilliers LATITUDE: 28°12'16.5"E
 BLOW YIELD: 0.5l/s DATE STARTED: 4/14/03 LONGITUDE: 31°42'38.9"S

BOREHOLE CONSTRUCTION	Apparent Water Quality	WATER STRIKE	STRIKE DEPTH	S.W.L	PENETRATION RATE (mm)	DEPTH	PROFILE	MATERIAL DESCRIPTION
Casing thickness:	m	m	(m)	(m)		(m)		
100	100				100	100		
						105		
						110		
						115		
						120		
						125		
						130		
						135		
						140		
						145		
						150		
						155		
						160		
						165		
						170		
						175		
						180		
						185		
						190		
						195		
						200		

155mm

155mm

155mm

ECH 150m

SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD
 9 SANSOM STREET
 VINCENT
 EAST LONDON


TEL NO: 043 726 2070
 FAX NO: 043 726 9232



BOREHOLE CONSTRUCTION & LITHOLOGY

BOREHOLE NO: EC-T11-004 PROJECT: Chris Hani Groundwater Study - Phase 2
 WATER LEVEL: DRILLER: BJ Cilliers LATITUDE: 28°09'45.0"
 BLOW YIELD: 0.5l/s DATE STARTED: 4/11/03 LONGITUDE: 31°34'50.3"

Apparent Water Quality: WATER STRIKE S.W.L. PENETRATION RATE (min) DEPTH PROFILE MATERIAL DESCRIPTION
 Casing thickness: mm STRIKE (l/s) DEPTH (m) (m) (m) (m) (m)



SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD


8 SANSOM STREET
VINCENT
EAST LONDON
TEL NO: 043 726 2070
FAX NO: 043 726 9232



BOREHOLE CONSTRUCTION & LITHOLOGY

BOREHOLE No EC-T11-004 Cont.1 PROJECT: Chris Hani Groundwater Study - Phase 2
WATER LEVEL: DRILLER: BJ Cilliers LATITUDE: 28°09'45.0"
BLOW YIELD: 0.5l/s DATE STARTED: 4/11/03 LONGITUDE: 31°34'50.3"

BOREHOLE CONSTRUCTION	Apparent Water Quality:	WATER STRIKE	DEPTH	S.W.L	PENETRATION RATE (min)	DEPTH	PROFILE	MATERIAL DESCRIPTION
Casing thickness:	mm	mm	(m)	(m)	0 10 20	(m)		
Casing depth:	m	STRIKE				100		
		(l/s)						



SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD
 9 SANSOM STREET
 VINCENT
 EAST LONDON

TEL NO: 043 726 2070
 FAX NO: 043 726 9232



BOREHOLE CONSTRUCTION & LITHOLOGY

BOREHOLE N° EC-T11-004 Cont.2 PROJECT: Chris Hani Groundwater Study - Phase 2
 WATER LEVEL: DRILLER: BJ Cilliers LATITUDE: 28°09'45.0"
 BLOW YIELD: 0.5l/s DATE STARTED: 4/11/03 LONGITUDE: 31°34'50.3"

BOREHOLE CONSTRUCTION	Apparent Water Quality:	Casing thickness:	mm	WATER STRIKE	DEPTH	S.W.L	PENETRATION RATE (min)	DEPTH	PROFILE	MATERIAL DESCRIPTION
CONSTRUCTION	Casing depth:	m	m	(l/s)	(m)	(m)		(m)		
200								200		
205	165mm							205		5
210								210		10
215								215		15
220								220		20
225	165mm							225		25
230								230		30
235								235		35
240	165mm							240		40
245								245		45
250								250		50
255								255		55
260								260		60
265								265		65
270								270		70
275	165mm							275		75
280								280		80
285								285		85
290								290		90
295								295		
300								300		

SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD

8 SANSOM STREET
VINCENT
EAST LONDON

TEL NO: 043 726 2070
FAX NO: 043 726 9232



BOREHOLE CONSTRUCTION & LITHOLOGY

BOREHOLE NF EC-T11-004 Cont.3

PROJECT : Chris Hani Groundwater Study - Phase 2

WATER LEVEL:

DRILLER : BJ Cilliers


LATITUDE : 29°09'45.0"

BLOW YIELD: 0.5l/s

DATE STARTED : 4/11/03

LONGITUDE : 31°34'50.3"

BOREHOLE CONSTRUCTION	Apparent Water Quality: Casing thickness:	mm	WATER STRIKE STRIKE (l/s)	STRIKE DEPTH (m)	S.W.L (m)	PENETRATION RATE (min)	DEPTH (m)	PROFILE	MATERIAL DESCRIPTION
-----------------------	--	----	------------------------------	---------------------	--------------	------------------------	--------------	---------	----------------------




SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD
 8 SANSOM STREET
 VINCENT
 EAST LONDON
 TEL NO: 043 726 2070
 FAX NO: 043 726 9232



BOREHOLE CONSTRUCTION & LITHOLOGY

BOREHOLE No EC-T11-005 PROJECT: Chris Hani Groundwater Study Phase 2
 WATER LEVEL: DRILLER: BJ Cilliers LATITUDE: 28°12'24.0"E
 BLOW YIELD: 0.5l/s DATE STARTED: 4/17/03 LONGITUDE: 31°42'34.4"



SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD
 8 SANSOM STREET
 VINCENT
 EAST LONDON


TEL NO: 043 726 2070
 FAX NO: 043 726 9232



BOREHOLE CONSTRUCTION & LITHOLOGY

BOREHOLE NF EC-T11-007
 PROJECT : Chris Hanl Groundwater Study - Phase 2
 WATER LEVEL: DRILLER : BJ Cilliers
 BLOW YIELD: 6 l/s DATE STARTED : 07/05/2003
 LATITUDE : 28°17'45.6"
 LONGITUDE : 31°34'36.9"S

Apparent Water Quality: WATER STRIKE S.W.L. PENETRATION RATE (min) DEPTH PROFILE MATERIAL DESCRIPTION
 Casing thickness: mm STRIKE (l/s) DEPTH (m) (m) (min) (m) (m)



165 mm

ECH 75 m

SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD
 8 SANSOM STREET
 VINCENT
 EAST LONDON


TEL NO: 043 726 2070
 FAX NO: 043 726 9232



BOREHOLE CONSTRUCTION & LITHOLOGY

BOREHOLE NO: EC-T11-008 PROJECT: Chris Hanj Groundwater Study - Phase 2
 WATER LEVEL: DRILLER: BJ Cilliers LATITUDE: 28°16'57.2"E
 BLOW YIELD: 10 l/s DATE STARTED: 9/5/03 LONGITUDE: 31°36'04.6"S

BOREHOLE CONSTRUCTION	Apparent Water Quality:	WATER STRIKE	STRIKE DEPTH	S.W.L	PENETRATION RATE (min)	DEPTH	PROFILE	MATERIAL DESCRIPTION
Casing thickness:	4 mm	4 mm	(m)	(m)		(m)		
Casing depth:	18 m	18 m	(m)					



SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD

8 SANSON STREET

VINCENT

EAST LONDON

TEL NO: 043 726 2070

FAX NO: 043 726 9232



BOREHOLE CONSTRUCTION & LITHOLOGY

BOREHOLE NF EC-T12-004

PROJECT :

Chris Hani Groundwater Study - Phase 2

WATER LEVEL:

DRILLER :

BJ Cilliers


LATITUDE : 27°46'50.1"E

BLOW YIELD: 15l/s

DATE STARTED : 25/04/2003

LONGITUDE : 31°37'11.9"S

BOREHOLE CONSTRUCTION	Apparent Water Quality: Good	Casing thickness: mm	WATER STRIKE (l/s)	STRIKE DEPTH (m)	S.W.L (m)	PENETRATION RATE (min)	DEPTH (m)	PROFILE	MATERIAL DESCRIPTION
-----------------------	------------------------------	----------------------	--------------------	------------------	-----------	------------------------	-----------	---------	----------------------




SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD
 8 SANSOM STREET
 VINCENT
 EAST LONDON

TEL NO: 043 726 2070
 FAX NO: 043 726 9232



BOREHOLE CONSTRUCTION & LITHOLOGY
 BOREHOLE No: EC-T12-005 PROJECT: Chris Hani Groundwater Study - Phase 2
 WATER LEVEL: DRILLER: BJ Cilliers LATITUDE: 28°44'25.5"E
 BLOW YIELD: 21/s DATE STARTED: 4/22/03 LONGITUDE: 31°43'30.3"S



SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD
 8 SANSOM STREET
 VINCENT
 EAST LONDON


TEL NO: 043 726 2070
 FAX NO: 043 726 9232



BOREHOLE CONSTRUCTION & LITHOLOGY

BOREHOLE No EC-T12-005 Cont. PROJECT: Chris Hani Groundwater Study - Phase 2
 WATER LEVEL: DRILLER: BJ Cilliers LATITUDE: 28°44'25.5"E
 BLOW YIELD: 21/s DATE STARTED: 4/22/03 LONGITUDE: 31°43'30.3"S

Apparent Water Quality: WATER STRIKE S.W.L. PENETRATION RATE (min) DEPTH PROFILE MATERIAL DESCRIPTION
 Casing thickness: 4 mm STRIKE DEPTH (m) (m) (m) (m) (m) (m) (m)
 Casing depth: 6 m (l/s) (m)



SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD
 9 SANSON STREET
 VINCENT
 EAST LONDON

TEL NO: 043 726 2070
 FAX NO: 043 726 9232



BOREHOLE CONSTRUCTION & LITHOLOGY

BOREHOLE No EC-T12-006 (a) PROJECT: Chris Hani Groundwater Study Phase 2
 WATER LEVEL Dry DRILLER: BJ Cilliers LATITUDE: 31°46'9.6"S
 BLOW YIELD: Dry DATE STARTED: 4/25/03 LONGITUDE: 28°04'19.6"E

BOREHOLE CONSTRUCTION	Apparent Water Quality:	WATER STRIKE	STRIKE DEPTH	S.W.L	PENETRATION RATE (min)	DEPTH	PROFILE	MATERIAL DESCRIPTION
Casing thickness:	mm	STRIKE	(m)	(m)	0 10	(m)		
Casing depth:	m	(l/s)				0		
Concrete plug						0		
						5		
						10		
						15		
						20		
						25		
						30		
						35		
						40		
						45		
						50		
						55		
						60		
						65		
						70		
						75		
						80		
						85		
						90		
						95		
						100		

SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD
 8 SANSON STREET
 VINCENT
 EAST LONDON

TEL NO: 043 726 2070
 FAX NO: 043 726 9232



BOREHOLE CONSTRUCTION & LITHOLOGY

BOREHOLE N° EC-T12-006 (b) PROJECT : Chris Hani Groundwater Study Phase 2
 WATER LEVEL Dry DRILLER : BJ Cilliers LATITUDE : 31°46'9.6"S
 BLOW YIELD: Dry DATE STARTED : 4/25/03 LONGITUDE : 28°04'18.6"E

BOREHOLE CONSTRUCTION	Apparent Water Quality	WATER STRIKE	STRIKE DEPTH	S.W.L	PENETRATION RATE (min)	DEPTH	PROFILE	MATERIAL DESCRIPTION
Casing thickness:	mm	(l/s)	(m)	(m)		(m)		
Casing depth:	m							
Concrete plug						0		
						5		
						10		
						15		
						20		
						25		
						30		
						35		
						40		
						45		
						50		
						55		
						60		
						65		
						70		
						75		
						80		
						85		
						90		
						95		
						100		

SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD

8 SANSOM STREET

VINCENT

EAST LONDON

TEL NO: 043 726 2070

FAX NO: 043 726 9232



BOREHOLE CONSTRUCTION & LITHOLOGY

BOREHOLE N° EC-T12-006 (c)

PROJECT :

Chris Hani Groundwater Study Phase 2

WATER LEVEL Dry

DRILLER :


BJ Cilliers

LATITUDE : 31°46'9.6"S

BLOW YIELD: Dry

DATE STARTED : 4/25/03

LONGITUDE : 28°04'18.6"E



SOUTHERN AFRICA GEOCONSULTANTS (PTY) LTD
 8 SANSON STREET
 VINCENT
 EAST LONDON
 TEL NO: 043 726 2070
 FAX NO: 043 726 9232



BOREHOLE CONSTRUCTION & LITHOLOGY

BOREHOLE NO: EC-T12-009 PROJECT: Chris Hani Groundwater Study - Phase 2
 WATER LEVEL: DRILLER: BJ Cilliers LATITUDE: 28°17'51.9"E
 BLOW YIELD: 1.2 l/s DATE STARTED: 5/12/03 LONGITUDE: 31°49'14.2"S

Apparent Water Quality: WATER STRIKE S.W.L. PENETRATION RATE (min) DEPTH PROFILE MATERIAL DESCRIPTION
 Casing thickness: 4 mm STRIKE DEPTH (m) (m)
 Casing depth: 11.5 m (l/s)

