





Appendix 1 An Introduction to the Electronic Water Quality Management System (eWQMS)

NOTE: The reader should not be constrained by the current configuration or functionality of the eWQMS. The current eWQMS framework could be easily modified and adapted to meet the requirements of the Adopt-A-River Programme. The eWQMS is therefore used as an example to highlight what can be achieved.

1. Background

WSAs have responsibilities including protection and management of water resources, operation and maintenance of infrastructure, monitoring and management of drinking water quality, reporting to DWAF with regards to the aforementioned, etc. In order to ensure an effective and sustainable water service, the above mentioned aspects must be addressed by WSAs. However, a number of recent surveys have indicated that many WSAs in the South Africa are not effectively monitoring and managing the quality of drinking water. Accordingly, DWAF and other water sector partners (e.g. IMESA, SALGA, WRC) have undertaken various initiatives to assist WSAs with operation and management of water services. In particular, DWAF, together with IMESA have rolled out the eWQMS to all 169 WSAs in South Africa. The eWQMS allows WSAs to interpret water quality data and highlights issues of concern requiring intervention. Data loaded by WSAs onto the eWQMS have further enhanced functional Information System (NIS). Recent developments to the eWQMS have further enhanced functionality including the ability of WSAs to conduct self assessments of DWQM, infrastructure, etc.

2. IMESA Lead Iterative Enhancement Process

IMESA's specific roll is as an impartial honest broker ensuring that the eWQMS solution is appropriate and supportive of Municipal Engineering requirements. This is achieved by IMESA participating in both initial municipal interaction forums, and subsequently by IMESA led iterative feedback sessions with municipal users. At these sessions, recent new developments are presented to WSAs, ideas are brainstormed with WSAs, and WSAs are given the opportunity to provide feedback regarding:

- Useful features/functions of the eWQMS
- Features/functions that could be improved/amended
- Future desirable features/functions

WSAs are also asked to rank new and/or desirable features/functions from High to Low.

The above process helps to determine the actual on-the-ground needs at WSAs. Feedback obtained from these sessions is collated and desirable features/functions categorised and ranked. Subsequently, incremental improvements and enhancements are introduced to the tool.







3. Brief Overview of the eWQMS System

The eWQMS tool is a well proven comprehensive Water Quality Management tool, which has an established track record of being successfully used by WSA's, Regional and National DWAF offices, and the public. eWQMS has been set up to assist WSAs to meet the National Drinking Water Quality Management Framework requirements, and is a full management system. In particular, the eWQMS able to guide:

- Regulatory compliance by WSAs
- The timeous supportive intervention in water quality failures (chronic and acute)
- Infrastructure improvement
- Capacity development of municipal staff

The eWQMS is an internet accessible database system (accessible at www.wqms.co.za) utilising **open source** components (mySQL, XML, etc), and has been found following detailed assessment by DWAF's IT support team to be fully compatible with and compliant to DWAF Water Services National Information System and DWAF Regulatory System requirements.

Importantly, the eWQMS has been developed in a "bottom up" approach with WSAs, IMESA, DWAF and the Water Research Commission. Data can be loaded by WSAs onto eWQMS via the internet, spreadsheet or specific import scripts. Furthermore, the eWQMS can provide useful automated regulatory compliance reporting to all WSAs and sector partners. The eWQMS also provides easy access to useful water quality tools and information. Presently, the eWQMS consists of the following main components:

- Login/Logout
- Water Quality
- Infrastructure
- Risk Toolbox
- Administration
- Information

Considering the above, the following main features are described (*NOTE:* A full demonstration will be gladly provided on request):

System Access

The system is usually accessible via the internet for full use (including via DBSA's LGNET), providing considerable costs and operational efficiency benefits over local application based systems. Nevertheless, the system can run as an independent local application if required. Information and reference material can be accessed without the need to login (This is especially useful to members of the public (e.g. teachers, students, etc) and saves municipal officials time).



Figure A1: eWQMS access via the internet



Figure A2: eWQMS access via DBSA's LGNET

System Compatibility

The system can be set up to run off existing water quality management systems, such as







LIMS systems. A number of "import scripts/patches" already exist, and where necessary additional will be written for data import. *E.g. of import scripts/patches includes Johannesburg Water and eThekweni*

Login/logout

A user is provided with username and password. A particular user will be provided with a WSA, District, Provincial or National view. Furthermore, limited detail "public" views of DWQ can be set up if required. *E.g. of Provincial view includes Free State; public view includes Stellenbosch.*



Figure A3: eWQMS login (Delmas Municipality, Mpumalanga)



Figure A4: WSA homepage (Drakenstein Municipality, Western Cape)







Water Quality Management

A key functional requirement is easy water quality data loading and interpretation. The system can interpret data against a range of standards, but defaults to SANS 241. The system is capable of interpreting wastewater and river water quality data. Current functionality includes:

Management Dashboard [summarised monthly view of legislative compliance & identification of areas requiring urgent attention; easy colour coding to show compliance (green), failure of SANS 241 class 1 (yellow), and failure of SANS 241 class 2 (red)].



Figure A6: Detail of "Red" failure and actions taken to address issue of concern (Buffalo City, Eastern Cape)

Done

King William's Town

KWT Beaconhill Reservoir

E.coli (health)

2007/06/05







 Overview (map-based interface with "period based" compliance summary of bacteriological, physical and chemical DWQ).



Drinking Water Quality Summary

Microbiological Safety :: Microbiological Operational :: Physical :: Chemical

Configure Parameters	Faecal Colif	orms (health)	E.coli	(health)
Area	SampleCount	Compliance %	SampleCount	Compliance %
South Africa	11920	98 (view)	24070	96 (view)
North West	1295	99 (view)	1139	99 (view)
Bojanala Platinum District Municipality	114	100 (view)	642	99 (<mark>view</mark>)
Madibeng Municipality			161	100 (<mark>view</mark>)
Brits			15	100 (view)
Cosmos East			15	100 (view)
Damonsville			19	100 (view)
Elandsrand			15	100 (view)
Hartbeespoort			17	100 (view)
Jericho			17	100 (view)
Letlhabile			12	100 (view)
Madidi			11	100 (view)
Meerhof			13	100 (view)
Mmakau			14	100 (view)
Sonop			13	100 (view)
Data Period		2006/09/01 t	o 2007/08/30	

Quality of Water System	Microbiological requirement	Chemical requirement

	Column 5 of Table 1	Class I	Class II
Excellent	>= 99%	>= 95%	>= 97%
Good	>= 98%	>= 90%	>= 95%
Fair	>= 97%	>= 85%	>= 90%
Poor	< 97%	< 85%	< 90%

Figure A7: *eWQMS Overview (microbiological safety) (Local Municipality of Madibeng, North West)*



water & forestry Department:

Water Affairs and Forestry REPUBLIC OF SOUTH AFRICA





Configure Parameters		Aluminium (he	alth)	Iro	n (aesthetic/ope	erational)
Area	SampleCount	Compliance %	Median(mg/L as Al)	SampleCount	Compliance %	Median(mg/L as Fe)
South Africa	1917	87 (view)	0.07	5351	85 (view)	0.04
Western Cape	482	76 (view)	0.12	1142	68 (view)	0.11
Knysna Municipality	67	34 (view)	0.41	67	47 (view)	0.20
Buffalo Bay	15	0 (view)	1.14	15	93 (view)	0.06
Karatara	13	100 (view)	0.05	13	69 (view)	0.11
Knysna (Town)	12	50 (view)	0.29	12	41 (view)	0.30
Rheenendal	12	8 (view)	1.30	12	0 (view)	0.40
Sedgefield	15	20 (view)	0.36	15	26 (view)	0.25
Data Period		-	2006/05/021	o 2007/04/30		^

Notes:

- The median value displayed is the median of all samples collected in the particular area. The median value is compared to SANS 241 an
- The percentage compliance displayed is the percentage of all samples collected in the area falling within SANS: Physical, Organoleptic, C · Based on samples taken during the last 12 months.

Applicable Standards

SANS: Physical, Organoleptic, Chemical: Class I	
SANS: Physical, Organoleptic, Chemical: Class II	
Failure Phys-Organo-Chem: Class II (Aesth/Operat)	
SANS: Failure Phys-Organo-Chem: Class II (Health)	

SANS 241-2005 Table C.2: Compliance frequency targets in respect of microbiological and chemical requirements that have health implicati

Quality of Water System	Microbiological requirement	Chemical r	equirement
	Column 5 of Table 1	Class I	Class II
Excellent	>= 99%	>= 95%	>= 97%
Good	>= 98%	>= 90%	>= 95%
Fair	>= 97%	>= 85%	>= 90%
Poor	< 97%	< 85%	< 90%

Figure A8: eWQMS Overview (chemical) (Knysna Municipality, Western Cape)

Quick Analysis (quick links to regularly used operational efficiency and legislative 0 compliance tables/graphs and trend analysis)

e Hotmail 📄	Windows Marketplace 📄	Windows Media 📋 Windo	ows				
	Sandton / Alex	732	0				
	Soweto	606	0				
	Data Period	2006/09/01 to 2007/08/	30				
	Notes:						
	 The median value The percentage Based on sample 	ue displayed is the medi compliance displayed is les taken during the last	an of all samples co the percentage of 12 months.	ollected in the p all samples coll	articular area. The media lected in the area falling w	n value is compared to SAN. ithin SANS: Microbiological	S 241 and colou 'Safety: Columr.
	Applicable Standards						
	SANS: Microbiological	Safety: Column 3					
	SANS: Microbiological	Safety: Column 4					
	SANS: Microbiological	Safety: Column 5					
	SANS: Failure Microbio	logical Safety: Column 5					
	Quality of Water Syste	m Microbiological requi	rement Chemical I	equirement	ogroa and onemedi req		in protectorio
		Column 5 of Tabl	e 1 Class I	Class II			
	Excellent	>= 99%	>= 95%	>= 97%			
	Good	>= 98%	>= 90%	>= 95%			
	Fair	>= 97%	>= 85%	>= 90%			
	Poor	< 97%	< 85%	< 90%			
	Configure Parameters Useful Tables and • E.coli - Percenta • Free Chlorine R	for Summary Graphs age Failure esidual - Median per Are	a				
	 pH - Median per Total Coliform - Turbidity - Media 	Area Percentage Failure an per Area				6	

Figure A9: Example of quick analysis links at the bottom of the Overview

Detailed Analysis (dynamic Tables and Graphs with full flexibility) 0







Drinking Water Analysis

Report Selection

Point Analysis Table

single determinant | determinant set The point analysis table provides a detailed water quality analysis for a selected sampling point vs. the applicable water quality standards.

Point Analysis Graph single determinant

The point analysis graph provides a graphical water quality analysis for a selected sampling point vs. the applicable water quality standards.

Median Value Graph

single determinant The median value graph shows the median value of a particular determinant in an area vs. the applicable water quality standards.

Compliance Table single determinant | multiple determinants

The compliance table analyses the percentage compliance in an area vs. the applicable water quality standards.

Failure Table

The failure table highlights failures in an area vs. the applicable water quality standards.

Failure Graph single determinant

The failure graph shows the percentage failure of a particular determinant in an area vs. the applicable water quality standards.

Combined Compliance/Failure Graph

single determinant The combined Comliance/Failure graphs show the percentages of particular determinant in an area vs. the applicable water quality standards.

Raw Analysis Data analysis values as csv

analysis values as csv Download analysis values in CSV format.

Raw Sample Point Data

Figure A10: eWQMS Analysis (tables and graphs)

Dynamic Drinking Water Reports

Water Quality Compliance Table

E.coli (health) (count per 100 mL) for Central

	June 20	106	July 20	06	August 2	006
Area	Samples Complied	% Compliance	Samples Complied	% Compliance	Samples Complied	% Compliance
Central	22 / 22	100%	22 / 22	100%	23 / 23	100%
Berea North	2/2	100%	2/2	100%	2/2	100%
Berea South	2/2	100%	2/2	100%	2/2	100%
Bluff	2/2	100%	2/2	100%	2/2	100%
Chatsworth	2/2	100%	2/2	100%	2/2	100%
Durban Centre	2/2	100%	2/2	100%	2/2	100%
Durban North	2/2	100%	1/1	100%	2/2	100%
Merebank	2/2	100%	1/1	100%	2/2	100%
New Germany	2/2	100%	2/2	100%	2/2	100%
Phoenix	1/1	100%	2/2	100%	2/2	100%
Pinetown	2/2	100%	2/2	100%	2/2	100%
Umbilo	2/2	100%	3/3	100%	2/2	100%
Umhlanga	1/1	100%	1/1	100%	1/1	100%
				Water & fore Department Water Affairs and Forestry REPUBLIC OF SOUTH A		@WISA

Notes

Figure A11: Compliance table example (Ethekwini Municipality, KwaZulu-Natal)







Polokwane Water Treatment Plant Final Point Analysis Turbidity (aesthetic/operational/indirect health) (NTU) 1.5 1.0 0.5 0.0-^{Jan 2006} Feb 2006 ⁴0r 2006 May 20061 Jun 2006 Sep 2006 Mar 2006 141 2006 1 Aug 2006 - Turbidity (aesthetic/operational/indirect health) (NTU) - SANS: Physical, Organoleptic, Chemical: Class I upper limit water & forestry WISA IMES of South AFRICA

Figure A12: Point analysis graph example (Polokwane Municipality, Limpopo)



Figure A13: Percentage failure graph example (Tokologo Municipality, Free State)







compliance Graph



o *Reports* (archive of water quality management reports in Adobe Acrobat format).



Figure A15: eWQMS reports (Free State)







Data Entry - mostly via internet and/or Excel, but patches exist and can be developed for to link to existing systems such as LIMS / UNIX / etc for specific clients)

• 🕪 • 😹 🔝 🚺 [http://www.wqms.co.za/	'admin/				
Customize Links 📔 Free Hotmail [🗋 Windows Marketplace 📋	Window	is Media 📘	Windows		
import data import sample points	Date Analysed (optional)					
	Lab Number (optional)				1	
	Type (optional)	Not ap	plicable		×	
	Comments (optional)	Poor addre safe Manae	disinf essed. to dri ger (da	ection efficiency Re-sampling indic nk. Issue has bee te)	. Issue has been ated that water is n resolved. Mr	
	Determinant		Value	Unit	Reason for no value	
	Aluminium (health)		0.15	mg/L as Al	None	~
	E.coli (health)		10	count per 100 mL	None	*
	Electrical Conductivity (aesthetic)			mS/m	Analysis not carried out	*
	Fluoride (health)			mg/L as F-	Analysis not carried out	*
	Free Chlorine Residua (operational)	al	0	mg/L	None	~
	Iron (aesthetic/operatio	onal)	0.15	mg/L as Fe	None	*
	Nitrates and Nitrites (h	iealth)	0	mg/Las N	None	*
	pH (aesthetic/operation	nal)	7.6	pH units	None	~
	Total Coliforms (opera	itional)	25	count per 100 mL	None	~
	Turbidity (aesthetic/operational/	indirect	4.5	NTU	None	~

Figure A16: eWQMS data entry via the internet (Sol Plaatje, Northern Cape)

and a						
×	Microsoft Excel - Umzinyathi LM July 2007 (1).:	ds				
	Eile Edit Yiew Insert Format Iools Data	Window Help				Type a question for help 🛛 🗧 🛛
	📸 🖬 💫 🖂 🖂 🖉 🛍 👗 🖬 🕵 •		Z Courier New	- 10 - B I U	E 🗏 🖬 📑 % , 🐭	-09 == == =
: 💴		ply with Changes End Review	5			
_	A1/ 👻 🏂 Sample ID		2	-	-	
1	A	B	U U	U	E	<u> </u>
2	Sampling organisation	omzinyachi Discricc M	unicipality	Testing Laboratory		
3	Autress			Auuress		
4						
5	Telephone			Telephone		
6	Fax			Fax		
7	E-mail			E-mail		
8	Contact Person			Contact Person		
10	Organisation	Umzinyathi District Mu	unicipality		Reasons for Lack of Sa	mple Results
11	Sampler	Umzinyathi District Mu	unicipality		N/s	Not applicable
12	Report Date	2007/07/02			8	Maintenance/repair:
13	Date Samples Received	2007/07/02			h	Not sampled
14	Date Analysis Completed	2007/07/02				
15	Municipality	Endumeni Municipality				Msinga Municipalit
10	Sample Point Description	Biggarsberg WTW Final	Biggarsberg Bulk Manifold	Vant's Drift WTW Final	Wasbank Reservoir	Sampofu WTW Final
10	Sample 10	K20MEN-001	KZUREN-UUZ	RZUMEN-UU3	K20REN-004	KZUMMS-001
10		2007/07/02	2007/07/02	125	2007/07/02	71
19	Aikaiinity (mg/L as cacos)	a .	60	E4		18
20	calcium (aestnetic/operational) (mg/	α			α.	10
21	Calcium Carbonate Dissolution Potent	d	C	C	d	L 10
22	Electrical Conductivity (aesthetic)	d		5/	d	22
23	Faecal Coliforms (health) (count per	b	U	U 15	b	
24	Free Chlorine Residual (operational)	b	0.86	1.5	b	2
25	Iron (aesthetic/operational) (mg/L a	b	0.02	0.03	b	0.02
26	Fluoride (health) (mg/L as F-)	b	U.42	0.32	b	0.12
27	Calcium Hardness (mg/L as CaCO3)	b	130	135	b	40
28	Magnesium Hardness (mg/L as CaCO3)	b	34	71	b	30
29	Total Hardness (mg/L as CaCO3)	b	165	205	b	70
30	Heterotrophic Plate Count (operation	b	1	Ū.	b	0
31	Magnesium (aesthetic/health) (mg/L a	b	8.3	17	b	7.3
22	Care and the second	1-	9.1	7.0	1-	7.5

Figure A17: eWQMS data entry via spreadsheet (submitted via e-mail) (Umzinyathi Municipality, KwaZulu-Natal)



Figure A18: *eWQMS* data loading via import script/patch (Ethekwini Municipality, KwaZulu-Natal)

• **Automation** (auto-notification by e-mail of failures, generation of auto-reports and summary reports for feedback to the full range of participating parties)



Figure A19: eWQMS e-mail with report as attachment ((Bitou Municipality, Western Cape)



Figure A20: *eWQMS e-mail with report accessible via internet link (Gamagara Municipality, Northern Cape)*

3. Drinking V	Vater Quality	y Overview		
3.1. Managemer	t Dashboard			
Sites are categorized as	follows:			
 Green/Blue (A Class I (Accept 	cceptable): All paramet table) limits)	ers monitored satisfy requir	red minimum standar	ds (i.e. SABS 241-200
 Yellow: One o minimum guid 	r more parameters mor elines	itored fail SABS 241-2001	Class I (Acceptable) I	Limits or other require
Red: One or n	ore parameters monito	red fail SABS 241-2001 Cla	ass II (Maximum Allov	vable) Limits
The following results are	presented for Decemb	per 2005:		
	a)-	21 sites or 84% of mo	nitored sites	
Acceptable (Blue/Gree	ay.	21 Sites of 0470 01110	intored sites	
Acceptable (Blue/Gree Needs Attention (Yello	•••• w):	4 sites or 16% of mon	itored sites	
Acceptable (Blue/Gree Needs Attention (Yello Failure of SABS-241-2 Detailed information rel following table presents	w): 001 Class II Limits (Re ated to the above table details of those sites v	4 sites of 04 x of mon 4 sites or 16% of mon 0 0 sites can be accessed via the N which were classified as be	litored sites	ard of your website. Th GABS 241-2001 Class
Acceptable (Blue/Gree Needs Attention (Yelia Failure of SABS 241-2 Detailed information rel following table presents (Maximum Allowable) L	w): 001 Class II Limits (Re ated to the above table details of those sites w mits).	4 sites of 04 x of Hol 4 sites or 18% of moni 0 it 0 sites can be accessed via the N which were classified as be Red: December 2005	Anagement Dashboa	ard of your website. Th ABS 241-2001 Class
Acceptable (Blue/Gree Needs Attention (Yello Failure of SABS 241-2 Detailed information rel following table presents (Maximum Allowable) L Area	w): 001 Class II Limits (Re ated to the above table details of those sites w mits).	4 sites of 64 x 6 moi 4 sites or 18% of mon 0 sites can be accessed via the N which were classified as be Red: December 2005 Sample Point	Itored sites Ianagement Dashboz ing Red (i.e. failing S Determinan	ard of your website. Th SABS 241-2001 Class
Acceptable (Blue/Gree Needs Attention (Yelio Failure of SABS 241-2 Detailed information rel following table presents (Maximum Allowable) L Area	w): 001 Class II Limits (Rei ated to the above table details of those sites w mits).	4 sites of 04 x 0 mol 4 sites or 18% of mon 0) D sites can be accessed via the N which were classified as be Red. December 2005 Sample Point None	Itored sites Itored sites Itanagement Dashboo eing Red (i.e. failing S Determinant	ard of your website. T SABS 241-2001 Class Date Occurre

Figure A21: Extract from an automatic monthly summary report

Infrastructure

0

Captures WSA infrastructure details related to abstraction points, treatment systems, storage facilities (e.g. reservoirs), reticulation/point of use (e.g. sampling points), DWQM Programmes (frequency of monitoring, parameters, etc) and laboratories utilised.



Figure A22: eWQMS Infrastructure component

Figure A23: *Example of raw water abstraction details on the eWQMS (Stellenbosch Municipality, Western Cape)*

DWQM Risk Profiles

Assessment tools have been introduced which allow WSAs to perform a self-assessment of the status of their WSA. Examples include a strategic level WQM Sustainability Analysis (Gap Analysis) and a Water Research Commission "Drinking-Water Treatment Plant and Distribution Network Assessment and Risk Profile" system.







😇 City of Johannesburg Water Quality Management System - Mozilla Firefox						
<u>File Edit View History Bookma</u>	arks Iools Help					
- 🔶 - 💽 🐼 🚮	http://www.wgms.co.za/questionnaires/gap?st=18mi=3					
Customize Links - Free Hotmail - Windows Marketplace - Windows Media - Windows						
CityOfJohannesburg						
Drinking Water 🔽 🔹 water quality infrastructure 💺 risk profile administration information logout						
 * reports risk assessment reports * gap analysis gestonnaire * gap analysis spider chart and detailed breakdown * drinking water supply questonnaire * waste stabilization ponds waste stabilization ponds report spider chart and detailed breakdown 	Answer Gap Questionnaire Click Save at any time to save the current set of answers. Once you are satisfied with your answers click Complete. Only answer sets withems in red require your attention. Part A: Water Legislation, Policies and Regulations 1. Do you have a copy of the National Water Act? ③ Yes ○ No 2. Do you have a copy of the Water Services Act? ④ Yes ○ No 3. Do you have a copy of Compulsory National Standards for Potable Water ? ④ Yes ○ No 4. Do you have a copy of National DWQM Framework? ④ Yes ○ No 5. Do you have a copy of SANS 241-2005 Drinking Water Specification? ④ Yes ○ No 6. Have you read, understood and implemented the National Water Act? ④ Yes ○ No 7. Have you read, understood and implemented the Compulsory National Standards for Potable Water? ④ Yes ○ No 8. Have you read, understood and implemented the Compulsory National Standards for Potable Water? ④ Yes ○ No 8. Have you read, understood and implemented the Compulsory National Standards for Potable Water? ④ Yes ○ No 8. Have you read, understood and implemented the National DWQM Framework? ④ Yes ○ No 9. Have you read, understood and implemented the National DWQM Framework?					















Figure A25: Water supply system questionnaire and spider diagram output (Kannaland Municipality, Western Cape)







Administration

Current WSA functionality includes the ability to manage sample points (add new/edit existing), manage recipients/distribution lists for automated communications, manage required automatic notifications (e-mail, summary report), data entry (water quality, infrastructure, etc) and ability to add comments related to drinking-water failures and actions taken to address issues of concern (i.e. comments serve as an action record taken to address issues of concern).

🕲 City of Tshwane Metropolitan	Water Quality M	anagement System - Mozilla F	irefox	
<u>File E</u> dit <u>V</u> iew Hi <u>s</u> tory <u>B</u> ookman	rks <u>T</u> ools <u>H</u> elp			
 	🕒 http://www.wqm	s.co.za/samplepoints?st=18mi=4		
📄 Customize Links 📄 Free Hotmail [Windows Marketpl	ace 📄 Windows Media 📄 Windows	5	
City Of Tshwane	Metropolit	an		W
Drinking Water 💌 💺 water o	quality 🚺 infras	tructure 🔹 risk profile 🊦 a	administration information log	out
0) is comple points	Drinkina V	ater Administration		
manage sample points definitions	Sample Poin	ts		
in strecipients t manage recipient list	new sample poi	nt		
t > notifications	ID	Description	Area	
Q manage recipient	GPCTHA-001	Hammanskraal Reservoir New	Hammanskraal Bulk Zone	
 notifications 	GPCTHA-002	Hammanskraal Reservoir Old	Hammanskraal Bulk Zone	
	GPCTMA-001	Madidi Reservoir	Madibeng Bulk Zone	
	GPCTMA-002	Oskraal Reservoir	Madibeng Bulk Zone	
	GPCTNW-001	Makepanstad Reservoir	Temba North (NW Prov)	
	GPCTOS-001	Varsfontein	Own Sources Bulk Zone	
	GPCTOS-002	Erasmia Borehole	Own Sources Bulk Zone	
	GPCTRA-001	Garankuwa East Reservoir	Rand 1 (Garankuwa) Bulk Zone	
	GPCTRA-002	Garankuwa West Reservoir	Rand 1 (Garankuwa) Bulk Zone	
	GPCTRD-001	Mabopane Central Reservoir	Rand 3 (Mabopane) Bulk Zone	
	GPCTRD-002	Mabopane Main Resevoir	Rand 3 (Mabopane) Bulk Zone	
	GPCTRD-003	Mabopane Reservoir	Rand 3 (Mabopane) Bulk Zone	
	GPCTRD-004	Odi Hospital Reservoir	Rand 3 (Mabopane) Bulk Zone	
	GPCTRD-005	Winterveldt Reservoir	Rand 3 (Mabopane) Bulk Zone	
	GPCTRN-001	Garankuwa Industrial Reservoir	Rand 2 (Garankuwa Industrial) Bulk Zone	
	GPCTRN-002	Klipgat Reservoir	Rand 2 (Garankuwa Industrial) Bulk Zone	
	GPCTTE-001	Temba Final Water	Temba	
	GPCTTR-001	Temba Reservoir 1	Temba WTP Bulk Zone	
	GPCTTR-002	Temba Reservoir 2	Temba WTP Bulk Zone	
	GPCTTR-003	Temba Reservoir 3	Temba WTP Bulk Zone	
		Record 1 to 2	0 of 148 Next ►	

Figure A26: Sample point administration (City of Tshwane, Gauteng)

Guiding Information

Current functionality includes a convenient repository of drinking-water related information including: abstraction, treatment, storage, reticulation and point of use, Water Quality Monitoring and Management Programmes, water quality parameters, their effects and how to rectify issues, laboratories, water related sites and news and References including National Water Act, Water Services Act, Compulsory National Standards for DWQ, National DWQM Framework, etc.



nt	Microbiological Parameters
	Escherichia coli (E.coli) is used as an indicator of faecal pollution by warm blooded animals (often interpreted as human faecal pollution). The presence of faecal pollution by warm blooded animals (often interpreted as human faecal pollution). The presence of faecal pollution by warm blooded animals (often interpreted as human faecal pollution). The presence of faecal pollution by warm blooded animals (often interpreted as human faecal pollution). The presence of faecal pollution by warm blooded animals (often interpreted as human faecal pollution). The presence of faecal pollution by warm blooded animals (often interpreted as human faecal pollution).
itation	Effect and possible implications of failure
	◆ Health
	The risks of being infected correlates with the level of contamination of the water and the amount of contaminated water consumed. Higher concentrations of <i>E.coli</i> in water will indicate a higher risk of contracting waterborne disease, even if small amounts of water are consumed. Any bacteriological failure with regards to <i>E.coli</i> can therefore be considered a direct indication of risk to health.
	SANS 241-2005 Standards
	 SANS 241-2005 Table 1 (Microbiological safety requirements) column 3 Allowable Compliance Contribution (95% of samples min) Upper Limit: Not detected (count per 100 ml) SANS 241-2005 Table 1 (Microbiological safety requirements) column 4 Allowable Compliance Contribution (4% of samples max) Upper Limit: Not detected (count per 100 ml) SANS 241-2005 Table 1 (Microbiological safety requirements) column 5 Allowable Compliance Contribution (1% of samples max) Upper Limit: Not detected (count per 100 ml) SANS 241-2005 Table 1 (Microbiological safety requirements) column 5 Allowable Compliance Contribution (1% of samples max) Upper Limit: 1 (count per 100 ml)
	Possible reason/s for failure
	 No disinfection (e.g. no chlorine dosing, no ozone dosing, no UV system) No residual chlorine or low level of residual chlorine (e.g. chlorine not added at plant, residual chlorine below 0.2 mg/L at point of consumption) Contamination (e.g. from pipe breaks and bursts, from repairs to network, infiltration or seepage from a contaminated source, sewage near groundwater sources, contamination from pit latines/septic tanks, rubbish and faecal matter around standpipes) Lack of maintenance (e.g. reservoirs and pipes not cleaned/flushed) Poor design (e.g. long retention times in reservoir and distribution network, open reservoirs, large reticulation network with no additional chlorine dosing at reservoirs) Sabotage/vandalism
	Faecal Coliforms
	Faecal collform bacteria are found in water wherever the water is contaminated with faecal waste of human or animal origin. Faecal collforms are primarily used to indicate the presence of bacterial pathogens such as Salmonella spp., Shigella spp., Vibrio cholerae, Campylobacter jejuni, Campylobacter coli, Yersinia enterocollitica and pathogenic E. coli. These organisms can be transmitted via the faecal/oral route by contaminated or poorly treated water and may cause diseases such as gastroenteritis, salmonellosis, dysentery, cholera and typhoid fever.
	Effect and possible implications of failure

Figure A27: Information examples

4. User Requested Enhancements to the eWQMS System

As noted in Section 2, through the national roll-out process and IMESA led workshops, a number of enhancements to eWQMS functionality have been requested by system users. This has lead to the prioritisation of system user requirements and necessary incremental IT development of the eWQMS to meet the specified system user requirements. The development to the eWQMS includes enhancements to numerous components of the eWQMS including the Management Dashboard, Overview, Analysis (tables and graphs), Automatic Monthly Report and Communications. The methodology to be followed included development of the specified enhancement, testing and refinement of the specified enhancement and subsequent deployment







of the specified enhancement to eWQMS users. These enhanced components were made available to users in September 2007.

Furthermore, it must be noted that during the abovementioned enhancement phase, eWQMS users have noted the need for further developments and enhancements. Although some of these have already been implemented, other requests have only been noted and prioritised. The above highlights both the fact that WSAs find the eWQMS useful and contributes positively to improved water quality management, and the need to continuously develop the eWQMS to meet on-going user requirements for effective water quality management. In particular, eWQMS users have noted the need to further enhance wastewater components.