



water affairs

Department:
Water Affairs
REPUBLIC OF SOUTH AFRICA

Water Requirements and Availability Reconciliation Strategy for the Mbombela Municipal Area



FINAL RECONCILIATION STRATEGY

FEBRUARY 2014


FINAL

APPROVAL

Report Title	Final Reconciliation Strategy
Study Name	Water Requirements and Availability Reconciliation Strategy for the Mbombela Municipal Area
DWA Report No.	PWMA 05/X22/00/2012/6
Submitted by	IWR Water Resources in association with Aurecon South Africa (Pty) Ltd SRK Consulting Engineers and Scientists (Pty) Ltd Kyamandi Development Services (Pty) Ltd WRP Consulting Engineers (Pty) Ltd
Address	Postnet Suite 40 Private Bag X4 Menlo Park 0102
Authors	J Beumer and S Mallory
Report Status	Final
Date	February 2014

Professional Service Provider: IWR Water Resources (Pty) Ltd.

Approved on behalf of the Professional Service Provider by:




S Mallory
Director

DEPARTMENT OF WATER AFFAIRS

Directorate: National Water Resources Planning

Approved for Department of Water Affairs:



NJ van Wyk
Project Manager



T Nditwani
Acting Director

Executive summary

Water use within the Mbombela Local Municipality (MLM) has increased rapidly over the last few years and the available water resources will soon be insufficient to supply the users within the municipal area at an acceptable level of assurance. A strategy is therefore required to ensure continued secure water supply to this region over the medium to long term.

The MLM does not occupy a single clearly defined catchment, but straddles the Crocodile (East) and Sabie River catchments. Activities within these upstream catchments have a great impact on the available water supply to the municipality.

Towns in the municipal area include Nelspruit, Hazyview, White River, Rocky Drift, Ngodwana, Matsulu, the Nsikazi area, Elandshoek and Kaapsehoop. The MLM forms part of the bigger Ehlanzeni District Municipality.

The purpose of this study is to develop a Water Requirements and Availability Reconciliation Strategy for the Mbombela Municipal area. Information from existing studies has been reviewed, updated and integrated into a reconciliation strategy that will meet the specific water services requirements of the MLM. This is within the visionary framework and strategy of the Inkomati Catchment Management Agency (ICMA) and is a part of promoting and supporting the sustainable development of the available water resources in the Crocodile and Sabie River catchments.

The primary objectives of this study are to:

- Address growing water requirements as well as water quality problems experienced in the catchment;*
- Assess current water availability and water deficit/surplus;*
- Identify water resource management and development options, and*
- Recommend and sequence management and structural reconciliation interventions.*

The reconciliation of water requirements with the available water resources within the Mbombela Municipal area has been evaluated in terms of the following eight water demand centres:

- Nelspruit (including Mataffin, the Agricultural College and Matumi Golf Course);*
- White River Town (including White River Country Estate and Rocky Drift);*
- Hazyview;*
- Nsikazi North;*
- Nsikazi South;*
- Karino/Plaston Corridor;*
- Matsulu, and*
- The smaller centres of Kaapsehoop, Ngodwana and Elandshoek.*

The founding principles for water allocation for the MLM areas are based on the policies and regulations of the Department of Water Affairs and the ICMA. Priority principles are:

- recognition of international water sharing obligations, and*

- *protection of the environment.*

Thereafter development and allocation of the water resource shall be sustainable, an implication of which is that water use must be shown to be efficient.

This study is focused on water for domestic and industrial use and is not specifically investigating additional irrigation use. However, where opportunities for conjunctive use (i.e. domestic and irrigation use) present themselves, these have been evaluated and reported on.

Several options for reconciling increasing water demands with the current supply are considered in this study. These options can be broadly categorised into options which (i) reduce the water demand, such as water conservation and water demand management (WC/WDM), and (ii) those that augment the water resource, such as water transfers and the construction of dams. Even assuming a high level of success in reducing water losses, the water resources will most probably need to be augmented in the not-too-distant future.

Several augmentation options were investigated, broadly classified as local and regional schemes. The Boschjeskop Dam on the Nels River, the raising of the Ngodwana Dam and the Lepulelu Dam both on different tributaries of the Elands River are three local schemes considered, while the Montrose Dam (at the confluence of the Elands and Crocodile River), the Mountain View Dam (on the Lower Kaap River) and the Strathmore Dam (an off-channel Dam near the confluence of the Kaap and Crocodile Rivers) have been considered as regional schemes.

During the evaluation of the eight demand centres, it became apparent that per capita water use within the Mbombela municipal area is one of the highest in the country. This has to be addressed before embarking on the construction of dams. If there is unlawful water use within the upstream catchment, then this must also be addressed as a priority. There is a separate process in progress to identify and eradicate unlawful water use.

The preliminary strategy for each demand centre is summarised below in order of recommended implementation priority:

Demand Centres within the Crocodile Catchment:

Nelspruit

- WC/WDM;
- Removal of Invasive Alien Plants (IAPs);
- Confirming DWA's approval for conversion of irrigation entitlements into licences for domestic water use
- Groundwater development, and
- Construct a new dam .

White River/Rocky Drift

- WC/WDM.

Karion/Plaston Corridor

- WC/WDM;
- Groundwater development;
- Confirming DWA's approval for conversion of irrigation entitlements into licences for domestic water use
- System Operating Rules for Primkop and other upstream dams, and
- Reallocation of water.

Nsikazi South

- WC/WDM, and
- Groundwater development.

Matsulu

- WC/WDM;
- Removal of Invasive Alien Plants (IAPs) in the Primkop Dam catchment area
- Groundwater development, and
- Water reallocation.
- Confirming DWA's approval for conversion of irrigation entitlements into licences for domestic water use
- System Operating Rules for Primkop and other upstream dams, and

Elandshoek/Kaapsehoop/Ngodwana

- Groundwater development, and
- Rain and fog harvesting.

Demand Centres in the Sabie River catchment:

Hazyview and Nsikazi North

- The options are limited for both of these demand centres. At this stage only one mechanism for sourcing water (other than WC/CDM) has been identified. This is to re-allocate unused irrigation water entitlements to allocations for domestic use.

Regional approaches

It became apparent during this evaluation that while the analysis of each demand centre was a useful exercise, certain regional interventions, if implemented, could resolve the water supply situation for many of the water demand centres simultaneously. Furthermore, these multi-target strategies, or regional schemes, appear to be the most promising. Three possible schemes have been identified within the Crocodile River catchment that could make more water available than is required within the foreseeable future by the Mbombela Municipality. These three schemes are:

- The Montrose Dam;
- The Mountain View Dam; and
- The Strathmore off-channel storage dam.

Each of these dams could make more than 50 million m³/a of additional water (after meeting the ecological Reserve) available for use. Since this is more than the future domestic requirements, the suggestion is that these could form part of a larger regional scheme which

supplies surplus water to emerging irrigators in the Lower Crocodile River and/or to irrigators in Mozambique.

Note that the implementation of a regional scheme does not mean that the above local interventions within demand centres should not be implemented. The implementation of WC/WDM measures is a condition for the allocation of additional water, and the long time frames required for the completion of a new dam will in any event require these other more immediate actions.

The Mountain View and Strathmore options are considerably more economical than the Montrose Dam option and the recommendation is made that the Montrose Dam should not be considered further. This then leaves only the Mountain View and Strathmore Dams. These options, located in the Kaap River and lower Crocodile respectively, are somewhat more complex than the Montrose and Boschjeskop options in that they are located either downstream or in a different catchment to the demand centres in the Mbombela Municipal area. However, water can be gravitated from Mountain View Dam to Matsulu hence freeing up water for abstraction from the Crocodile River for Nelspruit and/or Nsikazi South. A similar more extensive water exchange can be made with irrigators on the lower Crocodile River.

Table of Contents

1	INTRODUCTION.....	1
1.1	PURPOSE OF THIS STUDY	1
1.2	THE APPROACH TO THIS STUDY	3
1.3	REPORT STRUCTURE.....	3
2	OVERVIEW OF THE STUDY AREA	4
2.1	ADMINISTRATIVE BOUNDARIES OF THE MBOMBELA LOCAL MUNICIPALITY	4
2.2	WATER DEMAND CENTRES	6
2.3	WATER SUPPLY INSTITUTIONS.....	8
2.4	OVERLAPPING CATCHMENTS AND WATER RESOURCES.....	9
2.5	THE RESERVE.....	11
2.6	WATER RESOURCE INFRASTRUCTURE IN OVERLAPPING CATCHMENTS	11
2.7	IRRIGATION.....	12
2.8	STREAM FLOW REDUCTION ACTIVITIES.....	14
2.9	INVASIVE ALIEN PLANTS	15
2.10	RAINWATER HARVESTING	16
2.11	GROUNDWATER	17
3	CONSIDERATIONS FOR SELECTING THE MOST APPROPRIATE RECONCILIATION OPTIONS	18
3.1	INTRODUCTION	18
3.2	FOUNDING PRINCIPLES	18
3.3	ENVIRONMENTAL SCREENING OF OPTIONS	19
3.4	SELECTION CRITERIA.....	20
4	BASE POPULATION ESTIMATE AND GROWTH SCENARIOS.....	22
4.1	BASE POPULATION	22
4.2	GROWTH SCENARIOS	23
5	RECONCILIATION STRATEGY FOR NELSPRUIT (INCLUDING MATAFFIN, THE AGRICULTURAL COLLEGE AND MATUMI GOLF COURSE)	25
5.1	POPULATION GROWTH	25
5.2	CURRENT WATER USE	27
5.3	PROJECTED FUTURE WATER REQUIREMENTS.....	28
5.4	LOW, HIGH, AND EXTRA HIGH SCENARIO WATER REQUIREMENT PROJECTIONS	30
5.5	WATER RESOURCE AVAILABILITY	30
5.6	WATER QUALITY.....	32
5.7	THE WATER BALANCE	33
5.8	POSSIBLE INTERVENTION OPTIONS	34
5.9	ALTERNATIVE AND SELECTED RECONCILIATION SCENARIOS	43
5.10	RECONCILING THE WATER REQUIREMENTS WITH THE WATER RESOURCE	46
6	WHITE RIVER TOWN (INCLUDING WHITE RIVER COUNTRY ESTATE AND ROCKY DRIFT).....	49
6.1	POPULATION GROWTH	49
6.2	CURRENT WATER USE	49
6.3	PROJECTED FUTURE WATER REQUIREMENTS.....	50
6.4	HIGH AND LOW SCENARIO WATER REQUIREMENT PROJECTIONS.....	51
6.5	WATER RESOURCE AVAILABILITY	51
6.6	WATER QUALITY.....	52
6.7	THE WATER BALANCE	53
6.8	POSSIBLE INTERVENTION OPTIONS	54
6.9	SELECTED RECONCILIATION SCENARIOS	57
7	KARINO/PLASTON CORRIDOR (INCLUDING AREAS IN NSIKAZI SOUTH NOT GETTING WATER FROM KANYAMAZANE, E.G. MAMELODI, TEKWANE NORTH AND EMOYENI) ...	60
7.1	POPULATION GROWTH	60

7.2	CURRENT WATER USE	60
7.3	PROJECTED FUTURE WATER REQUIREMENTS.....	61
7.4	HIGH AND LOW SCENARIO WATER REQUIREMENT PROJECTIONS.....	62
7.5	WATER RESOURCE AVAILABILITY	62
7.6	WATER QUALITY.....	63
7.7	THE WATER BALANCE	63
7.8	POSSIBLE INTERVENTION OPTIONS	65
7.9	SELECTED RECONCILIATION SCENARIOS	69
7.10	RECONCILING THE WATER REQUIREMENTS WITH THE WATER RESOURCE	70
8	NSIKAZI SOUTH	71
8.1	POPULATION GROWTH	71
8.2	CURRENT WATER USE	71
8.3	PROJECTED FUTURE WATER REQUIREMENTS.....	72
8.4	HIGH AND LOW SCENARIO WATER REQUIREMENT PROJECTIONS.....	72
8.5	WATER RESOURCE AVAILABILITY	73
8.6	WATER QUALITY.....	73
8.7	THE WATER BALANCE	75
8.8	POSSIBLE INTERVENTION OPTIONS	76
8.9	SELECTED RECONCILIATION SCENARIOS	80
8.10	RECONCILING THE WATER REQUIREMENTS WITH THE WATER RESOURCE	81
9	MATSULU	83
9.1	POPULATION GROWTH	83
9.2	CURRENT WATER USE	84
9.3	PROJECTED FUTURE WATER REQUIREMENTS.....	84
9.4	WATER RESOURCE AVAILABILITY	84
9.5	WATER QUALITY.....	85
9.6	THE WATER BALANCE	86
9.7	POSSIBLE INTERVENTION OPTIONS	87
9.8	SELECTED RECONCILIATION SCENARIOS	92
9.9	RECONCILING THE WATER REQUIREMENTS WITH THE WATER RESOURCE	94
9.10	TEMPORARY WATER SHORTAGES AT THE MATSULU ABSTRACTION WORKS.....	95
10	OTHER WATER DEMAND CENTRES (ELANDSHOEK, NGODWANA, KAAPSE HOOP,).....	99
10.1	POPULATION GROWTH	99
10.2	CURRENT WATER USE	100
10.3	PROJECTED FUTURE WATER REQUIREMENTS.....	100
10.4	HIGH AND LOW SCENARIO WATER REQUIREMENT PROJECTIONS.....	101
10.5	WATER RESOURCE AVAILABILITY	101
10.6	WATER QUALITY.....	102
10.7	THE WATER BALANCE	103
10.8	SELECTED RECONCILIATION SCENARIOS	104
11	HAZYVIEW.....	105
11.1	POPULATION GROWTH	105
11.2	CURRENT WATER USE	105
11.3	PROJECTED FUTURE WATER REQUIREMENTS.....	106
11.4	HIGH AND LOW SCENARIO WATER REQUIREMENT PROJECTIONS.....	106
11.5	WATER RESOURCE AVAILABILITY	106
11.6	WATER QUALITY.....	107
11.7	THE WATER BALANCE	109
11.8	POSSIBLE INTERVENTION OPTIONS	110
11.9	SELECTED RECONCILIATION SCENARIOS	114
11.10	RECONCILING THE WATER REQUIREMENTS WITH THE WATER RESOURCE	115
12	NSIKAZI NORTH	116

12.1	POPULATION GROWTH	116
12.2	CURRENT WATER USE	116
12.3	PROJECTED FUTURE WATER REQUIREMENTS.....	117
12.4	HIGH AND LOW SCENARIO WATER REQUIREMENT PROJECTIONS.....	117
12.5	WATER RESOURCE AVAILABILITY	118
12.6	WATER QUALITY.....	118
12.7	THE WATER BALANCE	119
12.8	POSSIBLE INTERVENTION OPTIONS	121
12.9	SELECTED RECONCILIATION SCENARIOS	126
12.10	RECONCILING THE WATER REQUIREMENTS WITH THE WATER RESOURCE	127
13	OVERARCHING RECONCILIATION STRATEGY FOR THE MBOMBELA MUNICIPAL AREA	129
13.1	INTRODUCTION	129
13.2	OVERALL WATER BALANCE IN THE CROCODILE RIVER CATCHMENT	129
13.3	INTERVENTION MEASURES IN THE CROCODILE CATCHMENT	130
13.4	DAM OPTION FOR THE CROCODILE RIVER CATCHMENT	130
13.5	OVERALL WATER BALANCE IN THE SABIE RIVER CATCHMENT	132
13.6	INTERVENTION MEASURES IN THE SABIE RIVER CATCHMENT	133
13.7	OVERARCHING STRATEGY FOR MLM IN THE SABIE RIVER CATCHMENT	134
14	IMPLEMENTATION ARRANGEMENTS	135
14.1	INSTITUTIONAL RESPONSIBILITIES	135
14.2	PUBLIC ENGAGEMENT	138
15	RECOMMENDATIONS FOR FURTHER WORK	141
15.1	FURTHER WORK FOR THE CONTINUATION STUDY.....	141
15.2	FURTHER STUDIES BY ROLE PLAYERS OTHER THAN NWRP	141
	REFERENCES.....	142

List of Figures

Figure 1.1: Study area with catchments.....	2
Figure 2.1: Boundaries of municipalities proximal to Mbombela Local Municipality	5
Figure 2.2: Water demand centres	7
Figure 2.3: The Mbombela Golden Triangle	8
Figure 2.4: The Crocodile and Sabie River catchments and the boundaries of the MLM area	10
Figure 2.5: Irrigation Boards within and around the Mbombela LM area.....	13
Figure 4.1: 2010 Population figures per WDC	23
Figure 5.1: Low and high population growth for Nelspruit	26
Figure 5.2: Location of possible site ground water resources for Nelspruit.....	31
Figure 5.3: Nelspruit's water balance without any interventions.....	34
Figure 5.4: The left hand graph shows the effect of the licence applications based on conversions and the right hand graph the additional effect of groundwater development and IAP removals	44
Figure 5.5: Water reconciliation for Nelspruit WDC (without the construction of a new dam) but assuming that the surplus in White River is used in Nelspruit	45
Figure 5.6: Water reconciliation for Nelspruit WDC assuming that the surplus in White River is used in Nelspruit and including the construction of a new dam (note the delay in the need to construct this dam)46	
Figure 6.1: Low and high population growth for White River WDC	49
Figure 6.2 : Water balance graph for White River without any interventions.....	54
Figure 6.3: Water balance graph for White River with 20% savings through WC/WDM	58
Figure 6.4: Temporary surplus in the White River WDC.....	59
Figure 7.1: High and Low Population Growth scenarios for Karino/Plaston Corridor.....	60
Figure 7.2: Karino/Plaston Corridor's future water balance without any interventions	64
Figure 7.3: Water reconciliation for Karino/Plaston Corridor	69
Figure 8.1: Low and High Population Growth scenarios for Nsikazi South	71
Figure 8.2: Nsikazi South future water balance without any interventions	76
Figure 8.3: Water reconciliation for Nsikazi South.....	81
Figure 9.1: Low and high population growth for Matsulu	83
Figure 9.2: Projected water demand for high and extra high growth water requirement scenarios and the available water resource	87
Figure 9.3: Water balance for Matsulu with possible interventions	94
Figure 9.4: Kaapmuiden weir and Van Graan Canal.....	96
Figure 9.5: Kaapmuiden weir and inlet to the Van Graan Canal	97
Figure 10.1: Elandshoek Population Growth	99
Figure 11.1: Low and high population growth for Hazyview	105
Figure 11.2: Hazyview water balance without any interventions	109
Figure 11.3: Water reconciliation for Hazyview.....	114
Figure 12.1: Low and high population growth scenarios for Nsikazi North.....	116
Figure 12.2: Water balance graph for Nsikazi North without any interventions.....	120
Figure 12.3: Shear zones west of Nsikazi North.....	125
Figure 12.4: Nsikazi North's water balance graph assuming an additional yield made available re- allocating unused irrigation entitlements of irrigators upstream.....	127
Figure 13.1: The water balance of MLM in the Crocodile River catchment without interventions	129
Figure 13.2: The water balance of the MLM with various interventions	130

Figure 13.3: Water balance for MLM in the Crocodile catchment with interventions including the construction of a new dam	132
Figure 13.4: Water balance for Sabie River with only current intervention of the package plants at farm dams	133
Figure 13.5: Water balance for MLM in the Sabie River with interventions	134

List of Tables

Table 2.1: Major dams in the Crocodile catchment	12
Table 2.2: Details of medium size and major dams in the Sabie River catchments.....	12
Table 2.3: Irrigation within the Crocodile and Sabie River catchments	14
Table 2.4: Streamflow reduction due to afforestation within the Crocodile and Sabie River catchments	15
Table 2.5: Streamflow reduction due to IAPs within the Crocodile and Sabie River catchments.....	16
Table 4.1: Base population comparison.....	22
Table 4.2: Base population comparison between calculated base and other sources.....	22
Table 4.3: Summary of population growth per WDC	25
Table 5.1: Low, high and extra high population growth for Nelspruit.....	26
Table 5.2: Projected domestic water requirements in million m ³ /a	29
Table 5.3: Projected domestic water requirements in Mℓ/day.....	29
Table 5.4: Projected industrial water requirements in million m ³ /a	29
Table 5.5: Projected industrial water requirements in Mℓ/day.....	29
Table 5.6: Projected low, high and extra high scenario projections for domestic and industrial use in million m ³ /a	30
Table 5.7: Projected low, high and extra high scenario projections for domestic and industrial use in Mℓ/day	30
Table 5.8: WC/WDM Status quo assessment and strategy.....	35
Table 5.9: Key performance indicators for Nelspruit WDC	36
Table 5.10: Information for potential sites that would benefit Nelspruit	42
Table 5.11: Actions that need to be initiated as a matter of urgency – responsibilities and timelines.....	48
Table 6.1: Low and high population growth for White River WDC.....	49
Table 6.2: Projected domestic water requirements in million m ³ /a	50
Table 6.3: Projected domestic water requirements in Mℓ/day.....	50
Table 6.4: Projected industrial water requirements in million m ³ /a	51
Table 6.5: Projected industrial water requirements in Mℓ/day.....	51
Table 6.6: Projected low and high scenario projections in million m ³ /a	51
Table 6.7: Projected low and high scenario projections in Mℓ/day.....	51
Table 6.8: Current water use and allocations – White River.....	53
Table 6.9: Status quo assessment and strategy.....	55
Table 6.10: White River Town performance indicators	56
Table 6.11: Actions required for White River	59
Table 7.1: Low and high population growth scenarios for Karino/Plaston Corridor	60
Table 7.2: Projected water requirements in million m ³ /a.....	61
Table 7.3: Projected water requirements in Mℓ/day	61
Table 7.4: Projected industrial use in million m ³ /a	61
Table 7.5: Projected industrial use in Mℓ/day	61

Table 7.6: Projected water requirements in million m ³ /a.....	62
Table 7.7: Projected water requirements in Mℓ/day	62
Table 7.8: Current abstractions and licences for Karino/Plaston	64
Table 7.9: Recommended WC/WDM measures for Karino/Plaston Corridor.....	65
Table 7.10: Performance indicators	67
Table 7.11: Actions that need to be initiated– responsibilities and timelines.....	70
Table 8.1: Low and high population growth for Nsikazi South	71
Table 8.2: Projected water requirements in million m ³ /a.....	72
Table 8.3: Projected water requirements in Mℓ/day	72
Table 8.4: Current abstraction and licences for Nsikazi South	75
Table 8.5: Status quo assessment and strategy.....	76
Table 8.6: Performance indicators	78
Table 8.7: Actions that need to be initiated – responsibilities and timelines.....	82
Table 9.1: Low and high population growth for Matsulu	83
Table 9.2: Projected domestic water requirements in million m ³ /a	84
Table 9.3: Projected domestic water requirements in Mℓ/day.....	84
Table 9.4: Current abstractions and licences for Matsulu.....	86
Table 9.5: Status quo assessment and strategy.....	88
Table 9.6: Performance indicators	89
Table 9.7: Actions required, responsibilities and timelines	95
Table 10.1: Expected population growth for Elandshoek	99
Table 10.2: Domestic use for Elandshoek, Ngodwana and Kaapsehoop in million m ³ /a.....	100
Table 10.3: Domestic use for Elandshoek, Ngodwana and Kaapsehoop in Mℓ/day.....	100
Table 10.4: Water requirement projections for Elandshoek, Ngodwana and Kaapsehoop in million m ³ /a	101
Table 10.5: Water requirement projections for Elandshoek, Ngodwana and Kaapsehoop in Mℓ/day ..	101
Table 11.1: Low and high population growth for Hazyview	105
Table 11.2: Projected water requirements in million m ³ /a.....	106
Table 11.3: Projected water requirements in Mℓ/day	106
Table 11.4: Summary of current (2012) and future water requirements within the Sabie River catchment (excluding the Sand River).....	107
Table 11.5: Current water use and allocations – Hazyview.....	109
Table 11.6: Status quo assessment and strategy.....	110
Table 11.7: Performance indicators for Hazyview	112
Table 11.8: Action plan for Hazyview.....	115
Table 12.1: Low and high population growth scenarios for Nsikazi North	116
Table 12.2: Projected water requirements in million m ³ /a.....	117
Table 12.3: Projected water requirements in Mℓ/day	117
Table 12.4: Licensed abstraction for Nsikazi North	119
Table 12.5: Situation analysis and WC/WDM strategy	121
Table 12.6: Performance indicators for Nsikazi North	123
Table 14.1: Institutional responsibilities and target dates	135

List of Acronyms and Abbreviations

AIDS	Acquired Immune Deficiency Syndrome
BHN	Basic Human Needs
BLM	Bushbuckridge Local Municipality
BWB	Bushbuckridge Water Board
DM	District Municipality
DWA	Department of Water Affairs (previously DWAF)
EC	Electrical Conductivity
EWR	Ecological Water Requirements
FSA	Full Supply Area
FSL	Full Supply Level
HIV	Human Immunodeficiency Virus
IAPs	Invasive Alien Plants
IDP	Integrated Development Plan
IWAAS	Inkomati Water Availability Assessment Study
ICMA	Inkomati Catchment Management Agency
MAR	Mean Annual Runoff
MBWS	Mbombela Bulk Water Strategy
MIG	Municipal Infrastructure Grant
MLM	Mbombela Local Municipality
MMC	Manganese Metal Company
NRW	Non-Revenue Water
NWA	National Water Act
LM	Local Municipality
PES	Present Ecological State
PRV	Pressure reducing valve
RDP	Rural Development Programme
PMF	Probable Maximum Flood
PSP	Professional Service Provider
SADC	South African Development Community
SANS	South African National Standard
SBC	Spot Building Counts
SDF	Spatial Development Plan
StatsSA	Statistics South Africa
TDS	Total Dissolved Solids
URV	Unit Reference Value
WAR	Water Allocation Reform
WfW	Working for Water
WDC	Water Demand Centre
WC/WDM	Water Conservation / Water Demand Management
WMA	Water Management Area
WSP	Water Service Provider
WTW	Water Treatment Works
WWTW	Waste Water Treatment Works

Units of Measurement

Cusecs	Cubic feet per second
ha	hectare
km	kilometre
ℓ/s	litres per second
Mℓ/day	Megalitres per day (1 Ml = 1000 l)
million m ³ /a	Million cubic metres per annum
m ³ /s	Cubic metres per second
ℓ/c/d	litres per capita per day

1 INTRODUCTION

1.1 PURPOSE OF THIS STUDY

Water use within the Mbombela Local Municipality (MLM) has increased rapidly over the last few years and the available water resources will soon be insufficient to supply the users within the municipal area at an acceptable level of assurance. A strategy is therefore required to ensure continued secure water supply to this region over the medium to long term.

The MLM does not occupy a single clearly defined catchment, but straddles the Crocodile (East) and Sabie River catchments as shown in **Figure 1.1**. Activities within these upstream catchments have a great impact on the available water supply to the municipality.

Towns in the municipal area include Nelspruit, Hazyview, White River, Rocky Drift, Ngodwana, Matsulu, the Nsikazi area, and Kaapsehoop as shown in **Figure 1.1**. The MLM forms part of the bigger Ehlanzeni District Municipality.

The purpose of this study is to develop a Water Requirements and Availability Reconciliation Strategy for the Mbombela Municipal area. Information from existing studies has been reviewed, updated and integrated into in a reconciliation strategy aimed at meeting the specific water services requirements of the MLM, This is within the visionary framework and strategy of the Inkomati Catchment Management Agency (ICMA) and is a part of promoting and supporting the sustainable development of the available water resources in the Crocodile and Sabie River catchments.

The primary objectives of this study are to:

- Address growing water requirements as well as water quality problems experienced in the catchment;
- Assess current water availability and water deficit/surplus;
- Identify resource management and development options, and
- Recommend and sequence management and structural reconciliation interventions.




Figure 1.1: Study area with catchments

1.2 THE APPROACH TO THIS STUDY

This study was required to first produce a Preliminary Water Reconciliation Strategy for the Mbombela Municipal Area from which a final strategy would then be developed. The Preliminary Strategy was based on the available information that could be collected following on the inception of the study, and formed the basis for further discussion and for exchanging ideas with the stakeholders. The Preliminary Strategy included a number of assumptions made where uncertainties and information gaps existed, and these uncertainties and gaps have as far as possible since been investigated and resolved. This Final Reconciliation Strategy contains significant improved information and inputs from the stakeholders.

1.3 REPORT STRUCTURE

Following this Introduction, this report gives an overview of the study area (Chapter 2) in which administrative and catchment boundaries, water demand centres (WDCs), infrastructure, institutions, and the extent of irrigation, commercial forestry and invasive alien plants, etc. are described.

Chapter 3 deals with founding principles and the selection criteria to be used when decisions in respect of reconciliation options need to be taken.

The projected water balance situation for each of the WDCs is then analysed up to 2030, and the water surplus / deficit for each WDC determined. Possible intervention scenarios are described and a preferred scenario for each WDC presented. These scenarios contain the preferred reconciliation interventions and their sequencing, and form the basis of the strategies for the WDCs.

The report concludes with a chapter on implementation arrangements.

2 OVERVIEW OF THE STUDY AREA

2.1 ADMINISTRATIVE BOUNDARIES OF THE MBOMBELA LOCAL MUNICIPALITY

The Mbombela Local Municipality is part of the Ehlanzeni District Municipality (EDM) - along with the Bushbuckridge, Thaba Chweu, Nkomazi and Umjindi Local Municipalities. The municipal boundaries and those of neighbouring municipalities are shown in **Figure 2.1**.




Figure 2.1: Boundaries of municipalities proximal to Mbombela Local Municipality

2.2 WATER DEMAND CENTRES

The main current water use sectors in the MLM area are:

- Irrigation;
- Commercial Forestry (Streamflow Reduction Activity (SRA));
- Domestic Urban;
- Domestic Rural, and
- Industrial.

This study focuses on the domestic and industrial water use sectors. These two sectors are experiencing high growth in water demand. The water demands of the irrigation and forestry sectors are expected to remain constant over the planning period unless additional water can specifically be made available; this is outside the brief of this strategy.

The urban and rural areas that contribute to the water demand of the MLM area are spread over a very large portion of the MLM area. These urban and rural areas can be divided into eight distinct WDCs (or urban/rural clusters) as shown on the map in **Figure 2.2**. These WDCs are listed below.

1. Nelspruit (including Mataffin, the Agricultural College and Matumi Golf Course);
2. White River Town (including White River Country Estate and Rocky Drift);
3. Hazyview;
4. Nsikazi North;
5. Nsikazi South;
6. Karino/Plaston Corridor;
7. Matsulu, and
8. Smaller centres: Kaapsehoop, Ngodwana and Elandshoek.

Industrial development is mainly centred in and around Nelspruit, Ngodwana and Rocky Drift.

L:\PROJECTS_2107596_Mbombela Reconciliation Strategy\Workspaces\March_2012\Mbombela_WaterSupplyAreas_a3_bb.WOR




Figure 2.2: Water demand centres

Regional situation

The highest growth in both population and industrial activity is expected within an area known as the Golden Triangle. One leg of the triangle stretches eastwards from the top of Schoemanskloof to Nelspruit and further east to Matsulu. The second leg stretches from Matsulu northwards to Hazyview, and the third leg extends from Hazyview back to the head of Schoemanskloof. The three legs of the triangle represent respectively the commercial/industrial Development zone, the rural Development Zone and the Tourism Development Zone. The Mbombela Golden Triangle is shown in **Figure 2.3**.




Figure 2.3: The Mbombela Golden Triangle

The growth in water requirements will be significantly higher within the Mbombela Golden Triangle than within the rest of the study area. (Mbombela Spatial Development Framework – 2011/2012). This growth will be described for each WDC in later chapters.

2.3 WATER SUPPLY INSTITUTIONS

MLM is the Water Services Authority (WSA) for the municipal area. There are three water service providers (WSP) operating within the municipal area namely, MLM, Sembcorp (Silulumanzi) and Bushbuckridge Water Board (BWB). BWB is responsible for bulk water supply in Nsikazi North and Nsikazi South. Sembcorp is responsible for

bulk water supply in Karino Nelspruit, which includes Mataffin and Matsulu. MLM is directly responsible for water supply in Hazyview and White River.

2.4 OVERLAPPING CATCHMENTS AND WATER RESOURCES

The MLM boundaries do not follow the watersheds, with the result that there is no relation between catchment boundaries and the municipal boundaries. This poses quite a challenge since a portion of a WDC can fall in one catchment and the remainder in another.

The MLM overlaps with two main tributaries of the Incomati River, namely the Crocodile and the Sabie Rivers. Only a portion of the catchments of these two tributaries falls within the MLM area but it remains crucial to take the whole catchment of the Crocodile and Sabie tributaries into consideration, especially the catchment areas upstream of MLM. The boundaries of the two catchments in relation to that of the MLM are shown in **Figure 2.4**.




Figure 2.4: The Crocodile and Sabie River catchments and the boundaries of the MLM area

The area formed by the three tributaries of the Incomati River, i.e. the Komati, Crocodile and Sabie Rivers, has been proclaimed by the Department of Water Affairs (DWA) as the Inkomati Water Management Area (WMA) in terms of Government Gazette Notice, 1 October 1999 no. 20491.

This area is currently managed by the Inkomati Catchment Management Agency (ICMA).

2.5 THE RESERVE

The National Water Act (Act 36 of 1998) (NWA) requires that sufficient water must be left in rivers in order to sustain their ecological functioning. This water is referred to in the NWA as the Ecological Reserve. The Ecological Reserve and the Human Needs Reserve are the only water uses with the right to water, and as such must be given the highest priority of water supply. The ecological water requirements (EWR) of the Reserve must thus be determined and taken into account as part of any process to reconcile water requirements with the available water resource.

The EWR of both the Crocodile and Sabie River catchments have been determined (DWA, 2010). For the Crocodile River it was decided that it would be adequate to maintain the Present Ecological State (PES) of the river (Class C) by maintaining the current flow regime. This means that compulsory licencing will not be needed to meet the Ecological Reserve, as had been suggested in previous studies. It also means that increased water abstractions are not possible. It is stated in the Reserve Study report (DWA, 2010d) that should new dams be constructed in the Crocodile River catchment to augment the water resource, higher EWRs will become applicable in order to meet the recommendations of the ecologists. These higher EWRs have been taken into account when determining the available water resource.

In the case of the Sabie River, a Class A/B Reserve has been recommended to maintain the river in its PES. As a result, the Sabie River is now fully allocated and additional allocations are not possible without augmenting the water resource. Should a lower management class result from the Resource Classification process then additional water will become available for allocation. This scenario is included in the report as a possible intervention to make water available for allocation.

2.6 WATER RESOURCE INFRASTRUCTURE IN OVERLAPPING CATCHMENTS

As noted in section 2.4, the MLM is situated within the Inkomati WMA. This forms part of the larger Incomati River Basin shared by the Republic of Mozambique, the Kingdom of Swaziland and the Republic of South Africa. It has also been noted that the municipal area does not occupy a single clearly defined catchment, but straddles the Crocodile (East) and Sabie River catchments.

There are a number of medium-sized dams in both the Crocodile and Sabie catchments, but only one big dam in each catchment. The dams in the Crocodile catchment are summarised in **Table 2.1**.

Table 2.1: Major dams in the Crocodile catchment

Dam	Fully supply capacity (FSC)		Full supply area (FSA) (km ²)	Construction date
	million m ³	%MAR		
Kwena Dam	158,9	134%	12,5	1984
Witklip Dam	12,69	64%	1,88	1969
Klipkopje Dam	11,87	63%	2,31	1959
Longmere Dam	4,32	17%	0,96	1942
Primkop Dam	1,97	5%	0,41	1970
Ngodwana Dam	10,00	17%	1,00	1983

Source: RSA Department of Water Affairs and Forestry: Dam Safety Office, 2006

The dams in the Sabie catchment are summarised in **Table 2.2**.

Table 2.2: Details of medium size and major dams in the Sabie River catchments

Dam	Fully supply capacity (FSC)		Full supply area (FSA) (km ²)	Construction date
	million m ³	% MAR		
Inyaka Dam	123,7	156%	8,11	2000
Da Gama Dam	13,6	66,5%	1,29	1971

Source: RSA Department of Water Affairs and Forestry: Dam Safety Office, 2006

2.7 IRRIGATION

The rural area surrounding Mbombela's urban centres is characterised by extensive irrigation. Most of this irrigation is regulated through Irrigation Boards but there is also some limited diffuse irrigation along various tributaries, with regulation the direct responsibility of the Department of Water Affairs. The areas of jurisdiction of the irrigation boards or water user associations in the Crocodile and Sabie River catchments are shown in

Figure 2.5. Most prominent is the large Crocodile River Major Irrigation Board which stretches from Dullstroom in the West to Komatipoort in the East. A total of 28 271 ha of irrigation (225,7 million m³/a) is supported by Kwena Dam, with a further 1 632 ha allocated above Kwena Dam, although not formally administered by the Crocodile River Irrigation Board.




Figure 2.5: Irrigation Boards within and around the Mbombela LM area

An estimated 15 000 ha of irrigated agriculture, with a water requirement of 147 million m³/a, falls within the Mbombela municipal area. It is, however, misleading to consider only the irrigation within the municipal area as upstream irrigators will already have had a major impact on river flows. Also, irrigators downstream of the municipal area have water use allocations and a legitimate expectation that enough water will be allowed to flow through the municipal area to meet their water demands at an acceptable level of assurance.

Table 2.3 summarises the estimated water requirements within the Crocodile and Sabie River catchments and indicates the portion that lies within the Mbombela Municipal area. Note that this table excludes irrigation in the Kaap and Sand tributaries since they are not relevant to this study.

Table 2.3: Irrigation within the Crocodile and Sabie River catchments

Catchment	Irrigation requirement (million m ³ /a)
Crocodile catchment	
Upstream of Mbombela	95
Within Mbombela	114
Downstream of Mbombela	209
Sabie catchment	
Upstream of Mbombela	7
Within Mbombela	33
Downstream of Mbombela	9

2.8 STREAM FLOW REDUCTION ACTIVITIES

There are large areas of forestry within both the Crocodile and Sabie River catchments and it is a well-established fact that exotic plantations such as Pine, Eucalyptus and Wattle reduce the amount of water that would otherwise flow in the rivers in the catchments where the plantations are located. As with irrigation, the afforested areas within the MLM area are not the only concern since forestry upstream of Mbombela reduces river flow that could otherwise conceivably be used for domestic or industrial use within the municipal area.

The streamflow reduction within the Crocodile and Sabie Rivers is indicated in **Table 2.4**. It must be pointed out that there is not a clear relationship between streamflow reduction and yield. Water reallocation through a reduction in afforested area, which is an option, therefore needs to be carefully considered. For example, removing all the forestry from the Crocodile (excluding the Kaap River) and Sabie River (excluding the Sand River) catchments would increase the mean annual runoff (MAR) of these catchments by 122 and 81 million m³/a respectively, but this water will mostly be in the form of increased floods. The yield made available by removing forestry is discussed further under reallocation options. As a rule of thumb for the Sabie and Crocodile catchments, between one third to one fifth of the streamflow reduction will become available as high assurance yield, should forestry plantations be removed.

Table 2.4: Streamflow reduction due to afforestation within the Crocodile and Sabie River catchments

Catchment	Streamflow reduction (million m ³ /a)
Crocodile catchment	
Upstream of Mbombela	70
Within Mbombela	52
Downstream of Mbombela	0
Sabie catchment	
Upstream of Mbombela	69
Within Mbombela	12
Downstream of Mbombela	0

2.9 INVASIVE ALIEN PLANTS

Invasive alien plants (IAPs) have an impact on water resources similar to that of exotic forests in that they reduce the runoff that would have flowed in the river under natural conditions. The difference between exotic forests and IAPs is that IAPs tend to invade riparian zones where water is more readily available and hence these trees can consume much more water than licenced forestry. Also, unless controlled, IAPs will spread and result in increased reductions in runoff.

As part of the Inkomati Water Availability Assessment Study (IWAAS) (DWA, 2009), the areas of IAPs were quantified and the streamflow reduction was estimated. Working for Water (WfW) subsequently completed a national study (Kotze, 2010) and updated estimates of IAPs from the WfW study have therefore been used for this Mbombela Strategy. The estimated streamflow reduction due to IAPs is given in **Table 2.5**. It worth noting that while IAPs in riparian zones are the biggest concern for water resource managers, there appear to be very limited riparian IAPs remaining within the Crocodile and Sabie River catchments. The invaded areas are almost exclusively upland, that is, out of the riparian zone. This can be attributed to the efforts of WfW who focused their IAP removal efforts on the riparian zones.

Table 2.5: Streamflow reduction due to IAPs within the Crocodile and Sabie River catchments

Catchment	Streamflow reduction (million m ³ /a)	Estimated yield increase due to removal of IAPs
Crocodile catchment		
Upstream of Mbombela	17	8
Within Mbombela	10	1
Downstream of Mbombela	~0	~0
Sabie catchment		
Upstream of Mbombela	~0	~
Within Mbombela	1,0	0,5
Downstream of Mbombela	~0	~0

It has been established that the infested area in the Kwena Dam catchment is as much as 77 km². Removal of IAPs will not usually result in an increase in yield equivalent or even close to the increase in runoff. However, due to the location of the Kwena Dam and the operation of the Kwena Dam within a systems context, the removal of these IAPs from the Crocodile River upstream of the Kwena Dam will result in a significant increase in the system yield. This is because the Kwena Dam has the capacity to store much of the increased runoff.

The removal of IAPs in the Primkop Dam catchment could also improve the yield of Primkop Dam significantly. There are approximately 17,5 km² IAPs upstream of this dam.

2.10 RAINWATER HARVESTING

In many rural areas, reticulated water supply is not available from major dams and less capital-intensive options including boreholes, run-of-river supply and Rainwater Harvesting (RWH) serve as the main sources of water. Increased rainwater harvesting is also seen as one of the adaptation measures to climate change (Kundzewicz *et al* 2007). In South Africa, where 2,1 million people have no access to water supply infrastructure, the Department of Water Affairs (DWA) has implemented a pilot domestic RWH project meant to improve food security in rural areas by providing water for home gardening (De Lange, 2006). Duncker (2000) pointed out that some households also use this water for drinking and other purposes. Water resource management and water supply in Mbombela Municipal boundary is facing major challenges due to the limited water resources and increasing uncertainties caused by climate change.

In light of the above challenges, Mbombela Municipality should encourage installation of rainwater harvesting systems in its rural water supply. Rooftop RWH systems normally consist of a small impervious catchment area (roof area in this case) and a storage tank of 2 500 or 5 000 litres.

Using software developed by the Institute for Water Research (DA Hughes, 2013), rainwater harvesting for three types of dwellings were analysed. Firstly, small Rural Development Programme (RDP) houses with roof areas of 40 m², average small to medium houses (150 m²), and large houses (300 m²). Based on these analyses, the following conclusions were reached:

- Rainfall harvesting is not a solution on its own but can supplement the water supply and hence reduce the demand on stressed systems.
- Due to the limited surface area of RDP houses, rainwater harvesting does not provide a sustainable source of water for rural water use. Pumping and treatment costs will be reduced through rainwater harvesting but this needs to be compared with the cost of providing rainwater harvesting infrastructure.
- The amount of water that can be harvested from medium to large houses in the Mbombela municipal area is significant and this could reduce the demand on the domestic water demands currently supplied from the Crocodile and Sabie Rivers by about 5%.

Based on the above it is recommended that all houses with a roof area in excess of 150 m² be fitted with rainwater harvesting systems (with 5 000 litre tanks). As a starting point the approval of all new developments should be subject to the inclusion of rainwater tanks. Implementing rainfall harvesting on existing properties will be more problematic due to the cost involved but this could be enhanced through pricing strategies.

2.11 GROUNDWATER

The geology of the study area consists mostly of grey and white granites south of Nelspruit, and potassic gneiss to the north of the city. The occurrence of groundwater is mainly associated with the deeper weathered zones, whereas fault zones and dyke contacts represent other groundwater occurrences. The groundwater yield potential from the granite and gneiss is classified as “low”, with potential yields between 0,1 to 0,5 l/s in the granite and 0,5 to 2,0 l/s in the gneiss. According to Vegter (1995) the probability of drilling a successful borehole is below 40%. The possibility of drilling a borehole yielding more than 2 l/s is only 20% to 30% in the granite, and 10% to 20% in the gneiss.

The western part of the Municipal area contains a dolomite reef which can yield as much as 5 l/s per borehole. The probability of drilling a successful borehole in these dolomites lies between 40 and 60%. However, it is thought that there is a direct link between these dolomites and the surface flow and that the strong baseflows observed in the Elands River are due to the presence of the dolomite. Water sourced from the dolomites should not therefore be seen as additional water.

It can be concluded that groundwater availability within the Mbombela Municipality is generally low and will require further detailed investigations for development.

3 CONSIDERATIONS FOR SELECTING THE MOST APPROPRIATE RECONCILIATION OPTIONS

3.1 INTRODUCTION

There are a number of basic or founding principles, generic to all water demand centres, that must be accepted or agreed upon before examining the water requirements and status of water resources for each demand centre. It is also necessary to agree upon the criteria used to guide choices when selecting and prioritising identified reconciliation options. These principles and criteria, described in the sections below, have largely been determined by national policy and legislation, but also shaped and agreed to by stakeholders in the development of this strategy.

3.2 FOUNDING PRINCIPLES

Policies and regulations of the DWA and the ICMA that drive this strategy include:

- South Africa's International Obligations in terms of the Southern African Development Community (SADC) Revised Protocol on Shared Water Courses in terms of which there should be fair and equitable sharing of the water resource between South Africa and Mozambique, must be recognised.
- Social and economic water requirements and the protection of the environment must be balanced to achieve sustainable development.
- Water must be used efficiently.
- Unlawful water use must be eliminated.

The following founding principles for water allocation in the MLM have been derived from the above:

- Principle 1: Water for basic human needs in the study area will always be made available. Together with this, appropriate sanitation must be provided.
- Principle 2: The EWR will be met as soon as possible and in the best practical way. The water required to maintain, and where agreed, improve the environmental status of the Sabie and Crocodile River catchments, will be reserved.
- Principle 3: Equitable access to water.
- Principle 4: Water for strategic use for the benefit of the country (e.g. water supply to power stations) will be given priority above any other economic development.
- Principle 5: Water will be provided for economic growth, within the policy parameters of the government.
- Principle 6: The total allocation of water to irrigation and forestry is not a part of this strategy. It is not expected that total water use by these sectors will increase. Re-allocation to meet the needs of other sectors could be an important strategy.

3.3 ENVIRONMENTAL SCREENING OF OPTIONS

3.3.1 Process

Each proposed water reconciliation option was first put through a process of environmental screening, which may produce a “no-go” result or a “fatal flaw”. A reconciliation option returning a “no-go” result or a “fatal flaw” in the environmental screening process was not considered further.

The environmental screening process comprised the following steps:

- Put forward any key environmental or social issues that should be taken into account when considering and comparing options;
- Identify any environmental or social “fatal flaws” or “red flags” associated with any of the projects; and
- Identify environmental authorisations that will be required for any of the projects.

3.3.2 Information gathering

The assessment was based on available documented information: no site visits, field work or additional data collection would be undertaken to verify or update the available information.

3.3.3 The Reserve

Implementation of the Reserve was assumed to be a condition of any proposed scheme. It was assumed that this would ensure that the aquatic ecology and requirements for basic human needs were adequately provided for and protected.

3.3.4 Environmental impact assessment

The construction of bulk water supply infrastructure such as dams and pipelines would require an environmental impact assessment which would include a public participation process.

3.3.5 Groundwater

The potential impacts of groundwater development on the groundwater resources of adjacent landowners were assessed, as well as impacts on the surface flow, riverine ecology and groundwater-dependent ecosystems: potentially these could all be affected by groundwater development if not sustainably implemented.

3.3.6 Inter-catchment transfers

Any water transfers into the catchment would impact on the receiving streams due to an increase in their flow and loss of natural variability with consequent ecological affects. Organisms from the donor catchment would inevitably be transferred with the water.

3.4 SELECTION CRITERIA

3.4.1 Introduction

Each scenario found to be acceptable within the principles set out above, and which resulted in an acceptable water balance, was assessed against the following criteria, as described below:

3.4.2 Political priorities

The priorities of the relevant government departments of South Africa should be weighed against the possible intervention options for water reconciliation.

3.4.3 Water resources implications or implications in assurance of supply

Although the objective is to achieve a water balance it was possible that in some scenarios there could be a lower assurance of supply or a greater likelihood of restrictions or longer periods of restrictions than in other scenarios.

3.4.4 Flood mitigation

The extent to which the scenario will assist in flood mitigation (e.g. as result of additional storage) was assessed. A scenario that included a dam with significant storage will assist in flood mitigation when the dam is not operated at full storage level.

3.4.5 Drought mitigation

The extent to which the scenario will assist with drought mitigation was assessed. Typically the inclusion of a new dam will assist with drought mitigation in some areas.

3.4.6 Environmental benefits

The effectiveness of flow regulation in achieving low flow EWRs in river reaches where that is not currently possible was assessed.

3.4.7 Environmental impacts

A variety of environmental impacts were assessed, including:

- The impact on downstream flow regimes;
- Barriers to migration; and
- Inundated habitats.

3.4.8 Social benefits

The main social benefits will arise from:

- Job creation, both temporary during construction and permanently through economic development; and/or
- The extent to which disruption to communities will be minimised.

3.4.9 Economic assessment

Unit Reference Value (URV), i.e. the cost per m³ of water supplied from the scheme made available by the management intervention. This allows scenarios to be compared.

3.4.10 Required institutional capacity

Each scenario was examined in the light of the following questions:

- Is there significant institutional capacity for the implementation of this scenario?
- To what extent can the existing institutional capacity be utilised?
- What additional resources are required to implement this scenario?
- To what extent will this option help to develop institutional capacity?

3.4.11 Impact on governance and institutional development

The positive impact that the proposed scenario will have on governance and institutional development was considered.

3.4.12 Water quality impacts

The extent to which the scenario would have a beneficial or detrimental impact on the water quality was assessed.

3.4.13 Hydropower potential

Some scenarios include the construction of dams with greater potential for the generation of hydropower. Factors that affect the generation of hydropower were examined, including the:

- Height of the dam;
- Flow rate and regularity of flow releases out of the dam; and
- Demand for electricity in the vicinity of the dam.

4 BASE POPULATION ESTIMATE AND GROWTH SCENARIOS

4.1 BASE POPULATION

A historical perspective is required in understanding the MLM and all its components.. This perspective provides a picture of trends and impacts which inform future population growth. For the purposes of this discussion, data from Statistics SA was used.

A 2010 base population figure was used as the starting point for the demographic modelling. Demographic information was sourced from various municipal documents and previous studies. The various sources however each provide a different 2010 population figure, as highlighted in **Table 4.1**.

Table 4.1: Base population comparison

Source	2010 Population
Municipal IDP	527 203
Municipal SDF (MBWS ¹ historic)	546 411
MBWS (low scenario)	543 178
MBWS (high scenario)	553 460
DWA 2008 (Mbombela WSDP)	776 386

Due to the discrepancies highlighted in **Table 4.1** and the difficulty in comparing population data at levels lower than that of the Municipality, the base population was recalculated and determined by making use of Statistics SA data and sub-place information from 2009 Spot Building Counts (SBC), as well as by creating new sub-places where large concentrations of development and growth were evident. The recalculated populations are provided in **Table 4.2** below.

Table 4.2: Base population comparison between calculated base and other sources

Source	2010 Population
This Study calculated base (low scenario)	548 467
This Study calculated base (high scenario)	550 024

The base population for 2010 was split between the various WDCs in the study area. The high population base figure of 550 024 for 2010 is depicted in Figure 4.1.

¹ MBWS: Mbombela Bulk Water Strategy




Figure 4.1: 2010 Population figures per WDC

As can be seen in **Figure 4.1**, the majority of people in the MLM are located in the Nsikazi North and South WDC, with approximately 72% of the total population of the municipality residing in these two areas. The WDCs with the lowest population are Elandshoek and Ngodwana, both located to the west of Nelspruit. Approximately 33 000 people stay outside of WDCs, and have not been indicated in **Figure 4.1**.

4.2 GROWTH SCENARIOS

The smaller settlements in MLM will not grow at the same rate as larger nodes such as Hazyview, White River and Nelspruit, as the factors affecting each area vary, according to their individual characteristics. Different growth scenarios were therefore developed.

Low and high growth scenarios were derived for each WDC, taking into account various development determinants (or “push and pull” factors) that would impact on growth and resultant population size. The following demographic development determinants were identified as factors likely to cause different growth and consequent water resource responses:

- Migration;
- Mortality;
- Fertility; and
- Health and life expectancy (HIV/AIDS), etc.

There are large numbers of immigrants into South Africa, placing enormous pressure on already over-extended and under-supplied social services (e.g. schools, clinics) and infrastructural services (e.g. water, electricity, etc.). Population predictions thus took immigration into account and determined the implications for future population distribution and resource needs.

Population projections, however, also need to account for inherent internal movement dynamics of people. Whilst very little information was available about migration patterns on a municipal level, it is however a fact that a lack of sufficient job opportunities to accommodate the economically active population, together with apartheid policies of influx control, has entrenched a migratory labour pattern on the country.

This pattern is very much evident from Census information, which indicated a discrepancy in the gender structure. Male absenteeism is higher in many rural areas. Substantially fewer females form part of the migratory labour pattern.

Other demographic shifts could result from changes in fertility, mortality rates and HIV/AIDS infection rates. According to data from Statistics SA, the fertility rate has declined significantly from an average of 2,92 children per woman in 2001 to 2,35 children in 2011. Whilst still high, the infant mortality rate has declined from an estimated 53 per 1 000 in 2001 to 38 per 1 000 in 2011.

Life expectancy at birth declined between 2001 and 2005 but has increased steadily from 2005 onwards to 2011, partly due to the roll-out of antiretroviral medication. The increase in life expectancy at birth is expected to continue due to breakthroughs in medical technologies, improved education, improved living conditions, etc.

The total number of persons living with HIV/AIDS in South Africa increased from an estimated 4,21 million in 2001 to 5,38 million by 2011. In 2011 an estimated 10,6% of the total population was HIV positive. Approximately one-fifth of South African women of reproductive age are HIV-positive. HIV prevalence is expected to increase in future.

The above trends influencing population growth were taken into account for both the high and low growth scenarios designed for the MLM. This is discussed in more detail in the following subsections.

4.2.1 Low growth scenario

For the low growth scenario, it is expected that natural population growth in the MLM will follow historical trends. Little development will take place within the municipal boundaries, due to fairly low economic growth and the lack of large industries establishing in the MLM. Due to low economic growth, in-migration into the area is expected to be low, as few additional employment opportunities, which normally attract large numbers of people, will become available. The prevalence of HIV is expected to increase steadily, putting further strain on population growth.

4.2.2 High growth scenario

In the high growth scenario, the local economy prospers, with new industries establishing in the MLM due to its strategic regional location, especially in terms of the N4 Maputo Corridor. Employment opportunities increase, attracting more people to the municipality. The major economic nodes (Nelspruit, Hazyview and White River) will be the preferred destination for jobseekers, not only from other the surrounding rural areas, other local municipalities and provinces (especially Limpopo), but also from Mozambique.

Higher in-migration into the area will in turn require additional social services (schools, hospitals, community centres, etc.) and supply infrastructure (water, electricity, sanitation, etc.), as well as additional housing development. The proposed university will attract large numbers of people to Nelspruit and surrounds, increasing the demand for housing and for retail and commercial facilities. **Table 4.3** shows the projected low and high growth scenario for each WDC.

Table 4.3: Summary of population growth per WDC

WDC	Growth scenario	2010-2015	2015-2020	2020-2025	2025-2030	2010-2030
Elandshoek	Low	2,4%	2,1%	1,8%	1,5%	1,9%
	High	2,4%	2,1%	1,8%	1,5%	1,9%
Hazyview	Low	1,0%	0,9%	0,8%	0,7%	0,9%
	High	1,2%	1,1%	1,0%	0,9%	1,1%
KPC	Low	8,1%	7,4%	3,8	1,6%	5,4%
	High	9,8%	8,0%	4,5	2,3%	5,9%
Matsulu	Low	3,2%	2,6%	1,9%	1,2%	2,3%
	High	3,3%	2,9%	2,1%	1,4%	2,5%
Nelspruit	Low	2,5%	2,2%	1,9%	1,7%	2,1%
	High	2,9%	2,7%	2,5%	2,3%	2,6%
	Extra High	3,7%	4,8%	3,5%	2,7%	3,7%
Ngodwana	Low	0,0%	0,0%	0,0%	0,0%	0,0%
	High	0,0%	0,0%	0,0%	0,0%	0,0%
Nsikazi North	Low	1,0%	0,9%	0,8%	0,6%	0,8%
	High	1,3%	1,2%	1,1%	0,8%	1,1%
Nsikazi South	Low	0,7%	0,1%	0,2%	0,4%	0,4%
	High	0,9%	0,6%	0,7%	0,8%	0,7%
White River	Low	1,8%	1,6%	1,4%	1,2%	1,5%
	High	2,3%	2,1%	1,8%	1,6%	2,0%


5 RECONCILIATION STRATEGY FOR NELSPRUIT (INCLUDING MATAFFIN, THE AGRICULTURAL COLLEGE AND MATUMI GOLF COURSE)

5.1 POPULATION GROWTH

The low and high population growth scenarios for Nelspruit are shown in **Table 5.1** and **Figure 5.1**. The population of the Nelspruit WDC is expected to grow steadily up to 2030, with an average growth rate of 2,1% in the low growth scenario, 2,6% in the high growth scenario and 3,7% in the extra high growth scenario. The additional extra-high growth scenario has been added to account for population growth due to the planned university.

Table 5.1: Low, high and extra high population growth for Nelspruit

Year	2009	2010	2015	2020	2025	2030
Low	48 703	49 907	56 388	62 777	68 975	74 912
High	48 703	50 138	57 976	66 240	74 831	83 658
Extra high	48 703	50 138	60 445	76 431	90 592	103 734


Figure 5.1: Low and high population growth for Nelspruit

5.2 CURRENT WATER USE

Sembcorp is the WSP in Nelspruit. Water is abstracted from the Crocodile River, treated and distributed.

The bulk abstraction records for Sembcorp show that during 2011/12 a volume of 15,08 million m³ was abstracted from the Crocodile River for supply to the Nelspruit area. Of this volume 1,29 million m³ was supplied to Rocky Drift, Phumelani and White River which is in a separate water demand centre. This volume also includes the supply to Mattafin which is estimated on 0,13 million m³/a. The water use for Nelspruit in 2011/12 was therefore 13,98 million m³/a (38,30 Mℓ/day).

5.2.1 Domestic water use

The current domestic use in Nelspruit is estimated at 24,84 Mℓ/day or 9,07 million m³/a. This was derived from Mbombela Municipality's metered water use.

A factor that needs to be taken into account is that this domestic water is not all used by the residents of Nelspruit. A high number of daily visitors to Nelspruit, tourists that pass Nelspruit on their way to the Kruger National Park and employees that work in Nelspruit but live somewhere else, also use Nelspruit's water. Based on the assumptions and calculations in the information box, it is estimated that 2,3 Mℓ/day are taken up by daily visitors/employees to Nelspruit and the rest (22,5 Mℓ/d) by the residents themselves.

The assumptions and estimates in the information box need to be verified and it is recommended that the volume of water used by non-residents be investigated further during the course of the continuation study.

Daily visitors and non-resident employees to Nelspruit

- *Estimated number daily visitors/non-resident employees = 80 000 (According to Silulumanzi)*
- *Assume 75% are passing by on their way to a destination outside Nelspruit*
- *Assume 25% are non-resident employees*

By-passers (75%)

- *2 ℓ/c/d for hand washing; 10 ℓ/c/d for toilet flushing; Total 12 ℓ/c/d*

Employees from elsewhere (25%)

- *4 ℓ/c/d for hand washing; 40 ℓ/c/d for toilet flushing; 4 ℓ/c/d for cooking; 4 ℓ/c/d for drinking; 10 ℓ/c/d for showering; Total 62 ℓ/c/d*

Total water use = (60 000 x 12) + 20 000 x 62 = 1 960 000 ℓ/d = 1,96 Mℓ/d

*Assume 15% losses: **Total water use = 2,3 Mℓ/d***

5.2.2 Industrial water use

An analysis of water use in the MLM area showed that commercial water use (e.g. water for schools, shops, hospitals, garden centres, municipal watering etc.), industrial and domestic water use can be broken up as follows:

- Domestic 67%;
- Commercial 28%; and
- Industrial 6%.

For the purpose of this strategy commercial and industrial water use had been grouped together and was regarded as industrial water use.

The current commercial and industrial water use in Nelspruit is estimated to be 13,45 Ml/day or 4,91 million m³/a. This was derived from Mbombela Municipality's metered water use. The larger industrial water users in the Nelspruit area include Mondipak, Manganese Metal Company, Delta EMD, Nelspruit Abattoir and Coke (ABI) with an average daily demand of 2,35 Ml/day or 0,86 million m³/a.

5.3 PROJECTED FUTURE WATER REQUIREMENTS

5.3.1 Domestic water requirements

It was initially anticipated that domestic water use would increase steadily up to 2030 in direct relation to the population growth rate described in paragraph 5.1.

In the process of documenting this water reconciliation strategy, rumours surfaced of a new university and hospital for Nelspruit, which would influence the population growth rate of the town. As the strategy progressed, it became clear that the rumours could become a reality and that the impact of these developments needs to be studied in more detail in the continuation study.

For the purpose of this strategy the projected future water requirements for domestic use are based on very provisional assumptions that the university can carry approximately 20 000 students in 2030, and grow up to 30 000 students eventually sometime after 2030. Similarly it was assumed that the hospital would have 1 000 beds which will require 100 staff members with their families that will have to move to Nelspruit. It was assumed that the hospital would come into operation in 2015 and the university in 2014.

Another aspect that came to the attention of the study team during the course of the study is that 1 000 stands for housing had been allocated for Mattafin. It was assumed that all these houses would be built over the next 5 years.

For the low growth scenario it was assumed that the hospital and university would not go ahead and that, apart for the 1000 families that will settle in Mattafin over the first 5 years, the water requirements will further grow steadily in accordance with the low growth population growth scenario described in paragraph 5.1.

With the above planned developments taken into account, it was assumed that the high growth scenario would include the new hospital and growth in Mataffin. However, due to expected number of students an additional extra high growth scenario was developed to take the additional growth as a result of the new university into account. The projected domestic future water requirements for the low, high and extra high water requirement scenario are shown in **Table 5.2** and **Table 5.3** respectively

Table 5.2: Projected domestic water requirements in million m³/a

Year	2010	2015	2020	2025	2030
Low	8,98	10,15	11,30	12,41	13,48
High	9,02	10,43	11,92	13,47	15,05
Extra high	9,02	10,64	12,79	14,82	16,78

Table 5.3: Projected domestic water requirements in Mℓ/day

Year	2010	2015	2020	2025	2030
Low	24,59	27,78	30,93	33,98	36,91
High	24,70	28,56	32,64	36,87	41,22
Extra high	24,70	29,13	35,03	40,58	45,95

5.3.2 Industrial water requirements

There are no major industrial developments projected and it was anticipated that industrial use will increase steadily up to 2030 as shown in **Table 5.4** and **Table 5.5**.

Table 5.4: Projected industrial water requirements in million m³/a

Year	2010	2015	2020	2025	2030
Low	4,20	4,74	5,28	5,80	6,30
High	4,21	4,87	5,57	6,29	7,03
Extra high	4,21	5,08	6,43	7,62	8,72

Table 5.5: Projected industrial water requirements in Mℓ/day

Year	2010	2015	2020	2025	2030
Low	11,49	12,98	14,45	15,88	17,24
High	11,54	13,34	15,25	17,22	19,25
Extra high	11,54	13,91	17,59	20,85	23,88

5.4 LOW, HIGH, AND EXTRA HIGH SCENARIO WATER REQUIREMENT PROJECTIONS

The projected low, high and extra high scenario water requirements (including both domestic and industrial use) within the Nelspruit area, are shown in **Table 5.6** and **Table 5.7** below.

Table 5.6: Projected low, high and extra high scenario projections for domestic and industrial use in million m³/a

Year	2010	2015	2020	2025	2030
Low	13,18	14,89	16,57	18,21	19,78
High	13,24	15,31	17,49	19,76	22,09
Extra high	13,24	15,72	19,22	22,44	25,50

Table 5.7: Projected low, high and extra high scenario projections for domestic and industrial use in Mℓ/day

Year	2010	2015	2020	2025	2030
Low	36.08	40.76	45,38	49,86	54.15
High	36,24	41,91	47,88	54.09	60,47
Extra high	36,24	43.04	52,62	61,43	69.83

5.5 WATER RESOURCE AVAILABILITY

5.5.1 Groundwater availability

The geology of the study area as shown on the hydrogeological map in **Figure 5.2** consists of grey and white granites south of Nelspruit, and potassic gneiss to the north of the city. Northwest southeast striking diabase dykes are present in the area. The aquifer is classified as an inter-granular and fractured aquifer according to the 1:500 000 hydrogeological map (1:500 000 Hydrogeological Map Series of the Republic of South Africa – Nelspruit 2530, (DWAF, 1999)). The occurrence of groundwater is mainly associated with the deeper weathered zones, whereas fault zones and dyke contacts represent other groundwater occurrences.

The groundwater yield potential is classed as “low”, with potential yields between 0,1 to 0,5 ℓ/s in the granite and 0,5 to 2,0 ℓ/s in the gneiss. According to Vegter (1995) the probability of drilling a successful borehole is below 40%. The possibility of drilling a borehole yielding more than 2 ℓ/s is only 20% to 30% in the granite, and 10% to 20% in the gneiss.

Assuming that a well field of 10 successful boreholes was drilled to service a WDC, with each yielding an average of 1 ℓ/s, total yield would be 10 ℓ/s, approximately 1 000m³/day, or 365 000 m³/annum.

It can be concluded that groundwater availability is generally low and will require further detailed investigations for development.




Figure 5.2: Location of possible site ground water resources for Nelspruit

5.5.2 Surface water availability

Nelspruit obtains all its water from the Crocodile River, with the flow in the river being regulated by releases from the Kwenza Dam. Water is diverted from the Crocodile River into an unlined canal which then gravitates water to the treatment plant. Since there are large irrigation requirements downstream of Nelspruit (see **Table 2.4**) as well as international and ecological requirements, which are met by releases from the Kwenza Dam, the flow in the river at Nelspruit's abstraction point is always more than sufficient for Nelspruit's current and future water requirements. However, Nelspruit should not exceed its licensed water allocation of 14,60 million m³/a or the town will encroach on the water releases that are earmarked for downstream users, for meeting the Reserve requirements and for meeting the international obligations.

From time to time the cross-border flows in the Crocodile and Komati Rivers between South Africa and Mozambique drop to the minimum flow requirement which is currently set at 2,0 m³/s at the border of the two countries (as documented in the Pigg's Peak agreement). The Crocodile River contributes 0,9 m³/s of this amount.

The minimum ecological flow at the outlet of the Crocodile River, where it joins the Komati River, has been set at 0,9 m³/s. Should Nelspruit abstract more than its current allocation it will jeopardise the cross-border flows as well as the ecological flow requirements, especially during times of drought. As requirements grow it becomes essential both to reduce the water demand of the different user sectors, and in all probability also to find additional water resources, to ensure a sustainable water supply for all users in the catchment.

5.6 WATER QUALITY

5.6.1 Sources of pollution

The water quality at the intake works of Nelspruit's Water Treatment Works (WTW), which is located on the Crocodile River, is generally good. The main impact on water quality upstream of Nelspruit is the Ngodwana paper mill on the Elands River, but this water is sufficiently diluted, after the Elands join the Crocodile River, with water released from the Kwena Dam.

The Kingstonsvale Waste Water Treatment Works (WWTW) contributes to the high nutrient loads in the Crocodile River affecting users downstream of Nelspruit. This has become specifically evident after the raised water quality standards were set in 2009 resulting in lower compliance, since the plant was designed for the general and not special standards.

The Manganese Metal Company (MMC) and Delta industries also from time to time release manganese-rich water into the Nelspruit sewer system when they experience failures of their water treatment processes. This discharge is then received by the Kingstonsvale WWTW. This situation is however carefully monitored, with 24 hour sampling on industrial effluent clients and on Sembcorp who operate the Kingstonsvale WWTW.

Possible diffuse source releases from Papas Quarry at the confluence with the Gladdespruit could be a source of increased Manganese concentrations in the Crocodile River. Pollution in the Gladdespruit might affect the quality of water supplied to Nelspruit itself, as the confluence of Crocodile and Gladdespruit Rivers is located just above the diversion weir of the Nelspruit intake canal. Sampling of this raw water has been adjusted to monitor the manganese on a more frequent basis at the Nelspruit WTW.

The logging of forestry areas may bring about an increase in manganese background values and in sediment loads, whilst pH values may decrease.

Runoff from agricultural areas has increased electrical conductivity (EC), trace elements and nutrients.

Littering is a huge problem along the entire Crocodile River and in Nelspruit itself. This implies significant human use and associated faecal contamination.

5.6.2 Actual water quality versus water quality objectives

DWA's water quality standards and guidelines are met in the Crocodile River and its tributaries in the vicinity of Nelspruit in terms of the 90th percentile for pH, conductivity, total dissolved solids, chlorides and sulphates. However, ammonia levels in the discharge stream from Kingstonsvale WWTW previously exceeded the DWA standard by more than a factor of 10. This anomaly was also caused by the application of stricter special standards, for which the plant was not designed. The

situation has improved since the WSP obtained Blue and Green Drop status for the WTW and WWTW respectively.

Overall, the water quality in the Crocodile River at the intake of the abstraction works of the Nelspruit domestic/industrial water supply network is good, and hence water quality has no effect on water availability for Nelspruit (i.e. no special treatment or dilution water is required). A water safety plan is in place and is being implemented.

5.6.3 Trend analyses

Sampling has been taking place in the Crocodile River at Weltevreden since 1972 and data is available until June 2011. A total of 1 251 electrical conductivity (EC) measurements are available. The EC varies between 3,86 and 90,3. EC has been steadily increasing since 2000, but appears to have stabilised. The increase EC could possibly be ascribed to rapid urbanisation, since the same trend is observed for phosphate and ammonia.

5.7 THE WATER BALANCE

5.7.1 Current water balance with no interventions

When the water licence for Nelspruit was considered, it was stipulated that the present ecological state of the river and the current flow regime would be maintained, and that international obligations would be met. The current allowable abstraction rate and volume of Nelspruit was therefore carefully determined: this rate and volume may not be exceeded. The current licensed abstraction volume is 14,6 million m³/a. This volume is regarded as the current water allocation for Nelspruit, (including Mataffin, the Agricultural College, and Matumi Golf Course).

Nelspruit and its associated water supply areas have therefore not exceeded their licenced abstraction as yet, but they are at risk of doing so shortly.

5.7.2 Future water balance with no interventions

The projection of the future water requirements of Nelspruit and its supply areas for the high, extra high and low growth scenarios is summarised in **Table 5.7**.

Without any interventions, the water supply to Nelspruit will still be within the licenced volume until about 2013/14, as shown in **Figure 5.3**.



Figure 5.3: Nelspruit's water balance without any interventions

From the graph it can be seen that Nelspruit and its water supply areas will experience deficits from 2013 in the case of the high growth scenario and from 2014 in the case of the low growth scenario. By 2030, without WC/WDM, the water requirement will be between 5 and 10 million m³/a, depending on the growth scenario.

It is clear that some form of intervention will be necessary in order to meet the growing water requirements of Nelspruit and its supply areas.

5.8 POSSIBLE INTERVENTION OPTIONS

5.8.1 Reconciliation options that will reduce water requirements

5.8.1.1 Water Conservation and Water Demand Management

Status quo and strategy

The Nelspruit WDC is operated and maintained under concession by Sembcorp under the jurisdiction of MLM. The demand centre comprises mostly formal areas with formal infrastructure which means that metering, billing and cost recovery systems are in place. These are operated adequately.

Sembcorp has already put a Water Conservation/Water Demand Management (WC/WDM) business plan in place and is in the process of implementing this. The strategic actions suggested by this Reconciliation Strategy are set out in **Table 5.8**. Sembcorp should ensure that all these actions are covered in its business plan. The plan should be adopted even if all the actions are not being implemented.

Table 5.8: WC/WDM Status quo assessment and strategy

Status quo	Strategy
Institutional and legal assessment	
<ul style="list-style-type: none"> Sembcorp is well structured and has sufficient capacity to implement WC/WDM but training and increased capacity is required in WC/WDM section. The WSP uses the municipal bylaws which are currently under review, but has its own customer charter. The relationship with the municipality and politicians has improved and this should be improved ever further. 	<ul style="list-style-type: none"> Appoint additional staff to increase WC/WDM section and implement training programme. Enforce bylaws to promote WC/WDM. Setup WC/WDM task team, chaired by senior official or MEC to meet on monthly basis to address WC/WDM issues. This should improve communications between organisations, highlight problem areas and transfer skills.
Financial assessment	
<ul style="list-style-type: none"> The existing metering, billing and cost recovery system is fully operational. Non-revenue water (NRW) is in the order of 27%. Water tariffs are cost reflective and organisation runs on business principles. A rising block water tariff structure is in place to promote WC/WDM. Meter reading acceptable but can improve. Billing is informative. 	<ul style="list-style-type: none"> Considering the scarcity of water in the area, consideration could be given to increase the top domestic tariff to around R15/kℓ which is in line with metro councils. Provide training to meter readers to improve meter reading and reporting.
Social assessment	
<ul style="list-style-type: none"> The relationship with the community is generally positive. Water is paid for but not valued very highly and excessive garden watering is a common phenomenon. WSP has an effective customer call centre and promote reporting of leaks. 	<ul style="list-style-type: none"> Promote water wise gardening and implementation of rainwater harvesting in formal areas. Expand schools awareness programme to promote reporting of leaks and water wise practices.
Technical assessment	
<ul style="list-style-type: none"> There is sufficient macro management information available to perform a proper assessment of the water losses and potential savings. Bulk metering, pressure management, sectorisation, and leak repairs are performed but can improve. Pump stations are visited on a weekly basis and logged on the job card system. Consumer meters are generally in excess of 8 years old and are considered the main contributor to the 	<ul style="list-style-type: none"> Implement and maintain sectorisation to identify key problem areas, maintain pressure management and reduce pipe bursts. Expand existing pressure management programme and focus on maintenance and monitoring. Will result in reduced number of pipe bursts and prolong infrastructure design life. An in-house maintenance department and job card system is already in place. Pressure-reducing valves (PRVs) /

Status quo	Strategy
<p>high NRW.</p> <ul style="list-style-type: none"> The WSP has existing loggers and leak detection equipment. Existing telemetry system and control room. Top consumers (approximately 120) are pro-actively monitored. High pipe burst frequency (approximately 100 / month) 	<p>zones must be continuously monitored to ensure discreteness and PRV settings.</p> <ul style="list-style-type: none"> Improve micro management information through proper sectorisation to obtain a better understanding of problem areas. Implement a consumer meter replacement programme, starting with the top consumers, whereby 10% of all water meters are replaced per annum.
General observations	
<ul style="list-style-type: none"> All four water treatment plants operated by the WSP received Blue Drop status which is an indication of a well-managed system. Nelspruit is one of few systems to achieve Platinum Status (Blue Drop Status since the first Blue Drop awards in 2009) and is the second best managed system in the country with a score of 99,15%. A water safety plan and management system is in place for the Nelspruit distribution systems. 	<ul style="list-style-type: none"> Maintain Blue Drop status and expand performance to water distribution network through proper management and control.

Performance indicators

The key performance indicators for the Nelspruit demand centre are summarised in **Table 5.9**.

Table 5.9: Key performance indicators for Nelspruit WDC

Indicator	Current Value	Realistic Target Value 15% reduction	Optimistic Target Value 30% reduction
Annual input volume (million m ³ /annum),	14,03	11,93	9,82
Daily input volume (Ml/day)	38,4	32,7	26,9
Domestic input volume (million m ³ /annum)	7,47	6,92	6,02
Population (2012)	53 137	-	-
Households (2012)	15 714	-	-
% Non-revenue water	27%	20%	15%
% Water Losses	22%	15%	10%
Total Unit Consumption Litres/capita/day*	723	614	506
Domestic Authorised Unit	40	36	33,7

Indicator	Current Value	Realistic Target Value 15% reduction	Optimistic Target Value 30% reduction
Consumption m ³ /households/month*			
Domestic Authorised Unit Consumption litres/c/d	385	356	311
Domestic Authorised Unit Consumption with daily visitors subtracted l/c/d	342	313	267

* Including system/distribution losses

Based on the unit consumption, it is clear that WC/WDM should be implemented as a matter of priority. The current domestic water consumption is almost twice the international average of approximately 180 l/c/d. However it needs to be taken into account that Nelspruit's climate is warm and that many households in Nelspruit have their own swimming pools. The current domestic water consumption of 342 l/c/d can however be reduced considerably.

Summary and conclusions

There is tremendous scope for WC/WDM in the Nelspruit area. This will result in a reduction of both non-revenue water and the total system input volume. The institutional capacity and skills are available to embark on such a programme and should focus on the following interventions:

- Zone metering and sectorisation to improve micro management information. This will assist with the identification of key water loss areas and reduce number of pipe bursts.
- Improved pressure management programme in conjunction with sectorisation and continuous monitoring.
- Consumer meter replacement programme whereby 10% of all consumer meters are replaced on an annual basis.
- Increase the high end of the domestic water tariffs to promote WC/WDM.
- Community awareness programme that promotes the value of water and water wise gardening.

5.8.1.2 Water licence applications for conversions of irrigation entitlements

MLM has already applied to DWA in 2003 for the conversion of irrigation entitlements into a licence for domestic water use. The property which had the irrigation entitlement was Portion 82 of the farm Boschrand 283 JT and the converted volume of water applied for was 759 325 m³/a. This licence is still outstanding and it has been assumed that it will eventually be issued.

For the purpose of the new university, the Friedenheim Irrigation Board offered unused irrigation entitlements equivalent to 2,5 cusecs which amounts to 2,23 million m³/a. The MLM still has to apply for the licence and it is expected that 70% of this amount might be allocated by DWA owing to the difference in assurances of supply between water for irrigation use and water for

domestic/industrial water use. It was therefore assumed that a licence for 1,56 million m³/a may be issued.

The total water availability if both licences are issued will be 2,32 million m³/a. It was assumed that the licence would be issued in 2013.

5.8.1.3 Removal of invasive alien plants

The assumption was made that removal of IAPs upstream of the Nelspruit diversion works on the Crocodile River would make water available that could be allocated to MLM. This scenario was analysed and it was estimated that up to 8 million m³/a could be made available if the IAPs upstream of Kweni Dam in the Crocodile catchment, are removed. Since it is not realistic or cost effective to remove all IAPs, it is suggested that a more realistic estimate of increased yield would be half this amount, which is still a very significant 4 million m³/a.

5.8.1.4 Water requirement reduction measures for irrigation farmers upstream of the Nelspruit abstraction point

There are a number of possible measures that can be implemented by upstream irrigators that will reduce their water demand on the water resource. This will then, in effect, increase the water availability at the Nelspruit abstraction point. These possible measures are:

Eliminating unlawful water use

The first step in developing a Water Allocation Reform (WAR) Plan for the WMA is through the validation and verification of water use. The ICMA therefore initiated a study named '*Finalise the data collection and lawfulness assessment in support of the verification of existing lawful use within the Inkomati Water Management Area*'. The three focus water uses for this study in terms of the NWA are Section 21(a) *Taking water from a water resource*, Section 21(b) *Storage of water* and Section 21(d) *Engaging in a stream flow reduction activity*.

The aims of the study will be to identify and stop unlawful water uses, and also to identify and quantify lawful water uses.

Since, pending the study, the extent of unlawful water use is not yet known, this particular intervention has not yet been taken into account in the reconciliation. It can be factored in when the Continuation Study is undertaken if a timeous reliable estimate of the unlawful water use upstream of Nelspruit is made. However, this strategy is not expected to make much water available.

Compulsory Licensing

The NWA allows the Minister of Water Affairs to require the licensing of all water use, implying that nearly all existing users would be compelled to apply for a licence. The Minister considers all the licence applications, taking cognisance of the water availability, and may license and where required reduce the existing uses to ensure that International Obligations and the Reserve (Basic Human

Needs (BHN) and EWR) are met within the water balance. The Minister may also reallocate the available water in a fair and equitable manner.

The procedure for Compulsory Licensing is described in Sections 43 to 48 of the NWA 1998 (Act No. 36 of 1998). The process is started when the responsible authority issues a notice in the Government Gazette that water users must apply for licences within a certain period of time.

The procedure makes provision for the compilation of a proposed allocation schedule and any water user will have the opportunity to object to his/her new water allocation within 60 days after the proposed allocation schedule has been published in the Government Gazette. After considering all objections, the Preliminary Allocation Schedules must be published and after a prescribed appeal period the Preliminary Schedule becomes the Final Allocation Schedule.

Compulsory Licensing for the irrigation sector should be linked to a WC/WDM initiative. If curtailment of water entitlements is found to be the only way to achieve a water balance, the objective should be to minimise the economic impact on the water users and the consequent job losses. By applying WC/WDM together with Compulsory Licensing, irrigators may be able, depending on the current irrigation technologies in use, to reduce their water requirements without reducing the area and irrigation - and thus retain their levels of income. However, they should not then expand their enterprises with the saved water, should they have the land on which to do so. The saved water would then become available for reallocation when implementing Compulsory Licensing.

One issue linking Compulsory Licensing with WC/WDM is the timing of the process. If a WC/WDM initiative precedes a Compulsory Licensing process, the WC/WDM measures will be to the immediate advantage of the water user insofar that the water user may lawfully expand his/her enterprise with saved water, should land be available. This implies that when Compulsory Licensing is implemented these (now efficient) users will not have WC/WDM as a way of making up for cuts in allocations, assuming that these users will then be operating at maximum efficiency.

It is, however, not good practice to postpone any WC/WDM initiative in the irrigation sector should it not be possible to implement Compulsory at the same time, e.g. if the Compulsory Licensing process has to wait for the processes of validation and verification of water entitlements. If Compulsory Licensing cannot start immediately then the linking of WC/WDM with the Purchasing of Water Entitlements could instead be undertaken.

Compulsory Licensing as a standalone curtailment process can certainly reduce the water requirements on the system but, where the objective is to achieve a water balance, should only be applied as a last resort since it may have significant social consequences, e.g. economic prejudice of the water users, job losses, etc. However it is a relatively inexpensive, but very tedious process.

5.8.1.5 Water reallocation

Purchasing water entitlements

WC/WDM savings could be re-allocated if the water users (e.g. irrigation farmers) were prepared to relinquish this saving instead of expanding horizontally. An incentive must however be put in place to encourage the water users to relinquish their saved water. Alternatively a prohibition must be announced on any further horizontal expansion with saved water. Current legislation however does not make provision for such a prohibition.

The linking of WC/WDM savings to an incentive is a possible measure that will not necessarily cause economic prejudice and job losses. It means that a water user, after applying WC/WDM can offer a portion of his/her entitlement representing the amount of water saved, to the water resource authority. The incentive could be a remuneration of some kind, but it must be taken into consideration that DWA recently adopted a policy where water trading is no longer allowed. If a mechanism therefore could be found to discourage horizontal expansion with saved water by the water user who is saving the water, this option could be attractive in the sense that it can be implemented almost immediately and is not dependent on completion of the entire validation and verification processes. It is only those water users who offer a portion of their water use entitlements whose entitlements must be validated and verified and this can be done on an ad hoc basis.

This option should be further investigated in the contemplated continuation study.

An appropriate policy within DWA needs to be developed, and user guidelines need to be prepared.

Full water use entitlements

The department identified a number of emerging policies in the Second National Water Resource Strategy (NWRS2, 2013) and one of them is that a water user's entitlement could be re-allocated if that water user fails to use his/her water entitlement. ("use it or lose it principle"). The current legislation doesn't make provision for this re-allocation of water entitlements but it is anticipated that such a policy will be legislated in due course.

Previous mechanisms of water trading are no longer allowed by DWA in the NWRS2 and will not be considered further.

5.8.1.6 Reuse of water

Water reuse, or reclaimed water is becoming an increasingly accepted method of reducing man's dependence on fresh water supplies. The process involves treating wastewater effluent to a potable standard for domestic use and a non-potable standard for industrial or irrigation use. Namibia is an example of a country that has successfully used reclaimed water for domestic use for many years.

In South Africa, reclaimed water is already used extensively in industry but is only now becoming an accepted option for domestic water supply with the completion of the first operational domestic supply reuse plant in Beaufort West. The process is being actively promoted by DWA in Durban as a viable means of stretching the available water further in this metropolitan area.

The process of treating wastewater effluent to a potable standard is considerably cheaper than desalination, or the construction of new dams, with estimated costs of R2-50/m³ quoted in the literature. In terms of cost this is therefore a viable option that requires further investigation.

However, two problems that need to be overcome with the use of reclaimed water are (i) the disposal of the brine that remains as a by-product of the reclamation process and (ii) the acceptance of the process by society. Currently sewage effluent is treated at the wastewater treatment plants and discharged into rivers while the brine remaining at the end of the recycling plant process must be disposed of in some other manner.

There is currently an inadequate understanding of the potential for reuse of water in the Mbombela Municipality and the recommendation is that this be addressed as part of the maintenance phase of the project.

One consequence of water reuse is that much of this water otherwise finds its way back into the system as 'return flow'. This return flow in the rivers can then be allocated to further users downstream and a dependency on this water can develop. Very efficient reuse will mean far less return flow on which downstream users have come to rely. This also applies to very efficient irrigation techniques. It remains good policy to persist with both efficient irrigation and with reuse; there is no obligation on a user of water that becomes available for reuse (e.g. industrial water or sewage) to return that water to the stream, and efficiencies call for its cost effective use. However the potential impact on volumes available for downstream allocation does need to be considered by water authorities.

5.8.2 Reconciliation options that will increase water supply

5.8.2.1 Groundwater development

As shown on the geological map of the area (**Figure 5.2**), several northwest/southeast-striking dykes and shear zones are present close to the city of Nelspruit. High potential groundwater resources are normally associated with these structural features. However, a high density airborne magnetic survey of the area is required to identify the exact locality of these structural features. Targets along these structures need to be selected for geophysical traversing. It is recommended that the radon emanation technique (Levin, 2000) be applied to locate optimum drilling sites.

5.8.2.2 Dam Construction to increase storage and hence yield

A total of six potential sites have been evaluated for dam development so as to increase yield storage for MLM. These are categorised as either regional or local schemes. Regional schemes are those that are multi-purpose schemes which can provide additional yield to the municipality and other water users while local schemes are those that would benefit only one or a few certain WDCs.

Table 5.10 summarises the information for the three local schemes which, if developed, would benefit Nelspruit. The three other regional schemes could of course also benefit Nelspruit. The possible local and regional schemes that were considered for the purpose of this study, are all described in the Water Requirements and Water Resources report, which is a supplementary report to this strategy.

Table 5.10: Information for potential sites that would benefit Nelspruit

Dam Site	Type of Dam	Incremental Yield, million m ³ /a	Capacity, million m ³	Additional Height/ Height, m	Cost Estimate, R (million)
Raising Ngodwana Dam	Earthfill embankment	7,0	100	15,0	550
Boschjeskop Dam	Earthfill embankment	19,5	125	51,6	831,5
Lupelule Dam (on Tributary of Elands)	Earthfill embankment	7,2	23,2	47	1 340

5.8.2.3 System operating rules

The water resources of the Crocodile River are managed through a recently developed real-time system which makes use of hydrodynamic flow-routing models coupled with longer term water resources models, to determine the required releases from the Kweni Dam and the level of restriction to be imposed on users during droughts. This modelling system is one of the most advanced in Southern Africa and there are therefore limited options for making additional water available through improved system operation. The following options have been identified:

Better control of diffuse irrigation

An estimated 80% of the irrigation within the Crocodile River catchment falls within irrigation boards which exercise control over their users by applying restrictions during droughts and through compliance with allocations. The remaining 20% of users do not necessarily comply with restrictions recommended by the real-time system operation system. Inclusion of all irrigators into the system and the enforcement of the restriction rules could make additional water available.

Allowance of additional river abstraction in times of high flows

The NWA does not allow users to abstract water at rates above their allocation even at times of high river flow. Should an operating rule be instituted which allows irrigators to pump water into off channel dams during floods, this would make additional yield available within the system.

5.8.2.4 A transfer of allocated but unused water from the White River WDC

The White River WDC currently has a comfortable surplus of 3,8 million m³/a thanks to a 5 million m³ allocation from the Crocodile River via the MLM (WSP for both the Nelspruit and White River WDCs). Whilst White River would run into deficit shortly if all of this surplus was immediately made available to Nelspruit, there are a number of interventions available (notably WC/WDM) that could keep White River in surplus for a number of years. One option would therefore be to transfer a portion this allocation to the Nelspruit WDC.

5.8.2.5 Water transfers from elsewhere

There is virtually no scope for water transfers from neighbouring catchments as most of the water is already allocated. With two dam sites identified on the Kaap River in the Crocodile Reconnaissance Study (DWA, 2008) there is a future possibility of transferring water from the Kaap River to Nelspruit but this would need significant infrastructure such as dams and bulk pipelines.

It should be noted that all of the water available from Inyaka Dam in the Sabie River Catchment has been allocated and that no additional water can be made available to the MLM from this source.

5.9 ALTERNATIVE AND SELECTED RECONCILIATION SCENARIOS

The following reconciliation scenarios have been considered in order to achieve a water balance for the Nelspruit water demand centre:

5.9.1 Enforcement of WC/WDM measures only

A 15% water saving (industrial, commercial and domestic) will not be sufficient to overcome the water deficit from 2013 as far as the high and extra high growth water requirement scenarios are concerned. However, it will postpone the water deficit on the low growth requirement scenario from 2014 to 2020/21. (See **Figure 5.4**).

If the domestic water requirement per person was to be set on the world average value of 180 l/c/d and all other water requirements remained the same equivalent to the high water requirement scenario, then the current water availability would satisfy the demand for the entire planning period (See White curve on **Figure 5.4**).

5.9.2 Enforcement of WC/WDM measures and water licence applications for conversions of irrigation entitlements

If the licence applications as discussed in **paragraph 5.8.1.2** were to be approved by DWA, it would push up the water availability by 2,32 million m³/a. The effect of this on top of the WC/WDM measures can be clearly seen in **Figure 5.4**. The low growth water requirements would then be satisfied until 2028 and the high growth until 2023/24. The extra high growth water requirements will then only be satisfied until 2016.

5.9.3 Enforcement of WC/WDM measures, approval of licence applications, the removal of IAPs and ground water resource development

When the removal of IAPs and groundwater development are considered together with WC/WDM measures and the approval of licence applications a water balance can be achieved for the low and high growth scenarios for the full planning period, but water deficits can be expected from the year 2018 for the extra high growth scenario. It was assumed that the IAPs removal programme will start showing benefits from 2014 and will reach its full 4 million m³/a yield gain by the end of the planning period. The groundwater will have a very small impact of only 0,1 million m³/a yield gain from 2015, which is barely visible on the graph. (See **Figure 5.4**).




Figure 5.4: The left hand graph shows the effect of the licence applications based on conversions and the right hand graph the additional effect of groundwater development and IAP removals

5.9.4 Transferring allocated but unused water from White River

As mentioned under White River in Section 6.10, there is currently a surplus of about 3,8 million m³/a in the White River WDC due to allocation made to Rocky Drift/White River and not yet taken up. Mbombela Municipality has approved numerous developments within White River on the strength of this surplus. However, these developments will only materialize over the next 15 years and White River is experiencing a short-term surplus that could be used for Nelspruit to delay the cost of constructing a dam.

Figure 5.5 and **Figure 5.6** shows the scenario in which the surplus water allocated to White River is made available to Nelspruit.




Figure 5.5: Water reconciliation for Nelspruit WDC (without the construction of a new dam) but assuming that the surplus in White River is used in Nelspruit

With this intervention in place, and provided White River is able to effect sufficient savings, Nelspruit WDC will gain significant time before a major intervention is required - until 2022 under the highest growth scenario, and not until after 2030 if the WDC is successful in its implementation of WC/WDM.

5.9.5 Enforcement of WC/WDM measures, approval of water use licence applications, the removal of IAPs, ground water resource development and construction of a new dam

The implementation of this scenario would result in the water requirements for Nelspruit being more than adequately met for the planning period. (See).

The construction of the Boschjeskop Dam, the raising of the Ngodwana Dam or the Lupelule Dam on a tributary of the Elands River could only be complete from 2018 at the earliest, and it was assumed that either of the three would take five years after commissioning to reach full yield. It therefore makes no difference which dam option is chosen from a water balance point of view: other criteria such as URV will determine which dam option should be selected.

For illustration purposes, Boschjeskop Dam was used in the graph of , but a water balance can be obtained with any of the six dam options that were investigated.




Figure 5.6: Water reconciliation for Nelspruit WDC assuming that the surplus in White River is used in Nelspruit and including the construction of a new dam (note the delay in the need to construct this dam)

5.10 RECONCILING THE WATER REQUIREMENTS WITH THE WATER RESOURCE

5.10.1 Water balance for selected reconciliation scenarios

Scenario 5.9.4 has been selected as the most appropriate intervention option for the reconciliation of the Nelspruit water balance, without specifying which dam of the three (i.e. Boschjeskop or one of the two regional options, Mountain View or Strathmore) must be chosen. Any one of the three options would achieve enough water for Nelspruit's water balance. The Water Resources and Water Requirements supplementary report indicates that Mountain View and Strathmore Dams are also attractive options which must be considered. The fact that they are downstream of Nelspruit is not regarded as an insurmountable problem since Kwena Dam water destined for irrigation farmers in the lower part of the Crocodile River can be provided to Nelspruit and the irrigation farmers can get their allocation out of the new dam which is upstream for them, instead of Kwena Dam.

A feasibility study must be done to determine which of the three options will be best. Boschjeskop Dam is cheaper than the other two but will yield far less than Mountain View and Strathmore Dams. The latter two dams' URV is much lower than Boschjeskop, but it was not possible to select between the two as the URVs are almost the same. The feasibility study will be done at a higher resolution than this desktop study and it is expected that it will become clearer which dam to select.

5.10.2 Actions that need to be initiated as a matter of urgency

demonstrates that construction of a dam would be necessary to achieve a water balance for Nelspruit within the planning period. However, this could be delayed to the end of the planning period, or even beyond, if surplus water currently allocated to White River were to be transferred to the Nelspruit WDC (See **Figure 5.6**); the following actions will need to be undertaken as a matter of urgency.

5.10.2.1 Development of the WC/WDM plan and implementation strategy

MLM/Sembcorp has already started to implement their WC/WDM business plan. They need to check that all the actions listed in **Table 5.11** are included in their plan and if not, they must update their plan accordingly. MLM and Sembcorp must seriously endeavour to save at least 15%. This is a conservative target and even better results can be achieved.

5.10.2.2 Approval of the outstanding licence applications for converting irrigation water use into domestic/industrial water use

The one licence application is outstanding from 2003 and it must be determined what is delaying the licence. If there is no impediment for issuing the licence, it should be considered as a matter of urgency. The other licence application to convert the 2,5 cusec from Friedenheim Irrigation Board into a domestic/industrial water use is new but should also be considered without delay.

5.10.2.3 Transfer of surplus water from White River WDC

Consideration should be given to the option of integrating supply needs and utilising this surplus water.

5.10.2.4 Removal of IAPs

Further investigations are necessary to establish the location and extent of IAP infestation and thereby confirm the yields that can be gained from their removal; this should be accomplished within a year of approval of this strategy. A removal plan needs to be developed and Working for Water forewarned to prioritise this clearing. Implementation, which can take up the remainder of the planning period.

The control of Invasive Alien Plants is a constant process and one that has to be undertaken not only to improve yields but also to prevent an erosion of the *status quo* which will otherwise ensue, resulting in even less available water. A long-term permanent budget needs to be set aside for this purpose.

5.10.2.5 Borehole siting

Groundwater development will make a small but useful difference to the overall water balance of Nelspruit, particularly if a local water requirement needs to be met quickly. Groundwater can offer additional and often very clean water with little development time. Boreholes need to be sited as explained under **Section 5.5.1**.

5.10.2.6 Feasibility study for the new dam

A feasibility study where the smaller yielding Boschjeskop Dam is weighed up against the higher yielding Mountain View and Strathmore options is required. A preliminary desk top assessment is described in the Water Requirements and Water Resources report, which is a supplementary report to this strategy.

Table 5.11: Actions that need to be initiated as a matter of urgency – responsibilities and timelines

Action	Responsibility	Timeline
Implementation of a WC/WDM plan for Nelspruit.	Sembcorp	Start beginning of 2014 and plan fully implemented by 2019.
Approval of licence applications.	DWA	As soon as possible, before end of 2013.
Negotiate transfer of surplus water from White River WDC to Nelspruit	MLM - DWA	Immediate
Removal of Invasive Alien Plants in Catchment Area of Kweni Dam.	Working For Water Teams of Department of Environmental Affairs	Start 2014 and remove IAPs with follow-up removals and establishment of indigenous vegetation for the next 16 years.
Groundwater development for short term water shortages.	Sembcorp	Start 2014 and abstract water in that same year.
Feasibility study Boschjeskop, Mountain View or Strathmore Dam.	DWA	Start immediately – dam should be commissioned by 2018.

6 WHITE RIVER TOWN (INCLUDING WHITE RIVER COUNTRY ESTATE AND ROCKY DRIFT)

6.1 POPULATION GROWTH

The low and high population growth scenarios for White River are shown in **Table 6.1** and **Figure 6.1** below. Based on the Statistics South Africa (StatsSA) and Eskom projections, the population of the White River WDC is expected to grow steadily until 2030, with an average growth rate of 1,5% in the low growth scenario, and 2,0% in the high growth scenario. However, it appears that StatsSA failed to take into account the new area under development referred to as Phumelani. This development consists of a formal area with 465 RDP level houses and an informal area with approximately 3 500 houses. The rapid growth due to development has been assumed to take place from 2010 to 2015 after which the growth rate will slow to that estimated by StatsSA.

Table 6.1: Low and high population growth for White River WDC

Year	2009	2010	2015	2020	2025	2030
Low	14 370	18 635	32 879	35 511	37 981	40 300
High	14 370	18 713	33 668	37 298	40 868	44 353




Figure 6.1: Low and high population growth for White River WDC

6.2 CURRENT WATER USE

MLM is the WSP for the White River WDC. This includes White River Country Estate and the industrial area of Rocky Drift. White River receives water from three sources, namely Witklip Dam on the Sand River, Longmere Dam on the White River, and from

the WTW in Nelspruit which takes water from the Crocodile River. This WTW supplies 2,5 Mℓ/day (0,7 Mℓ domestic, 1,8 Mℓ industrial) to Rocky Drift, Phumelani and White River.

5,5 Mℓ/day is supplied to White River from the Longmere and Witklip dams. The White River Country Estate also receives water from the Longmere Dam, via a dedicated 1 Mℓ/day WTW. There is also a borehole in town which can supply 0,4 Mℓ/day.

6.2.1 Domestic water use

During 2011/2012 the total volume of water supplied from the Crocodile River for domestic use was 0,70 Mℓ/day. Total domestic use is 7,6 Mℓ/day or 2,77 million m³/a.

6.2.2 Industrial water use

The industrial area of Rocky Drift is supplied from the Crocodile River. The current water use is 1,8 Mℓ/day or 0,66 million m³/a.

6.3 PROJECTED FUTURE WATER REQUIREMENTS

6.3.1 Domestic water requirements

It is anticipated that domestic water use will increase rapidly until 2015 and then steadily up to 2030. The White River Town Council has recently approved the development of a number of enterprises such as shopping centres, light industries etc. that will require commercial water. This will result in rapid growth in domestic water requirements in White River over the next 15 years. The projected domestic water requirements of the high growth scenario have been amended accordingly, and are shown in **Table 6.2** and **Table 6.3**, in million m³/a and Mℓ/day respectively.

Table 6.2: Projected domestic water requirements in million m³/a

Year	2010	2015	2020	2025	2030
Low	2,58	2,83	3,06	3,27	3,47
High	2,60	3,89	5,18	6,47	6,78

Table 6.3: Projected domestic water requirements in Mℓ/day

Year	2010	2015	2020	2025	2030
Low	7,08	7,75	8,37	8,96	9,51
High	7,11	10,64	14,19	17,72	18,55

6.3.2 Industrial water requirements

The projected industrial water requirements of the high growth scenario are shown in **Table 6.4** and **Table 6.5** in million m³/a and Mℓ/day respectively.

Table 6.4: Projected industrial water requirements in million m³/a

Year	2010	2015	2020	2025	2030
Low	0,64	0,71	0,76	0,81	0,86
High	0,64	1,01	1,37	1,73	1,81

Table 6.5: Projected industrial water requirements in Mℓ/day

Year	2010	2015	2020	2025	2030
Low	1,76	1,93	2,09	2,23	2,37
High	1,76	2,76	3,75	4,75	4,95

6.4 HIGH AND LOW SCENARIO WATER REQUIREMENT PROJECTIONS

The projected low and high scenario water requirements which include domestic and industrial use are shown in **Table 6.6** and **Table 6.7**.

Table 6.6: Projected low and high scenario projections in million m³/a

Year	2010	2015	2020	2025	2030
Low	3,23	3,54	3,82	4,09	4,34
High	3,24	4,49	5,75	7,00	7,37

Table 6.7: Projected low and high scenario projections in Mℓ/day

Year	2010	2015	2020	2025	2030
Low	8,84	9,68	10,46	11,19	11,88
High	8,86	12,30	15,73	19,15	20,19

6.5 WATER RESOURCE AVAILABILITY

6.5.1 Groundwater availability

The geology of the study area shown in **Figure 5.2** consists mainly of grey and white granite, with a small portion of potassic present to the south of White River. There are several northwest/southeast striking diabase dykes in the area. The aquifer is classified as an inter-granular and fractured aquifer according to the 1:500 000 hydrogeological map (1:500 000 Hydrogeological Map Series of the Republic of South Africa - Nelspruit 2530, (DWAf 1999). Groundwater occurrence is associated mainly with the deeper weathered zones, with fault zones and dyke contacts hosting other groundwater occurrences.

The groundwater yield potential was classed as “low”, with potential yields of between 0,1 to 0,5 ℓ/s in the granite, and 0,5 to 2,0 ℓ/s in the gneiss. According to Vegter (1995) the probability of drilling a successful borehole is below 40% but the probability of drilling a borehole yielding more than 2 ℓ/s is only 10% to 20% in the larger part of the area. It can be concluded that groundwater availability is low, and further detailed investigations would be necessary before embarking on its development.

6.5.2 Surface water availability

The town of White River and the industrial area of Rocky Drift receive their water from various sources. White River has an allocation of 0,75 million m³/a from the Witklip Dam on the Sand River, and a further allocation of 1,25 million m³/a from the Longmere Dam on the White River. The yield of the Witklip Dam was investigated in detail as part of a licence application for additional water for White River town (Mallory, 2010): it was found that the yield of the Witklip Dam has been fully allocated, and that no new allocations can be made from this source.

The yield of the Longmere Dam was assessed as part of this Reconciliation Strategy. The Longmere Dam cannot be viewed in isolation, since it is supported by releases from the Klipkopje Dam. The yield of this system was estimated to be 10,1 million m³/a, while the allocation made to irrigators from this dam is approximately 10 million m³/a. The Klipkopje/Longmere system is therefore, to all intents and purposes, fully allocated.

Until recently, Rocky Drift received water only from White River as part of its allocation from the Witklip and Longmere Dams, but more recently a pipeline was constructed from the Nelspruit WTW to Rocky Drift to supplement the water supply to this region. An allocation of 5 million m³/a has been made for Rocky Drift out of the Crocodile River. Abstractions from the Crocodile River for Rocky Drift are subject to the same constraints as abstractions for Nelspruit.

6.6 WATER QUALITY

6.6.1 Sources of pollution

The following water pollution threats currently exist in and around the town of White River:

- Rocky Drift is a light industrial area, with potential for contaminated run-off during storm events.
- Forestry activities close to or within the riparian zone are the primary threat to the health of the riparian habitats and vegetation.
- Trout hatcheries are a threat to in-stream ecological health, through diversion of water for dams and weirs, which impact on the water flows in the area. Also, rivers may become enriched with nutrients from fish feed and waste.
- Although the White River WWTW is operated well within its design capacity, water is being discharged that does not comply with the licenced standards. The operation of the treatment works has however been improving over the past year.
- Rocky Drift has a small activated sludge plant and no monitoring is currently being undertaken. It is however a potential source of nutrients and possibly metals since it serves an industrial area.

6.6.2 Actual water quality versus water quality guidelines

Measurements at Rocky Drift show that none of the parameters measured exceeds the target water quality guidelines.

The available data is however limited, with a sampling record only since 2009. 17 EC measurements have been taken which varied between 9,92 and 49,3 mS/m. Seasonal variation in water quality data was observed. The EC remained stable with no upward trend for the period for which data is available.

6.6.3 Trend analyses

No significant trends were observed that hold a threat to White River and its people.

6.7 THE WATER BALANCE

6.7.1 Current water balance with no interventions

The current water use and water use allocations in accordance with DWA water use licences are shown in **Table 6.8**.

Table 6.8: Current water use and allocations – White River

Source	Abstraction million m ³ /a	Licence million m ³ /a	Comments
Witklip Dam via Sand River	0,75	0,75	Currently abstraction for White River town 2,08 million m ³ /a and 0,37 million m ³ for White River Country Estate. The agricultural allocation still needs to be converted into a domestic allocation for the Country Estate.
Longmere Dam	1,7	1,25	
Borehole Kwik Spar	0,02	0,02	
Crocodile River	0,91	5,0	Allocation for White River and Rocky Drift
Totals	3,4	7,02	

From **Table 6.8** it can be seen that White River town and Rocky Drift do not experience any water deficits at present.

6.7.2 Future water balance with no interventions

A projection was made of the future water requirements of White River (including the country estate and Rocky Drift). The high and low growth scenarios for water requirements are shown in **Figure 6.2**.




Figure 6.2 : Water balance graph for White River without any interventions

Without any interventions, the available water supply will remain the same as the licenced volume, i.e. 7,02 million m³/a.

From **Figure 6.2** it can therefore be seen that the low growth water requirement scenario can be easily supplied with the current allocation, but that a water deficit will occur from 2025 onwards with the amended high growth water requirement scenario.

6.8 POSSIBLE INTERVENTION OPTIONS

The only water deficits that have to be overcome are those that arise from 2025 onwards as a result of the high water requirement scenario. This can be done by reducing the water demand through WC/WDM measures. The current system losses in White River are 37%. There is therefore ample opportunity to reduce this. Although the WDC itself may not be under stress, water use losses are unacceptably high and WC/WDM must be implemented; this will take pressure off the whole system which must be viewed as an integrated entity.

The Demand Centre is operated and maintained by MLM. The demand centre comprises of mostly formal areas with formal infrastructure which enables metering, billing and cost recovery systems to take place adequately. Based on the available information, qualitative and quantitative scorecards, the assessment and proposed strategy summarised in **Table 6.9** were made:

Table 6.9: Status quo assessment and strategy

Status quo	Strategy
Institutional and legal assessment	
<ul style="list-style-type: none"> Mbombela lacks capacity (45% vacancy) and necessary skills to implement WC/WDM. There is no WC/WDM training. The municipal bylaws are currently under review but not enforced. There is no customer service charter. The political support is acceptable but the understanding of the water business can improve. 	<ul style="list-style-type: none"> Appoint additional staff to fill vacancies and implement training programme. Enforce bylaws to promote WC/WDM. Setup WC/WDM task team, chaired by senior official or MEC to meet on monthly basis to address WC/WDM issues. This should improve communications between organisations, highlight problem areas and transfer skills. Perform Councillor training programme on water business and WC/WDM. Prepare a customer service charter.
Financial assessment	
<ul style="list-style-type: none"> The relationship between the technical and finance department can improve with access to information being a problem. The existing metering, billing and cost recovery system is fair but can improve. Non-revenue water is estimated to be in the order of 35%. Water tariffs are not cost reflective with limited input from technical department. A declining block water tariff structure is in place, which does not promote WC/WDM. Meter reading is not up to standard and often estimated. Billing is informative and shows 2 months of consumption. 	<ul style="list-style-type: none"> The setup of a WC/WDM task team should improve the relationship with the finance department and access to information. Provide training to meter readers to improve meter reading and reporting. Water tariffs should be reviewed to become cost reflective and promote WC/WDM.
Social assessment	
<ul style="list-style-type: none"> The relationship with the community is generally positive in formal income areas while strained in rural (informal) areas. Water is paid for in formal areas but not valued very highly and excessive garden watering is a common phenomenon. Illegal connections and non-payment prevalent in rural (informal) areas. WSP has an effective customer call centre and promote reporting of leaks. Rainwater harvesting is promoted with Parks department. 	<ul style="list-style-type: none"> Promote rainwater harvesting in formal and informal areas. Embark on community awareness programme that emphasise fixing of internal plumbing leaks. Embark on schools awareness programme promoting reporting of leaks and water wise practices.
Technical assessment	
<ul style="list-style-type: none"> There is very little macro and no micro management information available to perform a proper assessment of the 	<ul style="list-style-type: none"> Implement and maintain sectorisation to identify key problem areas. Implement pressure management

Status quo	Strategy
<p>water losses and potential savings.</p> <ul style="list-style-type: none"> No zone metering, pressure management and sectorisation is being done. Consumer meters are generally in excess of 5 years old and under recording. The WSP has no loggers and leak detection equipment. Existing telemetry system in some areas. Top consumers are not pro-actively monitored. Low pipe burst frequency (approximately 10/ week) 	<p>programme and focus on maintenance and monitoring. Will result in reduced number of pipe bursts and prolong infrastructure design life.</p> <ul style="list-style-type: none"> PRVs / zones must be continuously monitored to ensure discreteness and PRV settings. Improve micro management information through proper sectorisation to obtain a better understanding of problem areas. Implement a consumer meter replacement programme, starting with the top consumers, whereby 10% of all water meters are replaced per annum. Monitor top consumers on a pro-active basis.
General observations	
<ul style="list-style-type: none"> The White River and White River Country Estate WTWs received 90,8% and 91,54% respectively in the 2012 Blue Drop assessment indicating a well-managed water supply. 	<ul style="list-style-type: none"> Improve to obtain Blue Drop status and expand performance to water distribution network through proper management and control.

Table 6.10: White River Town performance indicators

Indicator	Current Value	Realistic Target Value 15% reduction	Optimistic Target Value 30% reduction
Annual input volume (million m ³ /annum)	3,4	3,1	2,8
Daily input volume (Mℓ/day)	9,2	8,5	7,7
Domestic Authorised Consumption (million m ³ /annum)	2,4	2,4	2,3
Population (2012)	31 635	-	-
Households (2012)	9 625	-	-
% Non-revenue water	50%	39%	29%
% Water Losses	30%	23%	18%
Total Unit Consumption Litres/capita/day	292	269	243
Domestic Authorised Unit Consumption - Litres/capita/day	205	208	200
Domestic Authorised Unit Consumption - m ³ /household/month	20	21	20

The unit consumption is high in White River and exceeds the world average of 180 ℓ/c/d. However, this is an area with a warm climate and many house owners in the White River town have swimming pools, and an authorised domestic unit consumption of 205 ℓ/c/d would not be unreasonable. WC/WDM must however be implemented as a matter of priority as the system water losses exceed 30%.

Summary and conclusions

There is scope for WC/WDM in the White River area which will result in both the reduction of non-revenue water and the total system input volume. There are, however, limited institutional capacity and skills available to embark on such a programme, and this situation should be resolved before focusing on the following interventions:

- Improve political support through a councillor awareness programme focusing on the water business.
- Review water tariffs to reflect cost of water and promote WC/WDM.
- Train meter readers and perform monthly audits to eliminate estimates and other inaccuracies.
- Develop and present community awareness programme that promotes the value of water and water wise gardening.
- Implement zone metering and sectorisation to improve micro management information. This will assist with the identification of key water loss areas and reduce number of pipe bursts.
- Initiate a Pressure management programme in conjunction with sectorisation and continuous monitoring.
- Initiate a consumer meter replacement programme whereby 10% of all consumer meters are replaced on an annual basis.
- Investigate the discrepancy between the values derived during the study and those used in the Blue Drop assessment.

6.9 SELECTED RECONCILIATION SCENARIOS

6.9.1 Achieving the water balance for White River

No reconciliation strategies other than WC/WDM measures were considered for the White River/Rocky Drift area, since the water balance can be achieved with WC/WDM measures only.

There are a number of options available from which to source additional water for White River in future. These are:

- Raising of the Longmere Dam wall; and/or
- Increasing the supply from the Crocodile River, supported by one of the possible regional water supply schemes, namely the construction of Boschjeskop Dam, Mountain View Dam or Strathmore Dam.

The raising of the Longmere Dam does not look promising as it will only make about 1,5 million m³/a of additional water available. The most likely solution to the problem of meeting water shortages within the White River/Rocky Drift area, should they materialise, is to increase supplies from the Crocodile River, supported by a dam project in the Crocodile River Catchment. This should however only be considered after all necessary WC/WDM interventions have been implemented, and White River is using its water efficiently as a result.

Even a conservative 15% saving for White River should already put the town in a positive water balance situation for the required planning horizon. The water balance graph with 15% water savings through WC/WDM measures is shown in **Figure 6.3**.




Figure 6.3: Water balance graph for White River with 20% savings through WC/WDM

The water demand curve for the world average domestic water demand of 180 l/c/d is also shown on **Figure 6.3** and is represented by the white line.

The reduced low water requirement projection by WC/WDM is very close to the world average curve, but the high water requirement scenario (even after WC/WDM) is much above the world average curve.

Despite an apparent surplus at the present time this is an artifact of the high allocation of 5 million m³/a to the WDC out of the Crocodile system.

Integrated Water Resource Management requires that the White River Demand Centre save as much water as possible, leaving valuable water to other users and reducing the overall pressure on resource use and infrastructure development. Should the projected growth in White River not materialize, then this allocation could be used elsewhere. Alternatively the current surplus could be utilized to good effect towards the more immediate needs of the Nelspruit WDC and WDCs lower down in the Crocodile River. The surplus above the high water requirement scenario as reduced through WC/WDM was regarded as temporarily available elsewhere in the system as shown in **Figure 6.4**.




Figure 6.4: Temporary surplus in the White River WDC

An option, discussed under sections 5.8 and 5.9, is that the surplus water that has been allocated to White River, which is in any event from the Crocodile River and managed by the MLM, be transferred to the Nelspruit WDC, at least until such time as it is needed by White River. This would put the White River WDC under a greater tension as it would need to manage its resource more consciously to avoid going into deficit but, as noted, this is an achievable target. The transfer would very significantly delay the need to construct additional storage for Nelspruit, and would be a logical and integrated way of managing the overall resource.

6.9.2 Actions that need to be taken

Table 6.11 below summarises the actions required for White River.

Table 6.11: Actions required for White River

Action	Responsibility	Timeline
Implementation of a WC/WDM plan for White River.	MLM	Start beginning of 2014 and plan fully implemented by 2019.
Monitor the water use of White River on a yearly basis, determine the actual surplus and allow this surplus to be used temporarily in Nelspruit and lower down in the Crocodile River	MLM/Semcorb	Start immediately and then ongoing

7 KARINO/PLASTON CORRIDOR (INCLUDING AREAS IN NSIKAZI SOUTH NOT GETTING WATER FROM KANYAMAZANE, E.G. MAMELODI, TEKWANE NORTH AND EMOYENI)

7.1 POPULATION GROWTH

The low and high population growth scenarios for the Karino/Plaston Corridor are shown in **Table 7.1** and **Figure 7.1**. The population growth of the Karino/Plaston Corridor is expected to be the highest in the study area, with an average growth rate of 5,4% in the low growth scenario, and 5,9% in the high growth scenario. Population growth in the Karino/Plaston Corridor WDC is expected to be especially high between 2010 and 2015 due to this area being zoned for new housing, after which it is expected to gradually slow down until 2030.

Table 7.1: Low and high population growth scenarios for Karino/Plaston Corridor

Year	2010	2015	2020	2025	2030
Low	15 622	32 437	46 312	55 807	60 416
High	15 622	34 628	50 881	63 406	71 041




Figure 7.1: High and Low Population Growth scenarios for Karino/Plaston Corridor

7.2 CURRENT WATER USE

Sembcorp is the WSP for this demand centre.

7.2.1 Current domestic water use

There are two WTWs supplying water to the Karino/Plaston Corridor: One at Primkop Dam and the other next to the Crocodile River. The combined water use is

3,6 Mℓ/day. In future some of the areas receiving water from Nsikazi South will be supplied from this WDC.

7.2.2 Current industrial water use

There is currently no industrial water use in this WDC.

7.3 PROJECTED FUTURE WATER REQUIREMENTS

7.3.1 Projected domestic water requirements

The projected future domestic water requirements will follow the population growth levels in the area until 2030. The projected domestic use is shown in **Table 7.2** and **Table 7.3** in million m³/a and in Mℓ/day, respectively.

Table 7.2: Projected water requirements in million m³/a

Year	2010	2015	2020	2025	2030
Low	1,08	1,66	2,37	2,86	3,09
High	1,09	1,74	2,56	3,18	3,57

Table 7.3: Projected water requirements in Mℓ/day

Year	2010	2015	2020	2025	2030
Low	2,97	4,55	6,49	7,82	8,47
High	2,99	4,77	7,00	8,73	9,78

7.3.2 Projected industrial water requirements

There are a number of Industrial Development Zones planned around the airport. The MLMs intention is to supply these industries with water from Primkop Dam, although this will have to be done through a process of water re-allocation as all Primkop Dam's remaining water is currently allocated to the irrigators.

The projected industrial use is shown in **Table 7.4** and **Table 7.5** in million m³/a and in Mℓ/day, respectively.

Table 7.4: Projected industrial use in million m³/a

Year	2010	2015	2020	2025	2030
Low	0,00	0,25	0,36	0,43	0,46
High	0,00	0,25	0,37	0,46	0,52

Table 7.5: Projected industrial use in Mℓ/day

Year	2010	2015	2020	2025	2030
Low	0,00	0,68	0,97	1,17	1,27
High	0,00	0,69	1,02	1,27	1,42

7.4 HIGH AND LOW SCENARIO WATER REQUIREMENT PROJECTIONS

The projected low and high scenario water requirements are shown in **Table 7.6** and **Table 7.7** in million m³/a and in Mℓ/day, respectively.

Table 7.6: Projected water requirements in million m³/a

Year	2010	2015	2020	2025	2030
Low	1,08	1,91	2,73	3,28	3,56
High	1,09	1,99	2,93	3,65	4,09

Table 7.7: Projected water requirements in Mℓ/day

Year	2010	2015	2020	2025	2030
Low	2,97	5,23	7,47	9,00	9,74
High	2,99	5,46	8,02	9,99	11,20

7.5 WATER RESOURCE AVAILABILITY

7.5.1 Groundwater availability

The geology of the study area as shown on the geological map in **Figure 5.2** consists mainly of grey and white granite with several northwest/southeast striking diabase dykes present in the area. A northwest/southeast shear zone cuts through the area. The aquifer is classified as an inter-granular and fractured aquifer according to the 1:500 000 hydrogeological map (1:500 000 Hydrogeological Map Series of the Republic of South Africa Nelspruit 2530, DWAF, 1999).

Groundwater occurrence is associated mainly with the deeper weathered zones, with fault zones and dyke contacts hosting other groundwater occurrences. The groundwater yield potential is classed as “low” with potential yields between 0,1 to 0,5 ℓ/s in the granite. According to Vegter (1995), the probability of drilling a successful borehole is below 40%, and of drilling a borehole yielding more than 2 ℓ/s only 10% to 20%. It is concluded that the groundwater availability is generally low, and would require further detailed investigations for development.

7.5.2 Surface water availability

The Karino/Plaston Corridor receives water from two sources, firstly water from the Primkop Dam that was recently traded with irrigation allocations from this dam, and secondly, water from the Crocodile River via a small, recently-constructed pump-station.

The supply from the Crocodile River is subject to the same water resources constraints as found in Nelspruit and Nsikazi South. The yield of the Primkop Dam was estimated to be 12 million m³/a, but this estimate needs to be reviewed once a better knowledge of upstream use and lawful allocations from this source becomes available from the Verification study, which is in progress. It is likely that additional water can be sourced from the Primkop Dam for Karino/Plaston.

7.6 WATER QUALITY

7.6.1 Sources of pollution

The following water pollution threats currently exist in the Karino/Plaston area:

- The Crocodile River is associated with domestic runoff, littering and an increase in nutrients.
- Irrigated agriculture in the area contributes to high nutrient loads and possibly high levels of pesticides and herbicides.
- Quarrying occurs along the lower Crocodile River before the confluence with the Kaap River; this has the potential to increase turbidity and suspended solids in the river.
- Sand mining occurs along the Crocodile River.
- Upstream WWTWs (e.g. Kingstonvale and White River) pollute when they are not complying with standards. The Kingstonvale WWTW has Green Drop status: if maintained as such it would not necessarily represent a pollution threat.
- Manganese spills from upstream are possible if MMC and Delta experience failures which Kingstonvale WWTW cannot handle.

7.6.2 Actual water quality versus water quality objectives

The quality of abstracted water at Karino on the Crocodile River meets the DWA standard and guidelines with respect to all the measured parameters in terms of pH, EC, Dissolved Solids, chloride, sulphates and ammonia. Karino's waste water is not treated together with the waste water of Nsikazi South. Therefore, as far as Karino's waste water for downstream users is concerned, this waste water quality is not controlled at Karino itself.

7.6.3 Trend analyses

Sampling records were available from 1972. All the parameters comply with the water user requirements. EC varies between 6 and 86,1 mS/m with a median of 17 mS/m. There was an initial increasing trend from 1997 to 2003 in EC, however if the measurements are now compared on a month-to-month and a year-on-year basis, the levels have stabilised. Measurements have not however been linked to flow rates in the river.

7.7 THE WATER BALANCE

7.7.1 Current water balance with no interventions

The present ecological state of the Crocodile River needs to be maintained and therefore the current licensed abstraction volume of 1,3 million m³/a at Karino may not be exceeded. The legality of the water supplied from the Primkop Dam still needs to be ascertained. The current abstractions and authorisations are provided in **Table 7.8**.

Table 7.8: Current abstractions and licences for Karino/Plaston

Source	Abstraction million m ³ /a	Licence million m ³ /a	Comments
Abstraction from Crocodile River	0,7	1,3	Licence issued on 26/02/2011 by DWA.
Primkop Dam	0,7	0,3	No licence. Only verbal agreements to convert Primkop agricultural water to water for domestic consumption. Water from Primkop Dam is supplied to Tekwane North which is now regarded as part of the Karino/Plaston water demand centre.
Total	1,4	1,6	

From the table it can be seen that the current water abstraction is in balance and does not exceed the available water in the resource.

7.7.2 Future water balance with no interventions

A projection was made of the future water requirements of Karino/Plaston Corridor as described in **Section 7.1**. The high and low growth scenarios for water requirements are shown in **Figure 7.2**.


**Figure 7.2: Karino/Plaston Corridor's future water balance without any interventions**

Figure 7.2 shows that the growing water requirements of Karino/Plaston cannot be satisfied with the available water resource without further interventions.

7.8 POSSIBLE INTERVENTION OPTIONS

7.8.1 Reconciliation options that will reduce water requirements

7.8.1.1 Water conservation and water demand management

The Demand Centre which includes Mamelodi, Tekwane North and Emoyeni is operated and maintained under concession by Sembcorp under the jurisdiction of MLM. The demand centre receives water from Primkop Dam, which is then treated at the WTW in the Broedershoek area on the farm Manchester. The treatment plant is operated by Sembcorp. Most of the demand centre is formally developed and has formal infrastructure: the level of services is above RDP standards. While most of WDC has bulk and domestic meters, there are smaller informal areas with limited metering, billing and cost recovery.

As shown in **Table 7.10**, it is not foreseen that there will be much scope for water savings through WC/WDM. However, good WC/WDM practices must be maintained. The recommended WC/WDM measures for Karino/Plaston Corridor are summarised in **Table 7.9**.

Table 7.9: Recommended WC/WDM measures for Karino/Plaston Corridor

Status quo	Strategy
Institutional and legal assessment	
<ul style="list-style-type: none"> Sembcorp is well structured and has sufficient capacity to implement WC/WDM but training and increased capacity is required in WC/WDM section. The WSP uses the municipal bylaws which are currently under review but have their own customer charter. 	<ul style="list-style-type: none"> Appoint additional staff to increase WC/WDM section and implement training programme. Enforce bylaws to promote WC/WDM. Setup WC/WDM task team, chaired by senior official or MEC to meet on monthly basis to address WC/WDM issues. This should improve communications between organisations, highlight problem areas and transfer skills.
Financial assessment	
<ul style="list-style-type: none"> Metering, billing and cost recovery system is generally good. Meter readers are outsourced. A high level (>50%) of consumers are non-paying. Water tariffs are cost reflective and organisation runs on business principles. A rising block water tariff structure is in place to promote WC/WDM. Billing is informative. 	<ul style="list-style-type: none"> Improve level of service and supply to the area and consider installing meters in areas where there is no metering and billing taking place Considering the scarcity of water in the area, consideration could be given to increase the top domestic tariff to around R15/kl which is in line with metro councils. Provide training to meter readers to improve meter reading and reporting. Water Conservation tips should be included on the water bill.

Status quo		Strategy
Social assessment		
<ul style="list-style-type: none"> The relationship with the community is generally fair. WSP has an effective customer call centre and promote reporting of leaks. Illegal connections and non-payment prevalent in rural (informal) areas. High level of indigent's consumer profile. Vandalism of infrastructure is a major concern. 		<ul style="list-style-type: none"> Improve the relationship with the community and focus on promoting payment for services through education and awareness. Promote water wise gardening and implementation of rainwater harvesting in formal areas. Expand schools awareness programme to promote reporting of leaks and water wise practices.
Technical assessment		
<ul style="list-style-type: none"> There is sufficient macro management information available to perform a proper assessment of the water losses and potential savings. Bulk metering, sectorisation, and leak repairs are performed but can improve. A large portion of the consumer meters are in excess of 8 years old and are considered the main contributor to the high NRW. The WSP has existing loggers and leak detection equipment. 		<ul style="list-style-type: none"> Implement and maintain sectorisation to identify key problem areas, maintain pressure management and reduce bursts. Expand existing pressure management programme and focus on maintenance and monitoring. Will result in reduced number of bursts and prolong infrastructure design life. PRVs / zones must be continuously monitored to ensure discreteness and PRV settings. Improve macro management information through proper sectorisation to obtain a better understanding of problem areas. Implement a consumer meter replacement programme, starting with the top consumers, whereby 10% of all water meters are replaced per annum.
General observations		
<ul style="list-style-type: none"> The Tekwane WTW received 97.97% while Karino WTW received 98,25% in the 2012 Blue Drop assessment which is an indication of a properly managed water supply. A water safety plan and management system is already in place for the Karino distribution systems. 		<ul style="list-style-type: none"> Maintain Blue Drop status Keep managing the distribution system efficiently.

Table 7.10: Performance indicators

Indicator	Current Value	Realistic Target Value 15% reduction	Optimistic Target Value 30% reduction
Annual input volume (million m ³ /annum)	1,31	1,31	1,31
Daily input volume (Ml/day)	3,6	3,6	3,6
Domestic Authorised Consumption (million m ³ /annum)	1,18	1,18	1,18
Population (2012)	26 263	-	-
Households (2012)	6 549	-	-
% Non-revenue water	15%	15%	15%
% Water Losses (Sembcorp)	10%	10%	10%
Total Unit Consumption Litres/capita/day	137	137	137
Domestic Authorised Unit Consumption Litres/capita/day	123	123	123
Domestic Authorised Unit Consumption Litres/household/month	15	15	15

The unit consumption of Karino/Plaston Corridor is under the internationally-accepted standard of 180 litres per capita per day and there is little scope for reducing this consumption. The thin black line in **Figure 7.3** reflects a water demand which progressively increases from 90 l/c/d to 180 l/c/d as unit consumption. This scenario assumes that the current informal households that do currently not pay for their water will gradually improve to households with water borne sewerage where 180 l/c/d could be the norm. Good WC/WDM practices should be maintained for this WDC.

Summary and conclusions

There is little scope for WC/WDM in the Karino/Plaston Corridor area. The focus in this area should be on improving service delivery, removing illegal connections, fixing visible leaks and promoting community education and awareness, through the following actions:

- Implement a community awareness programme that promotes the value of water and water wise gardening.
- Ensure continuous water supply by improving Broedershoek WTW and the commissioning of Karino WTW.
- Improve political support through councillor awareness programme focusing on the water business.
- Review water tariffs to reflect cost of water and promote WC/WDM.
- Implement zone metering and sectorisation to improve micro management information. This will assist with the identification of key water loss areas and reduce number of pipe bursts.
- Train meter readers and perform monthly audits to eliminate estimates and other inaccuracies.
- Consider implementing pressure management in areas experiencing high pressures.

- Perform meter audit and cleaning to improve meter reading and accessibility.

7.8.1.2 Removal of IAPs

Some of the water for Karino is sourced from the Primkop Dam. Removal of IAPs upstream of Primkop Dam can make some additional water available. Based on the areas of IAPs upstream of Primkop Dam derived from the WFW report (Kotze, 2010), the runoff into Primkop could be increased by about 0,9 million m³/a.

This will result in an increased yield of about 0,4 million m³/a.

7.8.2 Reconciliation options that will increase water supply

7.8.2.1 Water licence applications for conversions of irrigation entitlements

MLM has already applied to DWA in 2003 for the conversion of irrigation entitlements into a licence for domestic water use. The properties which had the irrigation entitlement were Portion 35 of Goedehoop 128 JU, Portion 9 of Manchester 121 JU, Portion 56 of Rietfontein 274 JT and various portions of the farms Broedershoek 129 JU and Broedersvrede 136 JU. The converted volume of water applied for was 2 365 499 m³/a. This licence is still outstanding and it was assumed that it will eventually be issued. It was assumed that the licence will be issued in 2013.

7.8.2.2 Groundwater development

As shown on the geological map of the area, several northwest/southeast striking dykes are present. A northwest/southeast striking shear zone cuts through the area. High potential groundwater resources are normally associated with these structural features. However, a high density airborne magnetic survey of the area is required to identify the exact locality of these structural features. Targets along these structures need to be selected for geophysical traversing. It is recommended that the radon emanation technique (Levin, 2000) be applied to locate the optimum drilling position.

It has been assumed that 200 000 m³/a can be utilised from the groundwater resource.

7.8.2.3 Dam construction to increase yield storage

No dam construction was considered specifically for the Karino-Plaston demand centre. However, if any of the dam options for Nelspruit were to be pursued it would benefit Karino/Plaston as well.

7.8.2.4 System operating rules

The operation of the Primkop Dam is complex, in that it is supplemented by pumping from the Crocodile River. This system has never been analysed in detail due to a lack of reliable information. Improved systems operation is likely

to result in additional water available for allocations from this source. For the purposes of this Strategy an estimated increase in water availability of 1 million m³/a has been assumed.

7.8.2.5 Water transfers from elsewhere

No options to transfer water in from other catchments could be identified. It was assumed that the remaining part of the White River temporary surplus not taken up by Nelspruit will be made available lower down for Matsulu.

7.9 SELECTED RECONCILIATION SCENARIOS

The following intervention scenarios have been analysed for the reconciliation of Karino/Plaston Corridor's water balance. The effect of each of these scenarios on the water balance is depicted in **Figure 7.3**.

7.9.1 Issuing the pending licence

The licence applied for is for 2,37 million m³/a .

7.9.2 Issuing the pending licence plus development of groundwater

The shear zones east and west of Karino/Plaston corridor should be investigated. 200 000 m³/a was assumed from this resource.




Figure 7.3: Water reconciliation for Karino/Plaston Corridor

7.10 RECONCILING THE WATER REQUIREMENTS WITH THE WATER RESOURCE

7.10.1 Interventions needed

Figure 7.3 illustrates that for the Karino/Plaston low growth scenario, a water balance can easily be achieved by implementing the two suggested interventions. Two options available for Karino/Plaston, namely the Operating rule for Primkop Dam and the removal of IAPs in the catchment of Primkop won't be needed for Karino/Plaston if the DWA issues the licence applied for. These options could however benefit Matsulu, which will later be shown in **Chapter 9**. The following assumptions have been made regarding the implementation of this intervention:

- The applied for licence will be issued.
- The groundwater target of 200 000 m³/a will be reached by 2029, if a groundwater scheme is started in 2028.

7.10.2 Actions needed for Karino Plaston

The actions as shown in **Table 7.11** are required for the reconciliation of Karino/Plaston's water balance:

Table 7.11: Actions that need to be initiated– responsibilities and timelines

Action	Responsibility	Timeline
Licence applied for need to be issued.	DWA Regional Office ICMA	Before end 2013.
Groundwater borehole siting using techniques described in Paragraph 5.5.1 .	Sembcorp/Silulumanzi	Start beginning of 2014 and drill and equip borehole(s) within 1 year.

8 NSIKAZI SOUTH

8.1 POPULATION GROWTH

The low and high population growth scenarios for Nsikazi South are shown in **Table 8.1** and **Figure 8.1**. The population of the Nsikazi South is expected to grow steadily up to 2030, with an average growth rate of 0,4% in the low growth scenario, and 0,7% in the high growth scenario. A slight decline in growth is evident between 2015 and 2020 in both the low and high growth scenarios, after which the growth rate increases gradually up to 2030.

Table 8.1: Low and high population growth for Nsikazi South

Year	2009	2010	2015	2020	2025	2030
Low	225 682	227 202	234 959	236 360	239 254	244 646
High	225 682	227 736	238 281	245 296	253 768	263 458




Figure 8.1: Low and High Population Growth scenarios for Nsikazi South

8.2 CURRENT WATER USE

Bushbuckridge Water Board (BWB) is the bulk WSP for Nsikazi South. MLM and Sembcorp are responsible for water distribution in the area. Sembcorp is responsible for water supply in the so-called concession area, which includes Tekwane South and Kanyamazane.

8.2.1 Domestic water use

Nsikazi South is supplied with water from the Nsikazi South Regional Raw water pump station, which is situated next to the Crocodile River. The water is pumped to the WTW works at Kanyamazane, from where it is distributed to Kanyamazane and Pienaar/Msogwaba. The capacity of the WTW has been upgraded to handle 54 Mℓ/day, but it is operated at an average of 50 Mℓ/day.

There is also a second pump station, known as the emergency pump station, which pumps water to the old WTW which has a capacity of approximately 1,8 Mℓ/d.

There are some formal villages which have yard connections and water borne sewage systems. These include Kanyamazane and Kabokweni. Tekwane South and Emoyeni also have water borne sewage systems. The remainder of the villages are served by stand pipes.

There is also a package water treatment plant at Dwaleni, which replaced the old WTW. The capacity of the package plant is 0,6 Mℓ/day. A total groundwater supply of 0,34 Mℓ/day is also provided from various boreholes .

The total volume of water treated for Nsikazi South is therefore 52,7 Mℓ/d or 19,3 million m³/a. This can be regarded as Nsikazi South's current water use.

8.2.2 Industrial water use

There is an industrial area in Nsikazi South which is supplied with water from Factories Reservoir. The current water use is approximately 0,8 Mℓ/day.

8.3 PROJECTED FUTURE WATER REQUIREMENTS

8.3.1 Domestic water use

The domestic water use is expected to follow the same growth trend as population growth up to 2030.

8.3.2 Industrial water use

The industrial use is expected to stay the same for Nsikazi South. New industrial developments around the Kruger Mpumalanga Airport will be supplied with water from Primkop Dam forming part of the Karino/Plaston Corridor WDC.

8.4 HIGH AND LOW SCENARIO WATER REQUIREMENT PROJECTIONS

The projected low and high scenario water requirements are shown in **Table 8.2** and **Table 8.3**.

Table 8.2: Projected water requirements in million m³/a

Year	2010	2015	2020	2025	2030
Low	19,01	19,65	19,77	20,01	20,46
High	19,01	19,78	20,37	21,07	21,88

Table 8.3: Projected water requirements in Mℓ/day

Year	2010	2015	2020	2025	2030
Low	52,06	53,81	54,13	54,79	56,02
High	50,06	54,17	55,76	57,69	59,89

8.5 WATER RESOURCE AVAILABILITY

8.5.1 Groundwater availability

The geology of the study area, as shown on the geological map (**Figure 5.2**) comprises grey and white coarse grained biotite granite in the western part of the area while the southern part and the eastern section along the boundary of the Kruger National Park consist of potassic gneiss. Several east west striking diabase dykes, as well as diabase sills are present in the north, and northwest/southeast shear zones cut through the area. Northwest/southeast striking dykes are present in the southern part of the area.

The aquifer is classified as an inter-granular and fractured aquifer according to the 1:500 000 hydrogeological map (1:500 000 Hydrogeological map series of the Republic of South Africa Nelspruit 2530 (DWAF, 1999)). Groundwater occurrence is associated mainly with the deeper weathered zones, as well as with fault zones and dyke contacts.

The groundwater yield potential is classed as low, with potential yields between 0,1 and 0,5 l/s in the granite, and 0,5 to 2,0 l/s in the gneiss. According to Vegter (1995) the probability of drilling a successful borehole in the western part is below 40%. The probability of drilling a borehole yielding more than 2 l/s is between 10 and 30%. In the east and northern areas the probability of drilling a successful borehole is between 40 to 60%, and of drilling a borehole yielding more than 2 l/s is between 30 to 40%.

It is concluded that groundwater is generally available, but will require detailed investigations for development.

8.5.2 Surface water availability

The situation at Nsikazi South is the same as at Nelspruit, i.e. relying largely on water supplied from the Crocodile River. As discussed in **Section 5 (Nelspruit)**, the Crocodile River is fully allocated and probably over-utilised due to unlawful abstractions. Additional allocations to Nsikazi South from the Crocodile will therefore encroach on both the Reserve and South Africa's international obligations. Therefore, further allocations can only be considered if interventions are implemented that will result in a higher yield.

Nsikazi South also makes use of abstractions from streams but these are not sustainable. It is suggested that they continue to be operated until such time as a more sustainable solution can be found to the water resources and water supply situation.

8.6 WATER QUALITY

8.6.1 Sources of pollution

Pollution sources upstream of Nsikazi South which can affect the drinking water quality in Nsikazi South must be considered, as well as pollution sources within the township itself.

More information is required regarding the water quality immediately upstream of the Nsikazi South abstraction works in the Crocodile River². The water quality at Nsikazi South can be affected by upstream WWTW (e.g. Kingstonsvale, Nelspruit), by fertilisers used by upstream irrigators, by upstream industries, etc.

However, no extraordinary problem was reported regarding the upstream water quality, and it is therefore assumed that the quality of the incoming water is adequate, and that the water is fit for treatment and use in Nsikazi South.

As far as the water flowing out from Nsikazi South is concerned, there are a number of possible pollution sources:

- Littering is a huge problem all along the Crocodile and Sabie Rivers, and Nsikazi South is no exception.
- The Kanyamazane WWTW complies with the general standards of DWA, but it was not designed for the special standards which DWA have imposed on the works. If these special standards are to be met the plant will need to be upgraded.

The discharging effluent from Kabokweni WWTW has had a 3% chemical compliance over the past year: The works received a 70% Risk Index during the recent Green Drop Assessment.

8.6.2 Trend analyses

8.6.2.1 Kabokweni

Water quality sampling downstream from Kabokweni started in mid-2009. With the exception of ammonia, all the parameters comply with the water users' requirements. The ammonia exceeds the requirements both for the aquatic environment and for drinking water standards. EC varies between 15,4 and 70,8 mS/m, with a median of 59,4 mS/m. EC is stable over the monitoring period on a year on year and month on month basis. The results of the water quality sampling measurements have not been linked to flow rates in river.

Ammonium shows a minimum concentration of 0,025 mg/l as N and maximum of 7,02 mg/l as N and a median of 1,31 mg/l as N.

8.6.2.2 Kanyamazane

Sampling downstream from Kanyamazane started in 2009 on a weekly basis.

TDS values are high, with a median of 394 mg/l and a 90th percentile of 417 mg/l. The average value for suspended solids from July 2011 to June 2012 is 19,2 mg/l. The 90th percentiles of both phosphates and ammonium, (6,2 mg/l as P and 4,7 mg/l as N) are high. Confirmation is required as to whether this is

² This will hopefully be covered in the final reconciliation strategy.

due to upstream pollution, or if it is caused by the WWTW itself. A ferric dosing trial has commenced to reduce the phosphate non-compliance.

8.7 THE WATER BALANCE

8.7.1 Current water balance with no interventions

The present ecological state of the Crocodile River needs to be maintained, and therefore the current licensed abstraction volume for Nsikazi South may not be exceeded. This current authorised abstraction is 18,3 million m³/a as summarised in **Table 8.4**.

Table 8.4: Current abstraction and licences for Nsikazi South

Source	Abstraction million m ³ /a	Licence million m ³ /a	Comments
Raw water pump station on Crocodile River.	18,3	18,3	
Emergency pump station on Crocodile River. (Kanyamazane)	0,7	0,7	
Kabokweni package plant.	0,2		No authorisation.
Various boreholes.	0,1	0,1*	Not certain which boreholes are authorised.
Total	19,3	19,1	

* Assumed licences have been issued for all boreholes

The current abstraction of 19,3 million m³/a is almost in balance with the available licence value of 18,3 million m³/a.

8.7.2 Future water balance with no interventions

A projection was made of the future water requirements of Nsikazi South and its supply areas. The high and low growth scenarios for water requirements are shown in **Table 8.1**.

Without any interventions, the water supply will remain on the licenced volume throughout the projection period, as shown in **Figure 8.2**.




Figure 8.2: Nsikazi South future water balance without any interventions

The current deficit will increase over time as a result of the growing water demand if no interventions are implemented, as shown in **Figure 8.2**.

8.8 POSSIBLE INTERVENTION OPTIONS

8.8.1 Reconciliation options that will reduce water requirements

8.8.1.1 WC/WDM

Nsikazi South distribution system is operated and maintained under concession by Sembcorp under the jurisdiction of MLM with the treatment plant operated by BWB. Parts of the Nsikazi South WDC are informal with low levels of services. There is however a relatively large formal area with formal infrastructure: viz. Kanyamazane, Tekwane South and Entokozweni Townships, where metering, billing and adequate cost recovery systems are implemented.

Table 8.5: Status quo assessment and strategy

Status quo	Strategy
Institutional and legal assessment	
<ul style="list-style-type: none"> The relationship with the municipality and politicians has improved lately. Sembcorp is well structured and has sufficient capacity to implement WC/WDM but training and increased capacity is required in WC/WDM section. The WSP uses the municipal bylaws which are currently under review but have their own customer charter. 	<ul style="list-style-type: none"> Set up WC/WDM task team, chaired by senior official or MEC to meet on monthly basis to address WC/WDM issues. This should improve communications between organisations, highlight problem areas and transfer skills. Conduct water business and awareness training to councillors to promote WC/WDM.

Status quo	Strategy
	<ul style="list-style-type: none"> Appoint additional staff to increase WC/WDM section and implement training programme. Develop partnerships with the legal departments as well as the SAPS and put bylaw enforcement back on track to promote WC/WDM.
Financial assessment	
<ul style="list-style-type: none"> Non-revenue water is estimated at above 50%. Water tariffs are cost reflective and organisation runs on business principles. A rising block water tariff structure is in place to promote WC/WDM. Meter reading acceptable but can improve. Billing is informative Metering and billing is generally problematic or non-existing and associated with reluctance to pay and illegal connections. High level of non-payments. 	<ul style="list-style-type: none"> Metering and billing will not improve until the level of service has improved and the overall system is stable. Consider installing water restricting devices to curb daily consumption. Improve relationship with the consumers and the leadership and focus on promoting payment for services through the councillors and through community education and awareness.
Social assessment	
<ul style="list-style-type: none"> The relationship with the community is generally positive. Infrastructure vandalism and illegal connection is problematic in the area. Water is paid for but not valued very highly and excessive garden watering is a common phenomenon. WSP has an effective customer call centre and promote reporting of leaks. 	<ul style="list-style-type: none"> Undertake a comprehensive community awareness programme to promote water efficient practices and make community aware that problems will not be solved without their support. Promote fixing of internal plumbing leaks. Deploy community plumbers to assist with fixing leaks and creating awareness. Consider hosepipe ban or restricted garden watering until system has stabilised. Improve schools awareness campaigns.
Technical assessment	
<ul style="list-style-type: none"> There is sufficient macro management information available to perform a proper assessment of the water losses and potential savings. The system is characterised by intermittent supply and poor service. Bulk metering and leak repairs are taking place. High prevalence of illegal connections 	<ul style="list-style-type: none"> Improve the level of services and focus on providing continuous supply which should reduce illegal connections. Meter all non-domestic consumers in the area such as car washes. Improve pressure management and maintain the satisfactory operating pressures.

Status quo	Strategy
<ul style="list-style-type: none"> with consumers trying to gain access to water supply. Reactive maintenance in the area. 	<ul style="list-style-type: none"> Consider undertaking an internal leak audit and repair exercise for indigent and non-paying consumers to drastically reduce the NRW. Implement a consumer meter replacement programme, starting with the top consumers, whereby 10% of all water meters are replaced per annum.
General observations	
<ul style="list-style-type: none"> Water treatment plants operated by Bushbuckridge Water received 84,61% in the 2012 Blue Drop assessment. There is room for improvement. A water safety plan and management system is already in place for the Kanyamazane distribution systems. 	<ul style="list-style-type: none"> Improve to achieve Blue Drop status and provide proper supply.

Table 8.6: Performance indicators

Indicator	Current Value	Realistic Target Value 15% reduction	Optimistic Target Value 30% reduction
Annual input volume (million m ³ /annum)	19,3	17,4	15,4
Daily input volume (Ml/day)	52,8	47,6	42,3
Population (2012)	230 273	-	-
Households (2012)	57 425	-	-
% Non-revenue water	60%	50%	40%
% Water Losses	45%	30%	20%
Total Unit Consumption Litres/capita/day*	229	207	184
Domestic Authorised Unit Consumption with daily visitors subtracted l/c/d	126	145	147
Domestic Authorised Unit Consumption m ³ /households/month*	15	18	18

The unit consumption in this area is relatively high. Some areas have water borne sewerage systems, but there are also areas with pit latrines and on average, 229 l/c/d is too high. The authorised domestic consumption is reasonable, namely 126 l/c/d. Attention must therefore be given to the 60% non-revenue water. The average world domestic unit consumption of 180 l/c/d is lower than the total domestic water use, but higher than the authorised domestic water use (126 l/c/d). It is understood that certain WC/WDM measures have already been implemented and this work needs to be expanded. The WSP must ensure that all the actions in **Table 8.5** receive the necessary attention.

Summary and conclusions

There is scope for WC/WDM in the Nsikazi South area but these measures will not necessarily result in the reduction of non-revenue water and the total system input volume. The main focus in this area should be on improving service delivery, fixing visible leaks, and creating community and institutional awareness programmes through the following interventions:

- Improve service delivery and strengthen the relationship with community.
- Ensure continuous supply by improving Kanyamazane WTW operation and maintenance.
- Deploy community plumbers to fix internal plumbing leaks and create WC/WDM awareness.
- Improve political support through a councillor awareness programme focusing on water.
- Maintain bulk meters to provide accurate macro management information.
- Implement a community awareness programme that promotes the value of water and water wise gardening.
- Establish a culture of payment for water.
- Introduce zone metering and sectorisation to improve micro management information. This will assist with the identification of key water loss areas and reduce the number of pipe bursts.
- Maintain pressure management programme in conjunction with sectorisation and continuous monitoring.

8.8.1.2 Water licence applications for conversions of irrigation entitlements

MLM has already applied to DWA in 2003 for the conversion of irrigation entitlements into a licence for domestic water use. The property which had the irrigation entitlement was Portions 10, 11 and 12 of the farm Broedershoek 129 JU and portions 10, 18 and 19 of the farm Broedersvrede 136 JU. The converted volume of water applied for was 753 200 m³/a. This licence is still outstanding and it was assumed that it will eventually be issued. It was assumed that the licence will be issued in 2013.

8.8.1.3 Removal of IAPs

The removal of IAPs in the upper parts of the Crocodile catchment will benefit Nelspruit. The removal of IAPs between Nelspruit and Nsikazi South will not result in a significant benefit.

The removal of IAPs in the Primkop Dam catchment can benefit Nsikazi South, but as will be shown this benefit would be more of value to Matsulu.

8.8.1.4 Operating rules Primkop Dam

As described in Par 7.8.2.4, the implementation of operating rules for Primkop Dam can make another 1 million m³/a available. This action can benefit Nsikazi South, but as will be shown this benefit would be more of value to Matsulu.

8.8.2 Reconciliation options that will increase water supply

8.8.2.1 Groundwater development

As shown on the geological map of the area, several northwest/southeast striking dykes are present. A northwest/southeast striking shear zone cuts through the area. (See **Figure 8.3**)

Groundwater resources with a potentially high yield are normally associated with these structural features. However, a high density airborne magnetic survey of the area is required to locate these structural features and select targets for more detailed geophysical traversing. It is recommended that the radon emanation technique (Levin, 2000) be applied to locate optimum drilling targets.

It is expected that at least 200 000 m³/a can be obtained from the ground water resources.

8.8.2.2 Dam construction to increase yield storage

Any of the dam options for Nelspruit as described in **Section 5.8.2.2** and in the Water Requirements and Water Resources report, can also benefit Nsikazi South.

8.8.2.3 System operating rules

The operating system for the Crocodile River is already one of the most advanced in the country: There are limited options for making additional water available through improved system operation. The improved operation of Primkop Dam could benefit Nsikazi South but as will be shown in the next chapter, this benefit could better be made available to Matsulu.

8.8.2.4 Water transfers from elsewhere

Water transfer from the Kaap River is possible, as described for Nelspruit. Such a transfer scheme will benefit more than one WDC and will benefit all the WDCs which take water from the Crocodile River.

8.9 SELECTED RECONCILIATION SCENARIOS

The following intervention scenarios have been considered for reconciliation of the Nsikazi South's water balance:

8.9.1 Continuing and expanding the WC/WDM measures

It is acknowledged that the water supply system is not 100% stable, and is prone to interruptions at places within Nsikazi South. It will therefore be very difficult to properly monitor leakage unless the system is stabilised. There are however measures that can be taken (e.g. raising public awareness, establishing a culture of payment, etc.): a target of 15% water saving is regarded as achievable.

The implementation of this 15% water saving scenario would result in a water balance for almost the entire planning horizon for both the low and high water requirement scenarios. (See **Figure 8.3** – Scenario 8.8.1)

Figure 8.3 also gives an indication of a gradually increasing unit consumption from 90 l/c/d towards the world average unit consumption of 180 l/c/d relative to the reduced water requirement scenarios (White curve).

8.9.2 WC/WDM measures plus pending licences

A quantity of 0,75 million m³ can be available for use once the licence is issued by DWA.

8.9.3 WC/WDM measures plus pending licences plus groundwater development

The shear zones immediately west of Nsikazi South provide an opportunity for the development of more groundwater. It is not expected that more than 200 000 m³/a can be provided from this resource. Groundwater development is a good option to satisfy local deficits within the WDC within a short span of time.




Figure 8.3: Water reconciliation for Nsikazi South

8.10 RECONCILING THE WATER REQUIREMENTS WITH THE WATER RESOURCE

8.10.1 Water balance for selected reconciliation scenarios

Scenario 8.9.3 was selected as the appropriate intervention option for Nsikazi South's water balance. The water requirement curve lies below the water supply line for the entire planning period, although temporary water restrictions may be necessary until the benefit of the WC/WDM measure have been achieved. The

remaining part of the White River surplus, not used by Nelspruit and on its way to Matsulu could also satisfy this temporary deficit. (not shown on graph).

8.10.2 Actions that need to be implemented

The actions in **Table 8.7** need to be undertaken.

- The abstraction works and distribution system for Nsikazi South need urgent repair in order to stabilise the interrupted water supply and subsequently enable the WSP to enforce WC/WDM measures.
- The licence application of 2003 need to be considered by DWA and, if there is no impediment for issuing, the licence should be issued without any further delay.
- Groundwater can be developed which will help to overcome the water shortages.

Table 8.7: Actions that need to be initiated – responsibilities and timelines

Action	Responsibility	Timeline
Implement WC/WDM. Draw up a WC/WDM plan	Sembcorp/Silulumanzi	Start with plan immediately and implement from 2014.
Stabilise the continuous interrupted water supply.*	Bushbuckridge Water Board	Immediately
Licence to be issued (irrigation entitlements to be converted)	DWA and ICMA	Before end 2013
Groundwater borehole siting using techniques described in Paragraph 5.5.1 .	Sembcorp/Silulumanzi	Start beginning of 2014 and drill and equip borehole(s) within 1 year.

* **Note:** Nsikazi South is currently experiencing regular interruptions in water supply as a result of breakdowns on the pumping station or the WTWs. No proper WC/WDM can be motivated and/or measured if this problem is not addressed.

9 MATSULU

9.1 POPULATION GROWTH

The low and high population growth scenarios for Matsulu are shown in **Table 9.1** and **Figure 9.1**. An ad hoc house count was done from 2007 and 2011 aerial photographs because Sembcorp indicated that the population growth should be much higher than documented in this study's Demographics and Future Water Requirements Report. It was found that the number of houses increased from 10 528 in 2007 to 11 983 in 2011 which means an increase of 3,29% per year. It was therefore assumed that, for the high growth scenario, this extraordinary growth rate would continue on this level until 2015 and will thereafter steadily decrease to a rate of 1,1% per year in 2030 which was the growth rate predicted in the Demographics and Future Water Requirements report for 2030. For the low growth it was assumed that the growth rate would steadily decrease from 2012 to 2030 where it would reach the rate of the Demographics and Future Water Requirements report of 0,9% per year.

Table 9.1: Low and high population growth for Matsulu

Year	2009	2010	2015	2020	2025	2030
Low	45 041	46 523	54 696	61 680	67 839	71 979
High	45 041	46 523	54 379	62 953	69 921	74 924




Figure 9.1: Low and high population growth for Matsulu

9.2 CURRENT WATER USE

Sembcorp is the WSP for Matsulu. Water is abstracted from the Crocodile River, then treated and distributed to Matsulu. The current domestic water use is 4,8 million m³/a, or 14,5 Mℓ/day. According to Sembcorp an extension of the current WTW capacity of 12 Mℓ/d is planned to 24 Mℓ/d in two phases of 6 Mℓ/d each. These expansion plans do not appear to have considered the limited water resource available at the current abstraction point in the Crocodile River.

9.2.1 Domestic water use

The domestic use is 4,8 million m³/a.

9.2.2 Industrial water use

There is no industrial use in Matsulu. There is some commercial use, but a breakdown between domestic and commercial use is not available.

9.3 PROJECTED FUTURE WATER REQUIREMENTS

9.3.1 Domestic water use

It is anticipated that domestic use will increase up to 2030 in line with the population growth. The projected domestic future water requirements are shown in **Table 9.2** and **Table 9.3**.

Table 9.2: Projected domestic water requirements in million m³/a

Year	2010	2015	2020	2025	2030
Low	4,96	5,80	6,58	7,24	7,68
High	4,96	5,84	6,72	7,46	7,99

Table 9.3: Projected domestic water requirements in Mℓ/day

Year	2010	2015	2020	2025	2030
Low	13,59	15,89	18,02	19,82	21,03
High	13,59	15,98	18,39	20,43	21,89

9.4 WATER RESOURCE AVAILABILITY

9.4.1 Groundwater availability

The geology of the study area as shown on the geological map (**Figure 5.2**) consists of biotite-trondhjemite gneiss to the north and west of the town. To the south and east the area is underlain by undifferentiated basaltic rocks and schists, and interlayered with banded iron formation. No dykes or structural features are shown on the geological map.

The aquifer is classified as an inter-granular and fractured aquifer according to the 1:500 000 hydrogeological map (1:500 000 Hydrogeological Map Series of the Republic of South Africa Nelspruit 2530 (DWAF, 1999)). The occurrence of

groundwater is associated mainly with the deeper weathered and fractured zones. The groundwater yield potential in the gneiss is classed as low, with potential yields between 0,5 l/s to 2,0 l/s, and high in the basaltic and schist formations, between 2,0 l/s and 5,0 l/s. According to Vegter (1995) the probability of drilling a successful borehole in the gneiss is below 40%, and of drilling a borehole yielding more than 2 l/s only 20 to 30%. The probability of drilling a successful borehole in the basaltic and schist formations is between 40 and 60% and the chance of drilling a borehole yielding more than 2 l/s is between 30 and 40%. It was concluded that the general groundwater availability was generally low to the north and west of the town, but good to the south and east. This will require further, more detailed investigations for development.

9.4.2 Surface water availability

The situation at Matsulu is the same as at Nelspruit and Nsikazi South, i.e. relying largely on water from the Crocodile River. As discussed in **Section 5 (Nelspruit)**, the Crocodile River is already fully allocated and probably over-utilised due to unlawful abstractions. Additional allocations to Matsulu from the Crocodile River, without interventions to increase the yield of the system, will therefore encroach on the Reserve, international obligations and downstream water users.

The Matsulu pump station is located downstream of the confluence of the Crocodile and Kaap River: hence Matsulu also has access to water from the Kaap River. The Kaap River is, however, also over-utilised, and there is currently no surplus water available from the Kaap River unless the yield of the Kaap River is increased by means of a dam such as Mountain View Dam. This is discussed in the Water Requirements and Water Resources report, which is a supplementary report to this strategy.

The Matsulu abstraction weir in the Crocodile River provides insufficient supply from time to time, owing to the presence of the Kaapmuiden Weir and Van Graan Canal upstream. Water is diverted through this canal, runs through a hydropower generator, and is discharged back into the river downstream of the Matsulu abstraction point. See **Section 9.10** where a possible solution for this problem is suggested.

9.5 WATER QUALITY

9.5.1 Sources of pollution

The water abstracted from the river at the Matsulu pump is fit for domestic use after treatment. At this stage, no records of the water quality upstream in the river have been found. The Matsulu WTW off-take is situated upstream of the Matsulu WWTW. Treated water from the WWTW can impact on lower water users in the river.

The Matsulu WWTW has only a 58% chemical discharge compliance with the Greendrop Assessment suggesting an increased risk of deterioration. It needs to be noted however, that the Matsulu WWTW plant has the second lowest risk in Mbombela, although this risk increased from 35% to 36% over the last year.

9.5.2 Trend analyses

DWA is currently only sampling the inlet at the WWTW. The closest downstream monitoring point in the Crocodile River is at Malalane. Sembcorp is however conducting upstream and downstream analyses from the WWTW on a weekly basis. A trend has not been studied by the PSP as no data was made available to the team.

9.6 THE WATER BALANCE

9.6.1 Current water balance with no interventions

The present ecological state of the Crocodile River needs to be maintained: therefore the current licensed abstraction volume of 4,4 million m³/a at Matsulu may not be exceeded.

The current abstractions and authorisations are summarised in **Table 9.4**.

Table 9.4: Current abstractions and licences for Matsulu

Source	Abstraction million m ³ /a	Licence million m ³ /a	Comments
Abstraction from Crocodile River	5,1	4,4	Licence issued by DWA. The current abstraction exceeds the authorised amount.
Total	5,1	4,4	

From the table it can be seen that the current water abstraction exceeds the authorised resource for Matsulu.

9.6.2 Future water balance with no interventions

A projection was made of the future water requirements over the full planning period for Matsulu. The high and low growth scenarios for water requirements are shown in **Figure 9.2**.




Figure 9.2: Projected water demand for high and extra high growth water requirement scenarios and the available water resource

9.7 POSSIBLE INTERVENTION OPTIONS

9.7.1 Reconciliation options that will reduce water requirements

9.7.1.1 WC/WDM

Water services at Matsulu are operated and maintained under concession by Sembcorp under the jurisdiction of MLM. A great portion of the demand centre is formal, with formal infrastructure which allows adequate metering, billing and cost recovery, however there is also an area with informal infrastructure.

A WC/WDM plan has already been compiled by Sembcorp but has not yet been formally released. The WSP is of opinion that 20% water saving could be achieved for this WDC. The actions in **Table 9.5** in terms of WC/WDM are required and Silulumanzi must ensure that they are all covered in their implementation plan.

Table 9.5: Status quo assessment and strategy

Status quo	Strategy
Institutional and legal assessment	
<ul style="list-style-type: none"> Sembcorp is well structured and has sufficient capacity to implement WC/WDM but training and increased capacity is required in WC/WDM section. The relationship between the stakeholders in this supply area is generally good. The relationship with the municipality and politicians has improved but can be better. 	<ul style="list-style-type: none"> Setup WC/WDM task team, chaired by senior official or MEC to meet on monthly basis to address WC/WDM issues. This should improve communications between organisations, highlight problem areas and transfer skills. Appoint additional staff to increase WC/WDM section and implement training programme Conduct water business and awareness training to councillors to promote WC/WDM.
Financial assessment	
<ul style="list-style-type: none"> Non-revenue water is estimated at above 50%. Metering, billing and cost recovery system is generally good. Water tariffs are cost reflective and organisation runs on business principles Very high level of non-paying consumers estimated at 60%. A rising block water tariff structure is in place to promote WC/WDM Water bill is informative. 	<ul style="list-style-type: none"> Metering and billing will not improve until the level of service has improved and the overall system is stable. Consider installing water restricting devices to curb daily consumption. Improve level of service and supply to the area and consider installing meters in areas where there is no metering and billing taking place
Social assessment	
<ul style="list-style-type: none"> The relationship with the community leaves room for improvement. Since limited consumers are paying for services, water wastage through excessive garden watering is evident in the area. There is a high level of low income earners and indigents. WSP has an effective customer call centre and promote reporting of leaks. There are school awareness programmes taking place, targeting two schools on monthly basis. Infrastructure vandalism and illegal connections is generally problematic. 	<ul style="list-style-type: none"> Continue with comprehensive community awareness programmes to promote water efficient practices. Promote fixing of internal plumbing leaks. Deploy community plumbers to assist with fixing leaks and creating awareness. Consider hosepipe ban or restricted garden watering until system has stabilised. Make community aware that problems will not be solved without their support.
Technical assessment	
<ul style="list-style-type: none"> There is macro management information available to perform a proper assessment of the water losses and potential savings. Bulk metering in place, no 	<ul style="list-style-type: none"> Maintain reading the bulk meters on a monthly basis and monitor input volumes and keep updating management information. Stabilise the supply and focus on

Status quo	Strategy
sectorisation reservoirs are interconnected. <ul style="list-style-type: none"> The system is characterised by intermittent supply and poor service. High prevalence of illegal connections with consumers trying to gain access to water supply. Aging infrastructure and high pressures. Internal plumbing leakages are problematic in the area. 	providing continuous supply which should reduce illegal connections. <ul style="list-style-type: none"> Implement and maintain sectorisation to identify key problem areas maintain pressure management and reduce bursts. Implement pressure management and install PRV's in critical areas experiencing high pressures and monitor on a monthly basis.
General observations	
<ul style="list-style-type: none"> Matsulu water treatment plant operated by Sembcorp received 96% in the 2012 Blue Drop assessment which is an indication of a well-managed water supply. A water safety plan and management system is already in place for the distribution system. 	<ul style="list-style-type: none"> Maintain Blue Drop status and expand performance to water distribution network through proper management and control.

Table 9.6: Performance indicators

Indicator	Current Value	Realistic Target Value 15% reduction	Optimistic Target Value 30% reduction
Annual input volume (million m ³ /annum)	5,3	4,51	3,71
Daily input volume (Ml/day)	14,5	12,3	10,2
Population (2012)	49 634		
Households (2012)	12 378		
% Non-revenue water	80%	60%	40%
% Water Losses	40%	30%	20%
Total Unit Consumption Litres/capita/day*	292	248	205
Domestic Authorised Unit Consumption	175	174	164
Domestic Authorised Unit Consumption m ³ /households/month*	21	21	20

Based on the unit consumption of Matsulu it is clear that WC/WDM should be implemented as a matter of priority. The current consumption is much higher than the international average of 180 l/c/d. It is not known what percentage of houses have waterborne sewerage systems and what percentage not. Even if the majority of the houses do have waterborne sanitation connections, the unit consumption of 292 l/c/d is much too high. The authorised domestic unit consumption looks better and is close to the international average of 180 l/c/d.

The thin black curve on the water balance graph reflects a target unit water consumption that gradually increases from 90 l/c/d to the international average of 180 l/c/d.

Summary and conclusions for WC/WDM

There is scope for WC/WDM in the Matsulu area which will result in both reduction of non-revenue water and the total system input volume. The effort of Sembcorp so far with compiling a WC/WDM implementation plan is a step in the right direction and the WSP is encouraged to maintain this progress. There is limited capacity and skills available to embark on such a programme which should be resolved before focusing on the following interventions:

- Improve political support through a councillor awareness programme focusing on water.
- Implement zone metering and sectorisation to improve micro management information. This will assist with the identification of key water loss areas and reduce number of pipe bursts.
- Undertake a community awareness programme that promotes the value of water and water wise gardening.
- Maintain satisfactory operating pressure: install PRVs in areas experiencing high pressure, and ensure that operating pressures never exceed the DWA regulatory standard of 9 Bar.
- Train meter readers and perform monthly audits to eliminate estimates and other inaccuracies.
- Perform meter audit and cleaning to improve meter reading and accessibility.
- Implement sectorisation in the areas where practicable into smaller manageable discrete zones to aid effective monitoring of the network.

9.7.1.2 Removal of IAPs

Removal of IAPs in the catchment of Primkop Dam can benefit Matsulu since Karino/Plaston and Nsikazi South can opt for more preferable options. The runoff to Primkop can be increased to 0,9 million m³/a which will yield 0,4 million m³/a.

9.7.1.3 Water re-allocation

Water re-allocation can be considered. As explained under **Par 5.8.1.5**, the water entitlements of irrigation farmers who are not using their water entitlements can be re-allocated to Matsulu. The DWA policy and legislation will have to be changed before such re-allocation can be done. The NWRS2 suggests such a change, but it is foreseen that it can take quite a while.

The precise quantification of the areas of available irrigation lands that could possibly become available for re-allocation has to await the completion of the validation and verification processes. In order to get a very provisional idea of the possibilities, the study team did a reconnaissance level investigation along the Elands (tributary of the Crocodile River) and Sabie Rivers with aerial

photography and satellite imagery, supported by limited ground truthing. Caution should however be exercised when interpreting results obtained by such purely remote means, since some aspects related to current and historical water use are not evident from remote imagery. A definitive assessment of water use will require direct interaction with stakeholders, including property owners and water management authorities.

The reconnaissance level investigation showed that of the 2 683 ha scheduled irrigation along the Elands River; approximately 1 200 ha was not being used at the time of the aerial photograph or satellite image. This does not necessarily imply that these lands are lying fallow, but merely provides an indication of a possible outcome of a more detailed future survey. The volume of water associated with this 1 200 ha of land is in the order of 7 million m³/a. Should the survey be expanded to the full irrigated area along the Crocodile River this volume would increase.

It will be seen from **Figure 9.3** under **Section 9.8** below that approximately 1,0 million m³/a will be needed to achieve a water balance. It can therefore be confirmed that this could be a reconciliation possibility with relatively low expected social impacts.

9.7.2 Reconciliation options that will increase water supply

9.7.2.1 Groundwater development

One of the few options to increase water availability in this area is groundwater development. However, only a small augmentation can be expected from this resource. Borehole siting must be done as described under **Paragraph 9.4.1**. It was assumed that 100 000 m³/a will become available with groundwater development.

It is recommended that groundwater development focus on the basaltic and schist formations to the south and east of the town. These formations extend across the district boundary into the Umjindi District area east of Kaapmuiden. Although no major geological structural features are indicated on the geological map (**Figure 5.2**), the 1:500 000 hydrogeological map (1:500 000 Hydrogeological Map Series of the Republic of South Africa Nelspruit 2530, (DWAF, 1999) of the area indicates a good potential for groundwater in these formations. Modern geophysical technology is capable of identifying potential water bearing-structures. High density airborne magnetic survey of the area will be required to identify the exact locality of these structural features. Targets along these structures need to be selected for geophysical traversing. It is recommended that the radon emanation technique (Levin, 2000) be applied to locate the optimum drilling positions.

9.7.2.2 Dam construction to increase yield storage

Matsulu's water deficit is relatively small and a large dam cannot be justified to meet only Matsulu's needs. However, if a dam is built for Nelspruit, Matsulu will

also benefit as it is situated on the Crocodile River downstream of Nelspruit: Any of the dam options described under **Paragraph 5.8.2.2** and in the Water Requirements and Water Resources report would suffice. The best option will be indicated by the result of an options analysis of the different dam sites. A dam on the Kaap River (such as the proposed Mountain View Dam) could benefit Matsulu directly through a gravity-fed water supply scheme. This is discussed under **Section 9.7.2.4**.

9.7.2.3 System operating rules

Since the operating system of the Crocodile River is already one of the most advanced in the country, there are limited options for making additional water available through improved system operation.

Matsulu can however benefit by improving the operating rules of Primkop Dam. As indicated in **paragraph 7.8.2.34** this option can free up approximately 1 million m³/a. Karino/Plaston is a WDC which is closer to Primkop Dam, but if the pending licence for conversion of irrigation entitlements to water for domestic use is approved by DWA, the benefit of Primkop Dam's improved operating rules can rather be passed on. Nsikazi South also has more preferable options; therefore this option can benefit Matsulu.

9.7.2.4 Water transfers from elsewhere

Matsulu is situated very close to the confluence of the Crocodile and Kaap Rivers. The Kaap River, which is a tributary of the Crocodile, does not fall within the municipal area. It is possible to transfer water from the Kaap River to Matsulu: this would need to be accompanied by the construction of a dam, since the run-of-river yield is fully utilised. There is also potential for using groundwater from the dolomites situated to the south of Matsulu in the Kaap river catchment.

9.7.2.5 Utilising the remaining temporary surplus from White River

The temporary surplus that will become available as a result of the interventions at Nelspruit, including the remaining part of the White River surplus, not used by Nelspruit could be used by Matsulu. There will also be surpluses available from Karino Plaston and Nsikazi South. This may help to overcome the immediate shortages but it must be considered that this benefit will phase out as the other WDCs' water requirements are rising and they are taking up all their available water.

9.8 SELECTED RECONCILIATION SCENARIOS

The following reconciliation scenarios have been considered in order to achieve a water balance for the Matsulu water demand centre:

9.8.1 Implementing WC/WDM only (20% water saving)

The effect of WC/WDM measures can be seen in **Figure 9.3**. Implementing this measure will not draw down the water requirement curves below the water availability line, but WC/WDM should anyway be implemented from a best practice point of view and to reduce the impacts of compulsory water curtailments.

9.8.2 WC/WDM and the surplus at Nelspruit

The temporary surplus at Nelspruit will help Matsulu to overcome its immediate water shortages and, as can be seen from Figure 9.3, will satisfy the Matsulu reduced water requirements (as result of WC/WDM measures) up to 2020. The temporary surpluses at Karino Plaston and Nsikazi South (See Figures 7.3 and 8.3) will also be available for Matsulu but have not been included in this scenario. The surplus at Nsikazi South will be available for a longer period of time and can be regarded as safety factor for Matsulu, should the re-allocation of water (Par 9.8.6) not materialise. This leaves some latitude for Nsikazi South, should it not be fully successful with its WC/WDM measures.

9.8.3 WC/WDM, Nelspruit surplus and borehole development

As can be seen on the second graph in **Figure 9.3**, only a small improvement is expected with groundwater development. The water deficit after 2020 still remains.

9.8.4 WC/WDM, Nelspruit surplus, borehole development and Operating Rules Primkop Dam

Water demands can be satisfied until 2021 with this option. (See **Figure 9.3**)

9.8.5 WC/WDM, Nelspruit surplus, borehole development, Operating Rules Primkop Dam and removal of IAPS in the catchment of Primkop Dam

The water demands can be satisfied for less than one more year.

9.8.6 Scenario 9.8.5 plus water reallocation

This scenario can meet demand completely as reflected in **Figure 9.3**. The focus should be on fallow scheduled lands that are no longer irrigated, so that the loss to agriculture will subsequently not lead to major job losses.

The water demands can be satisfied for the entire period with this scenario. (See **Figure 9.3**). The surpluses from Karino Plaston and Nsikazi South would also satisfy all Matsulu's water requirements for the full planning horizon but this is not shown on the graph and is regarded as safety factor, should any one of the Karino Plaston or Nsikazi South measures not be fully effective as planned.




Figure 9.3: Water balance for Matsulu with possible interventions

9.9 RECONCILING THE WATER REQUIREMENTS WITH THE WATER RESOURCE

9.9.1 Water balance for selected reconciliation scenarios

The selected scenario for reconciliation of Matsulu water balance is shown in **Paragraph 9.8.6** (and 9.8.6), and summarised in **Figure 9.3**. However, this will require careful consideration of the social issues associated with re-allocating irrigation entitlements.

9.9.2 Actions needed

The following immediate actions are seen as necessary:

- Ensure that all WC/WDM actions described in **Table 9.5** are incorporated in the existing WC/WDM plan, developed by Sembcorp for Matsulu and start implementing the plan.
- Investigate the possibility of groundwater development further. Undertake borehole siting in accordance with the methodology suggested in **paragraph 9.4.1**.
- Develop improved operating rules for Primkop Dam.
- Remove IAPs from the Primkop Dam catchment.
- Investigate the possibility of re-allocating water entitlements from upstream irrigators who are not currently practicing irrigation and where social consequences will be relatively low.

Table 9.7: Actions required, responsibilities and timelines

Action	Responsibility	Timeline
Implementation of a WC/WDM plan for Matsulu.	Sembcorp/Silulumanzi	Start beginning of 2014 and plan fully implemented by 2019.
Groundwater development for short term water shortages.	Sembcorp/Silulumanzi	Start 2014 and abstract water in that same year.
Developing improved Operating Rules for Primkop Dam	Directorate: Water Resource Planning Services in DWA	Must be implemented during 2014
Remove IAPs from the Primkop Dam catchment	Department of Environmental Affairs – Working for Water Teams	Start in 2014
Investigate the possibility of re-allocating water entitlements from upstream irrigators. Focus on fallow lands.	Sembcorp/Silulumanzi in collaboration with ICMA and DWA.	Start investigating 2014. Water licences must be in place by 2020.

9.10 TEMPORARY WATER SHORTAGES AT THE MATSULU ABSTRACTION WORKS

9.10.1 Introduction

In times of low flow in the Crocodile River the pumps at the Matsulu abstraction point runs dry owing to a diversion work upstream. The river flow then bypasses the Matsulu abstraction works through the Van Graan Canal and this water is only returned to the river at a point downstream of the Matsulu abstraction works. This poses a serious problem to Sembcorp and a possible solution to overcome this problem must be found.

9.10.2 Background

The Kaapmuiden Weir diverts water from the Crocodile River on portion 29 of the farm Kaapmuiden 212 JU into the Van Graan Canal. Water flows into the canal through two sluice gate openings, one of which seems to be without a sluice gate at present. From here, the canal conveys water across the property to a two-turbine hydro-electric plant on portion 73 of the farm, before discharging all water back into the river, roughly 5 km further downstream. Abstraction from the canal between the abstraction and discharge points appears to be limited to opportunistic subsistence farming by residents of Matsulu.

The canal and diversion are both legal, authorised under Permit 51E issued on 6 March 1984 in terms of which up to 7,8 m³/s may be diverted through the canal. The only condition is that no consumptive use of water may take place from the canal and all water is to be returned to the river. For this reason, downstream irrigators are not impacted.

However, the abstraction point for Matsulu lies between the canal diversion and discharge point (See **Figure 9.4**) and when the river is low, it has frequently happened in the past that the canal diverts most, even all of the river's flow. Very little water was, under those conditions, reached the Matsulu abstraction point. Historical correspondence on record at DWA refers to disputes between Mr. Van Graan and the (then) government of KaNgwane going back to the 1980s and early 1990s. Steadily growing water requirements by Matsulu since then suggests the problem might become worse in future.

Permit 51E made no allowance for Matsulu's domestic abstraction and only stipulated that at least $0,1 \text{ m}^3/\text{s}$ should remain in the river at all time for environmental purposes. In this respect, at least, the permit is clearly unsatisfactory. Matsulu's abstraction was periodically interrupted throughout the 1980s and early 1990 and the recurrence of the problem at the time resulted in pipes being installed in the canal (probably during the late 1980s), allowing emergency discharge back to the river during periods of low flow in the river. Two discharge pipelines, one 300 mm diameter and the other 200 mm diameter have been laid from the canal to the river. The smaller pipe is permanently open but the 300 mm pipe is operated by a manual valve and is opened only on request by SembCorp during periods of low flow. It is uncertain whether this valve is fully and timeously opened by the owners of the canal during periods of low flow or, indeed, whether the two pipelines are sufficient for the Matsulu abstraction works.




Figure 9.4: Kaapmuiden weir and Van Graan Canal

9.10.3 Possible solutions

The possible solutions offered below should be verified during times of low flow in the river, at a time when conditions of water shortage exist. Recent flows in the river were too high and the possible solutions could not be thoroughly assessed when this report was finalised (see **Figure 9.5**).



Figure 9.5: Kaapmuiden weir and inlet to the Van Graan Canal

The following need to be established during a further site inspection when the flow in the river is low and Matsulu reports water shortages.

- That the sluice gates at the weir are intact and in good working condition.
- That the 300 mm diameter and 200 mm diameter pipelines are free from any blockages, that the 300 mm diameter pipe's control valve is in working condition and that it is fully and timeously opened during times of low flow in the river when requested by Sembcorp.
- That Sembcorp is not over-abstracting at the Matsulu abstraction works and that they are adhering to their licence conditions.

If the above has been verified, and Matsulu's water-related problems persist, the following possible solutions could be investigated:

9.10.3.1 Revising the permit for the Van Graan Canal and issuing a new licence in terms of the National Water Act (NWA), 1998 (Act 26 of 1998)

The original permit 51E made no allowance for domestic requirements of Matsulu, even though the requirement was known to exist at the time, or became evident soon after the permit was issued.

The flow requirement in the river for the Matsulu abstraction works is 0,3 m³/s (based on the 12 Mℓ/day existing abstraction works and the 12 Mℓ/day planned extension) over and above the 0,1 m³/s for environmental flow requirements. Based on this, reasonable grounds exist to argue for an increase in the 100 ℓ/s minimum flow requirement stipulated in Permit 51E to 400 ℓ/s.

Replacing Permit 51E with a license and altering any of the permit conditions, even the permissible flow rates, is allowed within the legal framework of the compulsory licensing process. While the requirements of the canal owner should

be considered, Section 22(7)(b) of the NWA does address reductions in existing lawful uses to (i) rectify an over-allocation of water use from the resource in question; or to (ii) rectify an unfair or disproportionate water use. These two conditions may conceivably exist here.

The replacement of the permit with an amended licence will have practical implications. Measuring flumes will then need to be constructed at the inlets of the two pipelines to monitor the flow. If both the pipelines can't handle 400 l/s a further pipeline from the canal needs to be constructed. Alternatively the Kaapmuiden weir needs to be modified so that it can measure low flows (e.g. equipping it with a V-notch), the intake gates need to be refurbished so that the flow in the river can be set on 400 l/s during times of low flows

9.10.3.2 Moving the Matsulu abstraction works

The Matsulu abstraction pumps could possibly be moved to a point downstream of the turbine discharge point of the Van Graan Canal or immediately upstream of the Kaapmuiden weir where a domestic pump has historically existed

9.10.3.3 Supplying Matsulu under gravity from the Mountain View Dam

If the Mountain View Dam option is chosen as one of the long term strategies for the water reconciliation, the problem could automatically solve itself since Matsulu can then be supplied under gravity from the dam and the abstraction from the Crocodile River will no longer be required. This however could take a long time and the lead time for dam construction of the size of Mountain View Dam is approximately 5 years. One of the first two above options should therefore rather be considered.

10 OTHER WATER DEMAND CENTRES (ELANDSHOEK, NGODWANA, KAAPSE HOOP,)

10.1 POPULATION GROWTH

10.1.1 Elandshoek

Only one growth scenario was developed for Elandshoek, a small town situated to the west of Nelspruit. The expected population growth for Elandshoek is summarised in **Table 10.1** and shown in **Figure 10.1**.

Table 10.1: Expected population growth for Elandshoek

Year	2009	2010	2015	2020	2025	2030
Low & High	406	416	467	517	565	610




Figure 10.1: Elandshoek Population Growth

10.1.2 Ngodwana and Kaapsehoop

No population growth is expected for Ngodwana: it is expected to stay constant at 1 530 residents.

Kaapsehoop is a weekend/holiday town with 177 permanent residents. It has a maximum overnight accommodation for an additional 390 visitors.

10.2 CURRENT WATER USE

10.2.1 Domestic water use

10.2.1.1 Elandshoek

Elandshoek receives its water from a mountain stream which gravity feeds into a 1 Mℓ/day WTW. The current water use 0,148 Mℓ/day.

10.2.1.2 Ngodwana

Ngodwana takes water from the Ngodwana Dam. The current domestic use is 0,5 million m³/a or 1,37 Mℓ/day.

10.2.1.3 Kaapsehoop

There is no surface water supply in the town; the only water source is groundwater. However, the groundwater quality is low, due to high concentrations of iron.

10.2.1.4 Industrial water use

The SAPPI paper mill at Ngodwana is the largest single industrial user in the municipal area, using approximately 38,4 Mℓ/day or 14,0 million m³/a.

10.3 PROJECTED FUTURE WATER REQUIREMENTS

10.3.1 Domestic water use

The projected domestic water requirements for each of the three towns are summarised in **Table 10.2** and **Table 10.3**.

Table 10.2: Domestic use for Elandshoek, Ngodwana and Kaapsehoop in million m³/a

Year	2010	2015	2020	2025	2030
Elandshoek	0,025	0,028	0,032	0,034	0,037
Ngodwana	0,500	0,500	0,500	0,500	0,500
Kaapsehoop	0,031	0,031	0,031	0,031	0,031

Table 10.3: Domestic use for Elandshoek, Ngodwana and Kaapsehoop in Mℓ/day

Year	2010	2015	2020	2025	2030
Elandshoek	0,069	0,078	0,086	0,094	0,102
Ngodwana	1,370	1,370	1,370	1,370	1,370
Kaapsehoop	0,086	0,086	0,086	0,086	0,086

10.3.2 Industrial water use

SAPPI have indicated that they would also need additional water in terms of their proposed expansion plans for the Ngodwana paper mill. However, at this stage they have not quantified their additional future water requirements.

10.4 HIGH AND LOW SCENARIO WATER REQUIREMENT PROJECTIONS

The total projected water requirements for the three towns are shown in **Table 10.4** and **Table 10.5**.

Table 10.4: Water requirement projections for Elandshoek, Ngodwana and Kaapsehoop in million m³/a

Year	2010	2015	2020	2025	2030
Elandshoek	0,025	0,028	0,032	0,034	0,037
Ngodwana	14,50	14,50	14,50	14,50	14,50
Kaapsehoop	0,031	0,031	0,031	0,031	0,031
Total	14,56	14,56	14,56	14,57	14,57

Table 10.5: Water requirement projections for Elandshoek, Ngodwana and Kaapsehoop in Mℓ/day

Year	2010	2015	2020	2025	2030
Elandshoek	0,07	0,08	0,09	0,09	0,10
Ngodwana	39,73	39,73	39,73	39,73	39,73
Kaapsehoop	0,09	0,09	0,09	0,09	0,09
Total	39,88	39,89	39,90	39,91	39,91

10.5 WATER RESOURCE AVAILABILITY

10.5.1 Groundwater availability

The Malmani dolomite, which is underlain by the Black Reef Quartzite, is the most important geological unit impacting on both the surface and groundwater of the area. The dolomite dips beneath the Timeball Hill Shales to the west, but in the Kaapsehoop and Elandshoek areas, the dolomite and Black Reef are underlain by lava or granitic rocks.

In the Montrose area, serpentinised magmatic formations are present. These rocks, which are classed as inter-granular and fractured are (according to the 1:500 000 Hydrogeological map) host to the highest-yielding aquifer, with a potential yield greater than 5 ℓ/s. Both the dolomite and lava rock occurrences are classed as karst, and are inter-granular and fractured, with both types of formation yielding 2,0 to 5,0 ℓ/s. However the shales, which are also classed as inter-granular and fractured, only yield 0,5 to 2,0 ℓ/s.

In the dolomites and associated formations, the probability of drilling a successful borehole lies between 40 and 60%, and of drilling a borehole yielding more than 2 ℓ/s is between 40 and 50% (Vegter 1995). The probability of drilling a successful borehole in the shales is greater than 40% and of drilling a borehole yielding more than 2 ℓ/s between 20 to 30%.

It is therefore concluded that the general groundwater availability is good, but requires further detailed investigations for development. DWA (1999) undertook an

Intermediate Reserve Determination for the X2H catchment, and set the groundwater allocation for the significant water resources at 78 x 10 million m³/a.

This allocation was set on the basis that:

- Groundwater levels do not decline, and groundwater quality does not deteriorate, and
- Groundwater abstraction does not impact on the flow in the river.

Kaapsehoop is dependent on groundwater, but groundwater sources in and around Kaapsehoop are rich in iron. Alternative sources of water are therefore being sought for this village.

10.5.2 Surface water availability

SAPPI, which operates a paper mill at Ngodwana, is by far the largest water user within the Ngodwana demand centre. Water for the mill is sourced from the Ngodwana Dam which has an estimated yield of 21 million m³/a. In addition, SAPPI have apparently purchased water rights from irrigators in the Elands River. This needs to be confirmed and verified.

Another small user in the Ngodwana demand centre is Elandshoek, which sources water from the Crocodile River. Water quality is a problem since the Elands downstream of the SAPPI paper mill is polluted with industrial effluent. An alternative water source for Elandshoek must therefore be found.

10.6 WATER QUALITY

10.6.1 Sources of pollution

Water quality sampling records are available from 1972. All the parameters comply with the water user requirements. EC varies between 6 and 86,1 mS/m with a median of 17 mS/m. There was an initial increasing trend from 1997 to 2003 in EC, however if the measurements are now compared on a month to month and year on year basis the levels are now higher, but have stabilised. The results of the sampling measurements have not been linked to flow rates in river.

10.6.2 Trend analyses

Seasonal water quality variations are observed. Data from only 16 water quality samples is available from February 2009 to January 2012, of which chemical analysis has been done on only 4 samples. Observations are not linked to flow rates in the river.

It can be concluded that TDS is stabilised from a month on month and year on year comparison for available data from 2009 to 2012.

10.7 THE WATER BALANCE

10.7.1 Current water balance with no interventions

Elandshoek, Ngodwana and Kaapsehoop currently experience no water shortages, but they do experience water quality problems. Elandshoek and Kaapsehoop will need to supplement their water in future.

No future water supply problems are foreseen for Ngodwana (both the village and the factory), since the dam yield exceeds the future water demand.

The water requirements of Elandshoek and Kaapsehoop are very small and can easily be met from groundwater.

10.7.2 Reconciliation options that will reduce water requirements

No formal WC/WDM initiative is envisaged. The residents need to be encouraged to use water sparingly.

10.7.3 Reconciliation options that will increase water supply

10.7.3.1 Rainfall harvesting

Both villages (Elandshoek and Kaapsehoop) are situated in high rainfall areas, and additionally the fog density and frequency of occurrence at Kaapsehoop is one of the highest in the country. Both villages can therefore promote the use of rainwater harvesting among their residents for augmenting water supply, while fog harvesting using nets is an additional possibility at Kaapsehoop. Based on other pilot studies, approximately 5 to 10 l/day can be harvested per m² of net. The fog harvesting yield is however very site specific and it is therefore recommended that a pilot fog harvesting system be erected at Kaapsehoop.

10.7.3.2 Groundwater development

A study undertaken by DWA (1999) showed that 40% of boreholes in this area are dry, and that a further 40% yield less than 0,3 l/s. From this, DWA concluded that groundwater is not utilised to any great extent. Several structural features such as faults and dykes are shown on the geological map, and linear structures cutting through the dolomitic formations are visible on satellite imagery. High potential groundwater resources are normally associated with these structural features. Utilising the dolomitic aquifer to store groundwater for release from a weir could be considered as a development option. The construction of such a weir upstream from the Montrose Falls can be considered. Structural features crossing the Crocodile River need to be identified that can be recharged by the filling of the weir. However, a high density airborne magnetic survey of the area is required to identify the exact locality of these structural features. Targets along these structures need to be selected for detailed geophysical traversing. It is recommended that the radon emanation technique (Levin, 2000) be applied to locate the optimum drilling position.

10.8 SELECTED RECONCILIATION SCENARIOS

The potential for augmenting water supplies through rainwater harvesting should be investigated for the villages of Elandshoek and Kaapsehoop, and for fog harvesting at Kaapsehoop.

Additional boreholes can also be drilled to maintain a sustainable water supply to these two villages.

11 HAZYVIEW

11.1 POPULATION GROWTH

The low and high population growth scenarios for Hazyview are summarised in **Table 11.1** and depicted in **Figure 11.1**. The population of Hazyview is expected to grow steadily until 2030, with an average growth rate of 0,9% in the low growth scenario, and 1,1% in the high growth scenario.

Table 11.1: Low and high population growth for Hazyview

Year	2009	2010	2015	2020	2025	2030
Low	7 506	7 583	7 981	8 356	8 708	9 034
High	7 506	7 599	8 080	8 537	8 968	9 372




Figure 11.1: Low and high population growth for Hazyview

11.2 CURRENT WATER USE

MLM is the WSP in Hazyview. The town receives water from the Sabie River via the Sabie Irrigation Board canal and from a pump station on the Sabie River.

11.2.1 Domestic water use

Hazyview has an allocation of 3,25 Mℓ/day. MLM also has a pump station with a capacity of 2,6 Mℓ/day on the Sabie River which is used when the canal is not in operation or when the water provided from the canal needs to be supplemented. The current water use is 3,8 Mℓ/day or 1,39 million m³/a.

11.2.2 Industrial water use

There is no industrial water use in Hazyview.

11.3 PROJECTED FUTURE WATER REQUIREMENTS

11.3.1 Domestic water requirements

The projected water requirements are expected to increase in line with population growth, increasing steadily up to 2030. **Table 11.2** and **Table 11.3** shows projected domestic water requirements.

11.3.2 Industrial water requirements

No future industrial water requirements are projected.

11.4 HIGH AND LOW SCENARIO WATER REQUIREMENT PROJECTIONS

The projected low and high scenario water requirements are summarised in **Table 11.2** and **Table 11.3**.

Table 11.2: Projected water requirements in million m³/a

Year	2010	2015	2020	2025	2030
Low	1,38	1,46	1,52	1,59	1,65
High	1,39	1,47	1,56	1,64	1,71

Table 11.3: Projected water requirements in Mℓ/day

Year	2010	2015	2020	2025	2030
Low	3,79	3,99	4,18	4,35	4,52
High	3,80	4,04	4,27	4,48	4,69

11.5 WATER RESOURCE AVAILABILITY

11.5.1 Groundwater availability

The geology of the study area as shown on the geological map (**Figure 5.2**) consists mainly of potassic gneiss. Several east/west striking diabase dykes and sills are present in the area, and a northwest/southeast shear zone occurs close to the town. The aquifer is classified as an inter-granular and fractured aquifer according to the 1:500 000 hydrogeological map (1:500 000 Hydrogeological Map Series of the Republic of South Africa Nelspruit 2530 (DWAF, 1999)). The occurrence of groundwater is associated mainly with the deeper weathered zones, whereas fault zones and dyke contacts represent other groundwater occurrences. The groundwater yield potential is classed as low, with potential yields of between 0,5 to 2,0 ℓ/s likely in the gneiss. According to Vegter (1995) the probability of drilling a successful borehole in this area is between 40 to 60%, and of drilling a borehole yielding more than 2 ℓ/s is between 30 to 40%. It is concluded that groundwater is generally available but will require detailed investigations for development.

11.5.2 Surface water availability

Hazyview's main source of water is the Sabie River via the Sabie River Irrigation Board Canal. Water is diverted from the Sabie River some 15 km upstream of Hazyview into the canal, which traverses the right bank of the Sabie River and

discharges unused water back into the Sabie River at Hazyview. The town of Hazyview has an allocation of 1,33 cusecs (37,66 l/s) from this canal. The town also operates a small pump station on the Sabie River near the town which is used periodically either when the canal is empty due to maintenance procedures, or when the canal delivers insufficient water.

There is a perception that there is surplus water in the Sabie River and that the water supply problems of Mbombela can be solved simply by allocating more water from this source. The water resource of the Sabie River was therefore analysed in detail, and the results of the analysis reported in the Water Requirements and Water Resources report. A summary of this analysis is presented in this Strategy report.

Two scenarios were modelled during the assessment of the water resources of the Sabie River. Firstly, a present day situation based on current abstractions from the river was modelled, and secondly a scenario in which the full allocations already made from the Sabie River is supplied.

The current situation and future water use/allocation are summarised in **Table 11.4**.

Table 11.4: Summary of current (2012) and future water requirements within the Sabie River catchment (excluding the Sand River)

Scenario	Current (million m ³ /a)	Future (million m ³ /a)
Irrigation	49	52
Domestic	27	30
Transfer to the Sand River	8	20
Ecological Water Requirements	0	180
Available yield	~100	~0

Based on this analysis it was concluded that while there appears to be ample water currently available within the Sabie River catchment, this water has been allocated to the ecological Reserve and to the Sand River catchment. Transfers to the Sand River from the Inyaka Dam are currently in the order of 8 million m³/a and this will increase by a further 12 million m³/a with the completion of the Inyaka water treatment plant early in 2013. The implementation of the Reserve has recently commenced and entails increased releases from the Inyaka Dam.

The water resource currently available to Hazyview is therefore equivalent to their allocation from the system.

11.6 WATER QUALITY

11.6.1 Sources of pollution

Forestry activities close to or within the riparian zone are the primary threat to the health of the riparian habitats and vegetation. Trout farming is also a threat to in-stream ecological health. The diversion of water for dams and weirs impacts on the

flows in the area, and rivers downstream of trout farms become enriched with nutrients from fish feed and waste.

The Hazyview WWTW is currently being operated 50% above its design capacity, resulting in discharge of poor quality water and a low level of compliance, which can affect downstream users and Nsikazi North.

The water quality in the Sabie River indicates unacceptable levels of phosphates throughout the catchment. This is due to return flows from WWTWs, the large surface area dense settlements in Bushbuckridge that are mainly un-serviced, and runoff from the intensively fertilised cultivation of subtropical fruits.

The water quality trends in the Sabie River indicate increasing nutrient and turbidity levels. The turbidity trend is due to over grazing, and the removal of vegetation for firewood from the slopes of the river valley in the Bushbuckridge area. The increasing nutrient levels are due to the use of fertilisers for the growth of sub-tropical fruits, and sewage waste (both formal, and un-serviced).

11.6.2 Actual water quality versus water quality objectives

Hazyview sewage effluent conforms to the DWA Standard and guidelines as far as the parameters for pH, conductivity, TDS, chloride, sulphates and phosphates are concerned, but ammonia levels exceed the standard by a factor of more than 10.

11.6.3 Trend analyses

Water quality sampling only started in mid-2008. However no sampling or recorded measurements are available for 2009 and 2010. All the parameters, with the exclusion of ammonia, comply with the water user requirements. The levels for ammonia exceed the standard for both the aquatic environment and drinking water. EC varies between 4,24 and 100 mS/m with a median of 46,7 mS/m. Too few samples have been analysed for phosphates and ammonia to be able to make logical conclusions regarding the trend of these parameters.

11.7 THE WATER BALANCE

11.7.1 Current water balance with no interventions

The current water use allocations are summarised in **Table 11.5**.

Table 11.5: Current water use and allocations – Hazyview

Source	Abstraction million m ³ /a	Licence million m ³ /a	Comments
Current abstraction from Sabie Irrigation Board canal.	1,39	1,2	Agreement with Sabie Irrigation Board to abstract 37,7 l/s (1,33 cusecs).
Abstraction from Sabie River.		0,03	Authorisation lost but it is 30 l/s abstraction only if there is no water in the Sabie Canal or when there is a shortage of water in the canal, i.e. this is only a back-up and not an added allocation.
Totals	1,39	1,2	

The figures reveal that Hazyview is currently experiencing a water deficit in terms of their allocation. Whilst this can be mitigated if water is pumped from the Sabie River whilst abstracting from the canal, such an abstraction would be unlawful.

11.7.2 Future water balance with no interventions

A projection was made of the future water requirements of Hazyview and the high and low growth water requirements are shown in **Figure 11.2**.




Figure 11.2: Hazyview water balance without any interventions

From the graph it can be seen that the current water deficit will increase over time without any interventions.

11.8 POSSIBLE INTERVENTION OPTIONS

11.8.1 Reconciliation options that will reduce water requirements

11.8.1.1 WC/WDM within Hazyview

The Hazyview water demand centre is operated and maintained by MLM. The centre consists of mostly formal areas with formal infrastructure which enables adequate metering, billing and cost recovery systems to take place. Based on the available information, qualitative and quantitative scorecards, the assessment and proposed strategy shown in **Table 11.6** were made, and the key performance indicators summarised in **Table 11.7** were identified.

Table 11.6: Status quo assessment and strategy

Status quo	Strategy
Institutional and legal assessment	
<ul style="list-style-type: none"> Mbombela lacks capacity (45% vacancy) and necessary skills to implement WC/WDM. There is no WC/WDM training. The municipal bylaws are currently under review. There is no customer service charter. The level of political support is acceptable but the understanding of the water business can improve. 	<ul style="list-style-type: none"> Appoint additional staff to increase the capacity of the WC/WDM section and implement a training programme. Enforce bylaws that promote WC/WDM. Setup WC/WDM task team, chaired by senior official or MEC to meet on monthly basis to address WC/WDM issues. This should improve communications between organisations, highlight problem areas and transfer skills. Perform Councillor training programme on water business and WC/WDM. Prepare a customer service charter.
Financial assessment	
<ul style="list-style-type: none"> The relationship between the technical and finance department can improve with access to information being a problem. The existing metering, billing and cost recovery system is fair but can improve. Non-revenue water is in the order of 46%. Water tariffs are not cost reflective with limited input from technical department. A declining block water tariff structure is in place which does not promote WC/WDM. 	<ul style="list-style-type: none"> The setup of a WC/WDM task team should improve relationship with finance department and access to information. Provide training to meter readers to improve meter reading and reporting. Water tariffs should be reviewed to become cost reflective and promote WC/WDM.

Status quo	Strategy
<ul style="list-style-type: none"> • Meter reading is not acceptable and often estimated. • Billing is informative showing 2 months of consumption. 	
Social assessment	
<ul style="list-style-type: none"> • The relationship with the community is generally positive in formal income areas while strained in rural (informal) areas. • Water is paid for in formal areas but not valued very highly and excessive garden watering is a common phenomenon. • Illegal connections and non-payment prevalent in rural (informal) areas. • WSP has an effective customer call centre and promotes reporting of leaks. • Rainwater harvesting is promoted with Parks department. 	<ul style="list-style-type: none"> • Promote rainwater harvesting in formal and informal areas. • Embark on community awareness programme that emphasise fixing of internal plumbing leaks. • Embark on schools awareness programme promoting reporting of leaks and water wise practices.
Technical assessment	
<ul style="list-style-type: none"> • There is very little macro and no micro management information available to perform a proper assessment of the water losses and potential savings. • No zone metering, pressure management and sectorisation are being done. • Consumer meters are generally in excess of 5 years old, and under recording. • The WSP has no loggers and leak detection equipment. • Existing telemetry system in some areas. • Top consumers are not pro-actively monitored. • Low pipe burst frequency (approximately 10/ week). 	<ul style="list-style-type: none"> • Implement and maintain sectorisation to identify key problem areas. • Implement pressure management programme and focus on maintenance and monitoring. Will result in reduced number of pipe bursts and prolong infrastructure design life. • PRVs / zones must be continuously monitored to ensure discreteness and PRV settings. • Improve micro management information through proper sectorisation to obtain a better understanding of problem areas. • Implement a consumer meter replacement programme, starting with the top consumers, whereby 10% of all water meters are replaced per annum. • Monitor top consumers on a pro-active basis.
General observations	
<ul style="list-style-type: none"> • The Hazyview WTW received 87,97% in the 2012 Blue Drop assessment which is an indication of a properly managed water supply. 	<ul style="list-style-type: none"> • Improve to obtain Blue Drop status and expand performance to water distribution network through proper management and control.

Table 11.7: Performance indicators for Hazyview

Indicator	Current Value	Realistic Target Value 15% reduction	Optimistic Target Value 30% reduction
Annual input volume (million m ³ /annum)	1,39	1,18	0,97
Daily input volume (Ml/day)	3,8	3,2	2,7
Population (2012)	7 839		
Households (2012)	2 484		
% Non-revenue water	55%	40%	25%
% Water Losses	48%	30%	20%
Total Unit Consumption Litres/capita/day*	485	413	340
Domestic Authorised Unit Consumption with daily visitors subtracted l/c/d	252	289	272
Domestic Authorised Unit Consumption m ³ /households/month*	24	28	26

Based on the high per capita unit consumption recorded in **Table 11.7**, it is clear that WC/WDM should be implemented as a matter of priority. The current consumption is more than double (2,7 times) the international average of 180 litres per capita per day. This high unit consumption is excessive, and no further interventions should be considered before this situation is corrected. A water saving target of 30% is therefore set for Hazyview.

Summary and conclusions

There is scope for WC/WDM in the Hazyview area which will result in both reduction of non-revenue water and the total system input volume. There are limited institutional capacity and skills available to embark on such a programme which should be resolved before focusing on the following interventions:

- Improve political support through a Councillor awareness programme focusing on the water business.
- Review water tariffs to reflect cost of water and promote WC/WDM.
- Train meter readers and perform monthly audits to eliminate estimates and other inaccuracies.
- Perform meter audit and cleaning to improve meter reading and accessibility.
- Devise and implement a community awareness programme that promotes the value of water and water wise gardening.
- Implement zone metering and sectorisation to improve micro management information. This will assist with the identification of key water loss areas and reduce number of bursts.
- Implement a pressure management programme in conjunction with sectorisation and continuous monitoring.
- Undertake a consumer meter replacement programme whereby 10% of all consumer meters are replaced on an annual basis.

11.8.1.2 Removal of IAPs

Removal of IAPs upstream of the Da Gama Dam and upstream of the Sabie Irrigation Board Canal could theoretically make water available for allocation to Hazyview. However, according to the latest WfW survey there are negligible areas of IAPs in these catchments, so this does not appear to be a viable option for this area.

11.8.1.3 Water demand reduction measures in the irrigation sector

Similar to the situation described for Nelspruit in **Section 5.8.1.1**, measures can be implemented by irrigators upstream from Hazyview's abstraction points in the Sabie River to reduce their water demand, which will - in effect increase the water availability at the Hazyview abstraction point. These possible measures are:

- Eliminating unlawful water use (if any) upstream of the Hazyview abstraction point. The volume of unlawful water use in the Sabie River is not known at this stage, and is unlikely to be quantified in time for the completion of this study. It is however, an option that needs to be monitored in future.
- Compulsory licensing (Refer to **Section 5.8.1.4**. The same argument as for Nelspruit will apply).
- Water reallocation (Refer to **Section 5.8.1.4**. The same argument as for Nelspruit will apply.)

11.8.2 Reconciliation options that will increase water supply

11.8.2.1 Groundwater development

As shown on the geological map of the area (**Figure 5.2**) several east/west striking dykes are present close to Hazyview. A northwest/southeast striking shear zone is located to the east of the town. Potentially high-yielding groundwater resources are normally associated with this type of structural feature. However, a high density airborne magnetic survey of the area is required to accurately locate these structural features. Targets along these structures need to be selected for more detailed geophysical traversing. It is recommended that the radon emanation technique (Levin, 2000) be applied to locate the optimum drilling targets. It is assumed that 200 000 m³/a of groundwater can be found from this resource.

11.8.2.2 Dam construction to increase yield storage

There are no dam development options that would increase the yield in the Sabie catchment to benefit Hazyview.

11.8.2.3 System operating rules

A similar real-time operational model to that of the Crocodile River system is under development for the Sabie system. The Sabie real-time model includes a flow forecasting model which will help predict river flows for the week ahead,

based on rainfall forecasts. This should reduce unnecessary releases into the river from Inyaka Dam and will save some water. This model is now in its testing phase: it is too early to recommend new allocations based on the potential savings due to improved operation, but this is a possibility in future.

11.8.2.4 Water transfers from elsewhere

There is no scope for transfers into the Sabie from other catchments, since the neighbouring catchments are considerably more stressed than the Sabie River catchment.

11.9 SELECTED RECONCILIATION SCENARIOS

The reconciliation scenarios evaluated to balance Hazyview's water balance are as follows:

11.9.1 Implementation of WC/WDM measures by MLM

The implementation of WC/WDM measures is a DWA requirement for all water service providers. Although a target saving of 30% will almost balance Hazyview's current water use and water requirements, the high growth scenario runs into deficit again in 2024 (See **Figure 11.3**). The water requirement based on the international standard of 180 l/c/d is also shown. It is clear that water use in Hazyview remains way above this international standard even after a 30% water saving under all the scenarios considered.




Figure 11.3: Water reconciliation for Hazyview

11.9.2 Implementation of WC/WDM measures by MLM, ground water resource development and lowering the Reserve requirement for the Sabie River

Developing groundwater together with the WC/WDM measures will achieve the water balance over the full planning period. In Figure 11.3 the effect of the estimated 0.2 million m³/a groundwater can be seen.

Although the Reserve in the Sabie River catchment has been determined and is now being implemented, the Classification process (to commence early next year) will allow stakeholders to make informed choices between water for development, and water for the ecology.

Currently, the Reserve is essentially “taking up” all “surplus” water in order to maintain the current ecological state of the river: it is likely that water could be made available for domestic allocation through a downward adjustment or refinement of the quantity of water allocated to the ecological Reserve. This scenario would more than adequately meet the water resource requirement for Hazyview over the planning period, (see **Figure 11.3**). The challenge, however, will be obtaining buy-in from all stakeholders. It is therefore considered as an option only if the available yield from the reduction of irrigation demand is insufficient to balance Hazyview’s water use and water requirements. It is important to note that the additional yield obtained from the lowering of the amount allocated to the Reserve would also benefit the WDC of Nsikazi North, downstream of Hazyview.

11.10 RECONCILING THE WATER REQUIREMENTS WITH THE WATER RESOURCE

11.10.1 Water balance for selected reconciliation scenarios

The reconciliation of the Hazyview water requirements and water availability can be achieved by only implementing WC/WDM measures and utilising ground water.

11.10.2 Actions needed

The required actions for Hazyview are summarised **Table 11.8**.

Table 11.8: Action plan for Hazyview

Action	Responsibility	Timeline
Develop a WC/WDM plan for Hazyview	MLM	2014
Implementation of a WC/WDM plan for Hazyview	MLM	Start beginning of 2015 and plan fully implemented by 2019.
Groundwater investigation	MLM	2014
Drill and equip boreholes and lay feeder pipeline to town	MLM	2015, 2016

12 NSIKAZI NORTH

12.1 POPULATION GROWTH

The low and high population growth scenarios for Nsikazi North are summarised in **Table 12.1** and depicted graphically in **Figure 12.1**. The population of the Nsikazi North is expected to grow steadily until 2030, with an average growth rate of 0,8% in the low growth scenario, and 1,1% in the high growth scenario.

Table 12.1: Low and high population growth scenarios for Nsikazi North

Year	2009	2010	2015	2020	2025	2030
Low	156 417	157 909	165 584	173 009	180 032	185 421
High	156 417	158 427	168 870	178 977	188 576	196 423




Figure 12.1: Low and high population growth scenarios for Nsikazi North

12.2 CURRENT WATER USE

BWB is the bulk WSP for Nsikazi North and MLM is responsible for the distribution of water to the users.

12.2.1 Domestic water use

The main water supply for Nsikazi North comes from the Sabie River. Water is abstracted at the Nsikazi North Regional Raw Water pump station and pumped to Nyongane booster pump station where the water is chlorinated and distributed. The distribution of water to villages is according to a valve schedule: most villages get water twice a week. There are also package plants supplying water to Majika, Msadza and Mnganduzweni. The mode of service in most of the area is via stand pipes.

There is a memorandum of understanding between MLM and Bushbuckridge Local Municipality (BLM) to supply water from the Hoxane WTW to Nsikazi North. The WTW was constructed by DWA and consists of 4 x 9 Mℓ/day units. The mechanical and electrical works were, however, not completed and the intention is to commission the two incomplete units and supply 18 Mℓ/day to Nsikazi North. Although there should be more than sufficient water to supply the population in this area with a generous per capita rate, the reality is that the service delivery is very poor. The reason for this is not entirely clear but is probably due to excessive losses and illegal connections.

MLM does not want to depend on BLM for treated water and plans to construct a 30 Mℓ/day WTW at Nyongane. MLM appointed a PSP to design the WTW and also to apply for Municipal Infrastructure Grant (MIG) funding. A water use licence for this additional abstraction has not been issued.

12.2.2 Industrial water use

There is no industrial water use in Nsikazi North.

12.3 PROJECTED FUTURE WATER REQUIREMENTS

12.3.1 Domestic

The projected domestic water requirements are summarised in **Table 12.2** and **Table 12.3**.

12.3.2 Industrial water use

No industrial water requirements are projected for Nsikazi North.

12.4 HIGH AND LOW SCENARIO WATER REQUIREMENT PROJECTIONS

The projected low and high scenario water requirements are summarised in **Table 12.2** and **Table 12.3**.

Table 12.2: Projected water requirements in million m³/a

Year	2010	2015	2020	2025	2030
Low	10,66	11,18	11,68	12,16	12,52
High	10,70	11,40	12,09	12,73	13,26

Table 12.3: Projected water requirements in Mℓ/day

Year	2010	2015	2020	2025	2030
Low	29,21	30,63	32,01	33,31	34,30
High	29,31	31,24	33,11	34,89	36,34

12.5 WATER RESOURCE AVAILABILITY

12.5.1 Groundwater availability

The geology of the study area as shown on the geological map (**Figure 5.2**) consists of grey and white coarse grained biotite granite in the western part, while the eastern section along the border of the Kruger National Park and the southern part of the area consists of potassic gneiss. Several east/west striking diabase dykes and sills are present in the north, and northwest/southeast shear zones cut through the area. Northwest/southeast striking dykes are present in the southern part of the area.

The aquifer is classified as an inter-granular and fractured aquifer according to the 1:500 000 hydrogeological map (1:500 000 Hydrogeological Map Series of the Republic of South Africa Nelspruit 2530 (DWAF, 1999). The occurrence of groundwater is associated mainly with the deeper weathered zones, whereas fault zones and dyke contacts represent other potential groundwater targets. The groundwater yield potential is classed as low, with potential yields between 0,1 and 0,5 l/s in the granite, and 0,5 to 2,0 l/s in the gneiss. According to Vegter (1995) the probability of drilling a successful borehole in the western part is below 40% whilst the probability of drilling a borehole yielding more than 2 l/s is between 10 and 30%. In the east and northern areas, the probability of drilling a successful borehole is between 40 to 60%, and of drilling a borehole yielding more than 2 l/s is between 30 to 40%. It is concluded that groundwater is generally available but requires detailed investigations for development.

12.5.2 Surface water availability

Nsikazi North obtains most of its water from the Sabie River, abstracted at the Northern Nsikazi Regional raw water pump station. Currently these works are operating at maximum capacity. As discussed under **Section 11** (Hazyview), while there is currently surplus water available in the Sabie River, this water has been allocated and will be taken up shortly. Additional water can therefore not be made available from the Sabie River for Nsikazi North.

In addition to the Sabie River, Nsikazi North also obtains water from streams and a dam constructed by the Provincial Department of Agriculture. Many of these abstractions are not licenced and may not be sustainable. Nevertheless, it is suggested that they continue until such time as a more sustainable solution can be found to the water resources and water supply situation of Nsikazi North.

12.6 WATER QUALITY

12.6.1 Sources of pollution

Typical impacts on water quality from rural and informal settlements relate to poorly managed or absent sanitation systems, to littering, and to solid wastes being washed into the rivers and streams, elevating the levels of nutrients in the river and increasing bacteriological counts.

Small scale agriculture which takes place in the catchment may result in an increase in the levels of pesticides and of nutrients from fertilisers in the rivers.

12.6.2 Trend analysis

Water quality monitoring data is available from sampling being done by DWA for the Nsikazi North region. This takes place on the North Sand River which is upstream from Nkumbeni but downstream from Hazyview, and on the Nsikazi River at Matlabantu. Activities at this latter sampling point have however been suspended since 2001.

Sampling has been taking place since 1969 in the north Sand River. The 90th percentile for TDS is 156 mg/l. Ammonium has been steadily increasing since 2006 and the 90th percentile is 0,098 mg/l as N with the median being 0,043 mg/l as N.

12.7 THE WATER BALANCE

12.7.1 Current water balance with no interventions

The present ecological state of the Sabie River needs to be maintained. Therefore the current licensed abstraction volume for Nsikazi North from the Hoxane Weir may not be exceeded. The current authorised abstraction from the Sabie River is 8,03 million m³/a .

The licensed abstraction for Nsikazi North is augmented from other resources as indicated in **Table 12.4**.

Table 12.4: Licensed abstraction for Nsikazi North

Source	Abstraction million m ³ /a	Licence million m ³ /a	Comments
Nsikazi North raw water pump station on Sabie River.	8,18	8,03	Authorisation slightly exceeded.
Package plants on tributaries.	1,84	0,25	Only Mshadza is authorised for 0,25 million m ³ /a. No authorisations for Majika, Manzini and Mnganduzweni abstractions.
Mjeane borehole station.	0,37	0,16	Authorisation exceeded.
Various other boreholes.	0,33	0,33*	Uncertain which of the individual boreholes are authorised.
Totals	10,72	8,77	

* Assumed licences have been issued for all boreholes.

The current abstraction exceeds the total of the authorised volumes. There is uncertainty regarding which of the boreholes have been licensed, but it was assumed that the total volume of 0,33 million m³/a indicated in **Table 12.4** as abstraction from “various other boreholes” is indeed authorised. This gives a total water availability of 8,77 million m³/a.

The current water abstraction is 10,72 million m^3/a and it can therefore be seen that this system is already in deficit with the water requirements exceeding the water availability. Interruption in water supply is a regular occurrence in Nsikazi North: The water supply system “runs dry” regularly owing to these interruptions and the water requirements are exceeding the water availability.

12.7.2 Future water balance with no interventions

The projected water requirements of Nsikazi North for both the high and low growth scenarios are summarised in **Table 12.2** and **Table 12.3**.

Without appropriate interventions the current water deficit will increase and the situation will deteriorate as shown in **Figure 12.2**.




Figure 12.2: Water balance graph for Nsikazi North without any interventions

A water deficit of 4,255 million m^3/a is expected by the year 2030 if no further interventions are implemented and if the current water abstractions are maintained.

The thin black curve on the water balance graph reflects a target unit water consumption that gradually increases from 90 l/c.d to the international average of 180 l/c.d .

12.8 POSSIBLE INTERVENTION OPTIONS

12.8.1 Reconciliation options that will reduce water requirements

12.8.1.1 WC/WDM

The Nsikazi North demand centre is operated and maintained by MLM with the treatment plants operated by BWB. The WDC consists of mostly informal areas with informal infrastructure which have no bulk and domestic metering: billing and cost recovery are not taking place. **Table 12.5** summarises the situation in Nsikazi North and the resulting recommended WC/WDM actions, whilst **Table 12.5** summarises the performance indicators determined for Nsikazi North.

Table 12.5: Situation analysis and WC/WDM strategy

Status quo	Strategy
Institutional and legal assessment	
<ul style="list-style-type: none"> Mbombela lacks capacity (45% vacancy) and necessary skills to implement WC/WDM. There is no WC/WDM training. The municipal bylaws are currently under review. There is no customer service charter. The political support is acceptable but the understanding of the water business can improve The relationship between the municipality and politicians has improved. 	<ul style="list-style-type: none"> Setup WC/WDM task team, chaired by senior official or MEC to meet on monthly basis to address WC/WDM issues. This should improve communications between organisations, highlight problem areas and transfer skills. Perform Councillor training programme on water business and WC/WDM. Appoint additional staff to increase WC/WDM section and implement training programme Conduct water business and awareness training to councillors to promote WC/WDM. Develop partnerships with the legal departments as well as the SAPS and put bylaw enforcement back on track to promote WC/WDM.
Financial assessment	
<ul style="list-style-type: none"> Non-revenue water is estimated at above 50%. Metering and billing is non-existing. 	<ul style="list-style-type: none"> Engage with the community to improve level of services and consider installing water meters. Consider installing water restricting devices to curb daily consumption. Improve relationship with the consumers and the leadership and focus on promoting water savings and payment for services through the councillors.
Social assessment	
<ul style="list-style-type: none"> The relationship with the community is generally negative. High level of low income earners and 	<ul style="list-style-type: none"> Undertake a comprehensive community awareness programme to promote water efficient practices and

Status quo	Strategy
<p>indigents consumer base.</p> <ul style="list-style-type: none"> • Infrastructure vandalism and illegal connection is problematic in the area. • Rainwater harvesting is promoted through Parks Department. • No community education and awareness. 	<p>make the community aware that problems will not be solved without their support.</p> <ul style="list-style-type: none"> • Promote fixing of internal plumbing leaks. • Consider a hosepipe ban or restrict garden watering until system has stabilised. • Promote schools water awareness campaigns in the area.
Technical assessment	
<ul style="list-style-type: none"> • There is no macro management information available to perform a proper assessment of the water losses and potential savings. • No bulk metering in the area • The system is characterised by intermittent supply and poor service. • High prevalence of illegal connections with consumers trying to gain access to water supply. • No WC/WDM such as pressure management and sectorisation is being done. • Insufficient support structures and materials. 	<ul style="list-style-type: none"> • Install bulk meters and focus on obtaining macro management information. • Improve level of services and focus on providing continuous supply which should reduce illegal connections. Thereafter inspect and eliminate illegal connections. • Consider undertaking an internal leak audit and repair exercise for indigent consumers to reduce water losses. • Deploy community plumbers to assist with fixing leaks and creating water use awareness.
General observations	
<ul style="list-style-type: none"> • Water treatment plants operated by BWB received 59,28% in the 2012 Blue Drop assessment which is an indication of a poor supply. 	<ul style="list-style-type: none"> • Improve to achieve Blue Drop status and provide proper supply.

Table 12.6: Performance indicators for Nsikazi North

Indicator	Current Value	Realistic Target Value 15% reduction	Optimistic Target Value 30% reduction
Annual input volume (million m ³ /annum)	10,7	10,17	9,63
Daily input volume (Ml/day)	29,3	27,8	26,4
Population (2012)	163 648		
Households (2012)	38 850		
% Non-revenue water	60%	50%	40%
% Water Losses	33%	25%	20%
Total Unit Consumption Litres/capita/day*	179	170	161
Domestic Authorised Unit Consumption with daily visitors subtracted l/c/d	120	128	129
Domestic Authorised Unit Consumption m ³ /households/month*	15	16	17

The unit consumption in Nsikazi North appears to be within the international standard of 180 l/c/d, but the distribution of water is uneven across the area and major water wastage takes place, with the result that some occupants receive small quantities of water, some even below the RDP level of service.

Interruptions in water supply are one of the main causes of this uneven distribution of water. As a result it will be extremely difficult to implement WC/WDM in this area. Pressure control can, for instance, not be exercised if the system is not permanently under pressure. It is therefore crucial that the water supply to Nsikazi North is stabilised as a matter of priority.

Certain WC/WDM actions can still be implemented, such as water use awareness campaigns, combatting illegal connections, installing meters, etc. Full WC/WDM implementation should take place once the supply system is stable. No water savings have been assumed for the water balance of Nsikazi North.

12.8.1.2 Removal of IAPs

The most recent WFW survey indicates negligible areas of IAPs in the Nsikazi North area, so removal of IAPs does not appear to be an option that would make more water available in this area. However, since Nsikazi North obtains its water mostly from the Sabie River, removal of alien vegetation upstream of the Hoxani weir could potentially make more water available, although current indications are that there are negligible areas of IAPs in the Sabie River catchment, these needs to be confirmed.

12.8.1.3 Water requirement reduction measures for irrigation upstream of the Nsikazi North abstraction point

There are a number of possible measures that can be implemented by upstream irrigators that will reduce their water demand on the water resource which will, in effect, increase the water availability at the Nsikazi North water abstraction point in the Sabie River. These possible measures are:

Eliminating unlawful water use

There is currently no information available on the volume of unlawful water use taking place in the Sabie River catchment upstream of Hoxane Weir.

Compulsory licensing

The compulsory licensing process is described for Nelspruit under **Section 5.8.1.4**: The same principle would apply for the Sabie catchment. Compulsory licensing linked to WC/WDM is one way of minimising economic prejudice amongst the irrigation farmers, and ensuring that the irrigators do not expand their irrigation lands with saved water.

Water reallocation

As described for Nelspruit under **Section 5.8.1.4**, water re-allocation is a promising option for achieving the water balance in the Nsikazi North area. There are two types of water re-allocation:

- Partial water entitlements

WC/WDM savings could be re-allocated if the water users (e.g. irrigation farmers) were prepared to relinquish this saving instead of expanding horizontally.

- Re-allocation of full water use entitlements

Care must be taken that economic prejudice and job losses do not occur as a result of this measure. The focus should be on irrigation lands that lie fallow for several years, i.e. water entitlements that are not being used.

The NWRS2 envisage a new policy and legislation in order to enable water management authority to re-allocate water.

The precise quantification of the areas of available irrigation lands that could possibly become available for trading has to await the completion of the validation and verification processes. In order to get a very provisional idea of the possibilities, a reconnaissance level investigation along the Sabie River has been carried out with aerial photography and satellite imagery, supported by limited ground truthing. Caution should however be exercised when interpreting results obtained by such purely remote means, since some aspects related to current and historical water use are not evident from remote imagery. A definitive assessment of water use will require direct interaction with stakeholders, including property owners and water management authorities.

The reconnaissance level investigation showed that of the 46 million m³/a allocated to irrigation along the Sabie River, lands which approximately require 7 million m³/a were not being used at the time of the aerial photograph or

satellite image. This does not necessarily imply that these lands are lying fallow, but merely provides an indication of a possible outcome of a more detailed future survey.

It will be seen from **Figure 12.4** under Section 12.10 below that approximately 4 million m^3/a will be needed to achieve a water balance. It can therefore be confirmed that this could be a reconciliation possibility with relatively low expected social impacts.

12.8.2 Reconciliation options that will increase water supply

12.8.2.1 Groundwater development

As shown on the geological map of the area (**Figure 5.2**), several northwest/southeast striking dykes are present. A northwest/southeast striking shear zone cuts through the area, as shown in **Figure 12.3**. High potential groundwater resources are normally associated with these structural features. However, a high density airborne magnetic survey of the area is required to accurately locate these structural features. Targets along these structures need to be selected for more detailed geophysical traversing. It is recommended that the radon emanation technique (Levin, 2000) be applied to locate the optimum drilling targets.




Figure 12.3: Shear zones west of Nsikazi North

It is expected that at least another 200 000 m^3/a can be obtained from the groundwater resource.

12.8.2.2 Dam construction to increase yield storage

The dam construction options that have been evaluated do not result in increased yield within the Sabie River catchment.

12.8.2.3 System operating rules

As indicated for Hazyview under **Section 11.8.2.3**, a real-time operational model for optimising releases from Inyaka Dam is under development. As the model is currently in its testing phase, it is too early to confirm its success. No additional / saved water has been taken into account for this strategy.

12.8.2.4 Water transfers from elsewhere

Most of Nsikazi North is situated in the Crocodile catchment. Water is transferred from the Sabie catchment into the Crocodile catchment: As water requirements grow in Nsikazi North, more water may be transferred from the Sabie River.

12.8.2.5 Eliminating unlawful water use upstream of Nsikazi North abstraction point

The amount of water that would become available from implementing this option will only be confirmed once the verification exercise currently being undertaken by the ICMA is finalised. It is therefore not possible to illustrate the impact of this intervention on the water balance for Nsikazi North at this time.

12.8.2.6 Lowering the Reserve requirement for the Sabie River

It is possible that more water could become available as a result of the classification process. If so, some of this additional water could be made available to Nsikazi North. Conversely, the classification process might however result in an increase in the amount of water required for the ecological Reserve.

12.9 SELECTED RECONCILIATION SCENARIOS

Whilst WC/WDM is normally the first option that should be implemented by WDC, it would be difficult to implement in this case, due to the regular water shortages and water interruptions on the system. When the reservoirs run dry, the residents tend to open their taps in the hope that some water will go through at some time. Whilst this practice obviously leads to water wastages once supplies are restored, it would be very difficult to convince these residents to save water when the system is not functioning properly. The first priority is therefore to stabilise the water supply system by providing the necessary standby pumps, and by preventing further interruptions in supply. This in itself will not necessarily make more water available, but once the system is stable, a WC/WDM initiative can be launched.

The options that were selected for augmenting the water supply of Nsikazi North are:

12.9.1 Development of groundwater

It was assumed that another 200 000 m³/a can be supplied through this option. This option is not sufficient to balance the water use and water requirement for Nsikazi North.

12.9.2 Groundwater development plus water re-allocation

It is expected that the remaining deficit can be made up through this option. This means that approximately 4 million m³/a need to be re-allocated. This option can however only be implemented in a few years' time when the DWA policy and legislation is in place and could take 3 years for the full quantity of water to become available. In the meantime the MLM should continue with the package plants on farm dams to augment the deficit in the short term.

12.10 RECONCILING THE WATER REQUIREMENTS WITH THE WATER RESOURCE

12.10.1 Water balance for selected reconciliation scenarios

The appropriate scenario that is tentatively selected for the reconciliation of the Nsikazi North water balance is the combination of ground water resource development, and re-allocating unused water entitlements from the irrigators upstream of the abstraction point in the Sabie River. This is illustrated in **Figure 12.4**. There remains a deficit in the water balance for the first few years of the planning horizon, but it is hoped that this can be addressed by continuing to utilise the temporary package plants at the farm dams.




Figure 12.4: Nsikazi North's water balance graph assuming an additional yield made available re-allocating unused irrigation entitlements of irrigators upstream

12.10.2 Actions needed

- Although no WC/WDM savings can be expected at this time from the water users, due to the current instability of the water supply system, WC/WDM awareness raising initiatives need to be launched so that water users will cooperate in saving water over the longer term.
- Boreholes need to be sited along the shear zones as described under **Paragraph 11.8.2.1**.
- The verification and validation exercise commissioned by the ICMA needs to be completed as a matter of priority in order for the reconciliation of water balance for Nsikazi North to be finalised. Illegal water use, if any, should be eliminated in preference to re-allocation of water entitlements. The latter should be left as a last resort as it might be perceived negatively by the irrigation sector.
- The policy for the re-allocating of water entitlements needs to be finalised by DWA, and an initiative needs to be launched and facilitated by the responsible water authorisation authority.

Table 12.7: Actions required, responsibilities and timelines

Action	Responsibility	Timeline
Stabilise water supply to Nsikazi North, i.e. reduce interruptions at pumping station and WTWs	Bushbuck Ridge Water Board	Immediately – this should be a priority.
Maintain good WC/WDM practices	MLM	Ongoing
Site new boreholes at places of water shortage	MLM	2014. Assumed operational within one year
Complete the validation and verification exercise and eliminate illegal water use	DWA Regional Office ICMA	Ongoing
Investigate the possibility of re-allocating unused water entitlements. Focus on fallow irrigation lands.	MLM in collaboration with ICMA and DWA.	Start investigating 2014. Water licences must be in place as soon as possible afterwards.
Develop a policy for re-allocation of water entitlements.	DWA Policy and Regulation	2013 (urgently required)

13 OVERARCHING RECONCILIATION STRATEGY FOR THE MBOMBELA MUNICIPAL AREA

13.1 INTRODUCTION

The reconciliation of water requirements with the available water resources within the MLM area has been evaluated for eight separate WDCs. This has been a useful and necessary exercise offering certain interventions that must be implemented. There are, however, also regional options that could resolve the water supply situation for a number of the WDCs simultaneously. These multi-target regional schemes show great promise, without in any way negating the need for local solutions. This section describes the preferred regional options and how one scheme could resolve the water balance for the whole MLM area. It is stressed again that the adoption of a regional strategy should not be at the expense of local solutions.

The Crocodile River catchment and the Sabie River catchment are two separate systems and are dealt with separately below.

13.2 OVERALL WATER BALANCE IN THE CROCODILE RIVER CATCHMENT

Figure 13.1 shows the water balance for the Crocodile River catchment in the MLM area before any interventions are undertaken. This shows that the system as a whole is just in balance, but the gradually increasing water demands will result in a water deficit in the near future. This implies that when the next severe drought occurs, water use will need to be severely restricted should there be no progress with reducing losses by implementing the suggested WC/WDM measures.




Figure 13.1: The water balance of MLM in the Crocodile River catchment without interventions

13.3 INTERVENTION MEASURES IN THE CROCODILE CATCHMENT

The recommended intervention is to firstly implement WC/WDM measures in all WDCs to reduce the water demand, then to increase the water supply via less intensive capital investment interventions, such as the issuing of pending licence applications, improving and implementing system operating rules, developing groundwater resources, removing IAPs, and reallocating water entitlements. **Figure 13.2** illustrates that by implementing these measures water resource supply and demand can be balanced over the planning period for all but the high growth water requirement scenario, which falls short only over the last two years of the planning period,




Figure 13.2: The water balance of the MLM with various interventions

The water reconciliation graph in **Figure 13.2** must, however be interpreted with caution. It shows that the system will have almost no water deficits and will be in balance as a result of the non-capital intensive interventions. Although this is indeed the picture for the entire MLM in the Crocodile Catchment, the measures for reducing water demand or increasing the water supply will not necessarily be able to satisfy local water shortages everywhere. It could be impractical or expensive to transfer a local surplus in one WDC to another with a local water deficit, especially if water needs to be pumped upstream.

13.4 DAM OPTION FOR THE CROCODILE RIVER CATCHMENT

Of the six dam options evaluated, three could be obviously discarded, namely, the Lepulelu Dam and the raising of Ngodwane Dam, both on a tributaries of the Elands River, as a result of their high unit reference values (URV - R16/m³ and R19/m³ respectively), and the Montrose Dam just downstream of the confluence of the Crocodile and Elands Rivers due to its high cost and high environmental impact. The Mountain View Dam, Strathmore Dam and Boschjeskop Dam options are much more

economical and all have lower environmental impacts than the Montrose Dam option, leading to the recommendation that the Montrose Dam should not be considered further. The Mountain View and Strathmore Dams have similar URVs, whilst the URV for Boschjeskop Dam is somewhat higher.

Either Mountain View Dam (on the Kaap River) or Strathmore Dam (off-channel on tributary of the lower Crocodile) could make more than 50 million m³/a of additional water (after meeting the ecological Reserve) available for use. Since this is more than the foreseeable domestic requirements, particularly if other local interventions are necessary, it is suggested that the adopted option could form part of a larger regional scheme to supply surplus water to emerging irrigators in the Lower Crocodile River and/or to irrigators in Mozambique.

These options have an added complexity over the Boschjeskop option, with Strathmore Dam located downstream of the WDCs in the MLM and Mountain View Dam in a different catchment. However, water can be gravitated from Mountain View Dam to Matsulu, freeing up water currently used by Matsulu for abstraction from the Crocodile River for Nelspruit and/or Nsikazi South. A similar, more extensive water swap can be made with irrigators on the lower Crocodile River.

The ecological flow implications of these water swaps would need to be investigated since they would entail a change in the flow regime of the lower Crocodile and Kaap Rivers. Other than this caveat, there do not appear to be any serious flaws in either the Mountain View Dam or Strathmore Dam options. It is recommended that these two options be subjected to a feasibility study.

The Boschjeskop Dam site is on the Nels Tributary of the Crocodile River and ideally located for Nelspruit augmentation. Despite a yield of only 19,5 million m³/a this option has been used in the water balance graph below to show that even this would be more than enough to meet the growing demands of all the individual WDCs within the planning horizon of this study.

The water balance, including the effect of constructing the Boschjeskop Dam, is illustrated in **Figure 13.3**.




Figure 13.3: Water balance for MLM in the Crocodile catchment with interventions including the construction of a new dam

The new dam in **Figure 13.3** is the Boschjeskop Dam and chosen just for illustration purposes. If Strathmore Dam or Mountain View Dam is selected, the starting date and date of full yield will be the same as in **Figure 13.3** and these dams will show a similar surplus, taking cognisance of the fact that part of the yield of one of these regional schemes will be allocated for other purposes than domestic water use.

13.5 OVERALL WATER BALANCE IN THE SABIE RIVER CATCHMENT

Figure 13.4 shows the water balance for the Sabie River catchment in the MLM area before any interventions are undertaken. The system must be augmented with the temporary package plants in Nsikazi North to achieve a current water balance but this turns into a water deficit soon as a result of the growth in water demand. It can further be expected that the temporary package plants at the farm dams won't last for many years which will mean that the water deficit will increase even further to 4 million m³/a for the low growth scenario and 5 million m³/a for the high growth scenario.




Figure 13.4: Water balance for Sabie River with only current intervention of the package plants at farm dams

13.6 INTERVENTION MEASURES IN THE SABIE RIVER CATCHMENT

As described for each of the individual WDCs, it is not desirable to build a dam in the Sabie River, both because there is no appropriate dam site and because the river is categorised as an A/B class river. This classification reflects a relatively high ecological standard of river that would be severely compromised by a dam. The only viable options available at this point in time, therefore are WC/WDM for Hazyview, groundwater development for both Hazyview and Nsikazi North, and water reallocation in Nsikazi North. **Figure 13.5** shows that a water balance can be achieved with these measures.




Figure 13.5: Water balance for MLM in the Sabie River with interventions

13.7 OVERARCHING STRATEGY FOR MLM IN THE SABIE RIVER CATCHMENT

The package plants at the farm dams must be maintained until at least 2016.

Implement WC/WDM measures for Hazyview as a matter of urgency and maintain sound WC/WDM practices for Nsikazi North.

Investigate the possibility of reallocating unused water entitlements from upstream irrigators. Focus on fallow lands. A total of 4 million m³/a water entitlements must be reallocated. Water must be available as from 2014. If not achievable, the package plants at the farm dams must be operated and maintained for a longer period.

Site new boreholes at places of water shortage. Boreholes must be drilled in 2014.

14 IMPLEMENTATION ARRANGEMENTS

It must be realised from the outset that DWA, as custodian of the country's water resources, is only facilitating the process of water reconciliation *planning*, and that *implementation* is the responsibility of several other institutions.

14.1 INSTITUTIONAL RESPONSIBILITIES

The following entities will play a crucial role in all aspects of implementation of the strategy:

- DWA Regional and Head Office;
- ICMA;
- MLM;
- Sembcorp;
- BWB;
- Irrigation Boards and Water User Associations;
- Industries; and
- Nature Conservation Institutions.

Table 14.1 outlines the different interventions that have been considered for achieving a water balance, the required actions, and the institutional responsibility for those actions. It should be noted that allocations of responsibility and target dates are indicative. A detailed action plan needs to be compiled in which the actions will be broken down further, with descriptions of specific responsibilities and time lines. This is part of the implementation process.

Table 14.1: Institutional responsibilities and target dates

Intervention	Brief Description of Actions	Primary Responsibility	Comments	Target Date
Addressing the unlawful irrigation use (Compliance Monitoring and Enforcement)	<ul style="list-style-type: none"> Validation and verification 	ICMA & DWA	In process	Not set as the extent of unlawful irrigation is still unknown. Determine in the Continuation Study.
	<ul style="list-style-type: none"> Directives to unlawful water users 	ICMA and DWA	DWA will advise the CMA on the correct procedure	
	<ul style="list-style-type: none"> Legal action where needed 	ICMA and DWA	DWA Legal Services to assist the ICMA	
	<ul style="list-style-type: none"> Maintenance of lawful water use in controlled areas 	IBs / WUAs	Supervised by DWA Regional Office and ICMA	

Intervention	Brief Description of Actions	Primary Responsibility	Comments	Target Date
WC/WDM Urban	<ul style="list-style-type: none"> Infrastructure measures such as pressure management; mains replacement; Leak detection and repair 	MLM and Silulumanzi	A WC/WDM implementation plan must be developed for each water demand centre	All plans by end of 2014 ready for implementation
	<ul style="list-style-type: none"> Canvassing public collaboration such as public awareness on efficient appliances, water efficient gardening, retrofitting, friendly and informative billing, etc. 	MLM, Silulumanzi and the broad public	Awareness launches to be arranged by water MLM. Could be assisted by DWA Water Use Efficiency.	All plans by end 2014 ready for implementation
	<ul style="list-style-type: none"> Water pricing 	DWA Head Office, ICMA and MLM	In line with Water Pricing Strategy	Ongoing but new pricing structure for White River and Hazyview a priority
WC/WDM in the irrigation sector and relinquishing of water savings	<ul style="list-style-type: none"> Announcement of DWA policy whereby irrigators can relinquish their saved water Implementation of the policy 	DWA Head & Regional Offices DWA Regional Office, ICMA Irrigators	Not considered as the outcome is very uncertain	
Water re-allocation	<ul style="list-style-type: none"> Develop policy and guidelines 	DWA national and regional offices	Investigation required into unused water requirements	End 2014
Removal of IAPs	<ul style="list-style-type: none"> Removal of plants 	Working for Water Teams	CMAs, IBs, WUAs, Forestry Companies, Local Municipalities can all perform this function and	On-going. Removal must be faster than the growth of

Intervention	Brief Description of Actions	Primary Responsibility	Comments	Target Date
			should collaborate with the DEA Working for Water Teams	IAPs. Reduce IAPs by at least 50% over planning horizon.
	<ul style="list-style-type: none"> Rehabilitate land and re-establish indigenous vegetation 	WfW Teams		
	<ul style="list-style-type: none"> Follow up and maintenance 	WfW Teams		
Groundwater Development	<ul style="list-style-type: none"> Borehole siting Drilling Infrastructure development 	MLM, Sembcorp	Licences (if applicable) to be issued by DWA Regional Offices in collaboration with ICMA	On-going from 2013
Operationalisation of the Reserve	<ul style="list-style-type: none"> Finalise Water Resource Classification 	DWA HO		End 2013
	<ul style="list-style-type: none"> Review current operating rules and monitoring network 	DWA Regional Office, IBs, WUAs, MLM, Silulumanzi, Bushbuckridge WB		End 2014
	<ul style="list-style-type: none"> Monitor and adjust 	DWA Regional Office, IBs, WUAs, MLM, Silulumanzi, Bushbuckridge WB		Beginning of 2015
Pre-Feasibility Study into dams	<ul style="list-style-type: none"> Select between Mountain View, Strathmore and Boschjeskop Dams 	DWA national office	Decision is needed on best dam option	End 2014
New dam constructed	<ul style="list-style-type: none"> Feasibility Study 	DWA national office	Decision is needed on optimum dam site	End 2015
	<ul style="list-style-type: none"> Design 	DWA national office	Can be outsourced	End 2016
	<ul style="list-style-type: none"> Tendering 	Implementing Agency	E.g. TCTA	End 2017

Intervention	Brief Description of Actions	Primary Responsibility	Comments	Target Date
	<ul style="list-style-type: none"> Construction 	Implementing Agency	Outsourced	End 2020
	<ul style="list-style-type: none"> Commissioning and handover 	Implementing Agency and DWA RO		End 2022
System Operating Rules for Sabie River	<ul style="list-style-type: none"> Devise rules for efficient water distribution out of Inyaka Dam 	DWA HO in collaboration with DWA Region	Not considered for water balance as outcome is still unknown	End 2014
Operation rules for Primkop Dam	<ul style="list-style-type: none"> Optimise water distribution out of Primkop Dam 	DWA national office, ICMA, Irrigators and MLM		End 2013
Process long outstanding licence applications of MLM	<ul style="list-style-type: none"> DWA need to speed up processing of licence applications of as long ago as 2003 	DWA national office, DWA Regional Office, MLM	The applications entailed the conversion of irrigation entitlements to entitlements for domestic use	End 2013

14.2 PUBLIC ENGAGEMENT

A strategy of this nature, where different role players have different responsibilities, working towards the same goal, requires an orchestrated effort. In order to achieve this, the role players and key stakeholders must first buy into the strategy and adopt the responsibilities. This will require firstly that a Strategy Steering Committee be formed by whom the strategy is then adopted and responsibility is accepted for its implementation. Secondly, all other stakeholders and water users within MLM must become aware and understand the contents of the strategy. Thirdly the Strategy Steering Committee must be kept informed of the progress with implementation, amend the strategy when required and ensure full implementation.

14.2.1 Formation of the Strategy Steering Committee

The first and most important action that must be taken is a meeting with the key stakeholders where the membership of the Strategy Steering Committee is approved and where the strategy is adopted. The DWA must take the lead in this regard. DWA can use the same stakeholder database used for the Study Steering Committee and send out invitations to the former members of the Study Steering Committee. This forum can then approve that the Study Steering Committee simply becomes the Strategy Steering Committee or they can nominate new members to serve on the Strategy Steering Committee. The strategy must then be adopted by

the committee. Issues in the strategy that need to be explored further or that need to be amended can be identified for the continuation study. The main role players serving on the Strategy Steering committee must then be identified and they must accept responsibility for the implementation of their allocated actions.

14.2.2 Awareness making of the implementation of the strategy

All water users need to be made aware of the strategy and as good as possible understand the contents. This can be done by means of presentations to forums, such as municipal council meetings, water user associations, chambers of industry, etc. DWA Regional Office could take the lead and its officials can use a standard presentation of the strategy which was prepared as part of this study.

DWA can also distribute the last strategy newsletter to the public. Leaflets can be left at public places (e.g. libraries) and can also be distributed with local newspapers.

A specific awareness campaign is necessary for obtaining each water user's co-operation towards WC/WDM. Mechanisms such as newsletters, user friendly billing, and financial incentives can be used. MLM/Sembcorp should take the lead on this.

14.2.3 Participation in adapting the reconciliation strategy

The reconciliation strategy is a dynamic document which will need to be changed as circumstances change over time. It is foreseen that the strategy steering Committee takes responsibility for this. The membership of this committee may change over time but members must always be assembled from the main role player- and key stakeholders institutions. It is foreseen that two meetings per year will be held.

14.2.4 Summary of actions with regard to public engagement

Actions towards public engagement are summarised in **Table 14.2**

Table 14.2: Actions towards public engagement

Action	Responsibility	Timeline
Establish the Strategy Steering Committee	DWA	Early 2014
Adoption of the strategy and taking responsibility for its implementation	Strategy Steering Committee	Early 2014
Identification of issues to be further explored as part of the continuation study and overseeing the study	Strategy Steering Committee	From early 2014
Presenting the strategy to forums	DWA Regional Office, Nelspruit	Early 2014
Distributing newsletters	DWA national office and DWA Regional Office	Early 2014
Awareness campaign for WC/WDM	MLM/Sembcorp	From early 2014 to 2019
Monitor progress of implementation	Strategy Steering Committee	From 2014 onwards
Amend strategy when required	Strategy Steering Committee	Ongoing

15 RECOMMENDATIONS FOR FURTHER WORK

Recommendations for further work can be divided into two categories, i.e.:

- Further work recommended for the continuation study.
- Further studies recommended by role players other than the DWA's Directorate National Water Resource Planning.

15.1 FURTHER WORK FOR THE CONTINUATION STUDY

- Ensure that WC/WDM is implemented in all WDCs and monitor progress and outcomes
- Determine the extent of unlawful irrigation (in progress)
- Confirm the extent of alien plant infestation above Kwená Dam
- Investigate the expansion of the monitoring network.
- Develop operating rules for Primkop and upstream dams.
- Set up a pilot test plant for fog harvesting in Kaapsehoop
- Consider water reuse possibilities for Nelspruit and investigate possibilities for reuse in other WDCs
- Further investigate the problem with Matsulu abstraction works which runs short of water as a result of the Kaapmuiden diversion weir and canal.
- Capturing of data from dams and gauges in the White River area needs to be improved.
- Introduce regulations on compulsory rainwater harvesting systems for all new dwellings with roof top areas bigger than 150 m².
- Confirm the water requirement growth as a result of the hospital and university in Nelspruit.
- Pre-feasibility study to select between Mountain View, Strathmore and Boschjeskop Dams

15.2 FURTHER STUDIES BY ROLE PLAYERS OTHER THAN NWRP

The following further work/studies are required:

- Validation and verification of the water use in the Crocodile and Sabie River catchments. This is in progress.
- The Classification of the water resources of the Sabie River. This will provide updated information on the utilisable water available in the Sabie River.
- A more detailed study into the groundwater potential of the area. This entails low level aerial magnetic surveys of potential areas and radon gas monitoring.

REFERENCES

Department of Water Affairs and Forestry. (1996). *South African Water Quality Guidelines (Second Edition) Volume 1: Domestic Water Use*. Pretoria: Department of Water Affairs and Forestry

Department of Water Affairs and Forestry. (1996). *South African Water Quality Guidelines (Second Edition) Volume 2: Recreational Water Use*

Department of Water Affairs and Forestry. (1996). *South African Water Quality Guidelines (Second Edition) Volume 4: Agricultural Use: Irrigation*. Pretoria: Department of Water Affairs

Department of Water Affairs (1996). *South African Water Quality Guidelines (Second Edition) Volume 5: Industrial Water Use*. Department of Water Affairs and Forestry

Department of Water Affairs and Forestry. (1996). *South African Water Quality Guidelines (Second Edition) Volume 7: Aquatic Eco Systems*. Pretoria: Department of Water Affairs and Forestry

Department of Water Affairs (1999) *Resource Directed Measures for Protection of Water Resources: Groundwater Component. Version 1.0: 24 September 1999*.

Department of Water Affairs and Forestry, 2008. *Crocodile (East) River Development. Reconnaissance Study. Report no. PWMA 05/X22/00/0608*

Department of Water Affairs, 2009a. *Inkomati Water Availability Assessment - Hydrology report for the Sabie River and X4 catchments*. Report PWMA 05/X22/00/1608.

Department of Water Affairs, 2009b. *Inkomati Water Availability Assessment – Hydrology Report for the Crocodile (East) River Catchment Hydrology*. Report PWMA 05/X22/00/1508.

Department of Water Affairs, 2009c. *Inkomati Water Availability Assessment – Water Requirements*. Report PWMA 05/X22/00/1708.

Department of Water Affairs and Forestry, 2009d. *Inkomati Water Availability Assessment: Yield Modelling*. Report no. P WMA 05/X22/00/1708.

Department of Water Affairs, 2010a. *Development of a reconciliation strategy for all towns in the Eastern Region: First order reconciliation strategy for Nelspruit and White River*.

Department of Water Affairs, 2010b. *Development of a reconciliation strategy for all towns in the Eastern Region: First order reconciliation strategy for Nsikazi North villages*.

Department of Water Affairs, 2010c. *Development of a reconciliation strategy for all towns in the Eastern Region: First order reconciliation strategy for Hazyview and water supply scheme area – Mbombela Local Municipality*.

Department of Water Affairs and Forestry, South Africa. 2010d. *Comprehensive Reserve Determination Study for Selected Water Resources (Rivers, Groundwater and Wetlands) in the Inkomati Water Management Area, Mpumalanga.*

Mbombela Municipality, 2007. Integrated Development Plan.

Mbombela Municipality, 2008. Integrated Development Plan Review.

Mbombela Municipality, 2008. Socio-Economic Baseline Study.

Mbombela Local Municipality, 2009. Nzikasi Master Water Plan.

Mbombela Local Municipality, 2009. Water Services Development Plan.

Mbombela Municipality, 2010. Greater Mbombela Bulk Water Strategy.

Republic of South Africa. Director General: Water Affairs and Forestry, 1994. *Report on the proposed Sabie River Government Water Scheme. WP D-94*

1:250 000 scale Hydrogeological Map Series 2530 Barberton

1:500 000 General Hydrogeological Map Series 2530 Nelspruit, (DWAf, 1999).

Levin M (2000) *The Radon Emanation Technique as a Tool in Groundwater Exploration. Borehole Water Journal, Vol 46, 2000*

Vegter J R (1995) *An explanation of a set of national groundwater maps; Report TT 74/95, Water Research Commission.*

De Lange, M. (2006) War on hunger: some impacts of the DWAF Rainwater Harvesting Pilot Programme, Report to the Water Resources Finance and Pricing, DWAF directorate. Department of Water Affairs and Forestry, Pretoria, South Africa.

Duncker, L. C. (2000) Hygiene awareness for rural water supply and sanitation projects. Pretoria, RSA: Water Research Commission, Report no. 819/1/00.

Hughes, D. A. (2013). Personal Communication on rainwater harvesting.

Kundzewicz, Z. W., Mata, L. J., Arnell, N. W., Döll, P., Kabat, P., Jiménez, B., Miller, K. A., Oki, T., Sen, Z. & Shiklomanov, I. (2007) Freshwater resources and their management. In: *Climate Change 2007: Impacts, Adaptation and Vulnerability*, Contribution of Working Group II to the Fourth Assessment Report of the Intergovernmental Panel on Climate Change (M.L. Parry, O. F. Canziani, J. P. Palutikof, P. J. van der Linden and C. E. Hanson, eds), 173–210. Cambridge: Cambridge University Press.

Mwenge Kahinda, J., Taigbenu, A. E. Boroto, J. R. (2007) Domestic rainwater harvesting to improve water supply in rural South Africa. *Phys. Chem. Earth* 32, 1050–1057.